Process Piping

ASME Code for Pressure Piping, B31

AN INTERNATIONAL PIPING CODE®



ASME B31.3-2016

(Revision of ASME B31.3-2014)

Process Piping

ASME Code for Pressure Piping, B31

AN INTERNATIONAL PIPING CODE®



Date of Issuance: January 31, 2017

The next edition of this Code is scheduled for publication in 2018. This Code will become effective 6 months after the Date of Issuance.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations, Code Cases, and errata are published on the ASME Web site under the Committee Pages at http://cstools.asme.org/ as they are issued. Interpretations and Code Cases are also included with each edition.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at http://cstools.asme.org/. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

The American Society of Mechanical Engineers Two Park Avenue, New York, NY 10016-5990

Copyright © 2017 by THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS All rights reserved Printed in U.S.A.

CONTENTS

Foreword .		xii
Committee	Roster	xiv
	n	
•	f Changes	XX
Chapter I	Scope and Definitions	1
300	General Statements	1
Chapter II	Design	11
Part 1	Conditions and Criteria	11
301	Design Conditions	11
302	Design Criteria	13
Part 2	Pressure Design of Piping Components	21
303	General	21
304	Pressure Design of Components	21
Part 3	Fluid Service Requirements for Piping Components	31
305	Pipe	31
306	Fittings, Bends, Miters, Laps, and Branch Connections	31
307	Valves and Specialty Components	33
308	Flanges, Blanks, Flange Facings, and Gaskets	33
309	Bolting	34
Part 4	Fluid Service Requirements for Piping Joints	34
310	General	34
311	Welded Joints	34
312	Flanged Joints	35
313	Expanded Joints	35
314	Threaded Joints	35
315	Tubing Joints	36
316	Caulked Joints	36
317	Soldered and Brazed Joints	36
318	Special Joints	37
Part 5	Flexibility and Support	37
319	Piping Flexibility	37
320	Analysis of Sustained Loads	42
321	Piping Support	43
Part 6	Systems	45
322	Specific Piping Systems	45
Chapter III	Materials	47
323	General Requirements	47
325	Materials — Miscellaneous	58
Chapter IV	Standards for Piping Components	59
326	Dimensions and Ratings of Components	59
Chapter V	Fabrication, Assembly, and Erection	63
327	General	63
328	Welding and Brazing	63
330	Preheating	70
331	Heat Treatment	72
332	Bending and Forming	77

333 335	Brazing and Soldering Assembly and Erection	77 78
Chapter VI	Inspection, Examination, and Testing	80
340	Inspection	80
341	Examination	80
342	Examination Personnel	87
343	Examination Procedures	87
344	Types of Examination	87
345	Testing	89
346	Records	92
Chapter VII	Nonmetallic Piping and Piping Lined With Nonmetals	94
A300	General Statements	94
Part 1	Conditions and Criteria	94
A301	Design Conditions	94
A302	Design Criteria	94
Part 2	Pressure Design of Piping Components	96
A303	General	96
A304	Pressure Design of Piping Components	96
Part 3	Fluid Service Requirements for Piping Components	97
A305	Pipe	97
A306	Fittings, Bends, Miters, Laps, and Branch Connections	97
A307	Valves and Specialty Components	98
A308	Flanges, Blanks, Flange Facings, and Gaskets	98
A309	Bolting	98
Part 4	Fluid Service Requirements for Piping Joints	98
A310	General	98
A311	Bonded Joints in Plastics	98
A312	Flanged Joints	99
A313	Expanded Joints	99
A314	Threaded Joints	99
A315	Tubing Joints	99
A316	Caulked Joints	99
A318	Special Joints	99
Part 5	Flexibility and Support	100
A319	Flexibility of Nonmetallic Piping	100
A321	Piping Support	101
Part 6	Systems	102
A322	Specific Piping Systems	102
Part 7	Materials	102
A323	General Requirements	102
A325	Materials — Miscellaneous	103
Part 8	Standards for Piping Components	103
A326	Dimensions and Ratings of Components	103
Part 9	Fabrication, Assembly, and Erection	104
A327	General	104
A328	Bonding of Plastics	104
A329	Fabrication of Piping Lined With Nonmetals	110
A332	Bending and Forming	110
A334	Joining Nonplastic Piping	110
A335	Assembly and Erection	111
Part 10	Inspection, Examination, and Testing	111
A340	Inspection	111
A341	Examination	112
A342	Examination Personnel	112

A343 A344 A345 A346	Examination Procedures Types of Examination Testing Records	113 113 113 113
Chapter VIII	Piping for Category M Fluid Service	114
M300	General Statements	114
Part 1	Conditions and Criteria	114
M301	Design Conditions	114
M302	Design Criteria	114
Part 2	Pressure Design of Metallic Piping Components	114
M303	General	114
M304	Pressure Design of Metallic Components	114
Part 3	Fluid Service Requirements for Metallic Piping Components	114
M305	Pipe	114
M306	Metallic Fittings, Bends, Miters, Laps, and Branch Connections	114
M307	Metallic Valves and Specialty Components	115
M308	Flanges, Blanks, Flange Facings, and Gaskets	115
M309	Bolting	116
Part 4	Fluid Service Requirements for Metallic Piping Joints	116
M310	Metallic Piping, General	116
M311	Welded Joints in Metallic Piping	116
M312	Flanged Joints in Metallic Piping	116
M313	Expanded Joints in Metallic Piping	116
M314	Threaded Joints in Metallic Piping	116
M315	Tubing Joints in Metallic Piping	116
M316	Caulked Joints	116
M317	Soldered and Brazed Joints	116
M318	Special Joints in Metallic Piping	116
Part 5	Flexibility and Support of Metallic Piping	116
M319	Flexibility of Metallic Piping	116
M320	Analysis of Sustained Loads	116
M321	Piping Support	116
Part 6	Systems	116
M322	Specific Piping Systems	116
Part 7	Metallic Materials	117
M323	General Requirements	117
M325	Materials — Miscellaneous	117
Part 8	Standards for Piping Components	117
M326	Dimensions and Ratings of Components	117
Part 9	Fabrication, Assembly, and Erection of Metallic Piping	117
M327	General	117
M328	Welding of Metals	117
M330	Preheating of Metals	118
M331	Heat Treatment of Metals	118
M332	Bending and Forming of Metals	118
M335	Assembly and Erection of Metallic Piping	118
Part 10	Inspection, Examination, Testing, and Records of Metallic Piping	118
M340	Inspection	118
M341	Examination	118
M342	Examination Personnel	118
M343	Examination Procedures	118
M344	Types of Examination	118
M345	Testing	118
M346	Records	118

Parts 11 Thro	ough 20, Corresponding to Chapter VII	118
MA300	General Statements	119
Part 11	Conditions and Criteria	119
MA301	Design Conditions	119
MA302	Design Criteria	119
Part 12	Pressure Design of Nonmetallic Piping Components	119
MA303	General	119
MA304	Pressure Design of Nonmetallic Components	119
Part 13	Fluid Service Requirements for Nonmetallic Piping Components	119
MA305	Pipe	119
MA306	Nonmetallic Fittings, Bends, Miters, Laps, and Branch Connections	119
MA307	Valves and Specialty Components	119
MA308	Flanges, Blanks, Flange Facings, and Gaskets	119
MA309	Bolting	119
Part 14	Fluid Service Requirements for Nonmetallic Piping Joints	119
MA310	General	119
MA311	Bonded Joints	119
MA312	Flanged Joints	119
MA313	Expanded Joints	119
MA314	Threaded Joints	120
MA315	Tubing Joints in Nonmetallic Piping	120
MA316	Caulked Joints	120
MA318	Special Joints	120
Part 15	Flexibility and Support of Nonmetallic Piping	120
MA319		120
MA321	Piping Flexibility	120
	Piping Support	
Part 16	Nonmetallic and Nonmetallic Lined Systems	120
MA322	Specific Piping Systems	120
Part 17	Nonmetallic Materials	120
MA323	General Requirements	120
Part 18	Standards for Nonmetallic and Nonmetallic Lined Piping Components	120
MA326	Dimensions and Ratings of Components	120
Part 19	Fabrication, Assembly, and Erection of Nonmetallic and Nonmetallic Lined	
	Piping	120
MA327	General	120
MA328	Bonding of Plastics	120
MA329	Fabrication of Piping Lined With Nonmetals	120
MA332	Bending and Forming	
MA334	Joining Nonplastic Piping	120
MA335	Assembly and Erection	120
Part 20	Inspection, Examination, Testing, and Records of Nonmetallic and	1_0
rait 20	Nonmetallic Lined Piping	120
MA340	Inspection	120
MA341	Examination	120
MA342	Examination Personnel	121
MA343	Examination Procedures	121
MA344		121
MA345	Types of Examination	121
MA346	Testing	121
WIA340	Records	141
Chapter IX	High Pressure Piping	122
K300	General Statements	122
Part 1	Conditions and Criteria	122
K301	Design Conditions	122
K302	Design Criteria	123

Part 2	Pressure Design of Piping Components	125
K303	General	125
K304	Pressure Design of High Pressure Components	125
Part 3	Fluid Service Requirements for Piping Components	129
K305	Pipe	129
K306	Fittings, Bends, and Branch Connections	129
K307	Valves and Specialty Components	129
K308	Flanges, Blanks, Flange Facings, and Gaskets	129
K309	Bolting	130
Part 4	Fluid Service Requirements for Piping Joints	130
K310	General	130
K311	Welded Joints	130
K312	Flanged Joints	130
K313	Expanded Joints	130
K314	Threaded Joints	130
K314 K315	Tubing Joints	131
K316		131
K317	Caulked Joints	131
K317		131
	Special Joints	
Part 5	Flexibility and Support	131
K319	Flexibility	131
K321	Piping Support	131
Part 6	Systems	132
K322	Specific Piping Systems	132
Part 7	Materials	132
K323	General Requirements	132
K325	Miscellaneous Materials	137
Part 8	Standards for Piping Components	137
K326	Requirements for Components	137
Part 9	Fabrication, Assembly, and Erection	137
K327	General	137
K328	Welding	137
K330	Preheating	141
K331	Heat Treatment	141
K332	Bending and Forming	141
K333	Brazing and Soldering	142
K335	Assembly and Erection	142
Part 10	Inspection, Examination, and Testing	142
K340	Inspection	142
K341	Examination	142
K342	Examination Personnel	144
K343	Examination Procedures	144
K344	Types of Examination	144
K345	Leak Testing	145
K346	Records	147
Chanter V		1.40
Chapter X	High Purity Piping.	148
U300	General Statements	148
Part 1	Conditions and Criteria	148
U301		
0301	Design Conditions	148
Part 2		148148
Part 2	Pressure Design of Piping Components	148
Part 2 Part 3	Pressure Design of Piping Components	148 148
Part 2 Part 3 U306	Pressure Design of Piping Components Fluid Service Requirements for Piping Components Fittings, Bends, Miters, Laps, and Branch Connections	148 148 148
Part 2 Part 3	Pressure Design of Piping Components	148 148

Part 4	Fluid Service Requirements for Piping Joints	149
U311	Welded Joints	149
U314	Threaded Joints	149
U315	Tubing Joints	149
Part 5	Flexibility and Support	149
U319	Piping Flexibility	149
Part 6		149
	Systems	
Part 7	Metallic Materials	149
Part 8	Standards for Piping Components	150
Part 9	Fabrication, Assembly, and Erection	150
U327	General	150
U328	Welding	150
U330	Preheating	150
U331	Heat Treatment	150
U332	Bending and Forming	150
U333	Brazing and Soldering	150
U335	Assembly and Erection	150
Part 10	Inspection, Examination, and Testing	152
U340	Inspection	152
U341	Examination	152
U342	Examination Personnel	153
U343	Examination Procedures	153
U344	Types of Examination	153
U345	Testing	153
U346	Records	154
Part 11	High Purity Piping in Category M Fluid Service	154
UM300	General Statements	154
UM307	Metallic Valves and Specialty Components	154
UM322	Specific Piping Systems	154
UM328	Welding of Materials	154
UM335	Assembly and Erection of Metallic Piping	154
UM341	Examination	154
UM345	Testing	154
Figures		
300.1.1	Diagram Illustrating Application of B31.3 Piping at Equipment	3
302.3.5	Stress Range Factor, f	18
304.2.1	Nomenclature for Pipe Bends	22
304.2.3	Nomenclature for Miter Bends	22
304.3.3	Branch Connection Nomenclature	25
304.3.4	Extruded Outlet Header Nomenclature	27
304.5.3	Blanks	30
319.4.4A	Moments in Bends	41
319.4.4B	Moments in Branch Connections	41
323.2.2A	Minimum Temperatures Without Impact Testing for Carbon Steel Materials	50
323.2.2B	Reduction in Lowest Exemption Temperature for Steels Without Impact Testing	52
328.3.2	Typical Backing Rings and Consumable Inserts	65
328.4.2	Typical Butt Weld End Preparation	65
328.4.3	Trimming and Permitted Misalignment	65
328.4.4	Preparation for Branch Connections	66
328.5.2A	Fillet Weld Size	67
328.5.2B	Typical Details for Double-Welded Slip-On and Socket Welding Flange	
	Attachment Welds	67

K302.3.3D K305.1.2	Acceptable Severity Levels for Steel Castings	125 129
K323.3.1	Impact Testing Requirements	134
K323.3.5	Minimum Required Charpy V-Notch Impact Values	134
K325.5.5		
	Component Standards	138
K341.3.2	Acceptance Criteria for Welds	143
Appendices		
A	Allowable Stresses and Quality Factors for Metallic Piping and Bolting	
	Materials	155
	Specification Index for Appendix A	156
	Notes for Tables A-1, A-1M, A-1A, A-1B, A-2, and A-2M	159
	Table A-1 Basic Allowable Stresses in Tension for Metals	163
	Iron	
	Castings	163
	Carbon Steel	
	Pipes and Tubes	164
	Pipes (Structural Grade)	168
	Plates, Bars, Shapes, and Sheets	168
	Plates, Bars, Shapes, and Sheets (Structural)	170
	Forgings and Fittings	170
	Castings	170
	Low and Intermediate Alloy Steel	
	Pipes	172
	Plates	174
	Forgings and Fittings	176
	Castings	178
	Stainless Steel	
	Pipes and Tubes	180
	Plates and Sheets	186
	Forgings and Fittings	188
	Bar	192
	Castings	192
	Copper and Copper Alloy	
	Pipes and Tubes	194
	Plates and Sheets	194
	Forgings	196
	Castings	196
	Rod	196
	Nickel and Nickel Alloy	400
	Pipes and Tubes	198
	Plates and Sheets	202
	Forgings and Fittings	202
	Rod and Bar	206
	Castings	206
	Titanium and Titanium Alloy	200
	Pipes and Tubes	208
	Plates and Sheets	208
	Forgings	208
	Zirconium and Zirconium Alloy	200
	Pipes and Tubes	208
	Plates and Sheets	208
	Forgings and Bar	208
	Aluminum Alloy	210
	Seamless Pipes and Tubes	210
	Welded Pipes and Tubes	414

	Structural Tubes	212
	Plates and Sheets	213
	Forgings and Fittings	
	Castings	
	Table A-1M Basic Allowable Stresses in Tension for Metals (Metric)	
	Fe	
	Carbon Steel	218
	Low and Intermediate Alloy Steel	228
	Stainless Steel	
	Copper and Copper Alloy	
	Nickel and Nickel Alloy	
	Titanium and Titanium Alloy	
	Zirconium and Zirconium Alloy	
	Aluminum Alloy	
	Table A-1A Basic Casting Quality Factors, E _c	
	Table A-1B Basic Quality Factors for Longitudinal Weld Joints in Pipes and	
	Tubes, <i>E_i</i>	335
	Table A-2 Design Stress Values for Bolting Materials	338
	Table A-2M Design Stress Values for Bolting Materials (Metric)	346
В	Stress Tables and Allowable Pressure Tables for Nonmetals	
C	Physical Properties of Piping Materials	
D	Flexibility and Stress Intensification Factors	
E	Reference Standards	
F	Guidance and Precautionary Considerations	
G	Safeguarding	
Н	Sample Calculations for Branch Reinforcement	
Ţ	Nomenclature	
K	Allowable Stresses for High Pressure Piping	
L	Aluminum Alloy Pipe Flanges	
M	Guide to Classifying Fluid Services	
N	Application of ASME B31.3 Internationally	
Q	Quality System Program	
R	Use of Alternative Ultrasonic Acceptance Criteria	
S	Piping System Stress Analysis Examples	
V	Allowable Variations in Elevated Temperature Service	
X	Metallic Bellows Expansion Joints	
Z	Preparation of Technical Inquiries	
Index		

FOREWORD

Responding to evident need and at the request of The American Society of Mechanical Engineers, the American Standards Association initiated Project B31 in March 1926, with ASME as sole administrative sponsor. The breadth of the field involved required that membership of the Sectional Committee be drawn from some 40 engineering societies, industries, government bureaus, institutes, and trade associations.

Initial publication in 1935 was as the American Tentative Standard Code for Pressure Piping. Revisions from 1942 through 1955 were published as American Standard Code for Pressure Piping, ASA B31.1. It was then decided to publish as separate documents the various industry Sections, beginning with ASA B31.8-1955, Gas Transmission and Distribution Piping Systems. The first Petroleum Refinery Piping Code Section was designated ASA B31.3-1959. ASA B31.3 revisions were published in 1962 and 1966.

In 1967–1969, the American Standards Association became first the United States of America Standards Institute, then the American National Standards Institute. The Sectional Committee became American National Standards Committee B31 and the Code was renamed the American National Standard Code for Pressure Piping. The next B31.3 revision was designated ANSI B31.3-1973. Addenda were published through 1975.

A draft Code Section for Chemical Plant Piping, prepared by Section Committee B31.6, was ready for approval in 1974. It was decided, rather than have two closely related Code Sections, to merge the Section Committees and develop a joint Code Section, titled Chemical Plant and Petroleum Refinery Piping. The first edition was published as ANSI B31.3-1976.

In this Code, responsibility for piping design was conceptually integrated with that for the overall processing facility, with safeguarding recognized as an effective safety measure. Three categories of Fluid Service were identified, with a separate Chapter for Category M Fluid Service. Coverage for nonmetallic piping was introduced. New concepts were better defined in five Addenda, the fourth of which added Appendix M, a graphic aid to selection of the proper Fluid Service category.

The Standards Committee was reorganized in 1978 as a Committee operating under ASME procedures with ANSI accreditation. It is now the ASME Code for Pressure Piping, B31 Committee. Section committee structure remains essentially unchanged.

The second edition of Chemical Plant and Petroleum Refinery Piping was compiled from the 1976 Edition and its five Addenda, with nonmetal requirements editorially relocated to a separate Chapter. Its new designation was ANSI/ASME B31.3-1980.

Section Committee B31.10 had a draft Code for Cryogenic Piping ready for approval in 1981. Again, it was decided to merge the two Section Committees and develop a more inclusive Code with the same title. The work of consolidation was partially completed in the ANSI/ASME B31.3-1984 Edition.

Significant changes were made in Addenda to the 1984 Edition: integration of cryogenic requirements was completed; a new stand-alone Chapter on high-pressure piping was added; and coverage of fabrication, inspection, testing, and allowable stresses was reorganized. The new Edition was redesignated as ASME/ANSI B31.3-1987 Edition.

Addenda to the subsequent five Editions, published at three-year intervals, were primarily used to keep the Code up to date. New Appendices were added, however, on requirements for bellows expansion joints, estimating service life, submittal of Inquiries, aluminum flanges, and quality control in the 1990, 1993, 1999, and 2002 Editions, all designated as ASME B31.3.

In a program to clarify the application of all Sections of the Code for Pressure Piping, changes were made in the Introduction and Scope statements of the 1996 Edition, and its title was changed to Process Piping.

Under direction of ASME Codes and Standards management, metric units of measurement were emphasized. With certain exceptions, SI metric units were listed first in the 1996 Edition and were designated as the standard. Instructions for conversion were given where metric data

were not available. U.S. Customary units also were given. By agreement, either system may have been used.

Beginning with the 2004 Edition, the publication cycle of ASME B31.3 was changed to biennial. Other changes made in the 2004 Edition included the introduction of the weld joint strength reduction factor, *W*, and the additions of new Appendix P, Alternative Rules for Evaluating Stress Range, and Appendix S, Piping System Stress Analysis Examples.

Changes that were made to the 2006 and 2008 Editions of ASME B31.3 included the requirement that valves have blowout-proof stems and the addition of a definition for elevated temperature fluid service, respectively. The most significant change that was made to the 2010 Edition of ASME B31.3 was the addition of Chapter X, High Purity Piping. In the 2012 Edition, Tables A-1M and A-2M were added to Appendix A that give allowable design values in SI metric units, and Appendix N, Application of ASME B31.3 Internationally, was also added.

For the 2016 Edition, the allowable design values in SI metric units as shown in Tables A-1M and A-2M were changed from for information only to values that may be used to meet the requirements of the Code.

In this Edition, SI metric units are given first, with U.S. Customary units in parentheses. Table K-1 in Appendix K, and Tables C-1 and C-6 in Appendix C, are exceptions, containing only U.S. Customary units. The allowable design values in Tables A-1 and A-2 are given in U.S. Customary units, and the SI metric values are given in Tables A-1M and A-2M. Either the U.S. Customary units or the SI metric units for these allowable design values may be used. Except for Tables A-1, A-1M, A-2, A-2M, C-1, C-6, and K-1, values in SI metric units are to be regarded as the standard, unless otherwise agreed between the contracting parties. Instructions are given in Tables C-1, C-6, and K-1 for converting tabular data in U.S. Customary units to appropriate SI metric units.

Interpretations, Code Cases, and errata to the B31.3 Code on Process Piping are published on the following ASME web page: https://cstools.asme.org/csconnect/CommitteePages.cfm?Committee=N10020400.

ASME B31.3-2016 was approved by the American National Standards Institute on July 28, 2016.

ASME B31 COMMITTEE Code for Pressure Piping

(The following is the roster of the Committee at the time of approval of this Code.)

STANDARDS COMMITTEE OFFICERS

J. E. Meyer, Chair J. W. Frey, Vice Chair A. Maslowski, Secretary

STANDARDS COMMITTEE PERSONNEL

R. J. T. Appleby, ExxonMobil Pipeline Co.

C. Becht IV, Becht Engineering Co.

K. C. Bodenhamer, TRC Solutions

R. Bojarczuk, ExxonMobil Research & Engineering Co.

C. J. Campbell, Air Liquide

J. S. Chin, TransCanada Pipeline U.S.

D. D. Christian, Victaulic

R. P. Deubler, Fronek Power Systems, LLC

C. Eskridge, Jacobs Engineering

D. J. Fetzner, BP Exploration Alaska, Inc.

P. D. Flenner, Flenner Engineering Services

J. W. Frey, Stress Engineering Services, Inc.

D. R. Frikken, Becht Engineering Co.

R. A. Grichuk, Fluor Enterprises, Inc.

R. W. Haupt, Pressure Piping Engineering Associates, Inc.

G. A. Jolly, Flowserve/Gestra, USA

A. Maslowski, The American Society of Mechanical Engineers

W. J. Mauro, American Electric Power

J. E. Meyer, Louis Perry Group

T. Monday, Team Industries, Inc.

M. L. Nayyar, NICE

G. R. Petru, Acapella Engineering Services, LLC

D. W. Rahoi, CCM 2000

R. Reamey, Turner Industries Group, LLC

E. H. Rinaca, Dominion Resources, Inc.

M. J. Rosenfeld, Kiefner/Applus — RTD

J. T. Schmitz, Southwest Gas Corp.

S. K. Sinha, Lucius Pitkin, Inc.

W. J. Sperko, Sperko Engineering Services, Inc.

J. P. Swezy, Jr., Boiler Code Tech, LLC

F. W. Tatar, FM Global

K. A. Vilminot, Black & Veatch

L. E. Hayden, Jr., Ex-Officio Member

A. J. Livingston, Ex-Officio Member, Kinder Morgan

J. S. Willis, Ex-Officio Member, Page Southerland Page, Inc.

B31.3 PROCESS PIPING SECTION COMMITTEE

J. E. Meyer, Chair, Louis Perry Group

D. W. Diehl, Vice Chair, Intergraph Corp.

R. Mohamed, *Secretary,* The American Society of Mechanical Engineers

B. L. Agee, GE Energy

K. Armstrong, PCL Industrial Constructors, Inc.

C. Becht IV, Becht Engineering Co.

R. M. Bojarczuk, ExxonMobil Research & Engineering Co.

B. T. Bounds, Bechtel Corp.

R. D. Campbell, Bechtel

D. D. Christian, Victaulic

S. S. Cimorelli, DuPont

J. A. D'Avanzo, Fluoroseal Valves

C. E. Davila, Crane Energy

D. R. Edwards

J. P. Ellenberger

R. W. Engle, IHI E&C International Corp.

C. H. Eskridge, Jr., Jacobs Engineering

D. J. Fetzner, BP Exploration Alaska, Inc.

P. D. Flenner, Flenner Engineering ServicesD. R. Fraser, NASA Ames Research Center

D. R. Frikken, Becht Engineering Co.

B. S. Gordon, Under Pressure Code Consulting and Training

O. R. Greulich, NASA

R. A. Grichuk, Fluor Enterprises, Inc.

P. J. Guerrieri, Sr., Integrated Mechanical Services, Inc.

R. W. Haupt, Pressure Piping Engineering Associates, Inc.

B. K. Henon. Magnatech. LLC

J. F. Hodgins, Car-Ber Testing Services

W. M. Huitt, W. M. Huitt Co.

D. L. laniro, Mainthia Technologies, Inc.

W. J. Koves, Pi Engineering Software, Inc.

R. A. Leishear, Leishear Engineering, LLC

R. A. McLeod, General Electric Co.

C. J. Melo, Technip USA, Inc.

V. B. Molina III, Air Products & Chemicals, Inc.

C. A. Moore, NOV Fiberglass Systems

A. D. Nalbandian, Thielsch Engineering, Inc.

M. Nguyen, S&B Engineers and Constructors

K. A. Nisly-Nagele, Archer Daniels Midland Co.

D. W. Rahoi, CCM 2000

R. K. Reamey, Turner Industries Group, LLC

G. C. Reinhardt II, Team Industries, Inc.

K. S. Shipley, The Equity Engineering Group, Inc.

C. Y. Shyu, GE Oil & Gas — Flow & Process Technologies

R. J. Silvia, Process Engineers & Constructors, Inc.

J. L. Smith, Jacobs Engineering

J. P. Swezy, Jr., Boiler Code Tech, LLC

F. W. Tatar, FM Global

S. J. Tonkins, BP Americas

S. Vail, Bechtel National, Inc.

B. K. Walker, Consolidated Nuclear Security, LLC

- W. L. Weeks, Lummus Technology
- J. L. Welch, T. D. Williamson, Inc.
- T. D. Willis, Jr., Praxair, Inc.
- G. E. Woods, GCS Consulting Services, Inc.
- S. Biyuan, Delegate, PetroChina Pipeline Co.
- F. Zhang, Delegate, SINOPEC Engineering, Inc.

- D. L. Coym, Contributing Member, Intertek Moody
- D. C. Glover, Contributing Member, KBR
- J. C. Luf, Contributing Member, Jacobs Engineering
- Q. N. Truong, Contributing Member
- J. T. Wier, Honorary Member

B31.3 INTERNATIONAL REVIEW GROUP

- R. W. Engle, Chair, IHI E&C International Corp.
- D. W. Bikker, DuPont de Nemours (Nederland) B.V.
- G. Evans, BP Exploration
- R. Gopalakrishnan, Samsung Saudi Arabia Co. Ltd.
- P. Govindaraj, Dow Benelux B.V.
- S. Govindaraj, Dow Chemical International Private Ltd.
- M. Guidara, Engineering Procurement & Project Management S.A.
- J. M. Hamedi, Euromer Consultants
- S. LaForge, Total France

- J. K. Lambert, Welding Codes and Standards Consultant
- **H. W. Lange,** Lisega AG
- J. Langeland, My Energy AS
- M. S. B. M. Mokhtar, SBM Offshore, Inc.
- T. J. Naughton, Jacobs Engineering
- A. Rokhsativand, Pars Oil & Gas Co.
- **W. Y. Sam,** Shell Sarawak Berhad Deepwater Engineering
- P. Shriwal
- R. Sils, Santos Ltd.
- R. Verstegen, Dow Benelux B.V.

B31.3 SUBGROUP ON DESIGN

- D. L. laniro, Chair, Mainthia Technologies, Inc.
- R. M. Bojarczuk, Vice Chair, ExxonMobil Research & Engineering
- K. S. Shipley, Vice Chair, The Equity Engineering Group, Inc.
- D. Arnett, Chevron Energy Technology Co.
- S. Butler, Shell Global Solutions
- D. W. Diehl, Intergraph Corp.
- D. R. Edwards
- R. W. Haupt, Pressure Piping Engineering Associates, Inc.
- M. Jaouhari, Bechtel Corp.
- W. J. Koves, Pi Engineering Software, Inc.
- J. M. Krance, Swagelok Co.
- E. M. Kvarda, Swagelok
- R. A. Leishear, Leishear Engineering, LLC
- P. D. Moore, Burns & McDonnell

- K. A. Nisly-Nagele, Archer Daniels Midland Co.
- T. C. Scrivner, ExxonMobil Engineering Europe Ltd.
- S. Stelmar, Expansion Joint Manufacturers Association, Inc.
- M. J. Stewart, AECOM
- B. Swartz, SIG
- S. Tucky, CSA Group
- B. K. Walker, Consolidated Nuclear Security, LLC
- G. E. Woods, GCS Consulting Services, Inc.
- R. P. S. Bindra, Contributing Member, CB&I Lummus Private Ltd.
- J. P. Ellenberger, Contributing Member
- S. LaForge, Contributing Member, Total France
- H. W. Lange, Contributing Member, Lisega AG
- J. C. Luf, Contributing Member, Jacobs Engineering
 M. S. B. M. Mokhtar, Contributing Member, SBM Offshore, Inc.
- C. N. Trivedi, Contributing Member, GAIL (India) Ltd.

B31.3 SUBGROUP ON EDIT

- D. J. Fetzner, Chair, BP Exploration Alaska, Inc.
- C. Becht IV, Becht Engineering Co.
- R. W. Engle, IHI E&C International Corp.

- D. R. Frikken, Becht Engineering Co.
- J. E. Meyer, Louis Perry Group
- R. J. Silvia, Process Engineers & Constructors, Inc.

B31.3 SUBGROUP ON FABRICATION, EXAMINATION, AND TESTING

- C. H. Eskridge, Jr., Chair, Jacobs Engineering
- R. D. Campbell, Vice Chair, Bechtel
- K. Armstrong, PCL Industrial Contractors, Inc.
- D. A. Bingham, Los Alamos National Labs
- K. J. Chizen, NDE Level III
- A. C. Collins, JCM Industries, Inc.
- M. G. Collins, ConocoPhillips
- T. Dang, Chevron Energy Technology Co.
- J. Davio, Falcon Fabricators
- P. D. Flenner, Flenner Engineering Services
- B. S. Gordon, Under Pressure Code Consulting and Training
- P. T. Hayes, GE Inspection Technologies
- J. F. Hodgins, Car-Ber Testing Services
- C. Larsen, Team Industrial Services
- J. R. Lindlof, Jacobs Engineering
- D. H. Markman, Summit Mechanical Services, LLC

- R. A. McLeod, General Electric Co.
- A. D. Nalbandian, Thielsch Engineering, Inc.
- R. K. Reamey, Turner Industries Group, LLC
- G. C. Reinhardt II, Team Industries, Inc.
- L. G. Richardson, Crossbridge Compliance
- R. A. Sierra, R. A. Sierra, LLC
- W. J. Sperko, Sperko Engineering Services, Inc.
- J. P. Swezy, Jr., Boiler Code Tech, LLC
- S. W. Vail, Bechtel National, Inc.
- $\textbf{D. A. Williams,}\ \mathsf{Fixed}\ \mathsf{Equipment}\ \mathsf{Hess}\ \mathsf{Corp.}$
- A. T. Balloch, Contributing Member, A&S Consultants
- J. K. Lambert, Contributing Member, Welding Codes and Standards Consultant
- P. P. Buddhadeo, Contributing Member, Bechtel India Private Ltd.
- **A. Rokhsativand,** Contributing Member, Pars Oil & Gas Co.
- R. K. Srivastava, Contributing Member, Larsen & Toubro Ltd.

B31.3 SUBGROUP ON GENERAL REQUIREMENTS

- D. D. Christian, Chair, Victaulic
- S. S. Cimorelli. DuPont
- J. A. D'Avanzo, Fluoroseal Valves
- C. E. Davila, Crane Energy
- G. Evans, BP Exploration
- C. J. Melo, Technip USA, Inc.
- C. Y. Shyu, GE Oil & Gas Flow & Process Technologies
- G. B. Trinker, Victaulic Co.

- J. L. Welch, T. D. Williamson, Inc.
- T. D. Wills, Jr., Praxair, Inc.
- **A. Ali,** Contributing Member, Arabian Co. and Sasakura for Water & Power
- D. L. Coym, Contributing Member, Intertek Moody
- J. Langeland, Contributing Member, My Piping AS
- R. Nanda, Contributing Member, Engineers India Ltd.
- C. E. Sandino, Contributing Member, Atlaspro Engenharia
- P. S. Shriwal, Contributing Member

B31.3 SUBGROUP ON HIGH PRESSURE PIPING

- F. W. Tatar, Chair, FM Global
- B. T. Bounds, Bechtel Corp.
- D. R. Fraser, NASA Ames Research Center
- O. R. Greulich, NASA
- M. H. Nguyen, S&B Engineers and Constructors
- A. P. Rangus, Bechtel
- H. Tiwari, FMC Technologies, Inc.

- M. C. Warren, Xcel Energy
- W. L. Weeks, Lummus Technology
- **S. Govindaraj,** *Contributing Member,* Dow Chemical International Private Ltd.
- A. Jettley, Contributing Member, Bechtel India Private Ltd.
- Q. N. Truong, Contributing Member, Consultant

B31.3 SUBGROUP ON HIGH PURITY SYSTEMS

- P. J. Guerrieri, Sr., Chair, Integrated Mechanical Services, Inc.
- W. F. Daprile, Eli Lilly & Co.
- R. Foster, Hose Master, LLC
- B. K. Henon, Magnatech, LLC

- W. M. Huitt, W. M. Huitt Co.
- V. B. Molina III, Air Products & Chemicals, Inc.
- T. J. Naughton, Contributing Member, Jacobs Engineering

B31.3 SUBGROUP ON MATERIALS

- B. L. Agee, Chair, GE Energy
- S. J. Tonkins, Vice Chair, BP Americas
- C. Chang, Bechtel National, Inc.
- R. A. Grichuk, Fluor Enterprises, Inc.
- L. K. Hovey, Fluor Corp.
- M. Katcher, Haynes International
- D. W. Rahoi, CCM 2000
- A. Raza, SFRL Consultants Ltd.
- C. Reichert
- M. Senatore, Sandvik
- M. Sindelar, Lokring Technology
- J. L. Smith, Jacobs Engineering
- S. Tang, Swagelok Co.
- A. Yasemi, Cenovus Energy, Inc.
- **D. W. Bikker,** *Contributing Member,* DuPont de Nemours (Nederland) B.V.

- S. Biswas, Contributing Member, CH2M Hill
- X. Chen, Contributing Member, SINOPEC Engineering, Inc.
- R. Goel, Contributing Member, CB&I Lummus Private Ltd.
- **R. Gopalakrishnan,** *Contributing Member,* Samsung Saudi Arabia Co. Ltd.
- P. Govindaraj, Contributing Member, Dow Benelux B.V.
- **M. Guidara,** *Contributing Member,* Engineering Procurement & Project Management, S.A.
- A. Kumar, Contributing Member, Larsen & Toubro Ltd.
- R. K. Mittal, Contributing Member, GAIL India Ltd.
- **W. Y. Sam,** *Contributing Member,* Shell Sarawak Berhad Deepwater Engineering
- J. Wang, Contributing Member, SINOPEC Shanghai Engineering Corp.

B31.3 SUBGROUP ON NON-METALLIC PIPING

- J. M. Kalnins, Chair, Crane ResistoFlex
- J. R. Paschal, Vice Chair, Paschal Engineering & Forensic Consulting, Inc.
- J. Becker, ISCO Industries
- M. A. Clark, Nibco, Inc.
- M. McDaniel, The Dow Chemical Co.
- D. A. McGriff, ISCO Industries, LLC
- T. R. McPherson, IPS Corp.
- A. J. Miloser, Charlotte Pipe & Foundry Co.

- C. A. Moore, NOV Fiberglass Systems
- J. D. Roach, IPS Corp.
- N. J. Rollins, Aquatherm NA
- F. R. Volgstadt, Volgstadt & Associates, Inc.
- T. Wraight, Spears Manufacturing Co.
- D. Yanik, Crane ResistoFlex
- R. Hariharan, Contributing Member, COWI
- R. Muruganantham, Contributing Member, Larsen & Toubro Ltd.
- P. Sanyal, Contributing Member, Bechtel India Private Ltd.
- R. Sils, Contributing Member, Santos Ltd.

B31.3 PROCESS PIPING, INDIA INTERNATIONAL WORKING GROUP

- R. P. S. Bindra, Chair, CB&I Lummus Private Ltd.
- A. Kumar, Vice Chair, Larsen & Toubro Ltd.
- **R. Mohamed,** *Secretary,* The American Society of Mechanical Engineers
- S. Biswas, CH2M Hill
- R. Goel, CB&I Lummus Private Ltd.

- A. Jettley, Bechtel India Private Ltd.
- A. Meghani, Petroleum & Natural Gas Regulatory Board
- **D. D. Christian,** *Contributing Member,* Victaulic
- M. Sharma, Contributing Member, ASME India Private Ltd.
- R. K. Srivastava, Alternate, Larsen & Toubro Ltd.

B31 FABRICATION AND EXAMINATION COMMITTEE

- J. P. Swezy, Jr., Chair, Boiler Code Tech, LLC
- U. D'Urso, Secretary, The American Society of Mechanical Engineers
- R. D. Campbell, Bechtel
- R. D. Couch, Electric Power Research Institute
- R. J. Ferguson, Metallurgist
- P. D. Flenner, Flenner Engineering Services

- S. Gingrich, AECOM
- J. Hainsworth
- A. D. Nalbandian, Thielsch Engineering, Inc.
- R. J. Silvia, Process Engineers & Constructors, Inc.
- W. J. Sperko, Sperko Engineering Services, Inc.
- P. L. Vaughan, ONEOK Partners
- K. Wu, Stellar Energy Systems

B31 MATERIALS TECHNICAL COMMITTEE

- R. A. Grichuk, Chair, Fluor Enterprises, Inc.
- **C. E. O'Brien,** Secretary, The American Society of Mechanical Engineers
- B. T. Bounds, Bechtel Corp.
- W. P. Collins, WPC Sol, LLC
- R. P. Deubler, Fronek Power Systems, LLC
- C. H. Eskridge, Jr., Jacobs Engineering
- A. A. Hassan, Power Generation Engineering and Services Co.
- G. A. Jolly, Flowserve/Gestra, USA
- C. J. Melo, Technip USA, Inc.
- M. L. Nayyar, NICE
- M. B. Pickell, Willbros Engineers, Inc.
- D. W. Rahoi, CCM 2000
- R. A. Schmidt, Canadoil
- J. L. Smith, Jacobs Engineering
- Z. Djilali, Contributing Member, Sonatrach

B31 MECHANICAL DESIGN TECHNICAL COMMITTEE

- G. A. Antaki, Chair, Becht Engineering Co., Inc.
- J. E. Meyer, Vice Chair, Louis Perry Group
- R. Lucas, Secretary, The American Society of Mechanical Engineers
- D. Arnett, Chevron Energy Technology Co.
- C. Becht IV, Becht Engineering Co.
- $\begin{tabular}{ll} \bf R. \ \, Bethea, \ \, Huntington \ \, Ingalls \ \, Industries Newport \ \, News \\ Shipbuilding \end{tabular}$
- **P. Cakir-Kavcar,** Bechtel Corp. Oil, Gas & Chemicals
- N. F. Consumo, Sr.
- J. P. Ellenberger
- M. Engelkemier, Stanley Consultants, Inc.
- D. J. Fetzner, BP Exploration Alaska, Inc.
- D. Fraser, NASA Ames Research Center
- J. A. Graziano, Consultant

- J. D. Hart, SSD, Inc.
- R. W. Haupt, Pressure Piping Engineering Associates, Inc.
- **B. P. Holbrook,** Babcock Power, Inc.
- W. J. Koves, Pi Engineering Software, Inc.
- R. A. Leishear, Leishear Engineering, LLC
- G. D. Mayers, Alion Science & Technology
- J. F. McCabe, General Dynamics Electric Boat
- T. Q. McCawley, TQM Engineering PC
- J. C. Minichiello, Bechtel National, Inc.
- A. W. Paulin, Paulin Resource Group
- R. A. Robleto, KBR
- $\textbf{M. J. Rosenfeld,} \; \mathsf{Kiefner/Applus} \mathsf{RTD}$
- **T. Sato,** Japan Power Engineering and Inspection Corp.
- G. Stevick, Berkeley Engineering and Research, Inc.
- E. C. Rodabaugh, Honorary Member, Consultant

B31 CONFERENCE GROUP

- A. Bell, Bonneville Power Administration
- **R. A. Coomes,** Commonwealth of Kentucky, Department of Housing/Boiler Section
- D. H. Hanrath
- C. J. Harvey, Alabama Public Service Commission
- D. T. lagger. Ohio Department of Commerce
- K. T. Lau, Alberta Boilers Safety Association
- R. G. Marini, New Hampshire Public Utilities Commission
- I. W. Mault, Manitoba Department of Labour
- A. W. Meiring, Fire and Building Boiler and Pressure Vessel Division/Indiana

- R. F. Mullaney, Boiler and Pressure Vessel Safety Branch/ Vancouver
- P. Sher, State of Connecticut
- D. A. Starr, Nebraska Department of Labor
- D. J. Stursma, Iowa Utilities Board
- R. P. Sullivan, The National Board of Boiler and Pressure Vessel Inspectors
- J. E. Troppman, Division of Labor/State of Colorado Boiler Inspections
- W. A. M. West, Lighthouse Assistance, Inc.
- T. F. Wickham, Rhode Island Department of Labor

INTRODUCTION

The ASME B31 Code for Pressure Piping consists of a number of individually published Sections, each an American National Standard, under the direction of ASME Committee B31, Code for Pressure Piping.

Rules for each Section reflect the kinds of piping installations considered during its development, as follows:

- B31.1 Power Piping: piping typically found in electric power generating stations, in industrial and institutional plants, geothermal heating systems, and central and district heating and cooling systems
- B31.3 Process Piping: piping typically found in petroleum refineries; chemical, pharmaceutical, textile, paper, semiconductor, and cryogenic plants; and related processing plants and terminals
- B31.4 Pipeline Transportation Systems for Liquids and Slurries: piping transporting products that are predominately liquid between plants and terminals and within terminals, pumping, regulating, and metering stations
- B31.5 Refrigeration Piping and Heat Transfer Components: piping for refrigerants and secondary coolants
- B31.8 Gas Transmission and Distribution Piping Systems: piping transporting products that are predominately gas between sources and terminals, including compressor, regulating, and metering stations; gas gathering pipelines
- B31.9 Building Services Piping: piping typically found in industrial, institutional, commercial, and public buildings, and in multi-unit residences, which does not require the range of sizes, pressures, and temperatures covered in B31.1
- B31.12 Hydrogen Piping and Pipelines: piping in gaseous and liquid hydrogen service and pipelines in gaseous hydrogen service

This is the B31.3 Process Piping Code Section. Hereafter, in this Introduction and in the text of this Code Section B31.3, where the word *Code* is used without specific identification, it means this Code Section.

It is the owner's responsibility to select the Code Section that most nearly applies to a proposed piping installation. Factors to be considered by the owner include limitations of the Code Section; jurisdictional requirements; and the applicability of other codes and standards. All applicable requirements of the selected Code Section shall be met. For some installations, more than one Code Section may apply to different parts of the installation. The owner is also responsible for imposing requirements supplementary to those of the Code if necessary to assure safe piping for the proposed installation.

Certain piping within a facility may be subject to other codes and standards, including but not limited to

- ANSI Z223.1 National Fuel Gas Code: piping for fuel gas from the point of delivery to the connection of each fuel utilization device
- NFPA Fire Protection Standards: fire protection systems using water, carbon dioxide, halon, foam, dry chemicals, and wet chemicals
 - NFPA 99 Health Care Facilities: medical and laboratory gas systems
- building and plumbing codes, as applicable, for potable hot and cold water, and for sewer and drain systems

The Code specifies engineering requirements deemed necessary for safe design and construction of pressure piping. While safety is the primary consideration, this factor alone will not necessarily govern the final specifications for any piping installation. The Code is not a design handbook. Many decisions that must be made to produce a sound piping installation are not specified in detail within this Code. The Code does not serve as a substitute for sound engineering judgments by the owner and the designer.

To the greatest possible extent, Code requirements for design are stated in terms of basic design principles and formulas. These are supplemented as necessary with specific requirements to ensure uniform application of principles and to guide selection and application of piping elements. The Code prohibits designs and practices known to be unsafe and contains warnings where caution, but not prohibition, is warranted.

This Code Section includes the following:

- (a) references to acceptable material specifications and component standards, including dimensional requirements and pressure–temperature ratings
 - (b) requirements for design of components and assemblies, including piping supports
- (c) requirements and data for evaluation and limitation of stresses, reactions, and movements associated with pressure, temperature changes, and other forces
- (d) guidance and limitations on the selection and application of materials, components, and joining methods
 - (e) requirements for the fabrication, assembly, and erection of piping
 - (f) requirements for examination, inspection, and testing of piping

ASME Committee B31 is organized and operates under procedures of The American Society of Mechanical Engineers that have been accredited by the American National Standards Institute. The Committee is a continuing one, and keeps all Code Sections current with new developments in materials, construction, and industrial practice. New editions are published at intervals of two years.

Code users will note that paragraphs in the Code are not necessarily numbered consecutively. Such discontinuities result from following a common outline, insofar as practical, for all Code Sections. In this way, corresponding material is correspondingly numbered in most Code Sections, thus facilitating reference by those who have occasion to use more than one Section.

It is intended that this edition of Code Section B31.3 not be retroactive. Unless agreement is specifically made between contracting parties to use another issue, or the regulatory body having jurisdiction imposes the use of another issue, the latest edition issued at least 6 months prior to the original contract date for the first phase of activity covering a piping installation shall be the governing document for all design, materials, fabrication, erection, examination, and testing for the piping until the completion of the work and initial operation.

Users of this Code are cautioned against making use of Code revisions without assurance that they are acceptable to the proper authorities in the jurisdiction where the piping is to be installed.

The B31 Committee has established an orderly procedure to consider requests for interpretation and revision of Code requirements. To receive consideration, such request must be in writing and must give full particulars in accordance with Appendix Z.

The approved reply to an inquiry will be sent directly to the inquirer. In addition, the question and reply will be published as part of an Interpretation supplement.

A Case is the prescribed form of reply when study indicates that the Code wording needs clarification, or when the reply modifies existing requirements of the Code or grants permission to use new materials or alternative constructions. The Case will be published as part of a Case supplement.

Code Cases remain available for use until annulled by the ASME B31 Standards Committee.

A request for revision of the Code will be placed on the Committee's agenda. Further information or active participation on the part of the proponent may be requested during consideration of a proposed revision.

Materials ordinarily are listed in the stress tables only when sufficient usage in piping within the scope of the Code has been shown. Requests for listing shall include evidence of satisfactory usage and specific data to permit establishment of allowable stresses, maximum and minimum temperature limits, and other restrictions. Additional criteria can be found in the guidelines for addition of new materials in the ASME Boiler and Pressure Vessel Code, Section II. (To develop usage and gain experience, unlisted materials may be used in accordance with para. 323.1.2.)

ASME B31.3-2016 SUMMARY OF CHANGES

Following approval by the B31 Committee and ASME, and after public review, ASME B31.3-2016 was approved by the American National Standards Institute on July 28, 2016.

Changes given below are identified on the pages by a margin note, (16), placed next to the affected area.

Page	Location	Change
xii, xiii	Foreword	(1) Fifteenth paragraph added(2) Third-to-last and last paragraphs revised
xviii	Introduction	Sixth paragraph revised
1	300	Subparagraphs (c)(2) and (c)(3) revised
2–8	300.1.4	Added
	300.2	(1) inline portions of instruments added(2) miter (now miter or miter bend) and severe cyclic conditions revised
10	Table 300.4	Revised
13	302.2.2	Revised
14, 15	302.3.1	Revised
	302.3.2	Subparagraph (e) revised
16–18	Table 302.3.3C	General Note revised
	Table 302.3.3D	General Note revised
	302.3.5	Subparagraph (c) revised
	Table 302.3.4	Last row revised
19	302.3.6	In subparagraph (a), second paragraph revised
21	304.1.1	Nomenclature for S revised
	304.1.3	Subparagraph (a) revised
23–26	304.3.2	Subparagraphs (b) and (c) revised
	304.3.3	Subparagraph (e) revised
30, 31	304.7.2	Subparagraph (d) revised
	305.2.1	Revised
	305.2.3	Footnote 7 revised
32	306.1.4	Subparagraph (a)(2) revised
34	308.2.3	Revised
35	312.3	Added

Page	Location	Change
39, 40	319.4	(1) Subparagraph 319.4.4(c) revised(2) Paragraph 319.4.5 deleted
43	320.2	Revised
47–54	323.2.2	Revised
	Table 323.2.2	 (1) Last two column heads revised (2) Boxes B-3, A-4 (a) and (b), and B-4 revised (3) Notes (4), (5), and (6) renumbered as (7), (4), and (5), respectively, and new Note (6) added (4) Notes (3) and (4) revised
	Fig. 323.2.2A	Subtitle revised
	Fig. 323.2.2B	(1) Title revised(2) General Note (b) revised(3) General Note (c) added
	Table 323.2.2B	Added
60, 61	Table 326.1	Titles of API 602, ASME B16.9, and ASME B16.24 corrected by errata
64	328.4.3	Subparagraph (b) revised
71	Table 330.1.1	First row revised
73	Table 331.1.1	(1) In second column, entry for P-No. 15E revised(2) Note (6) revised
75, 76	Table 331.1.3	(1) Second column head revised(2) In fourth column, first entry for P-No. 3 revised
77	331.2.5	Revised
	332.1	Footnote 1 revised
78	335.2.3	Revised
	335.2.5	Added
81–86	341.3.3	First paragraph revised
	341.3.4	Subparagraph (f) revised
	341.4.1	Subparagraph (b)(1) revised
	Table 341.3.2	 In eleventh column, fifth and ninth entries revised Criterion Value Notes revised Note (3) revised Notes (10) and (11) added
87	341.5.2	Revised
	343	Revised
89	344.6.2	Revised

Page	Location	Change
90, 91	345.2.1	Subparagraph (a) revised
	345.2.3	Subparagraphs (d) and (e) added
	345.2.4	Revised in its entirety
	345.3.1	Revised in its entirety
	345.4.2	(1) Subparagraphs (b) and (c) revised(2) Subparagraph (d) deleted
92	345.5.4	Subparagraph (b) revised
93	346.3	Subparagraph (c) added
95	A302.3.2	Subparagraph (b) revised
97	A304.5.1	Footnote 4 revised
100, 101	A319.3.2	Revised in its entirety
	A319.3.3	Revised
104	A326.4	PEX added to text table
105, 106	Table A326.1	 Under Nonmetallic Fittings, Valves, and Flanges, ASTM F423, F491, F492, F546, F599, and F781 deleted Under Nonmetallic Pipes and Tubes, ASTM F2788/F2788M added
111	A335.2.5	Subparagraph (a)(1) revised
113	A345.4.2	Subparagraph (b) revised
117	M323.2	Revised
118	M341.4	Subparagraph (b) revised
124	K302.3.2	Subparagraph (b)(2) revised
125	K302.5	Revised
128	K304.8.1	Footnote 7 revised
131	K319	Revised
133	K323.2.2	Subparagraph (c) corrected by errata to read Note (2)
	K323.3.1	First sentence corrected by errata to read Note (2)
	K323.3.3	Subparagraph (c) corrected by errata to read Note (2)
137	K326.1.2	Revised
138	Table K326.1	 (1) Title of ASME B16.9 corrected by errata (2) For MSS SP-65, Note reference added (3) General Note and Note (1) revised
141	K331.1	Paragraph K331.1.7 deleted
143, 144	Table K341.3.2	Revised in its entirety
	K342	Revised
	K343	Revised

Page	Location	Change
145	K344.6.3	Revised in its entirety
150	U328.4	Revised
152	U341.3.2	Revised
153	U345	Revised
	U345.1	Revised
154	UM307	Revised in its entirety
	UM341.4	Revised
156–158	Specification Index for Appendix A	 (1) ASTM A167 and A202 deleted (2) For ASTM A453 and B705, titles revised (3) ASTM A536, A928, A995, and B474 added
159–162	Notes for Tables A-1, A-1M, A-1A, A-1B, A-2, and A-2M	(1) General Note (c) and Notes (5), (9), (46), and (77) revised(2) Notes (16) and (17) deleted
163	Table A-1	Under Iron, Castings, A536 65-45-12 added
164, 165	Table A-1	Under Carbon Steel, Pipes and Tubes, for API 5L A, Notes revised
170, 171	Table A-1	In Forgings and Fittings body head, Note reference deleted
172, 173	Table A-1	(1) For Low and Intermediate Alloy Steel entries, Nominal Composition and stress values revised(2) Under Pipes, for A691 9CR, Notes added
174, 175	Table A-1	 For Low and Intermediate Alloy Steel entries, Nominal Composition and stress values revised For A691 CM-65, CM-70, and CM-75, Grade revised For A691 91, Grade revised and Notes added
176, 177	Table A-1	 For Low and Intermediate Alloy Steel entries, Nominal Composition and stress values revised Under Plates, A202 A and B deleted In Forgings and Fittings body head, Note reference deleted
178, 179	Table A-1	 For Low and Intermediate Alloy Steel entries, Nominal Composition and stress values revised In Forgings and Fittings body head, Note reference deleted For A420 WPL3 and A350 LF3, stress values for 200°F through 650°F added

Page	Location	Change
180, 181	Table A-1	 For Stainless Steel entries, Nominal Composition (formerly Material) revised Under Pipes and Tubes, for A451 CPF10MC, UNS No. added For A312 TP310, UNS No. added and Notes revised For A358 310S, Notes revised A409 TP310S added A409 TP310 and TP309 deleted
182, 183	Table A-1	 For Stainless Steel entries, Nominal Composition (formerly Material) revised For A312 TP310H, Grade, UNS No., and Notes revised For A358 310S, Notes revised
184, 185	Table A-1	 For Stainless Steel entries, Nominal Composition (formerly Material) revised For A249 and A312 N08904, Grade deleted For A268 TP443, P-No. and Notes revised For A451 CPE20N, UNS No. added A928 2304 added For A426 CPCA15, Grade revised A358 S31254 added A928 S31803 added
186, 187	Table A-1	 For Stainless Steel entries, Nominal Composition (formerly Material) revised For A790 S32003, Size deleted A928 S32003, 2205, and 2507 added Under Plates and Sheets, for A240 439, Type revised, UNS No. added, and Tensile revised A167 302B, 310, 308, and 309 deleted For first A240 310S, Notes revised
188, 189	Table A-1	 For Stainless Steel entries, Nominal Composition (formerly Material) revised A167 347 and 348 deleted A240 2304 and S31803 added For A240 S31254, Notes added In Forgings and Fittings body head, Note reference deleted For A182 F310H, Grade, UNS No., and Notes revised

Page	Location	Change
190, 191	Table A-1	 For Stainless Steel entries, Nominal Composition (formerly Material) revised For A182 F44, A403 WPS31254, and A403 CRS31254, Notes added A182 F68 and F51 added A815 WPS31803 and CRS31803 added For A182 F60, Grade revised
192, 193	Table A-1	 For Stainless Steel entries, Nominal Composition (formerly Material) revised Under Bar, A479 S31803 added For A479 S31254, Notes added For A479 2205, Nominal Composition corrected by errata to read 22Cr–5Ni–3Mo–N Under Castings, for A351 CN7M, UNS No. revised A351 CE8MN and CD3MWCuN deleted A995 2A and 6A added
194, 195	Table A-1	For Copper and Copper Alloy entries, Nominal Composition revised
196, 197	Table A-1	 For Copper and Copper Alloy entries, Nominal Composition revised Under Plates and Sheets, for B96 C65500, Tensile and stress values revised Under Forgings, for B283 C65500,
198, 199	Table A-1	stress values revised (1) For Nickel and Nickel Alloy entries, Nominal Composition revised (2) Under Pipes and Tubes, B474 N08020 added
200, 201	Table A-1	 (1) For Nickel and Nickel Alloy entries, Nominal Composition revised (2) For B444 N06625, Grade added (3) B705 N06625 added (4) B619, B622, and B626 R20033 added
202, 203	Table A-1	 For Nickel and Nickel Alloy entries, Nominal Composition revised Under Plates and Sheets, for B443 N06625, Grade added For B575 N10362, Notes deleted B625 R20033 added In Forgings and Fittings body head, Note reference deleted
204, 205	Table A-1	 For Nickel and Nickel Alloy entries, Nominal Composition revised In Forgings and Fittings body head, Note reference deleted B462 N10276 and N06022 added For B564 N06022, Class/Condition/ Temper, Size Range, and Notes added

Page	Location	Change
206, 207	Table A-1	 For Nickel and Nickel Alloy entries, Nominal Composition revised B366, B462, and B564 R20033 added Under Rod and Bar, for B446 N06625, Grade added B649 R20033 added Under Castings, for A494 CW12MW, Grade revised, UNS No. added, and Notes revised For A494 CW6M and CX2MW, Grade revised and UNS No. added
208, 209	Table A-1	For Zirconium and Zirconium Alloy entries, Nominal Composition revised
210–215	Table A-1	 For Aluminum Alloy entries, Nominal Composition added In Forgings and Fittings body head, Note reference deleted
216–333	Table A-1M	(1) Min. Temp. entries revised(2) For all forgings & fittings, Note (2) deleted
216, 217	Table A-1M	A536 65-45-12 added
218	Table A-1M	For API 5L A, Notes revised
228	Table A-1M	 (1) For A426 CP15 and CP5b, A335 P11, A369 FP11, and A691 1½CR, Nominal Composition revised (2) For A691 9CR, Notes revised
230	Table A-1M	 For A672 L65, L70, and L75, Nominal Composition revised For A691 CM-65, CM-70, and CM-75, Nominal Composition and Grade revised For A691 91, Grade and Notes revised
232, 233	Table A-1M	 For A387 11 Cl. 1, 11 Cl. 2, and 21 Cl. 2, Nominal Composition revised A202 A and B deleted For A302 A, B, C, and D, Nominal Composition revised For A645 A, Nominal Composition revised For A182 F11 Cl. 1, Nominal Composition revised
234, 235	Table A-1M	 (1) For A182 F11 Cl. 2 and A234 WP11 Cl. 1 and 2, Nominal Composition revised (2) For A420 WPL3, Max. Use Temp. revised and stress values for 125°C through 350°C added (3) For A350 LF3, Max. Use Temp. and stress value for 65°C revised, and stress values for 125°C through 350°C added

Page	Location	Change
236	Table A-1M	For A217 WC4 and WC5, Nominal Composition revised
238–241	Table A-1M	 For A312 TP321, TP304L, TP316L, TP321, TP321H, and TP317L, Product Form revised For A358 304L and 316L, Product Form revised For A451 CPH8, Nominal Composition revised For A451 CPF10MC, Nominal Composition revised and UNS No. added For A268 TP430, Nominal Composition revised For A312 TP310, Product Form revised, UNS No. added, and Notes revised For A358 310S, Product Form and Notes revised A409 TP310S added For A358 321, Product Form revised For A312 TP309, Product Form revised For A358 309S, Product Form revised For A358 309S, Product Form revised A409 TP309 deleted
242, 243	Table A-1M	 (1) For A312 TP347 and TP348, Product Form revised (2) For A358 347 and 348, Product Form revised (3) For A451 CPH10 and CPH20, Nominal Composition revised (4) For A312 TP310H, Product Form and Grade revised, UNS No. added, and Notes revised (5) For A358 310S, Product Form and Notes revised (6) For A358 321 and 316, Product Form revised (7) For A213 TP316 and A269 TP316, Nominal Composition revised (8) For A312 TP316 and TP316H, Product Form revised (9) For A312 TP317, Nominal Composition and Product Form revised (10) For A409 TP317, Nominal Composition revised
246–249	Table A-1M	(1) For A312 TP347, TP348, TP347H, TP348H, TP304, and TP304H, Product Form revised (2) For A358 347, 348, and 304, Product

Form revised

Page Location

Change

- (3) For A451 CPF8M, Nominal Composition revised
- (4) For A249 and A312 N08904, Grade deleted
- (5) For A268 TP443, P-No. and Notes revised
- (6) For A268 TP446-1, Grade revised
- (7) For A451 CPE20N, Nominal Composition revised and UNS No. added
- (8) For A789 and A790 S32304, Nominal Composition and Product Form revised
- (9) A928 2304 added
- (10) A813 and A814 S31254 added
- (11) For A426 CPCA15, Nominal Composition and Grade revised
- (12) A358 S31254 added

250–253 Table A-1M

- (1) For A789 and A790 S31803, Nominal Composition and Product Form revised
- (2) A928 S31803 added
- (3) A249 and A312 S31254 added
- (4) For A789 and A790 S32900, Product Form revised
- (5) A789 and A790 S32101 added
- (6) For A790 S32003, Nominal Composition and Product Form revised, and Size deleted
- (7) A928 S32003 and 2205 added
- (8) For A789 S32003, Nominal Composition and Product Form revised
- (9) For A789 and A790 S32760, Product Form revised
- (10) A789 and A790 S32906 added
- (11) For A789 S32750 and A790 2507, Product Form revised
- (12) A928 2507 added
- (13) For A240 305, Nominal Composition revised

254–257 Table A-1M

- (1) For A240 439, Nominal Composition and Type revised, UNS No. added, and Min. Tensile Strength revised
- (2) A167 302B deleted
- (3) For A240 302, A1010 40, and A1010 50, Nominal Composition revised
- (4) A167 310, 308, 309, 347, and 348 deleted
- (5) For first A240 310S, Notes revised

Page	Location	Change
258–261	Table A-1M	 A240 2304 and S31803 added For A240 201LN, Nominal Composition revised A240 S31254 and S32101 added For A240 S32003, Nominal Composition revised A240 S32906 added For A182 F310H, Grade, UNS No., and Notes revised
262–265	Table A-1M	 (1) A182 F44, A403 WPS31254, and A403 CRS31254 added (2) A182 F68 and F51 added (3) A815 WPS31803 and CRS31803 added
266–269	Table A-1M	 (1) A815 S32101 added (2) A479 S31803, S31254, S32101, and S32906 added (3) For A351 CN7M, Nominal Composition and UNS No. revised (4) For A351 HT30 and CH8, Nominal Composition revised
270–273	Table A-1M	 For A351 CF10MC, CF3M, CH10, CH20, CF8C, CF8M, HK40, HK30, and CE20N, Nominal Composition revised A351 CE8MN and CD3MWCuN deleted A995 2A and 6A added
274–278	Table A-1M	For most copper materials, Nominal Composition revised
276, 277	Table A-1M	(1) For B96 C65500, Min. Tensile Strength and stress values revised, and value for 225°C added(2) For B283 C65500, stress values revised
280–308	Table A-1M	For nickel materials, Nominal Composition revised
280–283	Table A-1M	B474 N08020 added
284–287	Table A-1M	For B619, B622, and B626 N10276, stress values revised
288–291	Table A-1M	 For B619 and B622 N06022, stress value for 225°C revised B619, B622, and B626 N10362 added For B444 N06625, Grade added B705 N06625 added
292–295	Table A-1M	 B619, B622, and B626 R20033 added For B575 N10276, stress values revised For B443 N06625, Grade added For B575 N06022, stress value for 225°C revised

Page	Location	Change
296–299	Table A-1M	(1) B575 N10362 added(2) B625 R20033 added
300–303	Table A-1M	 For B366 and B564 N10276, stress values revised B462 N10276 added For B366 N06022, stress value for 225°C revised B462 N06022 added For B564 N06022, Class/Condition/Temper and Size added, and Notes and value for 225°C revised B366, B462, and B564 N10362 added
304–307	Table A-1M	 B366, B462, and B564 R20033 added For B574 N10276, stress values revised B574 N10362 added For B446 N06625, Grade added B649 R20033 added
308, 309	Table A-1M	 For A494 CW12MW, Grade revised, UNS No. added, and Notes revised For A494 CW6M and CX2MW, Grade revised and UNS No. added
312	Table A-1M	For B861 and B862 R52400, Nominal Composition revised
314	Table A-1M	For zirconium materials, Nominal Composition revised
316–332	Table A-1M	For aluminum alloys, Nominal Composition revised
334	Table A-1A	Under Iron, A536 added
335–337	Table A-1B	 For API 5L, A105, A181, A350, A182, A312, A789, A790, B160, B164, and B690, Descriptions revised A234, A420, A403, A815, B366, and B361 deleted A928 and B474 added
340, 341	Table A-2	Under Stainless Steel, for A453 660, UNS No. added, Min. Temp. revised, and stress values revised
347–361	Table A-2M	(1) Min. Temp. entries revised(2) Straddle head above temperature columns revised
354–357	Table A-2M	For A453 660, UNS No. added, and Min. Temp. and stress values revised
362	Appendix B	Notes moved to applicable tables
363	Specification Index for Appendix B	ASTM F2788/F2788M added
364, 365	Table B-1	(1) Metric columns moved to Table B-1M(2) 200°F column added(3) F2788/F2788M added

Page	Location	Change	
366, 367	Table B-1M	(1) Table created using data previously in Table B-1	
		(2) 93°C column added (3) F2788/F2788M added	
370	Appendix C	General Note moved to Table C-6	
378	Table C-5	PEX0006 and PEX0008 added	
383	Table C-8	PEX0006 and PEX0008 added	
388–393	Appendix E	Revised in its entirety	
394	Appendix F	Title revised	
	F300	Revised	
	F300.1	Added	
	F301.10.3	Added	
396	F323	Subparagraph (b) revised	
397, 398	F323.4	(1) Subparagraphs (b)(6), (c)(1), (c)(2), and (k) revised	
		(2) Footnote 1 revised	
	F345.2.3	Added	
401–403	H301	Second paragraph revised	
	H302	Sixth equation revised	
	Fig. H301	C changed to c in eight places	
406	Fig. H311	C changed to c in eight places	
410–422	Appendix J	Revised in its entirety	
424	Appendix K	Titles in Specification Index revised	
426, 427	Table K-1	(1) Under Carbon Steel, for all Spec. Nos. except API 5L and A694, stress values revised	
		(2) Under Low and Intermediate Alloy Steel, Pipes and Tubes, stress values revised(3) For A335 P5, P-No. revised	
428, 429	Table K-1	(1) Under Low and Intermediate Alloy	
120, 127	Table K-1	Steel, stress values revised (2) Under Forgings and Fittings, for A508 4N, Cl. 2, P-No. revised	
432, 433	Table K-1	Under Nickel and Nickel Alloy, for B622, B366, B564, and B574 N10276, P-No. revised	
440	Fig. M300	In Col. 3, third box revised	
441	N200	Last paragraph revised	
443–445	Appendix R	Added	
459, 460	V302	Subparagraph (c) revised	
	V303.1.2	Revised	

Page	Location	Change
462	X301.1.2	Revised
463	X302.1.2	Revised
	X302.1.3	Revised in its entirety
464	X302.2.3	Subparagraph (a) revised
467–479	Index	Revised in its entirety

NOTES:

- The interpretations to ASME B31.3 issued between April 14, 2014 and September 23, 2015 follow the last page of this edition as a separate supplement, Interpretations Volume 25.
 After the interpretations, a separate supplement containing Cases 180, 181, 185, 191, 193, and 196 follows.

PROCESS PIPING

Chapter I Scope and Definitions

(16) 300 GENERAL STATEMENTS

(a) Identification. This Process Piping Code is a Section of the American Society of Mechanical Engineers Code for Pressure Piping, ASME B31, an American National Standard. It is published as a separate document for convenience of Code users.

(b) Responsibilities

- (1) Owner. The owner of a piping installation shall have overall responsibility for compliance with this Code, and for establishing the requirements for design, construction, examination, inspection, and testing that will govern the entire fluid handling or process installation of which the piping is a part. The owner is also responsible for designating piping in Category D, Category M, High Pressure, and High Purity Fluid Services, and for determining if a specific Quality System is to be employed. [See paras. 300(d)(4) through (7) and Appendix Q.] Where applicable, the owner shall consider requirements imposed by the authority having jurisdiction regarding the piping installation.
- (2) Designer. The designer is responsible to the owner for assurance that the engineering design of piping complies with the requirements of this Code and with any additional requirements established by the owner.
- (3) Manufacturer, Fabricator, and Erector. The manufacturer, fabricator, and erector of piping are responsible for providing materials, components, and workmanship in compliance with the requirements of this Code and of the engineering design.
- (4) Owner's Inspector. The owner's Inspector (see para. 340) is responsible to the owner for ensuring that the requirements of this Code for inspection, examination, and testing are met. If a Quality System is specified by the owner to be employed, the owner's Inspector is responsible for verifying that it is implemented.

(c) Intent of the Code

- (1) It is the intent of this Code to set forth engineering requirements deemed necessary for safe design and construction of piping installations.
- (2) This Code is not intended to apply to the operation, examination, inspection, testing, maintenance, or

- repair of piping that has been placed in service. See para. F300.1 for examples of standards that may apply in these situations. The provisions of this Code may optionally be applied for those purposes, although other considerations may also be necessary.
- (3) The Code generally specifies a simplified approach for many of its requirements. A designer may choose to use a more rigorous analysis to develop design and construction requirements. When the designer decides to take this approach, the designer shall provide to the owner details and calculations demonstrating that design, construction, examination, and testing are consistent with the design criteria of this Code. These details shall be adequate for the owner to verify the validity and shall be approved by the owner. The details shall be documented in the engineering design.
- (4) Piping elements should, insofar as practicable, conform to the specifications and standards listed in this Code. Piping elements neither specifically approved nor specifically prohibited by this Code may be used provided they are qualified for use as set forth in applicable Chapters of this Code.
- (5) The engineering design shall specify any unusual requirements for a particular service. Where service requirements necessitate measures beyond those required by this Code, such measures shall be specified by the engineering design. Where so specified, the Code requires that they be accomplished.
- (6) Compatibility of materials with the service and hazards from instability of contained fluids are not within the scope of this Code. See para. F323.

(d) Determining Code Requirements

- (1) Code requirements for design and construction include fluid service requirements, which affect selection and application of materials, components, and joints. Fluid service requirements include prohibitions, limitations, and conditions, such as temperature limits or a requirement for safeguarding (see Appendix G). Code requirements for a piping system are the most restrictive of those that apply to any of its elements.
- (2) For metallic piping not designated by the owner as Category M, High Pressure, or High Purity Fluid

Service (see para. 300.2 and Appendix M), Code requirements are found in Chapters I through VI (the base Code) and fluid service requirements are found in

- (-a) Chapter III for materials
- (-b) Chapter II, Part 3, for components
- (-c) Chapter II, Part 4, for joints
- (3) For nonmetallic piping and piping lined with nonmetals, all requirements are found in Chapter VII. Paragraph designations begin with "A."
- (4) For piping in a fluid service designated as Category M, all requirements are found in Chapter VIII. Paragraph designations begin with "M."
- (5) For piping in a fluid service designated as Category D, piping elements restricted to Category D Fluid Service in Chapters I through VII, as well as elements suitable for other fluid services, may be used.
- (6) For piping designated as High Pressure Fluid Service, all requirements are found in Chapter IX. These rules apply only when specified by the owner. Paragraph designations begin with "K."
- (7) For piping designated as High Purity Fluid Service, all requirements are found in Chapter X. Paragraph designations begin with "U."
- (8) Requirements for Normal Fluid Service in Chapters I through VI are applicable under severe cyclic conditions unless alternative requirements for severe cyclic conditions are stated.
- (9) Requirements for Normal Fluid Service in Chapters I through VI are applicable for Elevated Temperature Fluid Service unless alternative requirements for Elevated Temperature Fluid Service are invoked.
- (e) Appendices. Appendices of this Code contain Code requirements, supplementary guidance, or other information. See para. 300.4 for a description of the status of each Appendix.
- (f) Code Cases. ASME issues Code Cases that are applicable to this Code. The Code Cases
 - (1) modify the requirements of this Code
- (2) are applicable from the issue date until the Cases are annulled
- (3) may be used only when approved by the owner. When so approved, the Code Cases shall be specified in the engineering design and become requirements of this Code.

300.1 Scope

Rules for the Process Piping Code Section B31.3¹ have been developed considering piping typically found in petroleum refineries; chemical, pharmaceutical, textile, paper, semiconductor, and cryogenic plants; and related processing plants and terminals.

300.1.1 Content and Coverage

- (a) This Code prescribes requirements for materials and components, design, fabrication, assembly, erection, examination, inspection, and testing of piping.
 - (b) This Code applies to piping for all fluids, including
 - (1) raw, intermediate, and finished chemicals
 - (2) petroleum products
 - (3) gas, steam, air, and water
 - (4) fluidized solids
 - (5) refrigerants
 - (6) cryogenic fluids
- (c) See Fig. 300.1.1 for a diagram illustrating the application of B31.3 piping at equipment. The joint connecting piping to equipment is within the scope of B31.3.
- **300.1.2 Packaged Equipment Piping.** Also included within the scope of this Code is piping that interconnects pieces or stages within a packaged equipment assembly.
- **300.1.3 Exclusions.** This Code excludes the following:
- (a) piping systems designed for internal gage pressures at or above zero but less than 105 kPa (15 psi), provided the fluid handled is nonflammable, nontoxic, and not damaging to human tissues as defined in 300.2, and its design temperature is from -29°C (-20°F) through 186°C (366°F)
- (*b*) power boilers in accordance with BPV Code² Section I and boiler external piping that is required to conform to B31.1
- (c) tubes, tube headers, crossovers, and manifolds of fired heaters that are internal to the heater enclosure
- (d) pressure vessels, heat exchangers, pumps, compressors, and other fluid handling or processing equipment, including internal piping and connections for external piping

300.1.4 Rounding. The rules described in this paragraph apply unless otherwise specified in the Code. For purposes of determining conformance with specified limits in this Code, an observed value or a calculated value shall be rounded "to the nearest unit" in the last right-hand significant digit used in expressing the requirement, in accordance with the rounding method of ASTM E29, Using Significant Digits in Test Data to Determine Conformance with Specifications. ASTM E29 requires that when rounding a number to one having a specified number of significant digits, choose that which is nearest. If two choices are possible, as when the digits

16)

 $^{^{1}}$ B31 references here and elsewhere in this Code are to the ASME B31 Code for Pressure Piping and its various Sections, which are identified and briefly described in the Introduction.

² BPV Code references here and elsewhere in this Code are to the ASME Boiler and Pressure Vessel Code and its various Sections as follows:

Section I, Power Boilers

Section II, Materials, Part D

Section V, Nondestructive Examination

Section VIII, Pressure Vessels, Divisions 1 and 2

Section IX, Welding, Brazing, and Fusing Qualifications




Fig. 300.1.1 Diagram Illustrating Application of B31.3 Piping at Equipment

GENERAL NOTE: The means by which piping is attached to equipment is within the scope of the applicable piping code.

dropped are exactly a 5 or a 5 followed only by zeros, choose that ending in an even digit.

For example, if the requirement were 6 mm maximum, a measured value of 6.2 mm would be acceptable because the measured value would first be rounded to 6 mm before comparing it to the requirement. If the requirement were 6.0 mm maximum, then a measured value of 6.2 mm would not meet the requirement.

(16) 300.2 Definitions

Some of the terms relating to piping are defined below. For welding, brazing, and soldering terms not shown here, definitions in accordance with AWS Standard $A3.0^3$ apply.

air-hardened steel: a steel that hardens during cooling in air from a temperature above its transformation range. anneal heat treatment: see heat treatment.

arc cutting: a group of cutting processes wherein the severing or removing of metals is effected by melting with the heat of an arc between an electrode and the base metal. (Includes carbon-arc cutting, metal-arc cutting, gas metal-arc cutting, gas tungsten-arc cutting, plasma-arc cutting, and air carbon-arc cutting.) See also oxygen-arc cutting.

arc welding (AW): a group of welding processes that produces coalescence of metals by heating them with an arc or arcs, with or without the application of pressure and with or without the use of filler metal.

assembly: the joining together of two or more piping components by bolting, welding, bonding, screwing, brazing, soldering, cementing, or use of packing devices as specified by the engineering design.

autogenous weld: a weld made by fusion of the base metal without the addition of filler metal [see also gas tungstenarc welding (GTAW)].

automatic welding: welding with equipment that performs the welding operation without adjustment of the controls by an operator. The equipment may or may not perform the loading and unloading of the work.

backing filler metal: see consumable insert.

backing ring: material in the form of a ring used to support molten weld metal.

³ AWS A3.0, Standard Welding Terms and Definitions, Including Terms for Adhesive Bonding, Brazing, Soldering, Thermal Coupling and Thermal Spraying

balanced piping system: see para. 319.2.2(a).

base material: the material to be brazed, soldered, welded, or otherwise fused.

basic allowable stress: see stress terms frequently used.

bolt design stress: see stress terms frequently used.

bonded joint: a permanent joint in nonmetallic piping made by one of the following methods:

- (a) adhesive joint: a joint made by applying an adhesive to the surfaces to be joined and pressing them together
- (b) butt-and-wrapped joint: a joint made by butting together the joining surfaces and wrapping the joint with plies of reinforcing fabric saturated with resin
- (c) heat fusion joint: a joint made by heating the surfaces to be joined and pressing them together to achieve fusion
- (d) hot gas welded joint: a joint made by simultaneously heating the surfaces to be joined and a filler material with a stream of hot air or hot inert gas, then pressing the surfaces together and applying the filler material to achieve fusion
- (e) solvent cemented joint: a joint made by using a solvent cement to soften the surfaces to be joined and pressing them together
- (f) electrofusion joint: a joint made by heating the surfaces to be joined using an electrical resistance wire coil that remains embedded in the joint.

bonder: one who performs a manual or semiautomatic bonding operation.

bonding operator: one who operates machine or automatic bonding equipment.

bonding procedure: the detailed methods and practices involved in the production of a bonded joint.

bonding procedure specification (BPS): the document that lists the parameters to be used in the construction of bonded joints in accordance with the requirements of this Code.

borescopic examination: a visual examination aided by a mechanical or electromechanical device to examine the inside diameter of inaccessible welds.

branch connection fitting: an integrally reinforced fitting welded to a run pipe and connected to a branch pipe by a buttwelding, socket welding, threaded, or flanged joint; includes a branch outlet fitting conforming to MSS SP-97.

brazing: a metal joining process wherein coalescence is produced by use of a nonferrous filler metal having a melting point above 427°C (800°F), but lower than that of the base metals being joined. The filler metal is distributed between the closely fitted surfaces of the joint by capillary attraction.

butt joint: a joint between two members aligned approximately in the same plane.

Category D: see fluid service.

Category M: see fluid service.

caulked joint: a joint in which suitable material (or materials) is either poured or compressed by the use of tools into the annular space between a bell (or hub) and spigot (or plain end), thus comprising the joint seal.

chemical plant: an industrial plant for the manufacture or processing of chemicals, or of raw materials or intermediates for such chemicals. A chemical plant may include supporting and service facilities, such as storage, utility, and waste treatment units.

cold spring: see para. 319.2.4.

compression type tube fittings: tube fittings consisting of a flareless, mechanical grip connection, including a body, nut, and single or dual ferrules. See also para. U306.6.

connections for external piping: those integral parts of individual pieces of equipment that are designed for attachment of external piping.

consumable insert: preplaced filler metal that is completely fused into the root of the joint and becomes part of the weld.

damaging to human tissues: for the purposes of this Code, this phrase describes a fluid service in which exposure to the fluid, caused by leakage under expected operating conditions, can harm skin, eyes, or exposed mucous membranes so that irreversible damage may result unless prompt restorative measures are taken. (Restorative measures may include flushing with water, administration of antidotes, or medication.)

design minimum temperature: see para. 301.3.1.

design pressure: see para. 301.2.

design temperature: see para. 301.3.

designer: the person or organization in responsible charge of the engineering design.

displacement stress range: see para. 319.2.3.

elements: see piping elements.

engineering design: the detailed design governing a piping system, developed from process and mechanical requirements, conforming to Code requirements, and including all necessary specifications, drawings, and supporting documents.

equipment connection: see connections for external piping.

erection: the complete installation of a piping system in the locations and on the supports designated by the engineering design including any field assembly, fabrication, examination, inspection, and testing of the system as required by this Code.

examination, examiner: see paras. 341.1 and 341.2.

examination, types of: see para. 344.1.3 for the following: (a) 100% examination

- (b) random examination
- (c) spot examination
- (d) random spot examination

extruded outlet header: see para. 304.3.4.

fabrication: the preparation of piping for assembly, including cutting, threading, grooving, forming, bending, and joining of components into subassemblies. Fabrication may be performed in the shop or in the field.

face of weld: the exposed surface of a weld on the side from which the welding was done.

face seal fitting: a High Purity Fluid Service fitting that incorporates two machined faces and a metallic gasket within an external/internal nut configuration to attain a high leak integrity seal. See also para. U315.3(b).

filler material: the material to be added in making metallic or nonmetallic joints.

fillet weld: a weld of approximately triangular cross section joining two surfaces approximately at right angles to each other in a lap joint, tee joint, or corner joint. (See also *size of weld* and *throat of a fillet weld.*)

flammable: for the purposes of this Code, describes a fluid that under ambient or expected operating conditions is a vapor or produces vapors that can be ignited and continue to burn in air. The term thus may apply, depending on service conditions, to fluids defined for other purposes as flammable or combustible.

fluid service: a general term concerning the application of a piping system, considering the combination of fluid properties, operating conditions, and other factors that establish the basis for design of the piping system. See Appendix M.

- (a) Category D Fluid Service: a fluid service in which all of the following apply:
- (1) the fluid handled is nonflammable, nontoxic, and not damaging to human tissues as defined in para. 300.2
- (2) the design gage pressure does not exceed 1 035 kPa (150 psi)
- (3) the design temperature is not greater than 186° C (366° F)
- (4) the fluid temperature caused by anything other than atmospheric conditions is not less than −29°C (−20°F)
- (b) Category M Fluid Service: a fluid service in which both of the following apply:
- (1) the fluid is so highly toxic that a single exposure to a very small quantity of the fluid, caused by leakage, can produce serious irreversible harm to persons on breathing or bodily contact, even when prompt restorative measures are taken
- (2) after consideration of piping design, experience, service conditions, and location, the owner determines that the requirements for Normal Fluid Service do not

sufficiently provide the leak tightness required to protect personnel from exposure

- (c) Elevated Temperature Fluid Service: a fluid service in which the piping metal temperature is sustained equal to or greater than T_{cr} as defined in Table 302.3.5, General Note (b).
- (d) High Pressure Fluid Service: a fluid service for which the owner specifies the use of Chapter IX for piping design and construction; see also para. K300.
- (e) High Purity Fluid Service: a fluid service that requires alternative methods of fabrication, inspection, examination, and testing not covered elsewhere in the Code, with the intent to produce a controlled level of cleanness. The term thus applies to piping systems defined for other purposes as high purity, ultra high purity, hygienic, or aseptic.
- (f) Normal Fluid Service: a fluid service pertaining to most piping covered by this Code, i.e., not subject to the rules for Category D, Category M, Elevated Temperature, High Pressure, or High Purity Fluid Service

full fillet weld: a fillet weld whose size is equal to the thickness of the thinner member joined.

fusion: the melting together of filler material and base material, or of base material only, that results in coalescence.

gas metal-arc welding (GMAW): an arc-welding process that produces coalescence of metals by heating them with an arc between a continuous filler metal (consumable) electrode and the work. Shielding is obtained entirely from an externally supplied gas, or gas mixture. Some variations of this process are called MIG or CO₂ welding (nonpreferred terms).

gas tungsten-arc welding (GTAW): an arc-welding process that produces coalescence of metals by heating them with an arc between a single tungsten (nonconsumable) electrode and the work. Shielding is obtained from a gas or gas mixture. Pressure may or may not be used and filler metal may or may not be used. (This process has sometimes been called TIG welding.)

gas welding: a group of welding processes wherein coalescence is produced by heating with a gas flame or flames, with or without the application of pressure, and with or without the use of filler material.

groove weld: a weld made in the groove between two members to be joined.

heat affected zone: that portion of the base material which has not been melted, but whose mechanical properties or microstructure have been altered by the heat of welding, brazing, soldering, forming, or cutting.

heat treatment: the following terms describe various types and processes of heat treatment:

(a) annealing: heating to and holding at a suitable temperature above the transformation temperature

range, followed by slow cooling to well below the transformation temperature range.

- (b) normalizing: heating a ferrous metal to a temperature above the transformation temperature range, followed by cooling in room-temperature still air to well below the transformation temperature range.
- (c) quenching: when used as a part of a heat-treating operation, a rapid cooling process that results in microstructural stabilization or changes in material properties that would not have occurred without rapid cooling.
- (d) recommended or required heat treatment: the application of heat to a metal section subsequent to a cutting, forming, or welding operation, as provided in para. 331.
- (e) solution heat treatment: heating an alloy to a suitable temperature, holding at that temperature long enough to allow one or more constituents to enter into solid solution, and then cooling rapidly enough to hold the constituents in solution.
- (f) stress-relief: uniform heating of a structure or portion thereof to a sufficient temperature below the transformation temperature range to relieve the major portion of the residual stresses, followed by uniform cooling slowly enough to minimize development of new residual stresses.
- (g) tempering: reheating a hardened metal to a temperature below the transformation range to improve toughness.
- (h) transformation range: the temperature range over which a phase change occurs.
- (i) transformation temperature: the temperature at which a phase change begins or ends. In metals, phase changes can be solid-state changes.

High Pressure Fluid Service: see fluid service.

High Purity Fluid Service: see fluid service.

hygienic clamp joint: a tube outside-diameter union consisting of two neutered ferrules having flat faces with a concentric groove and mating gasket that is secured with a clamp, providing a nonprotruding, recessless product contact surface. See also para. U315.3(b).

indication, linear: in magnetic particle, liquid penetrant, or similar examination, a closed surface area marking or denoting a discontinuity requiring evaluation, whose longest dimension is at least three times the width of the indication.

indication, rounded: in magnetic particle, liquid penetrant, or similar examination, a closed surface area marking or denoting a discontinuity requiring evaluation, whose longest dimension is less than three times the width of the indication.

inline portions of instruments: pressure-containing portions of instruments that are in direct contact with the fluid when installed in a piping system. Permanently sealed fluid-filled tubing systems furnished with instruments as temperature- or pressure-responsive devices,

e.g., pressure gages, pressure transmitters, and transducers, are excluded.

in-process examination: see para. 344.7.

inspection, Inspector: see para. 340.

integrally reinforced branch connection fitting: see branch connection fitting.

joint design: the joint geometry together with the required dimensions of the welded joint.

listed: for the purposes of this Code, describes a material or component that conforms to a specification in Appendix A, Appendix B, or Appendix K or to a standard in Table 326.1, A326.1, or K326.1.

manual welding: a welding operation performed and controlled completely by hand.

may: a term that indicates a provision is neither required nor prohibited.

mechanical joint: a joint for the purpose of mechanical strength or leak resistance, or both, in which the mechanical strength is developed by threaded, grooved, rolled, flared, or flanged pipe ends; or by bolts, pins, toggles, or rings; and the leak resistance is developed by threads and compounds, gaskets, rolled ends, caulking, or machined and mated surfaces.

miter or miter bend: for the purposes of this Code, two or more straight sections of pipe matched and joined in a plane bisecting the angle of junction so as to produce a change in direction greater than 3 deg.

nominal: a numerical identification of dimension, capacity, rating, or other characteristic used as a designation, not as an exact measurement.

Normal Fluid Service: see fluid service.

normalizing: see heat treatment.

notch-sensitive: describes a metal subject to reduction in strength in the presence of stress concentration. The degree of notch sensitivity is usually expressed as the strength determined in a notched specimen divided by the strength determined in an unnotched specimen, and can be obtained from either static or dynamic tests.

NPS: nominal pipe size (followed, when appropriate, by the specific size designation number without an inch symbol).

orbital welding: automatic or machine welding in which the electrode rotates (orbits) around the circumference of a stationary pipe or tube.

oxygen-arc cutting (OAC): an oxygen-cutting process that uses an arc between the workpiece and a consumable electrode, through which oxygen is directed to the workpiece. For oxidation-resistant metals, a chemical flux or metal powder is used to facilitate the reaction.

oxygen cutting (OC): a group of thermal cutting processes that severs or removes metal by means of the chemical

reaction between oxygen and the base metal at elevated temperature. The necessary temperature is maintained by the heat from an arc, an oxyfuel gas flame, or other source.

oxygen gouging: thermal gouging that uses an oxygen cutting process variation to form a bevel or groove.

packaged equipment: an assembly of individual pieces or stages of equipment, complete with interconnecting piping and connections for external piping. The assembly may be mounted on a skid or other structure prior to delivery.

petroleum refinery: an industrial plant for processing or handling of petroleum and products derived directly from petroleum. Such a plant may be an individual gasoline recovery plant, a treating plant, a gas processing plant (including liquefaction), or an integrated refinery having various process units and attendant facilities.

pipe: a pressure-tight cylinder used to convey a fluid or to transmit a fluid pressure, ordinarily designated "pipe" in applicable material specifications. Materials designated "tube" or "tubing" in the specifications are treated as pipe when intended for pressure service. Types of pipe, according to the method of manufacture, are defined as follows:

- (a) electric resistance-welded pipe: pipe produced in individual lengths or in continuous lengths from coiled skelp and subsequently cut into individual lengths, having a longitudinal butt joint wherein coalescence is produced by the heat obtained from resistance of the pipe to the flow of electric current in a circuit of which the pipe is a part, and by the application of pressure.
- (b) furnace butt welded pipe, continuous welded: pipe produced in continuous lengths from coiled skelp and subsequently cut into individual lengths, having its longitudinal butt joint forge welded by the mechanical pressure developed in passing the hot-formed and edgeheated skelp through a set of round pass welding rolls.
- (c) electric-fusion welded pipe: pipe having a longitudinal butt joint wherein coalescence is produced in the preformed tube by manual or automatic electric-arc welding. The weld may be single (welded from one side) or double (welded from inside and outside) and may be made with or without the addition of filler metal.
- (d) double submerged-arc welded pipe: pipe having a longitudinal butt joint produced by at least two passes, one of which is on the inside of the pipe. Coalescence is produced by heating with an electric arc or arcs between the bare metal electrode or electrodes and the work. The welding is shielded by a blanket of granular fusible material on the work. Pressure is not used and filler metal for the inside and outside welds is obtained from the electrode or electrodes.
- (e) seamless pipe: pipe produced by piercing a billet followed by rolling or drawing, or both.

(f) spiral (helical seam) welded pipe: pipe having a helical seam with either a butt, lap, or lock-seam joint that is welded using either an electrical resistance, electric fusion or double-submerged arc welding process.

pipe-supporting elements: pipe-supporting elements consist of fixtures and structural attachments as follows:

- (a) fixtures: fixtures include elements that transfer the load from the pipe or structural attachment to the supporting structure or equipment. They include hanging type fixtures, such as hanger rods, spring hangers, sway braces, counterweights, turnbuckles, struts, chains, guides, and anchors; and bearing type fixtures, such as saddles, bases, rollers, brackets, and sliding supports.
- (b) structural attachments: structural attachments include elements that are welded, bolted, or clamped to the pipe, such as clips, lugs, rings, clamps, clevises, straps, and skirts.

piping: assemblies of piping components used to convey, distribute, mix, separate, discharge, meter, control, or snub fluid flows. Piping also includes pipe-supporting elements, but does not include support structures, such as building frames, bents, foundations, or any equipment excluded from this Code (see para. 300.1.3).

piping components: mechanical elements suitable for joining or assembly into pressure-tight fluid-containing piping systems. Components include pipe, tubing, fittings, flanges, gaskets, bolting, valves, and devices such as expansion joints, flexible joints, pressure hoses, traps, strainers, inline portions of instruments, and separators.

piping elements: any material or work required to plan and install a piping system. Elements of piping include design specifications, materials, components, supports, fabrication, examination, inspection, and testing.

piping installation: designed piping systems to which a selected Code edition and addenda apply.

piping subassembly: a portion of a piping system that consists of one or more piping components.

piping system: interconnected piping subject to the same set or sets of design conditions.

plasma arc cutting (PAC): an arc cutting process that uses a constricted arc and removes molten metal with a high velocity jet of ionized gas issuing from the constricting orifice.

postweld heat treatment: see heat treatment.

preheating: the application of heat to the base material immediately before or during a forming, welding, or cutting process. See para. 330.

procedure qualification record (PQR): a document listing all pertinent data, including the essential variables employed and the test results, used in qualifying the procedure specification.

process unit: an area whose boundaries are designated by the engineering design within which reactions, separations, and other processes are carried out. Examples of installations that are *not* classified as process units are loading areas or terminals, bulk plants, compounding plants, and tank farms and storage yards.

quench annealing: see solution heat treatment under heat treatment.

quenching: see heat treatment.

reinforcement: see paras. 304.3 and A304.3. See also weld reinforcement.

room temperature: temperature between 10°C and 38°C (50°F and 100°F).

root opening: the separation between the members to be joined, at the root of the joint.

safeguarding: provision of protective measures of the types outlined in Appendix G, where deemed necessary. See Appendix G for detailed discussion.

seal bond: a bond intended primarily to provide joint tightness against leakage in nonmetallic piping.

seal weld: a weld intended primarily to provide joint tightness against leakage in metallic piping.

semiautomatic arc welding: arc welding with equipment that controls only the filler metal feed. The advance of the welding is manually controlled.

severe cyclic conditions: conditions applying to specific piping components or joints for which the owner or the designer determines that construction to better resist fatigue loading is warranted. See Appendix F, para. F301.10.3 for guidance on designating piping as being under severe cyclic conditions.

shall: a term that indicates a provision is a Code requirement.

shielded metal-arc welding (SMAW): an arc welding process that produces coalescence of metals by heating them with an arc between a covered metal electrode and the work. Shielding is obtained from decomposition of the electrode covering. Pressure is not used and filler metal is obtained from the electrode.

should: a term that indicates a provision is recommended as good practice but is not a Code requirement.

size of weld:

(a) fillet weld: the leg lengths (the leg length for equalleg welds) of the sides, adjoining the members welded, of the largest triangle that can be inscribed within the weld cross section. For welds between perpendicular members, the definitions in Fig. 328.5.2A apply.

NOTE: When the angle between members exceeds 105 deg, size is of less significance than effective throat (see also *throat of a fillet weld*).

(b) groove weld: the joint penetration (depth of bevel plus the root penetration when specified). The size of a groove weld and its effective throat are the same.

slag inclusion: nonmetallic solid material entrapped in weld metal or between weld metal and base metal.

soldering: a metal joining process wherein coalescence is produced by heating to suitable temperatures and by using a nonferrous alloy fusible at temperatures below 427°C (800°F) and having a melting point below that of the base metals being joined. The filler metal is distributed between closely fitted surfaces of the joint by capillary attraction. In general, solders are lead-tin alloys and may contain antimony, bismuth, and other elements.

solution heat treatment: see heat treatment.

stress ratio: see Fig. 323.2.2B.

stress relief: see heat treatment.

stress terms frequently used:

- (a) basic allowable stress: this term, symbol *S*, represents the stress value for any material determined by the appropriate stress basis in para. 302.3.2
- (b) bolt design stress: this term represents the design stress used to determine the required cross-sectional area of bolts in a bolted joint
- (c) hydrostatic design basis: selected properties of plastic piping materials to be used in accordance with ASTM D2837 or D2992 to determine the HDS [see (d) below] for the material
- (d) hydrostatic design stress (HDS): the maximum continuous stress due to internal pressure to be used in the design of plastic piping, determined from the hydrostatic design basis by use of a service (design) factor

submerged arc welding (SAW): an arc welding process that produces coalescence of metals by heating them with an arc or arcs between a bare metal electrode or electrodes and the work. The arc is shielded by a blanket of granular, fusible material on the work. Pressure is not used and filler metal is obtained from the electrode and sometimes from a supplemental source (welding rod, flux, or metal granules).

tack weld: a weld made to hold parts of a weldment in proper alignment until the final welds are made.

tempering: see heat treatment.

thermoplastic: a plastic that is capable of being repeatedly softened by increase of temperature and hardened by decrease of temperature.

thermosetting resin: a resin capable of being changed into a substantially infusible or insoluble product when cured at room temperature, or by application of heat, or by chemical means.

throat of a fillet weld:

(a) theoretical throat: the perpendicular distance from the hypotenuse of the largest right triangle that can be inscribed in the weld cross section to the root of the joint

- (b) actual throat: the shortest distance from the root of a fillet weld to its face
- (c) effective throat: the minimum distance, minus any reinforcement (convexity), between the weld root and the face of a fillet weld

toe of weld: the junction between the face of a weld and the base material.

tube: see pipe.

tungsten electrode: a nonfiller-metal electrode used in arc welding or cutting, made principally of tungsten.

unbalanced piping system: see para. 319.2.2(b).

undercut: a groove melted into the base material adjacent to the toe or root of a weld and left unfilled by weld material.

visual examination: see para. 344.2.1.

weld: a localized coalescence of material wherein coalescence is produced either by heating to suitable temperatures, with or without the application of pressure, or by application of pressure alone, and with or without the use of filler material.

weld coupon: a sample weld used to determine weld acceptance. Types of weld coupons are defined as follows:

- (a) primary weld coupon: made prior to the start of production welding to establish a benchmark of weld acceptance
- (b) production weld coupon: made when any of the conditions in para. U341.4.5 exist and used to compare

against a corresponding primary weld coupon to demonstrate continued acceptability of welds during production welding

weld coupon examination: see para. U344.8.1.

weld reinforcement: weld material in excess of the specified weld size.

welder: one who performs a manual or semi-automatic welding operation. (This term is sometimes erroneously used to denote a welding machine.)

welding operator: one who operates machine or automatic welding equipment.

welding procedure: the detailed methods and practices involved in the production of a weldment.

welding procedure specification (WPS): the document that lists the parameters to be used in construction of weldments in accordance with requirements of this Code.

weldment: an assembly whose component parts are joined by welding.

300.3 Nomenclature

Dimensional and mathematical symbols used in this Code are listed in Appendix J, with definitions and location references to each. Uppercase and lowercase English letters are listed alphabetically, followed by Greek letters.

300.4 Status of Appendices

Table 300.4 indicates for each Appendix of this Code whether it contains Code requirements, guidance, or supplemental information. See the first page of each Appendix for details.

Table 300.4 Status of Appendices in B31.3

Appendix	Title	Status
Α	Allowable Stresses and Quality Factors for Metallic Piping and Bolting Materials	Requirements
В	Stress Tables and Allowable Pressure Tables for Nonmetals	Requirements
C	Physical Properties of Piping Materials	Requirements (1)
D	Flexibility and Stress Intensification Factors	Requirements (1)
Е	Reference Standards	Requirements
F	Guidance and Precautionary Considerations	Guidance (2)
G	Safeguarding	Guidance (2)
Н	Sample Calculations for Branch Reinforcement	Guidance
J	Nomenclature	Information
K	Allowable Stresses for High Pressure Piping	Requirements (3)
L	Aluminum Alloy Pipe Flanges	Specification (4)
M	Guide to Classifying Fluid Services	Guidance (2)
N	Application of ASME B31.3 Internationally	Guidance (2)
Q	Quality System Program	Guidance (2)
R	Use of Alternative Ultrasonic Acceptance Criteria	Requirements (5)
S	Piping System Stress Analysis Examples	Guidance (2)
V	Allowable Variations in Elevated Temperature Service	Guidance (2)
Χ	Metallic Bellows Expansion Joints	Requirements
Z	Preparation of Technical Inquiries	Requirements (5)

NOTES:

- (1) Contains default requirements, to be used unless more directly applicable data are available.
- (2) Contains no requirements but Code user is responsible for considering applicable items.
- (3) Contains requirements applicable only when use of Chapter IX is specified.
- (4) Contains pressure-temperature ratings, materials, dimensions, and markings of forged aluminum alloy flanges.
- (5) Contains administrative requirements.

Chapter II Design

PART 1 CONDITIONS AND CRITERIA

301 DESIGN CONDITIONS

Paragraph 301 states the qualifications of the Designer, defines the temperatures, pressures, and forces applicable to the design of piping, and states the consideration that shall be given to various effects and their consequent loadings. See also Appendix F, para. F301.

301.1 Qualifications of the Designer

The Designer is the person(s) in charge of the engineering design of a piping system and shall be experienced in the use of this Code. The qualifications and experience required of the Designer will depend on the complexity and criticality of the system and the nature of the individual's experience. The owner's approval is required if the individual does not meet at least one of the following criteria:

- (a) Completion of a degree, accredited by an independent agency [such as ABET (U.S. and international), NBA (India), CTI (France), and CNAP (Chile)], in engineering, science, or technology, requiring the equivalent of at least 4 years of full-time study that provides exposure to fundamental subject matter relevant to the design of piping systems, plus a minimum of 5 years experience in the design of related pressure piping.
- (b) Professional Engineering registration, recognized by the local jurisdiction, and experience in the design of related pressure piping.
- (c) Completion of an accredited engineering technician or associates degree, requiring the equivalent of at least 2 years of study, plus a minimum of 10 years experience in the design of related pressure piping.
- (*d*) Fifteen years experience in the design of related pressure piping.

Experience in the design of related pressure piping is satisfied by piping design experience that includes design calculations for pressure, sustained and occasional loads, and piping flexibility.

301.2 Design Pressure

301.2.1 General

(a) The design pressure of each component in a piping system shall be not less than the pressure at the most severe condition of coincident internal or external pressure and temperature (minimum or maximum) expected during service, except as provided in para. 302.2.4.

- (b) The most severe condition is that which results in the greatest required component thickness and the highest component rating.
- (c) When more than one set of pressure–temperature conditions exist for a piping system, the conditions governing the rating of components conforming to listed standards may differ from the conditions governing the rating of components designed in accordance with para. 304.
- (d) When a pipe is separated into individualized pressure-containing chambers (including jacketed piping, blanks, etc.), the partition wall shall be designed on the basis of the most severe coincident temperature (minimum or maximum) and differential pressure between the adjoining chambers expected during service, except as provided in para. 302.2.4.

301.2.2 Required Pressure Containment or Relief

- (a) Provision shall be made to safely contain or relieve (see para. 322.6.3) any expected pressure to which the piping may be subjected. Piping not protected by a pressure-relieving device, or that can be isolated from a pressure-relieving device, shall be designed for at least the highest expected pressure.
- (b) Sources of pressure to be considered include ambient influences, pressure oscillations and surges, improper operation, decomposition of unstable fluids, static head, and failure of control devices.
- (c) The allowances of para. 302.2.4(f) are permitted, provided that the other requirements of para. 302.2.4 are also met.

301.3 Design Temperature

The design temperature of each component in a piping system is the temperature at which, under the coincident pressure, the greatest thickness or highest component rating is required in accordance with para. 301.2. (To satisfy the requirements of para. 301.2, different components in the same piping system may have different design temperatures.)

In establishing design temperatures, consider at least the fluid temperatures, ambient temperatures, solar radiation, heating or cooling medium temperatures, and the applicable provisions of paras. 301.3.2, 301.3.3, and 301.3.4.

301.3.1 Design Minimum Temperature. The design minimum temperature is the lowest component temperature expected in service. This temperature may establish special design requirements and material

301.3.2 Uninsulated Components

- (a) For fluid temperatures below 65°C (150°F), the component temperature shall be taken as the fluid temperature unless solar radiation or other effects result in a higher temperature.
- (b) For fluid temperatures 65°C (150°F) and above, unless a lower average wall temperature is determined by test or heat transfer calculation, the temperature for uninsulated components shall be no less than the following values:
- (1) valves, pipe, lapped ends, welding fittings, and other components having wall thickness comparable to that of the pipe 95% of the fluid temperature
- (2) flanges (except lap joint) including those on fittings and valves 90% of the fluid temperature
 - (3) lap joint flanges 85% of the fluid temperature
 - (4) bolting 80% of the fluid temperature
- **301.3.3 Externally Insulated Piping.** The component design temperature shall be the fluid temperature unless calculations, tests, or service experience based on measurements support the use of another temperature. Where piping is heated or cooled by tracing or jacketing, this effect shall be considered in establishing component design temperatures.
- **301.3.4 Internally Insulated Piping.** The component design temperature shall be based on heat transfer calculations or tests.

301.4 Ambient Effects

See Appendix F, para. F301.4.

- **301.4.1 Cooling Effects on Pressure.** The cooling of a gas or vapor in a piping system may reduce the pressure sufficiently to create an internal vacuum. In such a case, the piping shall be capable of withstanding the external pressure at the lower temperature, or provision shall be made to break the vacuum.
- **301.4.2 Fluid Expansion Effects.** Provision shall be made in the design either to withstand or to relieve increased pressure caused by the heating of static fluid in a piping component. See also para. 322.6.3(b)(2).
- **301.4.3 Atmospheric Icing.** Where the design minimum temperature of a piping system is below 0°C (32°F), the possibility of moisture condensation and buildup of ice shall be considered and provisions made in the design to avoid resultant malfunctions. This applies to surfaces of moving parts of shutoff valves, control valves, pressure-relief devices including discharge piping, and other components.
- **301.4.4 Low Ambient Temperature.** Consideration shall be given to low ambient temperature conditions for displacement stress analysis.

301.5 Dynamic Effects

See Appendix F, para. F301.5.

- **301.5.1 Impact.** Impact forces caused by external or internal conditions (including changes in flow rate, hydraulic shock, liquid or solid slugging, flashing, and geysering) shall be taken into account in the design of piping.
- **301.5.2 Wind.** The effect of wind loading shall be taken into account in the design of exposed piping. The analysis considerations and loads may be as described in ASCE 7. Authoritative local meteorological data may also be used to define or refine the design wind loads.
- **301.5.3 Earthquake.** The effect of earthquake loading shall be taken into account in the design of piping. The analysis considerations and loads may be as described in ASCE 7. Authoritative local seismological data may also be used to define or refine the design earthquake loads.
- **301.5.4 Vibration.** Piping shall be designed, arranged, and supported so as to eliminate excessive and harmful effects of vibration that may arise from such sources as impact, pressure pulsation, turbulent flow vortices, resonance in compressors, and wind.
- **301.5.5 Discharge Reactions.** Piping shall be designed, arranged, and supported so as to withstand reaction forces due to let-down or discharge of fluids.

301.6 Weight Effects

The following weight effects, combined with loads and forces from other causes, shall be taken into account in the design of piping.

- **301.6.1 Live Loads.** These loads include the weight of the medium transported or the medium used for test. Snow and ice loads due to both environmental and operating conditions shall be considered.
- **301.6.2 Dead Loads.** These loads consist of the weight of piping components, insulation, and other superimposed permanent loads supported by the piping.

301.7 Thermal Expansion and Contraction Effects

The following thermal effects, combined with loads and forces from other causes, shall be taken into account in the design of piping. See also Appendix F, para. F301.7.

- **301.7.1 Thermal Loads Due to Restraints.** These loads consist of thrusts and moments that arise when free thermal expansion and contraction of the piping are prevented by restraints or anchors.
- **301.7.2 Loads Due to Temperature Gradients.** These loads arise from stresses in pipe walls resulting from

large rapid temperature changes or from unequal temperature distribution as may result from a high heat flux through a comparatively thick pipe or stratified twophase flow causing bowing of the line.

301.7.3 Loads Due to Differences in Expansion Characteristics. These loads result from differences in thermal expansion where materials with different thermal expansion coefficients are combined, as in bimetallic, lined, jacketed, or metallic–nonmetallic piping.

301.8 Effects of Support, Anchor, and Terminal Movements

The effects of movements of piping supports, anchors, and connected equipment shall be taken into account in the design of piping. These movements may result from the flexibility and/or thermal expansion of equipment, supports, or anchors; and from settlement, tidal movements, or wind sway.

301.9 Reduced Ductility Effects

The harmful effects of reduced ductility shall be taken into account in the design of piping. The effects may, for example, result from welding, heat treatment, forming, bending, or low operating temperatures, including the chilling effect of sudden loss of pressure on highly volatile fluids. Low ambient temperatures expected during operation shall be considered.

301.10 Cyclic Effects

Fatigue due to pressure cycling, thermal cycling, and other cyclic loadings shall be considered in the design of piping. See Appendix F, para. F301.10.

301.11 Air Condensation Effects

At operating temperatures below -191°C (-312°F) in ambient air, condensation and oxygen enrichment occur. These shall be considered in selecting materials, including insulation, and adequate shielding and/or disposal shall be provided.

302 DESIGN CRITERIA

302.1 General

Paragraph 302 states pressure–temperature ratings, stress criteria, design allowances, and minimum design values together with permissible variations of these factors as applied to the design of piping.

302.2 Pressure-Temperature Design Criteria

302.2.1 Listed Components Having Established

Ratings. Except as limited elsewhere in the Code, pressure–temperature ratings contained in standards for piping components listed in Table 326.1 are acceptable for design pressures and temperatures in accordance with this Code. When the owner approves, provisions

of this Code may be used to extend the pressuretemperature ratings of a component beyond the ratings contained in the listed standard.

302.2.2 Listed Components Not Having Specific (16) Ratings

- (a) Some of the standards for fittings in Table 326.1 (e.g., ASME B16.9 and B16.11) state that pressure—temperature ratings are based on straight seamless pipe. Such fittings shall be rated as calculated for straight seamless pipe with the same allowable stresses as the fitting and the nominal thickness corresponding to the wall thickness or class designation of the fitting, less all applicable allowances (e.g., thread depth and corrosion allowance), and considering the manufacturing undertolerances of the fittings and the pipe.
- (b) For components with straight or spiral (helical seam) longitudinal welded joints, the pressure rating as determined for seamless pipe shall be multiplied by the weld joint strength reduction factor, *W*, as defined in para. 302.3.5(e).
- (c) Other listed components not addressed in para. 302.2.1 or 302.2.2(a) shall have their pressure-temperature ratings established in accordance with the rules in para. 304.
- **302.2.3 Unlisted Components.** Components not listed in Table 326.1 may be used within the following limitations:
- (a) The designer shall be satisfied that composition, mechanical properties, method of manufacture, and design are suitable for the intended service.
- (*b*) Pressure–temperature ratings shall be established in accordance with the rules in para. 304.

302.2.4 Allowances for Pressure and Temperature Variations. Occasional variations of pressure and/or temperature may occur in a piping system. Such variations shall be considered in selecting design pressure (para. 301.2) and design temperature (para. 301.3). The most severe coincident pressure and temperature shall determine the design conditions unless all of the follow-

(a) The piping system shall have no pressurecontaining components of gray iron or other nonductile metal.

ing criteria are met:

- (b) Circumferential pressure stresses (based on minimum pipe wall thickness, less allowances) shall not exceed the yield strength at temperature (see para. 302.3 of this Code and S_y data in BPV Code, Section II, Part D, Table Y-1).
- (c) Combined longitudinal stresses shall not exceed the limits established in para. 302.3.6.
- (d) The total number of pressure–temperature variations above the design conditions shall not exceed 1 000 during the life of the piping system.
- (e) In no case shall the increased pressure exceed the test pressure used under para. 345 for the piping system.

- (f) Occasional variations above design conditions shall remain within one of the following limits for pressure design.
- (1) Subject to the owner's approval, it is permissible to exceed the pressure rating or the allowable stress for pressure design at the temperature of the increased condition by not more than
- (-a) 33% for no more than 10 h at any one time and no more than 100 h/y, or
- (-b) 20% for no more than 50 h at any one time and no more than 500 h/y

The effects of such variations shall be determined by the designer to be safe over the service life of the piping system by methods acceptable to the owner. (See Appendix V.)

- (2) When the variation is self-limiting (e.g., due to a pressure-relieving event), and lasts no more than 50 h at any one time and not more than $500 \, h/y$, it is permissible to exceed the pressure rating or the allowable stress for pressure design at the temperature of the increased condition by not more than 20%.
- (g) The combined effects of the sustained and cyclic variations on the serviceability of all components in the system shall have been evaluated.
- (h) Temperature variations below the minimum temperature shown in Appendix A are not permitted unless the requirements of para. 323.2.2 are met for the lowest temperature during the variation.
- (i) The application of pressures exceeding pressuretemperature ratings of valves may under certain conditions cause loss of seat tightness or difficulty of operation. The differential pressure on the valve closure element should not exceed the maximum differential pressure rating established by the valve manufacturer. Such applications are the owner's responsibility.

302.2.5 Ratings at Junction of Different Services.

When two services that operate at different pressure-temperature conditions are connected, the valve segregating the two services shall be rated for the more severe service condition. Where multiple valves are used (e.g., in a double block and bleed arrangement), all of the valves shall be rated for the more severe service condition. If the valve(s) will operate at a different temperature due to remoteness from a header or piece of equipment, the valve(s) (and any mating flanges) may be selected on the basis of the different temperature. For piping on either side of the valve, however, each system shall be designed for the conditions of the service to which it is connected.

302.3 Allowable Stresses and Other Stress Limits

(16)

302.3.1 General. The allowable stresses defined in paras. 302.3.1(a), (b), and (c) shall be used in design calculations unless modified by other provisions of this Code.

(a) Tension. Basic allowable stresses, *S*, in tension for metals listed in Tables A-1 and A-1M, and design stresses, *S*, for bolting materials listed in Tables A-2 and A-2M were determined in accordance with para. 302.3.2.

In equations elsewhere in the Code where the product *SE* appears, the value *S* is multiplied by one of the following quality factors:¹

- (1) casting quality factor E_c as defined in para. 302.3.3 and tabulated for various material specifications in Table A-1A, and for various levels of supplementary examination in Table 302.3.3C, or
- (2) longitudinal weld joint factor E_j as defined in 302.3.4 and tabulated for various material specifications and classes in Table A-1B, and for various types of joints and supplementary examinations in Table 302.3.4

The stress values in Tables A-1, A-1M, A-2, and A-2M are grouped by materials and product forms, and are for stated temperatures up to the limit provided in para. 323.2.1(a). Straight-line interpolation between temperatures is permissible. The temperature intended is the design temperature (see para. 301.3).

- (b) Shear and Bearing. Allowable stresses in shear shall be 0.80 times the basic allowable stress in tension tabulated in Appendix A. Allowable stress in bearing shall be 1.60 times that value.
- (c) Compression. Allowable stresses in compression shall be no greater than the basic allowable stresses in tension as tabulated in Appendix A. Consideration shall be given to structural stability.
- **302.3.2 Bases for Design Stresses**. The bases for establishing design stress values for bolting materials and allowable stress values for other metallic materials in this Code are as follows:
- (a) Bolting Materials. Design stress values at temperature for bolting materials shall not exceed the lowest of the following:
- (1) except as provided in (3) below, the lower of one-fourth of specified minimum tensile strength at room temperature (S_T) and one-fourth of tensile strength at temperature
- (2) except as provided in (3) below, the lower of two-thirds of specified minimum yield strength at room temperature (S_Y) and two-thirds of yield strength at temperature

16)

Total water and a factor of the second

 $^{^{1}}$ If a component is made of castings joined by longitudinal welds, both a casting and a weld joint quality factor shall be applied. The equivalent quality factor E is the product of E_c , Table A-1A, and E_j , Table A-1B. 2 These bases are the same as those for BPV Code, Section III,

These bases are the same as those for BPV Code, Section III, Class 1 materials, given in Section II, Part D. Stress values in B31.3, Appendix A, at temperatures below the creep range generally are the same as those listed in Section II, Part D, Tables 2A and 2B, and in Table 3 for bolting, corresponding to those bases. They have been adjusted as necessary to exclude casting quality factors and longitudinal weld joint quality factors. Stress values at temperatures in the creep range generally are the same as those in Section II, Part D, Tables 1A and 1B, corresponding to the bases for Section VIII, Division 1.

- (3) at temperatures below the creep range, for bolting materials whose strength has been enhanced by heat treatment or strain hardening, the least of one-fifth of S_T , one-fourth of the tensile strength at temperature, one-fourth of S_Y , and two-thirds of the yield strength at temperature (unless these values are lower than corresponding values for annealed material, in which case the annealed values shall be used)
- (4) two-thirds of the yield strength at temperature [see para. 302.3.2(f)]
- (5) 100% of the average stress for a creep rate of 0.01% per 1 000 h
- (6) 67% of the average stress for rupture at the end of 100 000 h
- (7) 80% of minimum stress for rupture at the end of 100 000 h $\,$
- (b) Gray Iron. Basic allowable stress values at temperature for gray iron shall not exceed the lower of the following:
- (1) one-tenth of the specified minimum tensile strength at room temperature
- (2) one-tenth of the tensile strength at temperature [see para. 302.3.2(f)]
- (c) Malleable Iron. Basic allowable stress values at temperature for malleable iron shall not exceed the lower of the following:
- (1) one-fifth of the specified minimum tensile strength at room temperature
- (2) one-fifth of the tensile strength at temperature [see para. 302.3.2(f)]
- (d) Other Materials. Basic allowable stress values at temperature for materials other than bolting materials, gray iron, and malleable iron shall not exceed the lowest of the following:
- (1) the lower of one-third of S_T and one-third of tensile strength at temperature
- (2) except as provided in (3) below, the lower of two-thirds of S_Y and two-thirds of yield strength at temperature
- (3) for austenitic stainless steels and nickel alloys having similar stress–strain behavior, the lower of two-thirds of S_Y and 90% of yield strength at temperature [see (e) below]
- (4) 100% of the average stress for a creep rate of 0.01% per 1 000 h $\,$
- (5) 67% of the average stress for rupture at the end of 100 000 h
- (6) 80% of the minimum stress for rupture at the end of $100\,000\ h$
- (7) for structural grade materials, the basic allowable stress shall be 0.92 times the lowest value determined in paras. 302.3.2(d)(1) through (6)

In the application of these criteria, the yield strength at temperature is considered to be $S_Y R_Y$; the tensile strength at temperature is considered to be $1.1S_T R_T$.

- (e) Application Limits. Application of stress values determined in accordance with para. 302.3.2(d)(3) is not recommended for flanged joints and other components in which slight deformation can cause leakage or malfunction.
- (1) These values are shown in italics or boldface in Table A-1, as explained in Note (4a) to Appendix A Tables. Instead, either 75% of the stress value in Table A-1 or two-thirds of the yield strength at temperature listed in the BPV Code, Section II, Part D, Table Y-1 should be used.
- (2) Stress values determined in accordance with subpara. (d)(3) are not identified in Table A-1M. See Note (4b) to Appendix A. When using Table A-1M, two-thirds of the yield strength at temperature listed in the BPV Code, Section II, Part D, Table Y-1 should be used.
- (f) Unlisted Materials. For a material that conforms to para. 323.1.2, the tensile (yield) strength at temperature shall be derived by multiplying the average expected tensile (yield) strength at temperature by the ratio of S_T (S_Y) divided by the average expected tensile (yield) strength at room temperature.

302.3.3 Casting Quality Factor, E_c

- (a) General. The casting quality factors, E_c , defined herein shall be used for cast components not having pressure–temperature ratings established by standards in Table 326.1.
- (b) Basic Quality Factors. Castings of gray and malleable iron, conforming to listed specifications, are assigned a basic casting quality factor, E_c , of 1.00 (due to their conservative allowable stress basis). For most other metals, static castings that conform to the material specification and have been visually examined as required by MSS SP-55, Quality Standard for Steel Castings for Valves, Flanges and Fittings and Other Piping Components Visual Method, are assigned a basic casting quality factor, E_c , of 0.80. Centrifugal castings that meet specification requirements only for chemical analysis, tensile, hydrostatic, and flattening tests, and visual examination are assigned a basic casting quality factor of 0.80. Basic casting quality factors are tabulated for listed specifications in Table A-1A.
- (c) Increased Quality Factors. Casting quality factors may be increased when supplementary examinations are performed on each casting. Table 302.3.3C states the increased casting quality factors, E_c , that may be used for various combinations of supplementary examination. Table 302.3.3D states the acceptance criteria for the examination methods specified in the Notes to Table 302.3.3C. Quality factors higher than those shown in Table 302.3.3C do not result from combining tests (2)(a) and (2)(b), or (3)(a) and (3)(b). In no case shall the quality factor exceed 1.00.

Several of the specifications in Appendix A require machining of all surfaces and/or one or more of these

Table 302.3.3C Increased Casting Quality Factors, E_c

Supplementary Examination in Accordance With Note(s)					
(1)		0.85			
(2)(a) or (2)(b)		0.85			
(3)(a) or (3)(b)		0.95			
(1) and (2)(a) or	(2)(b)	0.90			
(1) and (3)(a) or	(3)(b)	1.00			
(2)(a) or (2)(b) a	nd (3)(a) or (3)(b)	1.00			
GENERAL NOTE: are as follows:	Titles of standards referenced in this	Table's Notes			
ASME B46.1	Surface Texture (Surface Roughness and Lay)	s, Waviness			
ASTM E94	Guide for Radiographic Examination				
ASTM E114	Practice for Ultrasonic Pulse-Echo St Contact Testing	raight-Beam			
ASTM E125	Reference Photographs for Magne Indications on Ferrous Castings	tic Particle			
ASTM E165	Practice for Liquid Penetrant Exam General Industry	nination for			
ASTM E709	Guide for Magnetic Particle Testing				
MSS SP-53	Quality Standard for Steel Castings a for Valves, Flanges, Fittings, and C Components — Magnetic Particle Method	Other Piping			
MSS SP-93	Quality Standard for Steel Castings a for Valves, Flanges, Fittings, and C Components — Liquid Penetrant Method	Other Piping			

NOTES:

- (1) Machine all surfaces to a finish of 6.3 μ m R_a (250 μ in. R_a in accordance with ASME B46.1), thus increasing the effectiveness of surface examination.
- (2) (a) Examine all surfaces of each casting (ferromagnetic material only) by the magnetic particle method in accordance with ASTM E709. Judge acceptability in accordance with MSS SP-53, Table 1.
 - (b) Examine all surfaces of each casting by the liquid penetrant method, in accordance with ASTM E165. Judge acceptability in accordance with SP-93, Table 1.
- (3) (a) Fully examine each casting ultrasonically in accordance with ASTM E114, accepting a casting only if there is no evidence of depth of defects in excess of 5% of wall thickness.
 - (b) Fully radiograph each casting in accordance with ASTM E94. Judge in accordance with the stated acceptance levels in Table 302.3.3D.

supplementary examinations. In such cases, the appropriate increased quality factor is shown in Table A-1A.

302.3.4 Weld Joint Quality Factor, E_i

- (a) Basic Quality Factors. The weld joint quality factors, E_j , tabulated in Table A-1B are basic factors for straight or spiral (helical seam) welded joints for pressure-containing components as shown in Table 302.3.4.
- (b) Increased Quality Factors. Table 302.3.4 also indicates higher joint quality factors that may be substituted for those in Table A-1B for certain kinds of welds if

Table 302.3.3D Acceptance Levels for Castings

(16)

Material Examined Thickness, T	Applicable Standard	Acceptance Level (or Class)	Acceptable Disconti- nuities
Steel $T \le 25 \text{ mm}$ (1 in.)	ASTM E446	1	Types A, B, C
Steel <i>T</i> > 25 mm, ≤ 51 mm (2 in.)	ASTM E446	2	Types A, B, C
Steel $T > 51 \text{ mm},$ $\leq 114 \text{ mm}$ $(4\frac{1}{2} \text{ in.})$	ASTM E186	2	Categories A, B, C
Steel <i>T</i> > 114 mm, ≤ 305 mm (12 in.)	ASTM E280	2	Categories A, B, C
Aluminum & magnesium	ASTM E155	• • •	Shown in reference radiographs
Copper, Ni–Cu Bronze	ASTM E272 ASTM E310	2 2	Codes A, Ba, Bb Codes A and B

GENERAL NOTE: Titles of ASTM standards referenced in this Table are as follows:

- E155 Reference Radiographs for Inspection of Aluminum and Magnesium Castings
- E186 Reference Radiographs for Heavy-Walled (2 to $4 \cdot \frac{1}{2}$ -in. (50.8 to 114 mm)) Steel Castings
- E272 Reference Radiographs for High-Strength Copper-Base and Nickel-Copper Alloy Castings
- E280 Reference Radiographs for Heavy-Walled ($4 \cdot \frac{1}{2}$ to 12 in. (114 to 305 mm)) Steel Castings
- E310 Reference Radiographs for Tin Bronze Castings
- E446 Reference Radiographs for Steel Castings Up to 2 in. (50.8 mm) in Thickness

additional examination is performed beyond that required by the product specification.

302.3.5 Limits of Calculated Stresses Due to (16) Sustained Loads and Displacement Strains

- (a) Internal Pressure Stresses. Stresses due to internal pressure shall be considered safe when the wall thickness of the piping component, including any reinforcement, meets the requirements of para. 304.
- (b) External Pressure Stresses. Stresses due to external pressure shall be considered safe when the wall thickness of the piping component, and its means of stiffening, meet the requirements of para. 304.
- (c) Stresses Due to Sustained Loads, S_L . The sum of the longitudinal stresses due to sustained loads, S_L , e.g., the pressure and weight in any component in a piping system (see para. 320), shall not exceed S_h , where S_h is taken from Table A-1 or Table A-1M at the metal

Table 302.3.4 Longitudinal Weld Joint Quality Factor, E_i

No.	Туре	e of Joint	Type of Seam	Examination	Factor, <i>E_j</i>
1	Furnace butt weld, continuous weld		Straight	As required by listed specification	0.60 [Note (1)]
2	Electric resistance weld		Straight or spiral (helical seam)	As required by listed specification	0.85 [Note (1)]
3	Electric fusion weld				
	(a) Single butt weld		Straight or spiral (helical seam)	As required by listed specification or this Code	0.80
	(with or without filler metal)			Additionally spot radiographed in accordance with para. 341.5.1	0.90
				Additionally 100% radiographed in accordance with para. 344.5.1 and Table 341.3.2	1.00
	(b) Double butt weld		Straight or spiral (helical seam) [except as provided in 4 below]	As required by listed specification or this Code	0.85
	(with or without filler metal)			Additionally spot radiographed in accordance with para. 341.5.1	0.90
				Additionally 100% radiographed in accordance with para. 344.5.1 and Table 341.3.2	1.00
4	Specific specification				
	API 5L, electric fusion weld, double butt seam		Straight (with one or two seams) or spiral (helical	As required by specification	0.95
	Jeun Jeun Jeun Jeun Jeun Jeun Jeun Jeun		seam)	Additionally 100% radiographed in accordance with para. 344.5.1 and Table 341.3.2	1.00

NOTE:

⁽¹⁾ It is not permitted to increase the joint quality factor by additional examination for joint 1 or 2.




Fig. 302.3.5 Stress Range Factor, f

temperature of the operating condition being considered.

(d) Allowable Displacement Stress Range, S_A . The computed displacement stress range, S_E , in a piping system (see para. 319.4.4) shall not exceed the allowable displacement stress range, S_A (see paras. 319.2.3 and 319.3.4), calculated by eq. (1a)

$$S_A = f(1.25S_c + 0.25S_h)$$
 (1a)

When S_h is greater than S_L , the difference between them may be added to the term $0.25S_h$ in eq. (1a). In that case, the allowable stress range is calculated by eq. (1b)

$$S_A = f[1.25(S_c + S_h) - S_L]$$
 (1b)

For eqs. (1a) and (1b)

 $f = \text{stress range factor,}^3 \text{ calculated by eq. (1c)}^4$

$$f$$
 (see Fig. 302.3.5) = $6.0(N)^{-0.2} \le f_m$ (1c)

- f_m = maximum value of stress range factor; 1.2 for ferrous materials with specified minimum tensile strengths \leq 517 MPa (75 ksi) and at metal temperatures \leq 371°C (700°F); otherwise $f_m = 1.0$
- N= equivalent number of full displacement cycles during the expected service life of the piping system⁵
- S_c = basic allowable stress⁶ at minimum metal temperature expected during the displacement cycle under analysis
 - = 138 MPa (20 ksi) maximum
- S_h = basic allowable stress⁶ at maximum metal temperature expected during the displacement cycle under analysis
 - = 138 MPa (20 ksi) maximum
- S_L = stress due to sustained loads; in systems where supports may be active in some conditions and inactive in others, the maximum value of sustained stress, considering all support conditions, shall be used

³ Applies to essentially noncorroded piping. Corrosion can sharply decrease cyclic life; therefore, corrosion resistant materials should be considered where a large number of major stress cycles is anticipated.

⁴ The minimum value for f is 0.15, which results in an allowable displacement stress range, S_A , for an indefinitely large number of cycles.

⁵ The designer is cautioned that the fatigue life of materials operated at elevated temperature may be reduced.

⁶ For castings, the basic allowable stress shall be multiplied by the applicable casting quality factor, E_c . For longitudinal welds, the basic allowable stress need not be multiplied by the weld quality factor, E_i .

When the computed stress range varies, whether from thermal expansion or other conditions, S_E is defined as the greatest computed displacement stress range. The value of N in such cases can be calculated by eq. (1d)

$$N = N_E + \sum (r_i^5 N_i)$$
 for $i = 1, 2, ..., n$ (1d)

where

 N_E = number of cycles of maximum computed displacement stress range, S_E

 N_i = number of cycles associated with displacement stress range, S_i

 $r_i = S_i/S_E$

 S_i = any computed displacement stress range smaller than S_E

(e) Weld Joint Strength Reduction Factor, W. At elevated temperatures, the long-term strength of weld joints may be lower than the long-term strength of the base material. For longitudinal or spiral (helical seam) welded piping components, the product of the allowable stress and the applicable weld quality factor, SE, shall be multiplied by the weld joint strength reduction factor, W, when determining the required wall thickness for internal pressure in accordance with para. 304. The designer is responsible for the application of weld joint strength reduction factors to welds other than longitudinal and spiral (helical seam) (e.g., circumferential). The weld joint strength reduction factor, W, is equal to 1.0 when evaluating occasional loads such as wind and earthquake, or when evaluating permissible variations in accordance with para. 302.2.4. The pressure rating or allowable stress for the occasional load or variation condition is not required to be reduced by the weld joint strength reduction factor. It is also not required when calculating the allowable stress range for displacement stresses, S_A , in para. 302.3.5(d). The weld joint strength reduction factor only applies at weld locations. The weld joint strength reduction factor is the ratio of the nominal stress to cause failure of the weld joint to that of the base material for the same duration. Except as provided in (f) below, the weld joint strength reduction factor, W, shall be in accordance with Table 302.3.5.

- (f) Unlisted Weld Strength Reduction Factors. A weld strength reduction factor other than that listed in Table 302.3.5 may be used in accordance with one of the following criteria:
- (1) Creep test data may be used to determine the weld joint strength reduction factor, W. However, the use of creep test data to increase the factor W above that shown in Table 302.3.5 is not permitted for the CrMo and Creep Strength Enhanced Ferritic (CSEF) steels materials, as defined in Table 302.3.5. Creep testing of weld joints to determine weld joint strength reduction factors, when permitted, should be full thickness crossweld specimens with test durations of at least 1 000 h. Full thickness tests shall be used unless the designer

otherwise considers effects such as stress redistribution across the weld.

(2) With the owner's approval, extensive successful experience may be used to justify the factor *W* above that shown in Table 302.3.5. Successful experience must include same or like material, weld metal composition, and welding process under equivalent, or more severe, sustained operating conditions.

302.3.6 Limits of Calculated Stresses Due to (16) Occasional Loads

(a) Operation. The sum of the longitudinal stresses, S_L , due to sustained loads, such as pressure and weight, and of the stresses produced by occasional loads, such as wind or earthquake, may be as much as 1.33 times the basic allowable stress given in Appendix A. Wind and earthquake forces need not be considered as acting concurrently. When detailed analysis is performed, the stresses shall be computed and combined using eqs. (23a) through (23d) with the applicable loads for the condition being evaluated.

For Elevated Temperature Fluid Service (see definition in para. 300.2), as an alternative to the use of 1.33 times the basic allowable stress provided in Appendix A, the allowable stress for occasional loads of short duration, such as surge, extreme wind, or earthquake, may be taken as the strength reduction factor times 90% of the yield strength at temperature for materials other than those with nonductile behavior. This yield strength shall be as listed in the BPV Code, Section II, Part D, Table Y-1, or determined in accordance with para. 302.3.2(f). The strength reduction factor represents the reduction in yield strength with long-term exposure of the material to elevated temperatures and, in the absence of more applicable data, shall be taken as 1.0 for austenitic stainless steel and 0.8 for other materials.

For castings, the basic allowable stress shall be multiplied by the casting quality factor, E_c . Where the allowable stress value exceeds two-thirds of yield strength at temperature, the allowable stress value must be reduced as specified in para. 302.3.2(e).

(b) Test. Stresses due to test conditions are not subject to the limitations in para. 302.3. It is not necessary to consider other occasional loads, such as wind and earthquake, as occurring concurrently with test loads.

302.4 Allowances

In determining the minimum required thickness of a piping component, allowances shall be included for corrosion, erosion, and thread depth or groove depth. See definition for c in para. 304.1.1(b).

302.5 Mechanical Strength

(a) Designs shall be checked for adequacy of mechanical strength under applicable loadings. When necessary,

Table 302.3.5 Weld Joint Strength Reduction Factor, W

					Co	mponen	t Tempe	rature, 7	r _i , °C (°F))					
Steel Group	427 (800)	454 (850)	482 (900)	510 (950)	538 (1,000)	566 (1,050)	593 (1,100)	621 (1,150)	649 (1,200)	677 (1,250)	704 (1,300)	732 (1,350)	760 (1,400)	788 (1,450)	816 (1,500)
CrMo [Notes (1)–(3)]	1	0.95	0.91	0.86	0.82	0.77	0.73	0.68	0.64						
CSEF (N + T) [Notes (3)–(5)]		• • •	• • •	1	0.95	0.91	0.86	0.82	0.77		• • •				• • •
CSEF [Notes (3) and (4)] (Subcritical PWHT)	•••	•••	1	0.5	0.5	0.5	0.5	0.5	0.5	•••	•••	•••	• • • •		•••
Autogenous welds in austenitic stainless grade 3xx, and N088xx and N066xx nickel alloys [Note (6)]	•••	•••	•••	1	1	1	1	1	1	1	1	1	1	1	1
Austenitic stainless grade 3xx and N088xx nickel alloys [Notes (7) and (8)]	•••	•••	•••	1	0.95	0.91	0.86	0.82	0.77	0.73	0.68	0.64	0.59	0.55	0.5
Other materials [Note (9)]															

GENERAL NOTES:

- (a) Weld joint strength reduction factors at temperatures above the upper temperature limit listed in Appendix A for the base metal or outside of the applicable range in Table 302.3.5 are the responsibility of the designer. At temperatures below those where weld joint strength reduction factors are tabulated, a value of 1.0 shall be used for the factor *W* where required; however, the additional rules of this Table and Notes do not apply.
- (b) T_{cr} = temperature 25°C (50°F) below the temperature identifying the start of time-dependent properties listed under "NOTES TIME-DEPENDENT PROPERTIES" (Txx) in the Notes to Tables 1A and 1B of the BPV Code Section II, Part D for the base metals joined by welding. For materials not listed in the BPV Code Section II, Part D, T_{cr} shall be the temperature where the creep rate or stress rupture criteria in paras. 302.3.2(d)(4), (5), and (6) governs the basic allowable stress value of the metals joined by welding. When the base metals differ, the lower value of T_{cr} shall be used for the weld joint.
- (c) T_i = temperature, °C (°F), of the component for the coincident operating pressure–temperature condition, i, under consideration.
- (d) CAUTIONARY NOTE: There are many factors that may affect the life of a welded joint at elevated temperature and all of those factors cannot be addressed in a table of weld strength reduction factors. For example, fabrication issues such as the deviation from a true circular form in pipe (e.g., "peaking" at longitudinal weld seams) or offset at the weld joint can cause an increase in stress that may result in reduced service life and control of these deviations is recommended.
- (e) The weld joint strength reduction factor, *W*, may be determined using linear interpolation for intermediate temperature values.
- (1) The Cr-Mo Steels include: ½Cr-½Mo, 1Cr-½Mo, 11/4Cr-½Mo-Si, 2½Cr-1Mo, 3Cr-1Mo, 5Cr-½Mo, 9Cr-1Mo. Longitudinal and spiral (helical seam) welds shall be normalized, normalized and tempered, or subjected to proper subcritical postweld heat treatment (PWHT) for the alloy. Required examination is in accordance with para. 341.4.4 or 305.2.4.
- (2) Longitudinal and spiral (helical seam) seam fusion welded construction is not permitted for $C-\frac{1}{2}Mo$ steel above 850°F.
- (3) The required carbon content of the weld filler metal shall be ≥0.05 C wt. %. See para. 341.4.4(b) for examination requirements. Basicity index of SAW flux ≥1.0.
- (4) The CSEF (Creep Strength Enhanced Ferritic) steels include grades 91, 92, 911, 122, and 23.
- (5) N + T = Normalizing + Tempering PWHT.
- (6) Autogenous welds without filler metal in austenitic stainless steel (grade 3xx) and austenitic nickel alloys UNS Nos. N066xx and N088xx. A solution anneal after welding is required for use of the factors in the Table. See para. 341.4.3(b) for examination requirements.
- (7) Alternatively, the 100,000 hr Stress Rupture Factors listed in ASME Section III, Division 1, Subsection NH, Tables I-14.10 A-xx, B-xx, and C-xx may be used as the weld joint strength reduction factor for the materials and welding consumables specified.
- (8) Certain heats of the austenitic stainless steels, particularly for those grades whose creep strength is enhanced by the precipitation of temper-resistant carbides and carbonitrides, can suffer from an embritlement condition in the weld heat affected zone that can lead to premature failure of welded components operating at elevated temperatures. A solution annealing heat treatment of the weld area mitigates this susceptibility.
- (9) For carbon steel, W = 1.0 for all temperatures. For materials other than carbon steel, CrMo, CSEF, and the austenitic alloys listed in Table 302.3.5, W shall be as follows: For $T_i \le T_{cr}$, W = 1.0. For $T_{cr} < T_i \le 1,500^{\circ}$ F, $W = 1 0.000909(T_i T_{cr})$. If T_i exceeds the upper temperature for which an allowable stress value is listed in Appendix A for the base metal, the value for W is the responsibility of the designer.

the wall thickness shall be increased to prevent overstress, damage, collapse, or buckling due to superimposed loads from supports, ice formation, backfill, transportation, handling, or other loads enumerated in para. 301.

(b) Where increasing the thickness would excessively increase local stresses or the risk of brittle fracture, or is otherwise impracticable, the impact of applied loads may be mitigated through additional supports, braces, or other means without requiring an increased wall thickness. Particular consideration should be given to the mechanical strength of small pipe connections to piping or equipment.

PART 2 PRESSURE DESIGN OF PIPING COMPONENTS 303 GENERAL

Components manufactured in accordance with standards listed in Table 326.1 shall be considered suitable for use at pressure–temperature ratings in accordance with para. 302.2.1 or para. 302.2.2, as applicable. The rules in para. 304 are intended for pressure design of components not covered in Table 326.1, but may be used for a special or more-rigorous design of such components, or to satisfy requirements of para. 302.2.2. Designs shall be checked for adequacy of mechanical strength as described in para. 302.5.

304 PRESSURE DESIGN OF COMPONENTS

304.1 Straight Pipe

304.1.1 General

(16)

(a) The required thickness of straight sections of pipe shall be determined in accordance with eq. (2)

$$t_m = t + c \tag{2}$$

The minimum thickness, T, for the pipe selected, considering manufacturer's minus tolerance, shall be not less than t_m .

- (b) The following nomenclature is used in the equations for pressure design of straight pipe:
 - c = sum of the mechanical allowances (thread or groove depth) plus corrosion and erosion allowances. For threaded components, the nominal thread depth (dimension h of ASME B1.20.1, or equivalent) shall apply. For machined surfaces or grooves where the tolerance is not specified, the tolerance shall be assumed to be 0.5 mm (0.02 in.) in addition to the specified depth of the cut.
 - D = outside diameter of pipe as listed in tables of standards or specifications or as measured
 - d = inside diameter of pipe. For pressure design calculation, the inside diameter of the pipe is

the maximum value allowable under the purchase specification.

E = quality factor from Table A-1A or Table A-1B

P = internal design gage pressure

S = stress value for material from Table A-1 or Table A-1M

T = pipe wall thickness (measured or minimum in accordance with the purchase specification)

 t = pressure design thickness, as calculated in accordance with para. 304.1.2 for internal pressure or as determined in accordance with para. 304.1.3 for external pressure

 t_m = minimum required thickness, including mechanical, corrosion, and erosion allowances

W = weld joint strength reduction factor in accordance with para. 302.3.5(e)

Y = coefficient from Table 304.1.1, valid for t < D/6 and for materials shown. The value of Y may be interpolated for intermediate temperatures. For $t \ge D/6$,

$$Y = \frac{d + 2c}{D + d + 2c}$$

304.1.2 Straight Pipe Under Internal Pressure

(a) For t < D/6, the internal pressure design thickness for straight pipe shall be not less than that calculated in accordance with either eq. (3a) or eq. (3b)

$$t = \frac{PD}{2(SEW + PY)} \tag{3a}$$

$$t = \frac{P(d+2c)}{2[SEW - P(1-Y)]}$$
 (3b)

(16)

(b) For $t \ge D/6$ or for P/SE > 0.385, calculation of pressure design thickness for straight pipe requires special consideration of factors such as theory of failure, effects of fatigue, and thermal stress.

304.1.3 Straight Pipe Under External Pressure. To determine wall thickness and stiffening requirements for straight pipe under external pressure, the procedure outlined in the BPV Code, Section VIII, Division 1, UG-28 through UG-30 shall be followed, using as the design length, L, the running centerline length between any two sections stiffened in accordance with UG-29. As an exception, for pipe with $D_o/t < 10$, the value of S to be used in determining P_{a2} shall be the lesser of the following values for pipe material at design temperature:


- (a) 1.5 times the stress value from Table A-1 or Table A-1M of this Code, or
- (b) 0.9 times the yield strength tabulated in Section II, Part D, Table Y-1 for materials listed therein

(The symbol D_0 in Section VIII is equivalent to D in this Code.)

				Tempera	ture, °C (°F)						
Material	482 (900) and Below	510 (950)	538 (1,000)	566 (1,050)	593 (1,100)	621 (1,150)	649 (1,200)	677 (1,250) and Above			
Ferritic steels	0.4	0.5	0.7	0.7	0.7	0.7	0.7	0.7			
Austenitic steels	0.4	0.4	0.4	0.4	0.5	0.7	0.7	0.7			
Nickel alloys UNS Nos. N06617, N08800, N08810, and N08825	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.7			
Gray iron	0.0										
Other ductile metals	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4			

Table 304.1.1 Values of Coefficient Y for t < D/6

Fig. 304.2.1 Nomenclature for Pipe Bends



304.2 Curved and Mitered Segments of Pipe

304.2.1 Pipe Bends. The minimum required thickness, t_m , of a bend, after bending, in its finished form, shall be determined in accordance with eqs. (2) and (3c)

$$t = \frac{PD}{2[(SEW/I) + PY]}$$
 (3c)

where at the intrados (inside bend radius)

$$I = \frac{4(R_1/D) - 1}{4(R_1/D) - 2}$$
 (3d)

and at the extrados (outside bend radius)


$$I = \frac{4(R_1/D) + 1}{4(R_1/D) + 2}$$
 (3e)

and at the sidewall on the bend centerline radius, I = 1.0, and where

 R_1 = bend radius of welding elbow or pipe bend

Thickness variations from the intrados to the extrados and along the length of the bend shall be gradual. The thickness requirements apply at the mid-span of the bend, $\gamma/2$, at the intrados, extrados, and bend centerline radius. The minimum thickness at the end tangents shall not be less than the requirements of para. 304.1 for straight pipe (see Fig. 304.2.1).

Fig. 304.2.3 Nomenclature for Miter Bends



304.2.2 Elbows. Manufactured elbows not in accordance with para. 303 shall be qualified as required by para. 304.7.2 or designed in accordance with para. 304.2.1, except as provided in para. 328.4.2(b)(6).

304.2.3 Miter Bends. An angular offset of 3 deg or less (angle α in Fig. 304.2.3) does not require design consideration as a miter bend. Acceptable methods for pressure design of multiple and single miter bends are given in (a) and (b) below.

(a) Multiple Miter Bends. The maximum allowable internal pressure shall be the lesser value calculated from eqs. (4a) and (4b). These equations are not applicable when θ exceeds 22.5 deg.

$$P_m = \frac{SEW(T-c)}{r_2} \left(\frac{T-c}{(T-c) + 0.643 \tan \theta \sqrt{r_2(T-c)}} \right)$$
 (4a)

$$P_m = \frac{SEW(T-c)}{r_2} \left(\frac{R_1 - r_2}{R_1 - 0.5r_2} \right)$$
 (4b)

- (b) Single Miter Bends
- (1) The maximum allowable internal pressure for a single miter bend with angle θ not greater than 22.5 deg shall be calculated by eq. (4a).
- (2) The maximum allowable internal pressure for a single miter bend with angle θ greater than 22.5 deg shall be calculated by eq. (4c)

$$P_{m} = \frac{SEW(T-c)}{r_{2}} \left(\frac{T-c}{(T-c) + 1.25 \tan \theta \sqrt{r_{2}(T-c)}} \right)$$
 (4c)

(c) The miter pipe wall thickness, T, used in eqs. (4a), (4b), and (4c) shall extend a distance not less than M from the inside crotch of the end miter welds where

 $M = \text{the larger of } 2.5(r_2T)^{0.5} \text{ or tan } \theta (R_1 - r_2)$

The length of taper at the end of the miter pipe may be included in the distance, *M*.

(*d*) The following nomenclature is used in eqs. (4a), (4b), and (4c) for the pressure design of miter bends:

c = same as defined in para. 304.1.1

E = same as defined in para. 304.1.1

 P_m = maximum allowable internal pressure for miter bends

 R_1 = effective radius of miter bend, defined as the shortest distance from the pipe centerline to the intersection of the planes of adjacent miter joints

 r_2 = mean radius of pipe using nominal wall \overline{T}

S = same as defined in para. 304.1.1

T = miter pipe wall thickness (measured or minimum in accordance with the purchase specification)

W = same as defined in para. 304.1.1

 α = angle of change in direction at miter joint

 $= 2\theta$

 θ = angle of miter cut

For compliance with this Code, the value of R_1 shall be not less than that given by eq. (5)

$$R_1 = \frac{A}{\tan \theta} + \frac{D}{2} \tag{5}$$

where *A* has the following empirical values:

(1) For SI metric units

$$\begin{array}{ccc}
 & (T-c), \text{ mm} & A \\
 & \leq 13 & 25 \\
 & 13 < (T-c) < 22 & 2(T-c) \\
 & \geq 22 & [2(T-c)/3] + 30
\end{array}$$

(2) For U.S. Customary units

304.2.4 Curved and Mitered Segments of Pipe Under External Pressure. The wall thickness of curved and mitered segments of pipe subjected to external pressure may be determined as specified for straight pipe in para. 304.1.3.

304.3 Branch Connections

304.3.1 General

- (a) Except as provided in (b) below, the requirements in paras. 304.3.2 through 304.3.4 are applicable to branch connections made in accordance with the following methods:
- (1) fittings (tees, extruded outlets, branch outlet fittings in accordance with MSS SP-97, laterals, crosses)
- (2) unlisted cast or forged branch connection fittings (see para. 300.2), and couplings not over DN 80 (NPS 3), attached to the run pipe by welding
- (3) welding the branch pipe directly to the run pipe, with or without added reinforcement, as covered in para. 328.5.4
- (b) The rules in paras. 304.3.2 through 304.3.4 are minimum requirements, valid only for branch connections in which (using the nomenclature of Fig. 304.3.3)
- (1) the run pipe diameter-to-thickness ratio (D_h/T_h) is less than 100 and the branch-to-run diameter ratio (D_b/D_h) is not greater than 1.0
- (2) for run pipe with $D_h/T_h \ge 100$, the branch diameter, D_h , is less than one-half the run diameter, D_h
 - (3) angle β is at least 45 deg
- (4) the axis of the branch intersects the axis of the run
- (c) Where the provisions of (a) and (b) above are not met, pressure design shall be qualified as required by para. 304.7.2.
- (*d*) Other design considerations relating to branch connections are stated in para. 304.3.5.

304.3.2 Strength of Branch Connections. A pipe having a branch connection is weakened by the opening that must be made in it and, unless the wall thickness of the pipe is sufficiently in excess of that required to sustain the pressure, it is necessary to provide added reinforcement. The amount of reinforcement required to sustain the pressure shall be determined in accordance with para. 304.3.3 or 304.3.4. There are, however, certain branch connections that have adequate pressure strength or reinforcement as constructed. It may be assumed without calculation that a branch connection has adequate strength to sustain the internal and external pressure that will be applied to it if

- (a) the branch connection is made with a listed branch type fitting such as an ASME B16.9 or ASME B16.11 tee, or MSS SP-97 branch connection fitting. See para. 303.
- (b) the branch connection is made by welding a listed threaded or socket welding coupling or listed half coupling directly to the run in accordance with para. 328.5.4,

provided the size of the branch does not exceed DN 50 (NPS 2) nor one-fourth the nominal size of the run. The minimum wall thickness of the coupling anywhere in the reinforcement zone (if threads are in the zone, wall thickness is measured from root of thread to minimum outside diameter) shall be not less than that of the unthreaded branch pipe. In no case shall a coupling or half coupling have a rating less than Class 3000 in accordance with ASME B16.11.

(c) the branch connection utilizes an unlisted branch connection fitting (see para. 300.2), provided the fitting is made from materials listed in Table A-1 or Table A-1M and provided that the branch connection is qualified as required by para. 304.7.2.

304.3.3 Reinforcement of Welded Branch Connections. Added reinforcement is required to meet the criteria in paras. 304.3.3(b) and (c) when it is not inherent in the components of the branch connection. Sample problems illustrating the calculations for branch reinforcement are shown in Appendix H.

(a) Nomenclature. The nomenclature below is used in the pressure design of branch connections. It is illustrated in Fig. 304.3.3, which does not indicate details for construction or welding. Some of the terms defined in Appendix J are subject to further definitions or variations, as follows:

b =subscript referring to branch

(16)

 d_1 = effective length removed from pipe at branch. For branch intersections where the branch opening is a projection of the branch pipe inside diameter (e.g., pipe-to-pipe fabricated branch), $d_1 = [D_b - 2(T_b - c)]/\sin \beta$

 d_2 = "half width" of reinforcement zone

= d_1 or $(T_b - c) + (T_h - c) + d_1/2$, whichever is greater, but in any case not more than D_h

h = subscript referring to run or header

 L_4 = height of reinforcement zone outside of run pipe

= $2.5(T_h - c)$ or $2.5(T_b - c) + T_r$, whichever is less

 T_b = branch pipe thickness (measured or minimum in accordance with the purchase specification) except for branch connection fittings (see para. 300.2). For such connections the value of T_b for use in calculating L_4 , d_2 , and A_3 is the thickness of the reinforcing barrel (minimum per purchase specification), provided that the barrel thickness is uniform (see Fig. K328.5.4) and extends at least to the L_4 limit (see Fig. 304.3.3).

 T_r = minimum thickness of reinforcing ring or saddle made from pipe (use nominal thickness if made from plate)

= 0, if there is no reinforcing ring or saddle

t = pressure design thickness of pipe, according to the appropriate wall thickness equation or procedure in para. 304.1. For welded pipe,

when the branch does not intersect the longitudinal weld of the run, the basic allowable stress, S, for the pipe may be used in determining t_h for the purpose of reinforcement calculation only. When the branch does intersect the longitudinal weld of the run, the product SEW (of the stress value, S; the appropriate weld joint quality factor, E_j , from Table A-1B; and the weld joint strength reduction factor, W; see para. 302.3.5) for the run pipe shall be used in the calculation. The product SEW of the branch shall be used in calculating t_b .

 β = smaller angle between axes of branch and run

(b) Required Reinforcement Area. The reinforcement area, A_1 , required for a branch connection under internal pressure is

$$A_1 = t_h d_1 \left(2 - \sin \beta \right) \tag{6}$$

For a branch connection under external pressure, area A_1 is one-half the area calculated by eq. (6), using as t_h the thickness required for external pressure.

(c) Available Area. The area available for reinforcement is defined as

$$A_2 + A_3 + A_4 \ge A_1 \tag{6a}$$

These areas are all within the reinforcement zone and are further defined below.

(1) Area A_2 is the area resulting from excess thickness in the run pipe wall

$$A_2 = (2d_2 - d_1)(T_h - t_h - c) \tag{7}$$

(2) Area A_3 is the area resulting from excess thickness in the branch pipe wall


$$A_3 = 2L_4(T_b - t_b - c) / \sin \beta$$
 (8)

If the allowable stress for the branch pipe wall is less than that for the run pipe, its calculated area must be reduced in the ratio of allowable stress values of the branch to the run in determining its contributions to area A_3 .

(3) Area A_4 is the area of other metal provided by welds and properly attached reinforcement. [See para. 304.3.3(f).] Weld areas shall be based on the minimum dimensions specified in para. 328.5.4, except that larger dimensions may be used if the welder has been specifically instructed to make the welds to those dimensions.

(d) Reinforcement Zone. The reinforcement zone is a parallelogram whose length extends a distance, d_2 , on each side of the centerline of the branch pipe and whose width starts at the inside surface of the run pipe (in its corroded condition) and extends beyond the outside surface of the run pipe a perpendicular distance, L_4 .





- (e) Multiple Branches. When two or more branch connections are so closely spaced that their reinforcement zones overlap, the distance between centers of the openings should be at least 1½ times their average diameter, and the area of reinforcement between any two openings shall be not less than 50% of the total that both require. Each opening shall have adequate reinforcement in accordance with paras. 304.3.3(b) and (c). No part of the metal cross section may apply to more than one opening or be evaluated more than once in any combined area. (Consult PFI Standard ES-7, Minimum Length and Spacing for Branch Connections, for detailed recommendations on spacing of welded nozzles.)
 - (f) Added Reinforcement
- (1) Reinforcement added in the form of a ring or saddle as part of area A_4 shall be of reasonably constant width.
- (2) Material used for reinforcement may differ from that of the run pipe provided it is compatible with run and branch pipes with respect to weldability, heat treatment requirements, galvanic corrosion, thermal expansion, etc.
- (3) If the allowable stress for the reinforcement material is less than that for the run pipe, its calculated area must be reduced in the ratio of allowable stress values in determining its contribution to area A_4 .
- (4) No additional credit may be taken for a material having higher allowable stress value than the run pipe.

304.3.4 Reinforcement of Extruded Outlet Headers

- (a) The principles of reinforcement stated in para. 304.3.3 are essentially applicable to extruded outlet headers. An extruded outlet header is a length of pipe in which one or more outlets for branch connection have been formed by extrusion, using a die or dies to control the radii of the extrusion. The extruded outlet projects above the surface of the header a distance h_x at least equal to the external radius of the outlet r_x (i.e., $h_x \ge r_x$).
- (b) The rules in para. 304.3.4 are minimum requirements, valid only within the limits of geometry shown in Fig. 304.3.4, and only where the axis of the outlet intersects and is perpendicular to the axis of the header. Where these requirements are not met, or where nonintegral material such as a ring, pad, or saddle has been added to the outlet, pressure design shall be qualified as required by para. 304.7.2.
- (c) Nomenclature. The nomenclature used herein is illustrated in Fig. 304.3.4. Note the use of subscript x signifying extruded. Refer to para. 304.3.3(a) for nomenclature not listed here.
 - d_x = the design inside diameter of the extruded outlet, measured at the level of the outside surface of the header. This dimension is taken after removal of all mechanical and corrosion allowances, and all thickness tolerances.
 - d_2 = half width of reinforcement zone (equal to d_x)

- h_x = height of the extruded outlet. This must be equal to or greater than r_x [except as shown in sketch (b) in Fig. 304.3.4].
- L_5 = height of reinforcement zone
 - $= 0.7\sqrt{D_bT_x}$
- r_x = radius of curvature of external contoured portion of outlet, measured in the plane containing the axes of the header and branch
- T_x = corroded finished thickness of extruded outlet, measured at a height equal to r_x above the outside surface of the header
- (*d*) Limitations on Radius r_x . The external contour radius, r_x , is subject to the following limitations:
- (1) minimum r_x the lesser of $0.05D_b$ or 38 mm (1.50 in.)
 - (2) maximum r_x shall not exceed
 - (a) for $D_b < DN 200$ (NPS 8), 32 mm (1.25 in.)
 - (b) for $D_b \ge DN 200$, $0.1D_b + 13$ mm (0.50 in.)
- (3) for an external contour with multiple radii, the requirements of (1) and (2) above apply, considering the best-fit radius over a 45 deg arc as the maximum radius
- (4) machining shall not be employed in order to meet the above requirements
- (e) Required Reinforcement Area. The required area of reinforcement is defined by

$$A_1 = Kt_h d_x \tag{9}$$

where *K* is determined as follows:

- (1) For $D_b/D_h > 0.60$, K = 1.00.
- (2) For $0.60 \ge D_b/D_h > 0.15$, $K = 0.6 + \frac{2}{3}(D_b/D_h)$.
- (3) For $D_b/D_h \le 0.15$, K = 0.70.
- (f) Available Area. The area available for reinforcement is defined as

$$A_2 + A_3 + A_4 \ge A_1 \tag{9a}$$

These areas are all within the reinforcement zone and are further defined below.

(1) Area A_2 is the area resulting from excess thickness in the header wall

$$A_2 = (2d_2 - d_x)(T_h - t_h - c)$$
 (10)

(2) Area A_3 is the area resulting from excess thickness in the branch pipe wall

$$A_3 = 2L_5(T_b - t_b - c) (11)$$


(3) Area A_4 is the area resulting from excess thickness in the extruded outlet lip

$$A_4 = 2r_x[T_x - (T_b - c)] (12)$$

(g) Reinforcement of Multiple Openings. The rules of para. 304.3.3(e) shall be followed, except that the required area and reinforcement area shall be as given in para. 304.3.4.

Fig. 304.3.4 Extruded Outlet Header Nomenclature


This Figure illustrates the nomenclature of para. 304.3.4. It does not indicate complete details or a preferred method of construction.



GENERAL NOTE: Sketch is drawn for condition where K = 1.00.

Fig. 304.3.4 Extruded Outlet Header Nomenclature (Cont'd)

This Figure illustrates the nomenclature of para. 304.3.4. It does not indicate complete details or a preferred method of construction.



- (h) Identification. The manufacturer shall establish the design pressure and temperature for each extruded outlet header and shall mark the header with this information, together with the symbol "B31.3" (indicating the applicable Code Section) and the manufacturer's name or trademark.
- **304.3.5 Additional Design Considerations.** The requirements of paras. 304.3.1 through 304.3.4 are intended to ensure satisfactory performance of a branch connection subject only to pressure. The designer shall also consider the following:
- (a) In addition to pressure loadings, external forces and movements are applied to a branch connection by thermal expansion and contraction, dead and live loads, and movement of piping terminals and supports. Special consideration shall be given to the design of a branch connection to withstand these forces and movements.
- (b) Branch connections made by welding the branch pipe directly to the run pipe should be avoided under the following circumstances:
- (1) when branch size approaches run size, particularly if pipe formed by more than 1.5% cold expansion, or expanded pipe of a material subject to work hardening, is used as the run pipe
- (2) where repetitive stresses may be imposed on the connection by vibration, pulsating pressure, temperature cycling, etc.

In such cases, it is recommended that the design be conservative and that consideration be given to the use

- of tee fittings or complete encirclement types of reinforcement.
- (c) Adequate flexibility shall be provided in a small line that branches from a large run, to accommodate thermal expansion and other movements of the larger line (see para. 319.6).
- (*d*) If ribs, gussets, or clamps are used to stiffen the branch connection, their areas cannot be counted as contributing to the reinforcement area determined in para. 304.3.3(c) or 304.3.4(f). However, ribs or gussets may be used for pressure-strengthening a branch connection in lieu of reinforcement covered in paras. 304.3.3 and 304.3.4 if the design is qualified as required by para. 304.7.2.
- (e) For branch connections that do not meet the requirements of para. 304.3.1(b), integral reinforcement, complete encirclement reinforcement, or other means of reinforcement should be considered.

304.3.6 Branch Connections Under External Pressure. Pressure design for a branch connection subjected to external pressure may be determined in accordance with para. 304.3.1, using the reinforcement area requirement stated in para. 304.3.3(b).

304.4 Closures

304.4.1 General

(*a*) Closures not in accordance with para. 303 or 304.4.1(b) shall be qualified as required by para. 304.7.2.

Table 304.4.1 BPV Code References for Closures

Type of Closure	Concave to Pressure	Convex to Pressure	
Ellipsoidal	UG-32(d)	UG-33(d)	
Torispherical	UG-32(e)	UG-33(e)	
Hemispherical	UG-32(f)	UG-33(c)	
Conical (no transition to knuckle)	UG-32(g)	UG-33(f)	
Toriconical	UG-32(h)	UG-33(f)	
Flat (pressure on either side)	UG-	34	

GENERAL NOTE: Paragraph numbers are from the BPV Code, Section VIII, Division 1.

(*b*) For materials and design conditions covered therein, closures may be designed in accordance with the rules in the BPV Code, Section VIII, Division 1, calculated from eq. (13)

$$t_m = t + c \tag{13}$$

where

c = sum of allowances defined in para. 304.1.1

t = pressure design thickness, calculated for the type of closure and direction of loading, shown in Table 304.4.1, except that the symbols used to determine t shall be as follows:

E = same as defined in para. 304.1.1

P =design gage pressure

S = S times W, with S and W as defined in para, 304.1.1

 t_m = minimum required thickness, including mechanical, corrosion, and erosion allowance

304.4.2 Openings in Closures

(a) The rules in paras. 304.4.2(b) through (g) apply to openings not larger than one-half the inside diameter of the closure as defined in Section VIII, Division 1, UG-36. A closure with a larger opening should be designed as a reducer in accordance with para. 304.6 or, if the closure is flat, as a flange in accordance with para. 304.5.

(b) A closure is weakened by an opening and, unless the thickness of the closure is sufficiently in excess of that required to sustain pressure, it is necessary to provide added reinforcement. The need for and amount of reinforcement required shall be determined in accordance with the subparagraphs below except that it shall be considered that the opening has adequate reinforcement if the outlet connection meets the requirements in para. 304.3.2(b) or (c).

(c) Reinforcement for an opening in a closure shall be so distributed that reinforcement area on each side of an opening (considering any plane through the center of the opening normal to the surface of the closure) will equal at least one-half the required area in that plane.

(*d*) The total cross-sectional area required for reinforcement in any given plane passing through the center of the opening shall not be less than that defined in UG-37(b), UG-38, and UG-39.

(e) The reinforcement area and reinforcement zone shall be calculated in accordance with para. 304.3.3 or 304.3.4, considering the subscript h and other references to the run or header pipe as applying to the closure. Where the closure is curved, the boundaries of the reinforcement zone shall follow the contour of the closure, and dimensions of the reinforcement zone shall be measured parallel to and perpendicular to the closure surface.

(f) If two or more openings are to be located in a closure, the rules in paras. 304.3.3 and 304.3.4 for the reinforcement of multiple openings apply.

(g) The additional design considerations for branch connections discussed in para. 304.3.5 apply equally to openings in closures.

304.5 Pressure Design of Flanges and Blanks

304.5.1 Flanges — General

(*a*) Flanges not in accordance with para. 303, or 304.5.1(b) or (d), shall be qualified as required by para. 304.7.2.

(*b*) A flange may be designed in accordance with the BPV Code, Section VIII, Division 1, Appendix 2, using the allowable stresses and temperature limits of the B31.3 Code. Nomenclature shall be as defined in Appendix 2, except as follows:

P =design gage pressure

 S_a = bolt design stress at atmospheric temperature

 S_b = bolt design stress at design temperature

 S_f = product SEW [of the stress value S, the appropriate quality factor E from Table A-1A or A-1B, and weld joint strength reduction factor in accordance with para. 302.3.5(e)] for flange or pipe material. See para. 302.3.2(e).

(c) The rules in (b) above are not applicable to a flanged joint having a gasket that extends outside the bolts (usually to the outside diameter of the flange).

(d) For flanges that make solid contact outside the bolts, Section VIII, Division 1, Appendix Y should be

(e) See Section VIII, Division 1, Appendix S, for considerations applicable to bolted joint assembly.


304.5.2 Blind Flanges

(a) Blind flanges not in accordance with para. 303 or 304.5.2(b) shall be qualified as required by para. 304.7.2.

(b) A blind flange may be designed in accordance with eq. (14). The minimum thickness, considering the manufacturer's minus tolerance, shall be not less than t_m

$$t_m = t + c \tag{14}$$

Fig. 304.5.3 Blanks



To calculate *t*, the rules of Section VIII, Division 1, UG-34 may be used with the following changes in nomenclature:

c = sum of allowances defined in para. 304.1.1

P = internal or external design gage pressure

 S_f = product *SEW* [of the stress value, *S*, and the appropriate quality factor, *E*, from Table A-1A or A-1B and weld joint strength reduction factor per para. 302.3.5(e)] for flange material. See para. 302.3.2(e).

 t = pressure design thickness, as calculated for the given styles of blind flange, using the appropriate equations for bolted flat cover plates in UG-34

304.5.3 Blanks

(*a*) Blanks not in accordance with para. 303 or 304.5.3(b) shall be qualified as required by para. 304.7.2.

(b) The minimum required thickness of a permanent blank (representative configurations shown in Fig. 304.5.3) shall be calculated in accordance with eq. (15)

$$t_m = d_g \sqrt{\frac{3P}{16SEW}} + c \tag{15}$$

where

c = sum of allowances defined in para. 304.1.1

 d_g = inside diameter of gasket for raised or flat face flanges, or the gasket pitch diameter for ring joint and fully retained gasketed flanges

E = same as defined in para. 304.1.1

P =design gage pressure

S = same as defined in para. 304.1.1

W = same as defined in para. 304.1.1

304.6 Reducers

304.6.1 Concentric Reducers

(a) Concentric reducers not in accordance with para. 303 or 304.6.1(b) shall be qualified as required by para. 304.7.2.

(b) Concentric reducers made in a conical or reversed curve section, or a combination of such sections, may be designed in accordance with the rules for conical and toriconical closures stated in para. 304.4.1.

304.6.2 Eccentric Reducers. Eccentric reducers not in accordance with para. 303 shall be qualified as required by para. 304.7.2.

304.7 Pressure Design of Other Components

304.7.1 Listed Components. Other pressure-containing components manufactured in accordance with standards in Table 326.1 may be utilized in accordance with para. 303.

304.7.2 Unlisted Components. Pressure design of unlisted components to which the rules elsewhere in para. 304 do not apply shall be based on the pressure design criteria of this Code. The designer shall ensure that the pressure design has been substantiated through one or more of the means stated in subparas. (a) through (d) below. Note that designs are also required to be

checked for adequacy of mechanical strength as described in para. 302.5. Documentation showing compliance with this paragraph shall be available for the owner's approval.

- (a) extensive, successful service experience under comparable conditions with similarly proportioned components of the same or like material.
- (*b*) experimental stress analysis, such as described in the BPV Code, Section VIII, Division 2, Annex 5.F.
- (c) proof test in accordance with ASME B16.9, MSS SP-97, or Section VIII, Division 1, UG-101.
- (d) detailed stress analysis (e.g., finite element method) with results evaluated as described in the BPV Code, Section VIII, Division 2, Part 5. The basic allowable stress from Table A-1 or Table A-1M shall be used in place of the allowable stress, S, in Division 2 where applicable. Load design factors used in a Division 2 evaluation shall be consistent with the design bases in para. 302.3.2. At design temperatures in the creep range, additional considerations beyond the scope of Division 2 may be necessary.
- (e) For any of the above, the designer may interpolate between sizes, wall thicknesses, and pressure classes, and may determine analogies among related materials.

304.7.3 Metallic Components With Nonmetallic Pressure Parts. Components not covered by standards listed in Table 326.1, in which both metallic and nonmetallic parts contain the pressure, shall be evaluated by applicable requirements of para. A304.7.2 as well as those of para. 304.7.2.

304.7.4 Expansion Joints

- (a) Metallic Bellows Expansion Joints. The design of bellows type expansion joints shall be in accordance with Appendix X. See also Appendix F, para. F304.7.4 for further design considerations.
 - (b) Slip Type Expansion Joints
- (1) Pressure-containing elements shall be in accordance with para. 318 and other applicable requirements of this Code.
- (2) External piping loads shall not impose excessive bending on the joint.
- (3) The effective pressure thrust area shall be computed using the outside diameter of the pipe.
- (c) Other Types of Expansion Joint. The design of other types of expansion joint shall be qualified as required by para. 304.7.2.

PART 3 FLUID SERVICE REQUIREMENTS FOR PIPING COMPONENTS

305 PIPE

Pipe includes components designated as "tube" or "tubing" in the material specification, when intended for pressure service.

305.1 General

Listed pipe may be used in Normal Fluid Service except as stated in paras. 305.2.1 and 305.2.2. Unlisted pipe may be used only as provided in para. 302.2.3.

305.2 Specific Requirements

305.2.1 Pipe for Category D Fluid Service. The following carbon steel pipe may be used only for Category D Fluid Service:

API 5L continuous welded (furnace butt-welded) ASTM A53, Type F

ASTM A134 made from other than ASTM A285 plate

305.2.2 Pipe Requiring Safeguarding. When used for other than Category D Fluid Service, the following carbon steel pipe shall be safeguarded:

ASTM A134 made from ASTM A285 plate ASTM A139

305.2.3 Pipe for Severe Cyclic Conditions

(16)

- (a) Except as limited in subparas. (b) through (d), only the following pipe may be used under severe cyclic conditions:
 - (1) pipe listed in Table A-1A, where $E_c \ge 0.90^{7}$ or
 - (2) pipe listed in Table A-1B, where $E_i \ge 0.90^7$
- (b) For API 5L pipe, only the following materials may be used:

Grade A or B, seamless

Grade A or B, SAW, str. seam, $E_i \ge 0.95$

Grade X42, seamless

Grade X46, seamless

Grade X52, seamless

Grade X56, seamless

Grade X60, seamless

- (c) For copper pipe, only ASTM B42 may be used.
- (d) For copper alloy pipe, only ASTM B466 may be used.
- (e) For aluminum alloy pipe, only ASTM B210 and B241, both in tempers O and H112, may be used.

305.2.4 Elevated Temperature Fluid Service. In Elevated Temperature Fluid Service, all longitudinal or spiral (helical seam) welds in P-No. 4 or P-No. 5 materials shall be examined by 100% radiography or 100% ultrasonic examination. Acceptance criteria are as stated in para. 341.3.2 and in Table 341.3.2, for Normal Fluid Service, unless otherwise specified.

306 FITTINGS, BENDS, MITERS, LAPS, AND BRANCH CONNECTIONS

Fittings, bends, miters, laps, and branch connections may be used in accordance with paras. 306.1 through 306.5. Pipe and other materials used in such components

⁷ See para. 302.3.3.

shall be suitable for the manufacturing or fabrication process and the fluid service.

306.1 Pipe Fittings

- **306.1.1 Listed Fittings.** Listed fittings may be used in Normal Fluid Service in accordance with para. 303.
- **306.1.2 Unlisted Fittings.** Unlisted fittings may be used only in accordance with para. 302.2.3.

306.1.3 Specific Fittings

- (a) Proprietary welding branch outlet fittings that have been design proof tested successfully as prescribed in ASME B16.9, MSS SP-97, or the BPV Code, Section VIII, Division 1, UG-101 may be used within their established ratings.
- (b) The lap thickness of a proprietary "Type C" lapjoint stub-end buttwelding fitting shall conform to the requirements of para. 306.4.2 for flared laps.

(16) 306.1.4 Fittings for Severe Cyclic Conditions

- (a) Only the following fittings may be used under severe cyclic conditions:
 - (1) forged.
- (2) wrought, seamless or welded. If welded, requires 100% radiograph of welds in accordance with para. 344.5.1 and Table 341.3.2.
 - (3) cast, with factor $E_c \ge 0.90.7$
- (b) Fittings conforming to MSS SP-43, MSS SP-119, and proprietary "Type C" lap-joint stub-end welding fittings shall not be used under severe cyclic conditions.

306.2 Pipe Bends

306.2.1 General

- (a) A pipe bend made in accordance with paras. 332.2.1 and 332.2.2, and verified for pressure design in accordance with para. 304.2.1, is suitable for the same service as the pipe from which it is made.
- (b) A pipe bend made in accordance with para. 332.2.2, but not meeting the flattening limits of para. 332.2.1, may be qualified for pressure design by para. 304.7.2 and shall not exceed the rating of the straight pipe from which it is made.
- **306.2.2 Corrugated and Other Bends.** Bends of other designs (such as creased or corrugated) shall be qualified for pressure design as required by para. 304.7.2.
- **306.2.3 Bends for Severe Cyclic Conditions.** A pipe bend designed as creased or corrugated shall not be used under severe cyclic conditions.

306.3 Miter Bends

306.3.1 General. Except as stated in para. 306.3.2, a miter bend made in accordance with para. 304.2.3 and welded in accordance with para. 311.1 is suitable for use in Normal Fluid Service.

306.3.2 Miter Bends for Category D Fluid Service.

A miter bend that makes a change in direction at a single joint (angle α in Fig. 304.2.3) greater than 45 deg, or is welded in accordance with para. 311.2.1, may be used only for Category D Fluid Service.

306.3.3 Miter Bends for Severe Cyclic Conditions.

A miter bend to be used under severe cyclic conditions shall be made in accordance with para. 304.2.3 and welded in accordance with para. 311.2.2, and shall have an angle α (see Fig. 304.2.3) \leq 22.5 deg.

306.4 Laps

The following requirements do not apply to fittings conforming to para. 306.1, specifically lap-joint stub ends conforming to ASME B16.9, nor to laps integrally hotforged on pipe ends, except as noted in paras. 306.4.3 and 306.4.4(a).

- **306.4.1 Fabricated Laps.** A fabricated lap is suitable for use in Normal Fluid Service, provided that all of the following requirements are met.
- (a) The outside diameter of the lap shall be within the dimensional tolerances of the corresponding ASME B16.9 lap-joint stub end.
- (*b*) The lap thickness shall be at least equal to the nominal wall thickness of the pipe to which it is attached.
- (c) The lap material shall have an allowable stress at least as great as that of the pipe.
- (*d*) Welding shall be in accordance with para. 311.1 and fabrication shall be in accordance with para. 328.5.5.
- **306.4.2 Flared Laps.** See para. 308.2.5 for requirements of lapped flanges for use with flared laps. A flared lap is suitable for use in Normal Fluid Service, provided that all of the following requirements are met.
- (a) The pipe used shall be of a specification and grade suitable for forming without cracks, surface buckling, or other defects.
- (*b*) The outside diameter of the lap shall be within the dimensional tolerances of the corresponding ASME B16.9 lap-joint stub end.
 - (c) The radius of fillet shall not exceed 3 mm ($\frac{1}{8}$ in.).
- (*d*) The lap thickness at any point shall be at least 95% of the minimum pipe wall thickness, *T*, multiplied by the ratio of the pipe outside diameter to the diameter at which the lap thickness is measured.
- (e) Pressure design shall be qualified as required by para. 304.7.2.
- **306.4.3 Forged Laps.** A lap integrally hot-forged on a pipe end is suitable for Normal Fluid Service only when the requirements of para. 332 are met. Its dimensions shall conform to those for lap-joint stub ends given in ASME B16.9.

306.4.4 Laps for Severe Cyclic Conditions

(a) A forged lap-joint stub end in accordance with para. 306.1 or a lap integrally hot-forged on a pipe end

in accordance with para. 306.4.3 may be used under severe cyclic conditions.

- (b) A fabricated lap to be used under severe cyclic conditions shall conform to the requirements of para. 306.4.1, except that welding shall be in accordance with para. 311.2.2. A fabricated lap shall conform to a detail shown in Fig. 328.5.5, sketch (d) or (e).
- (c) A flared lap is not permitted under severe cyclic conditions.

306.5 Fabricated Branch Connections

The following requirements do not apply to fittings conforming to para. 306.1.

306.5.1 General. A fabricated branch connection made and verified for pressure design in accordance with para. 304.3, and welded in accordance with para. 311.1, is suitable for use in Normal Fluid Service.

306.5.2 Fabricated Branch Connections for Severe Cyclic Conditions. A fabricated branch connection to be used under severe cyclic conditions shall conform to the requirements of para. 306.5.1, except that welding shall be in accordance with para. 311.2.2, with fabrication limited to a detail equivalent to Fig. 328.5.4D sketch (2) or (4), or to Fig. 328.5.4E.

306.6 Thermowells

Thermowells shall comply with ASME PTC 19.3 TW where applicable.

307 VALVES AND SPECIALTY COMPONENTS

The following requirements for valves shall also be met as applicable by other pressure-containing piping components, such as traps, strainers, and separators. See also Appendix F, paras. F301.4 and F307.

307.1 General

- **307.1.1 Listed Valves.** A listed valve is suitable for use in Normal Fluid Service, except as stated in para. 307.2.
- **307.1.2 Unlisted Valves.** Unlisted valves may be used only in accordance with para. 302.2.3. Unless pressure–temperature ratings are established by the method set forth in ASME B16.34, pressure design shall be qualified as required by para. 304.7.2.

307.2 Specific Requirements

- **307.2.1 Bonnet Bolting.** A bolted bonnet valve whose bonnet is secured to the body by less than four bolts, or by a U-bolt, may be used only for Category D Fluid Service.
- **307.2.2 Stem Retention.** Valves shall be designed so that the stem seal retaining fasteners (e.g., packing, gland fasteners) alone do not retain the stem. Specifically, the design shall be such that the stem shall not be

Table 308.2.1 Permissible Sizes/Rating Classes for Slip-On Flanges Used as Lapped Flanges

	Maximum F	Maximum Flange Size		
Rating Class	DN	NPS		
150	300	12		
300	200	8		

GENERAL NOTE: Actual thickness of flange at bolt circle shall at least equal minimum required flange thickness in ASME B16.5.

capable of removal from the valve, while the valve is under pressure, by the removal of the stem seal retainer (e.g., gland) alone.

308 FLANGES, BLANKS, FLANGE FACINGS, AND GASKETS

308.1 General

- **308.1.1 Listed Components.** A listed flange, blank, or gasket is suitable for use in Normal Fluid Service, except as stated elsewhere in para. 308.
- **308.1.2 Unlisted Components.** Unlisted flanges, blanks, and gaskets may be used only in accordance with para. 302.2.3.

308.2 Specific Requirements for Flanges

See Appendix F, paras. F308.2 and F312.

308.2.1 Slip-On Flanges

- (a) A slip-on flange shall be double-welded as shown in Fig. 328.5.2B when the service is
- (1) subject to severe erosion, crevice corrosion, or cyclic loading
 - (2) flammable, toxic, or damaging to human tissue
 - (3) under severe cyclic conditions
 - (4) at temperatures below -101°C (-150°F)
- (b) The use of slip-on flanges should be avoided where many large temperature cycles are expected, particularly if the flanges are not insulated.
- (c) Slip-on Flanges as Lapped Flanges. A slip-on flange may be used as a lapped flange only as shown in Table 308.2.1 unless pressure design is qualified in accordance with para. 304.5.1. A corner radius or bevel shall conform to one of the following as applicable:
- (1) For an ASME B16.9 lap joint stub end or a forged lap (see para. 306.4.3) the corner radius shall be as specified in ASME B16.5, Tables 9 and 12, dimension *r*.
- (2) For a fabricated lap, the corner bevel shall be at least half the nominal thickness of the pipe to which the lap is attached (see Fig. 328.5.5).
 - (3) For a flared lap see para. 308.2.5.
- **308.2.2 Expanded-Joint Flanges.** A flange having an expanded-joint insert is subject to the requirements for expanded joints in para. 313.

- **308.2.3 Socket Welding and Threaded Flanges.** A socket welding flange is subject to the requirements for socket welds in para. 311.2.5. A threaded flange is subject to the requirements for threaded joints in para. 314.
- **308.2.4 Flanges for Severe Cyclic Conditions.** Unless it is safeguarded, a flange to be used under severe cyclic conditions shall be welding neck conforming to ASME B16.5 or ASME B16.47, or a similarly proportioned flange designed in accordance with para. 304.5.1.
- **308.2.5 Flanges for Flared Metallic Laps.** For a flange used with a flared metallic lap (para. 306.4.2), the intersection of face and bore shall be beveled or rounded approximately 3 mm ($\frac{1}{8}$ in.). See also para. 308.2.1(c).

308.3 Flange Facings

The flange facing shall be suitable for the intended service and for the gasket and bolting employed.

308.4 Gaskets

Gaskets shall be selected so that the required seating load is compatible with the flange rating and facing, the strength of the flange, and its bolting. Materials shall be suitable for the service conditions. See also Appendix F, para. F308.4.

309 BOLTING

Bolting includes bolts, bolt studs, studs, cap screws, nuts, and washers. See also Appendix F, para. F309.

309.1 General

- **309.1.1 Listed Bolting.** Listed bolting is suitable for use in Normal Fluid Service, except as stated elsewhere in para. 309.
- **309.1.2 Unlisted Bolting.** Unlisted bolting may be used only in accordance with para. 302.2.3.
- **309.1.3 Bolting for Components.** Bolting for components conforming to a listed standard shall be in accordance with that standard if specified therein.
- **309.1.4 Selection Criteria.** Bolting selected shall be adequate to seat the gasket and maintain joint tightness under all design conditions.

309.2 Specific Bolting

- **309.2.1 Low Yield Strength Bolting.** Bolting having not more than 207 MPa (30 ksi) specified minimum yield strength shall not be used for flanged joints rated ASME B16.5 Class 400 and higher, nor for flanged joints using metallic gaskets, unless calculations have been made showing adequate strength to maintain joint tightness.
- **309.2.2 Carbon Steel Bolting.** Except where limited by other provisions of this Code, carbon steel bolting

may be used with nonmetallic gaskets in flanged joints rated ASME B16.5 Class 300 and lower for bolt metal temperatures at -29°C to 204°C (-20°F to 400°F), inclusive. If these bolts are galvanized, heavy hexagon nuts, threaded to suit, shall be used.

309.2.3 Bolting for Metallic Flange Combinations.

Any bolting that meets the requirements of para. 309 may be used with any combination of flange material and facing. If either flange is to the ASME B16.1, ASME B16.24, MSS SP-42, or MSS SP-51 specification, the bolting material shall be no stronger than low yield strength bolting unless

- (a) both flanges have flat faces and a full face gasket is used, or
- (b) sequence and torque limits for bolt-up are specified, with consideration of sustained loads, displacement strains, occasional loads (see paras. 302.3.5 and 302.3.6), and strength of the flanges
- **309.2.4 Bolting for Severe Cyclic Conditions.** Low yield strength bolting (see para. 309.2.1) shall not be used for flanged joints under severe cyclic conditions.

309.3 Tapped Holes

Tapped holes for pressure-retaining bolting in metallic piping components shall be of sufficient depth that the thread engagement will be at least seven-eighths times the nominal thread diameter.

PART 4 FLUID SERVICE REQUIREMENTS FOR PIPING JOINTS 310 GENERAL

Piping joints shall be selected to suit the piping material and the fluid service, with consideration of joint tightness and mechanical strength under expected service and test conditions of pressure, temperature, and external loading.

311 WELDED JOINTS

Joints may be made by welding in any material for which it is possible to qualify welding procedures, welders, and welding operators in conformance with the rules in Chapter V.

311.1 General

Except as provided in paras. 311.2.1 and 311.2.2, welds shall conform to the following:

- (a) Welding shall be in accordance with para. 328.
- (b) Preheating and heat treatment shall be in accordance with paras. 330 and 331, respectively.
- (c) Examination shall be in accordance with para. 341.4.1.
- (*d*) Acceptance criteria shall be those in Table 341.3.2 for Normal Fluid Service.

311.2 Specific Requirements

311.2.1 Welds for Category D Fluid Service. Welds that meet the requirements of para. 311.1, but for which examination is in accordance with para. 341.4.2, and acceptance criteria are those in Table 341.3.2 for Category D Fluid Service, may be used only in that service.

311.2.2 Welds for Severe Cyclic Conditions. Welds for use under severe cyclic conditions shall meet the requirements of para. 311.1 with the exceptions that examination shall be in accordance with para. 341.4.3, and acceptance criteria shall be those in Table 341.3.2 for severe cyclic conditions.

311.2.3 Welds for Elevated Temperature Fluid Service. Weld joints for Elevated Temperature Fluid Service shall meet the requirements for Normal Fluid Service, unless otherwise specified.

311.2.4 Backing Rings and Consumable Inserts

(a) If a backing ring is used where the resulting crevice is detrimental (e.g., subject to corrosion, vibration, or severe cyclic conditions), it should be removed and the internal joint face ground smooth. When it is impractical to remove the backing ring in such a case, consideration shall be given to welding without backing rings or to the use of consumable inserts or removable nonmetallic backing rings.

(b) Split backing rings shall not be used under severe cyclic conditions.

311.2.5 Socket Welds

- (a) Socket welded joints (para. 328.5.2) should be avoided in any service where crevice corrosion or severe erosion may occur.
- (b) Socket welded joints shall conform to the
- (1) Socket dimensions shall conform to ASME B16.5 for flanges and ASME B16.11 or MSS SP-119 for other socket-welding components.
- (2) Weld dimensions shall not be less than those shown in Figs. 328.5.2B and 328.5.2C.
- (c) Socket welds larger than DN 50 (NPS 2) shall not be used under severe cyclic conditions.
- (d) A drain or bypass in a component may be attached by socket welding, provided the socket dimensions conform to Fig. 4 in ASME B16.5.

311.2.6 Fillet Welds

- (a) Fillet welds in accordance with para. 328.5.2 may be used as primary welds to attach socket welding components and slip-on flanges.
- (b) Fillet welds may also be used to attach reinforcement and structural attachments, to supplement the strength or reduce stress concentration of primary welds, and to prevent disassembly of joints.
- **311.2.7 Seal Welds.** Seal welds (para. 328.5.3) may be used only to prevent leakage of threaded joints and

shall not be considered as contributing any strength to the joints.

312 FLANGED JOINTS

312.1 Joints Using Flanges of Different Ratings

Where flanges of different ratings are bolted together, the rating of the joint shall not exceed that of the lower rated flange. Bolting torque shall be limited so that excessive loads will not be imposed on the lower rated flange in obtaining a tight joint.

312.2 Metal to Nonmetal Flanged Joints

Where a metallic flange is bolted to a nonmetallic flange, both should be flat-faced. A full-faced gasket is preferred. If a gasket extending only to the inner edge of the bolts is used, bolting torque shall be limited so that the nonmetallic flange is not overloaded.

312.3 Flanged Joint Assembly

See para. 335.2.5.

313 EXPANDED JOINTS

- (a) Expanded joints shall not be used under severe cyclic conditions. For other services, adequate means shall be provided to prevent separation of the joint. If the fluid is toxic or damaging to human tissue, safeguarding is required.
- (b) Consideration shall be given to the tightness of expanded joints when subjected to vibration, differential expansion or contraction due to temperature cycling, or external mechanical loads.

314 THREADED JOINTS

314.1 General

Threaded joints are suitable for Normal Fluid Service except as stated elsewhere in para. 314. They may be used under severe cyclic conditions only as provided in paras. 314.2.1(c) and 314.2.2.

- (a) Threaded joints should be avoided in any service where crevice corrosion, severe erosion, or cyclic loading
- (b) When threaded joints are intended to be seal welded, thread sealing compound shall not be used.
- (c) Layout of piping employing threaded joints should, insofar as possible, minimize stress on joints, giving special consideration to stresses due to thermal expansion and operation of valves (particularly a valve at a free end). Provision should be made to counteract forces that would tend to unscrew the joints.
- (d) Except for specially designed joints employing lens rings or similar gaskets, threaded flanges in which the pipe ends project through to serve as the gasket surface may be used only for Category D Fluid Service.

(16)

Table 314.2.1 Minimum Thickness of External Threaded Components

Fluid	Notch- Sensitive	Size F [Note	Min. Wall Thickness	
Service	Material	DN	NPS	[Note (2)]
Normal	Yes [Note (3)]	≤40 50 65–150		Sch. 80 Sch. 40 Sch. 40
Normal	No [Note (4)]	≤50 65–150	≤ 2 $2^{1}/_{2}-6$	Sch. 40S Sch. 40S
Category D	Either	≤300	≤12	In accordance with para. 304.1.1

GENERAL NOTE: Use the greater of para. 304.1.1 or thickness shown in this Table.

NOTES:

- For sizes >DN 50 (NPS 2), the joint shall be safeguarded (see Appendix G) for a fluid service that is flammable, toxic, or damaging to human tissue.
- (2) Nominal wall thicknesses is listed for Sch. 40 and 80 in ASME B36.10M and for Sch. 40S in ASME B36.19M.
- (3) For example, carbon steel.
- (4) For example, austenitic stainless steel.

314.2 Specific Requirements

- **314.2.1 Taper-Threaded Joints.** Requirements in (a) through (c) below apply to joints in which the threads of both mating components conform to ASME B1.20.1.
- (a) External threaded components may be used in accordance with Table 314.2.1 and its Notes.
- (b) Internal threaded components shall be at least equivalent in strength and toughness to threaded components listed in Table 326.1 and otherwise suitable for the service.
- (c) Threaded components of a specialty nature that are not subject to external moment loading, such as thermometer wells, may be used under severe cyclic conditions.
- (*d*) A coupling having straight threads may be used only for Category D Fluid Service, and only with taper-threaded mating components.
- **314.2.2 Straight-Threaded Joints.** Threaded joints in which the tightness of the joint is provided by a seating surface other than the threads (e.g., a union comprising male and female ends joined with a threaded union nut, or other constructions shown typically in Fig. 335.3.3) may be used. If such joints are used under severe cyclic conditions and are subject to external moment loadings, safeguarding is required.

315 TUBING JOINTS

315.1 General

In selecting and applying flared, flareless, and compression type tubing fittings, the designer shall consider the possible adverse effects on the joints of such factors as assembly and disassembly, cyclic loading, vibration, shock, and thermal expansion and contraction.

315.2 Joints Conforming to Listed Standards

Joints using flared, flareless, or compression type tubing fittings covered by listed standards may be used in Normal Fluid Service provided that

- (a) the fittings and joints are suitable for the tubing with which they are to be used (considering maximum and minimum wall thickness) and are used within the pressure–temperature limitations of the fitting and the joint
- (b) the joints are safeguarded when used under severe cyclic conditions

315.3 Joints Not Conforming to Listed Standards

Joints using flared, flareless, or compression type tubing fittings not listed in Table 326.1 may be used in accordance with para. 315.2 provided that the type of fitting selected is also adequate for pressure and other loadings. The design shall be qualified as required by para. 304.7.2.

316 CAULKED JOINTS

Caulked joints such as bell type joints shall be limited to Category D Fluid Service and to a temperature not over 93°C (200°F). They shall be used within the pressure–temperature limitations of the joint and pipe. Provisions shall be made to prevent disengagement of joints, to prevent buckling of the piping, and to sustain lateral reactions produced by branch connections or other causes.

317 SOLDERED AND BRAZED JOINTS

317.1 Soldered Joints

Soldered joints shall be made in accordance with the provisions of para. 333 and may be used only in Category D fluid service. Fillet joints made with solder metal are not permitted. The low melting point of solder shall be considered where possible exposure to fire or elevated temperature is involved.

317.2 Brazed and Braze Welded Joints

(a) Brazed and braze welded joints made in accordance with the provisions in para. 333 are suitable for Normal Fluid Service. They shall be safeguarded in fluid services that are flammable, toxic, or damaging to human tissue. They shall not be used under severe cyclic

conditions. The melting point of brazing alloys shall be considered where possible exposure to fire is involved.

(b) Fillet joints made with brazing filler metal are not permitted.

318 SPECIAL JOINTS

Special joints are those not covered elsewhere in Chapter II, Part 4, such as bell type and packed gland type joints.

318.1 General

- **318.1.1 Listed Joints.** Joints using listed components are suitable for Normal Fluid Service.
- **318.1.2 Unlisted Joints.** For joints that utilize unlisted components, pressure design shall be qualified as required by para. 304.7.2.

318.2 Specific Requirements

- **318.2.1 Joint Integrity.** Separation of the joint shall be prevented by a means that has sufficient strength to withstand anticipated conditions of service.
- **318.2.2 Joint Interlocks.** Either mechanical or welded interlocks shall be provided to prevent separation of any joint used for a fluid service that is flammable, toxic, or damaging to human tissues, of any joint to be used under severe cyclic conditions, and of any joint exposed to temperatures in the creep range.
- **318.2.3 Bell and Gland Type Joints.** If not covered in para. 316, bell type and gland type joints used under severe cyclic conditions require safeguarding.

PART 5 FLEXIBILITY AND SUPPORT

319 PIPING FLEXIBILITY

319.1 Requirements

- **319.1.1 Basic Requirements.** Piping systems shall have sufficient flexibility to prevent thermal expansion or contraction or movements of piping supports and terminals from causing
- (a) failure of piping or supports from overstress or fatigue
 - (b) leakage at joints
- (c) detrimental stresses or distortion in piping and valves or in connected equipment (pumps and turbines, for example), resulting from excessive thrusts and moments in the piping
- **319.1.2 Specific Requirements.** In para. 319, concepts, data, and methods are given for determining the requirements for flexibility in a piping system and for assuring that the system meets all of these requirements. In brief, these requirements are that
- (a) the computed stress range at any point due to displacements in the system shall not exceed the allowable stress range established in para. 302.3.5

- (b) reaction forces computed in para. 319.5 shall not be detrimental to supports or connected equipment
- (c) computed movement of the piping shall be within any prescribed limits, and properly accounted for in the flexibility calculations

If it is determined that a piping system does not have adequate inherent flexibility, means for increasing flexibility shall be provided in accordance with para. 319.7.

319.2 Concepts

Concepts characteristic of piping flexibility analysis are covered in the following paragraphs. Special consideration is given to displacements (strains) in the piping system, and to resultant axial, bending, and torsional displacement stress ranges.

319.2.1 Displacement Strains

- (a) Thermal Displacements. A piping system will undergo dimensional changes with any change in temperature. If it is constrained from free expansion or contraction by connected equipment and restraints such as guides and anchors, it will be displaced from its unrestrained position.
- (b) Restraint Flexibility. If restraints are not considered rigid, their flexibility may be considered in determining displacement stress range and reactions.
- (c) Externally Imposed Displacements. Externally caused movement of restraints will impose displacements on the piping in addition to those related to thermal effects. Movements may result from tidal changes (dock piping), wind sway (e.g., piping supported from a tall slender tower), or temperature changes in connected equipment.

Movement due to earth settlement, since it is a single cycle effect, will not significantly influence fatigue life. A displacement stress range greater than that permitted by para. 302.3.5(d) may be allowable if due consideration is given to avoidance of excessive localized strain and end reactions.

(d) Total Displacement Strains. Thermal displacements, reaction displacements, and externally imposed displacements all have equivalent effects on the piping system, and shall be considered together in determining the total displacement strains (proportional deformation) in various parts of the piping system.

319.2.2 Displacement Stresses

- (a) Elastic Behavior. Stresses may be considered proportional to the total displacement strains in a piping system in which the strains are well-distributed and not excessive at any point (a balanced system). Layout of systems should aim for such a condition, which is assumed in flexibility analysis methods provided in this Code
- (b) Overstrained Behavior. Stresses cannot be considered proportional to displacement strains throughout a piping system in which an excessive amount of strain

may occur in localized portions of the system (an unbalanced system). Operation of an unbalanced system in the creep range may aggravate the deleterious effects due to creep strain accumulation in the most susceptible regions of the system. Unbalance may result from one or more of the following:

- (1) highly stressed small size pipe runs in series with large or relatively stiff pipe runs.
- (2) a local reduction in size or wall thickness, or local use of material having reduced yield strength (for example, girth welds of substantially lower strength than the base metal).
- (3) a line configuration in a system of uniform size in which the expansion or contraction must be absorbed largely in a short offset from the major portion of the run.
- (4) variation of piping material or temperature in a line. When differences in the elastic modulus within a piping system will significantly affect the stress distribution, the resulting displacement stresses shall be computed based on the actual elastic moduli at the respective operating temperatures for each segment in the system and then multiplied by the ratio of the elastic modulus at ambient temperature to the modulus used in the analysis for each segment.

Unbalance should be avoided or minimized by design and layout of piping systems, particularly those using materials of low ductility. Many of the effects of unbalance can be mitigated by selective use of cold spring. If unbalance cannot be avoided, the designer shall use appropriate analytical methods in accordance with para. 319.4 to assure adequate flexibility as defined in para. 319.1.

319.2.3 Displacement Stress Range

- (a) In contrast with stresses from sustained loads, such as internal pressure or weight, displacement stresses may be permitted to attain sufficient magnitude to cause local yielding in various portions of a piping system. When the system is initially operated at the condition of greatest displacement (highest or lowest temperature, or greatest imposed movement) from its installed condition, any yielding or creep brings about a reduction or relaxation of stress. When the system is later returned to its original condition (or a condition of opposite displacement), a reversal and redistribution of stresses occurs that is referred to as self-springing. It is similar to cold springing in its effects.
- (b) While stresses resulting from displacement strains diminish with time due to yielding or creep, the algebraic difference between strains in the extreme displacement condition and the original (as-installed) condition (or any anticipated condition with a greater differential effect) remains substantially constant during any one cycle of operation. This difference in strains produces a corresponding stress differential, the displacement stress range, that is used as the criterion in the design of piping for flexibility. In evaluating systems where supports may

be active in some conditions and not others (e.g., pipes lifting off supports), this difference in strains may be influenced by the changing distribution of sustained load. In such cases, the displacement strain range is based on the algebraic difference between the calculated positions of the pipe that define the range. In addition to the displacement strain, each calculated position shall include the sustained loads present in the condition under evaluation. See para. 302.3.5(d) for the allowable stress range, S_A , and para. 319.4.4(a) for the computed displacement stress range, S_E .

319.2.4 Cold Spring. Cold spring is the intentional deformation of piping during assembly to produce a desired initial displacement and reaction. Cold spring is beneficial in that it serves to balance the magnitude of the reaction under initial and extreme displacement conditions. When cold spring is properly applied there is less likelihood of overstrain during initial operation; hence, it is recommended especially for piping materials of limited ductility. There is also less deviation from asinstalled dimensions during initial operation, so that hangers will not be displaced as far from their original settings.

Inasmuch as the service life of a piping system is affected more by the range of stress variation than by the magnitude of stress at a given time, no credit for cold spring is permitted in stress range calculations. However, in calculating the thrusts and moments where actual reactions as well as their range of variations are significant, credit is given for cold spring.

319.3 Properties for Flexibility Analysis

The following paragraphs deal with properties of piping materials and their application in piping flexibility stress analysis.

319.3.1 Thermal Expansion Data

- (a) Values for Stress Range. Values of thermal displacements to be used in determining total displacement strains for computing the stress range shall be determined from Appendix C as the algebraic difference between the value at maximum metal temperature and that at the minimum metal temperature for the thermal cycle under analysis.
- (b) Values for Reactions. Values of thermal displacements to be used in determining total displacement strains for computation of reactions on supports and connected equipment shall be determined as the algebraic difference between the value at maximum (or minimum) temperature for the thermal cycle under analysis and the value at the temperature expected during installation.
- **319.3.2 Modulus of Elasticity.** The reference modulus of elasticity at 21°C (70°F), E_a , and the modulus of elasticity at maximum or minimum temperature, E_m , shall be taken as the values shown in Appendix C for

the temperatures determined in para. 319.3.1(a) or (b). For materials not included in Appendix C, reference shall be made to authoritative source data, such as publications of the National Institute of Standards and Technology.

319.3.3 Poisson's Ratio. Poisson's ratio may be taken as 0.3 at all temperatures for all metals. More accurate and authoritative data may be used if available.

319.3.4 Allowable Stresses

(a) The allowable displacement stress range, S_A , and permissible additive stresses shall be as specified in para. 302.3.5(d) for systems primarily stressed in bending and/or torsion.

(b) The stress intensification factors in Appendix D have been developed from fatigue tests of representative piping components and assemblies manufactured from ductile ferrous materials. The allowable displacement stress range is based on tests of carbon and austenitic stainless steels. Caution should be exercised when using eqs. (1a) and (1b) (para. 302.3.5) for allowable displacement stress range for some nonferrous materials (e.g., certain copper and aluminum alloys) for other than low cycle applications.

319.3.5 Dimensions. Nominal thicknesses and outside diameters of pipe and fittings shall be used in flexibility calculations.

319.3.6 Flexibility and Stress Intensification

Factors. The flexibility factors, k, and stress intensification factors, i, shall not be less than unity. In the absence of more directly applicable data, the flexibility factor, k, and stress intensification factor, i, shown in Appendix D shall be used for flexibility calculations described in para. 319.4.

Stress intensification factors may be developed in accordance with ASME B31J.

For piping components or attachments (such as valves, strainers, anchor rings, or bands) not covered in Table D300, suitable stress intensification factors may be assumed by comparison of their significant geometry with that of the components shown. The validity of any assumptions is the responsibility of the designer. If two or more of the geometries shown in Appendix D are combined, their combined k and i might be significantly different from the values shown. Examples include trunnions on elbows and branch connection fittings welded to anything other than straight pipe.

(16) 319.4 Flexibility Analysis

319.4.1 Formal Analysis Not Required. No formal analysis of adequate flexibility is required for a piping system that

(a) duplicates, or replaces without significant change, a system operating with a successful service record

(b) can readily be judged adequate by comparison with previously analyzed systems

(c) is of uniform size, has no more than two points of fixation, no intermediate restraints, and falls within the limitations of empirical eq. $(16)^8$

$$\frac{Dy}{(L-U)^2} \le K_1 \tag{16}$$

where

D = outside diameter of pipe, mm (in.)

 E_a = reference modulus of elasticity at 21°C (70°F), MPa (ksi)

 $K_1 = 208\,000\,S_A/E_{ar}\,(\text{mm/m})^2$

 $= 30 S_A/E_{ar} (in./ft)^2$

L = developed length of piping between anchors, m (ft)

 S_A = allowable displacement stress range in accordance with eq. (1a), MPa (ksi)

U = anchor distance, straight line between anchors, m (ft)

y = resultant of total displacement strains, mm (in.), to be absorbed by the piping system

319.4.2 Formal Analysis Requirements

(a) Any piping system that does not meet the criteria in para. 319.4.1 shall be analyzed by a simplified, approximate, or comprehensive method of analysis, as appropriate.

(b) A simplified or approximate method may be applied only if used within the range of configurations for which its adequacy has been demonstrated.

(c) Acceptable comprehensive methods of analysis include analytical and chart methods that provide an evaluation of the forces, moments, and stresses caused by displacement strains (see para. 319.2.1).

(d) Comprehensive analysis shall take into account stress intensification factors for any component other than straight pipe. Credit may be taken for the extra flexibility of such a component.

319.4.3 Basic Assumptions and Requirements.

Standard assumptions specified in para. 319.3 shall be followed in all cases. In calculating the flexibility of a piping system between anchor points, the system shall be treated as a whole. The significance of all parts of the line and of all restraints introduced for the purpose of reducing moments and forces on equipment or small branch lines, and also the restraint introduced by support friction, shall be recognized. Consider all displacements, as outlined in para. 319.2.1, over the temperature range defined by para. 319.3.1.

⁸ WARNING: No general proof can be offered that this equation will yield accurate or consistently conservative results. It is not applicable to systems used under severe cyclic conditions. It should be used with caution in configurations such as unequal leg U-bends or near-straight "sawtooth" runs, or for large thin-wall pipe ($i \ge 5$), or where extraneous displacements (not in the direction connecting anchor points) constitute a large part of the total displacement. There is no assurance that terminal reactions will be acceptably low, even if a piping system falls within the limitations of eq. (16).

319.4.4 Flexibility Stresses

(a) The axial, bending, and torsional displacement stress ranges shall be computed using the reference modulus of elasticity at 21°C (70°F), E_a , except as provided in para. 319.2.2(b)(4), and then combined in accordance with eq. (17) to determine the computed displacement stress range, S_E , which shall not exceed the allowable displacement stress range, S_A , in para. 302.3.5(d). See also eq. (1d) and Appendix S, Example 3 for the greatest computed displacement stress range.

$$S_E = \sqrt{(|S_a| + S_b)^2 + (2S_t)^2}$$
 (17)

where

 A_p = cross-sectional area of pipe; see para. 319.3.5

 F_a = axial force range between any two conditions being evaluated

 i_a = axial stress intensification factor. In the absence of more applicable data, i_a = 1.0 for elbows, pipe bends, and miter bends (single, closely spaced, and widely spaced), and i_a = i_o (or i when listed) in Appendix D for other components; see also para. 319.3.6.

 i_t = torsional stress intensification factor. In the absence of more applicable data, i_t = 1.0; also see para. 319.3.6.

 M_t = torsional moment range between any two conditions being evaluated

 S_a = axial stress range due to displacement strains = $i_a F_a / A_p$

 S_b = bending stress range due to displacement strains

 S_t = torsional stress range due to displacement strains

 $= i_t M_t / 2Z$

Z = section modulus of pipe; see para. 319.3.5

(*b*) The bending stress range, S_b , to be used in eq. (17) for elbows, miter bends, and full size outlet branch connections (Legs 1, 2, and 3) shall be calculated in accordance with eq. (18), with moments as shown in Figs. 319.4.4A and 319.4.4B.

$$S_b = \frac{\sqrt{(i_i M_i)^2 + (i_o M_o)^2}}{Z}$$
 (18)

where

 i_i = in-plane stress intensification factor; see para. 319.3.6

 i_o = out-plane stress intensification factor; see para. 319.3.6

 M_i = in-plane bending moment range between any two conditions being evaluated

 M_o = out-plane bending moment range between any two conditions being evaluated

(c) The bending stress range, S_b , to be used in eq. (17) for reducing outlet branch connections shall be calculated in accordance with eqs. (19) and (20), with moments as shown in Fig. 319.4.4B.

For header (Legs 1 and 2)

$$S_b = \frac{\sqrt{(i_i M_i)^2 + (i_o M_o)^2}}{Z}$$
 (19)

For branch (Leg 3), use eq. (20) when i_i or i_o is taken from Appendix D; when both i_i and i_o are determined by experimental or analytical means, e.g., ASME B31J, use eq. (19).

$$S_b = \frac{\sqrt{(i_i M_i)^2 + (i_o M_o)^2}}{Z_e}$$
 (20)

where

 r_2 = mean branch cross-sectional radius

 \overline{T}_b = thickness of pipe matching branch

 \overline{T}_h = thickness of pipe matching run of tee or header exclusive of reinforcing elements

 T_S = effective branch wall thickness, lesser of \overline{T}_h and $(i_t)(\overline{T}_h)$

 Z_e = effective section modulus of branch = $\pi r_2^2 T_S$; see para. 319.3.5

319.5 Reactions

Reaction forces and moments used to design restraints and supports for a piping system, and to evaluate the effects of piping displacement on connected equipment, shall be based on the maximum load from operating conditions, including weight, pressure, and other sustained loads; thermal displacement; and, where applicable, occasional loads. The reactions shall be calculated using the modulus of elasticity at the temperature of the condition, E_m (E_a may be used instead of E_m when it provides a more conservative result). The temperature of the condition may differ in different locations within the piping system.

Where cold spring is used in the piping system, experience has shown that it cannot be fully assured. Therefore, the reactions shall be computed both with the assumption that only two-thirds of the design cold spring is present, and with four-thirds of the design cold spring present.

If it is necessary to determine the reactions at ambient temperature, the designer shall consider loads at that condition, including the design cold spring and self springing of piping. Self springing may occur if the operating stress in the piping system exceeds the yield strength of the material or if the piping operates at temperatures in the creep range of the material.

319.5.1 Maximum Reactions for Simple Systems.

For a two-anchor piping system without intermediate

Fig. 319.4.4A Moments in Bends





Fig. 319.4.4B Moments in Branch Connections



Leg 1

restraints, the maximum instantaneous values of reaction forces and moments may be estimated from eqs. (21) and (22).

(a) For Extreme Displacement Conditions, R_m . The temperature for this computation is the maximum or minimum metal temperature defined in para. 319.3.1(b), whichever produces the larger reaction.

$$R_m = R\left(1 - \frac{2C}{3}\right) \frac{E_m}{E_a} \tag{21}$$

where

C = cold-spring factor varying from zero for no cold spring to 1.0 for 100% cold spring. (The factor two-thirds is based on experience showing that specified cold spring cannot be fully assured, even with elaborate precautions.)

 E_a = reference modulus of elasticity at 21°C (70°F)

 E_m = modulus of elasticity at maximum or minimum metal temperature

R = range of reaction forces or moments (derived from flexibility analysis) corresponding to the full displacement stress range and based on E_a

 R_m = estimated instantaneous maximum reaction force or moment at maximum or minimum metal temperature

(b) For Original Condition, R_a . The temperature for this computation is the expected temperature at which the piping is to be assembled.

 $R_a = CR$ or C_1R , whichever is greater

where nomenclature is as in para. 319.5.1(a) and

$$C_1 = 1 - \frac{S_h E_a}{S_E E_m} \tag{22}$$

= estimated self-spring or relaxation factor; use zero if value of C_1 is negative

 R_a = estimated instantaneous reaction force or moment at installation temperature

 S_E = computed displacement stress range (see para. 319.4.4)

 S_h = see definition in para. 302.3.5(d)

319.5.2 Maximum Reactions for Complex Systems.

For multianchor piping systems and for two-anchor systems with intermediate restraints, eqs. (21) and (22) are not applicable. Each case must be studied to estimate location, nature, and extent of local overstrain, and its effect on stress distribution and reactions.

319.6 Calculation of Movements

Calculations of displacements and rotations at specific locations may be required where clearance problems are involved. In cases where small-size branch pipes attached to stiffer run pipes are to be calculated separately, the linear and angular movements of the junction

point must be calculated or estimated for proper analysis of the branch.

319.7 Means of Increasing Flexibility

The layout of piping often provides inherent flexibility through changes in direction, so that displacements produce chiefly bending and torsional strains within prescribed limits. The amount of axial tension or compression strain (which produces large reactions) usually is small.

Where the piping lacks built-in changes of direction, or where it is unbalanced [see para. 319.2.2(b)], large reactions or detrimental overstrain may be encountered. The designer should consider adding flexibility by one or more of the following means: bends, loops, or offsets; swivel joints; corrugated pipe; expansion joints of the bellows or slip-joint type; or other devices permitting angular, rotational, or axial movement. Suitable anchors, ties, or other devices shall be provided as necessary to resist end forces produced by fluid pressure, frictional resistance to movement, and other causes. When expansion joints or other similar devices are provided, the stiffness of the joint or device should be considered in any flexibility analysis of the piping.

320 ANALYSIS OF SUSTAINED LOADS

320.1 Basic Assumptions and Requirements

Sustained conditions may be evaluated by detailed analysis, approximate methods, or simplified means such as span tables. When detailed analysis is performed, the stress due to sustained loads, S_L , shall be computed and combined as described in this paragraph and shall not exceed the allowable described in para. 302.3.5(c). See Appendix S, Example 2 for guidance on loading conditions and support scenarios that result in the greatest S_L for each operating condition being considered. The loads due to weight should be based on the nominal thickness of all system components unless otherwise justified in a more rigorous analysis. Section moduli used to compute the stresses in this paragraph shall be based on nominal pipe dimensions less allowances, i.e., the sum of mechanical (thread or groove depth), internal and external corrosion, and erosion allowances. Areas used to compute the stresses in this paragraph assume nominal pipe dimensions less allowances affecting the inside diameter of the pipe, i.e., the sum of mechanical and internal corrosion and erosion allowances. It is the responsibility of the designer to determine sustained stress indices, I_a , I_i , I_o , and I_t , when a piping component is not explicitly addressed in Appendix D, e.g., base-ells, reducing elbows, crosses, close proximity findings, etc., as well as elbows, pipe bends, or miters other than 90 deg or supported by a trunnion. Sustained stress indices shall not be lower than 1.00.

(16) 320.2 Stress Due to Sustained Loads

The equation for the stress due to sustained loads, such as pressure and weight, S_L , is provided in eq. (23a). Equations for the stress due to sustained bending moments, S_b , are presented in eqs. (23b1) and (23b2).

$$S_L = \sqrt{(|S_a| + S_b)^2 + (2S_t)^2}$$
 (23a)

$$S_b = \frac{\sqrt{(I_i M_i)^2 + (I_o M_o)^2}}{Z}$$
 (23b1)

For branch (Leg 3 in Fig. 319.4.4B), use eq. (23b2) only when I_i or I_o is based upon i, i_i , or i_o taken from Appendix D; when both I_i and I_o are determined by experimental or analytical means, e.g., ASME B31J, use eq. (23b1).

$$S_b = \frac{\sqrt{(I_i M_i)^2 + (I_o M_o)^2}}{Z_e}$$
 (23b2)

where

 I_i = sustained in-plane moment index. In the absence of more applicable data, I_i is taken as the greater of $0.75i_i$ or 1.00.

 I_o = sustained out-plane moment index. In the absence of more applicable data, I_o is taken as the greater of $0.75i_o$ or 1.00.

 M_i = in-plane moment due to sustained loads, e.g., pressure and weight

 M_o = out-plane moment due to sustained loads, e.g., pressure and weight

Z = sustained section modulus. Z in eqs. (23b1) and (23c) is described in para. 319.4.4 but is computed in this paragraph using nominal pipe dimensions less allowances; see para. 320.1.

 Z_e = sustained effective section modulus. Z_e in eq. (23b2) is described in para. 319.4.4, using i_i from Appendix D in T_s calculation, but Z_e is computed in this paragraph using nominal pipe dimensions less allowances; see para. 320.1.

The equation for the stress due to sustained torsional moment, S_t , is

$$S_t = \frac{I_t M_t}{2Z} \tag{23c}$$

where

 I_t = sustained torsional moment index. In the absence of more applicable data, I_t is taken as 1.00.

 M_t = torsional moment due to sustained loads, e.g., pressure and weight

The equation for the stress due to sustained longitudinal force, S_a , is

$$S_a = \frac{I_a F_a}{A_p} \tag{23d}$$

where

 A_p = cross-sectional area of the pipe, considering nominal pipe dimensions less allowances; see para. 320.1

 F_a = longitudinal force due to sustained loads, e.g., pressure and weight

 I_a = sustained longitudinal force index. In the absence of more applicable data, I_a is taken as 1.00.

The sustained longitudinal force, F_{ar} includes the sustained force due to pressure, which is P_jA_f unless the piping system includes an expansion joint that is not designed to carry this force itself, where P_j is the internal operating pressure for the condition being considered, $A_f = \pi d^2/4$, and d is the pipe inside diameter considering pipe wall thickness less applicable allowances; see para. 320.1. For piping systems that contain expansion joints, it is the responsibility of the designer to determine the sustained longitudinal force due to pressure in the piping system.

321 PIPING SUPPORT

321.1 General

The design of support structures (not covered by this Code) and of supporting elements (see definitions of piping and pipe supporting elements in para. 300.2) shall be based on all concurrently acting loads transmitted into such supports. These loads, defined in para. 301, include weight effects, loads introduced by service pressures and temperatures, vibration, wind, earthquake, shock, and displacement strain (see para. 319.2.2).

For piping containing gas or vapor, weight calculations need not include the weight of liquid if the designer has taken specific precautions against entrance of liquid into the piping, and if the piping is not to be subjected to hydrostatic testing at initial construction or subsequent inspections.

321.1.1 Objectives. The layout and design of piping and its supporting elements shall be directed toward preventing the following:

(a) piping stresses in excess of those permitted in this Code

(b) leakage at joints

(c) excessive thrusts and moments on connected equipment (such as pumps and turbines)

(d) excessive stresses in the supporting (or restraining) elements

(e) resonance with imposed or fluid-induced vibrations

- (f) excessive interference with thermal expansion and contraction in piping which is otherwise adequately flexible
- (g) unintentional disengagement of piping from its supports
- (h) excessive piping sag in piping requiring drainage slope
- (*i*) excessive distortion or sag of piping (e.g., thermoplastics) subject to creep under conditions of repeated thermal cycling
- *(j)* excessive heat flow, exposing supporting elements to temperature extremes outside their design limits
- **321.1.2 Analysis.** In general, the location and design of pipe supporting elements may be based on simple calculations and engineering judgment. However, when a more refined analysis is required and a piping analysis, which may include support stiffness, is made, the stresses, moments, and reactions determined thereby shall be used in the design of supporting elements.

321.1.3 Stresses for Pipe Supporting Elements.

Allowable stresses for materials used for pipe supporting elements, except springs, shall be in accordance with para. 302.3.1. Longitudinal weld joint factors, E_j , however, need not be applied to the allowable stresses for welded piping components that are to be used for pipe supporting elements.

321.1.4 Materials

- (a) Permanent supports and restraints shall be of material suitable for the service conditions. If steel is cold-formed to a centerline radius less than twice its thickness, it shall be annealed or normalized after forming
- (b) Gray, ductile, and malleable iron may be used for rollers, roller bases, anchor bases, and other supporting elements subject chiefly to compressive loading. Gray iron is not recommended if the piping may be subject to impact-type loading resulting from pulsation or vibration. Ductile and malleable iron may be used for pipe and beam clamps, hanger flanges, clips, brackets, and swivel rings.
- (c) Steel of an unknown specification may be used for pipe supporting elements that are not welded directly to pressure-containing piping components. (Compatible intermediate materials of known specification may be welded directly to such components.) Basic allowable stress in tension or compression shall not exceed 82 MPa (12 ksi) and the support temperature shall be within the range of -29°C to 343°C (-20°F to 650°F). For stress values in shear and bearing, see para. 302.3.1(b).
- (*d*) Wood or other materials may be used for pipe supporting elements, provided the supporting element is properly designed, considering temperature, strength, and durability.

- (e) Attachments welded or bonded to the piping shall be of a material compatible with the piping and service. For other requirements, see para. 321.3.2.
- **321.1.5 Threads.** Screw threads shall conform to ASME B1.1 unless other threads are required for adjustment under heavy loads. Turnbuckles and adjusting nuts shall have the full length of internal threads engaged. Any threaded adjustment shall be provided with a locknut, unless locked by other means.

321.2 Fixtures

321.2.1 Anchors and Guides

- (a) A supporting element used as an anchor shall be designed to maintain an essentially fixed position.
- (b) To protect terminal equipment or other (weaker) portions of the system, restraints (such as anchors and guides) shall be provided where necessary to control movement or to direct expansion into those portions of the system that are designed to absorb them. The design, arrangement, and location of restraints shall ensure that expansion joint movements occur in the directions for which the joint is designed. In addition to the other thermal forces and moments, the effects of friction in other supports of the system shall be considered in the design of such anchors and guides.
- (c) Piping layout, anchors, restraints, guides, and supports for all types of expansion joints shall be designed in accordance with para. X301.2 of Appendix X.

321.2.2 Inextensible Supports Other Than Anchors and Guides 9

- (a) Supporting elements shall be designed to permit the free movement of piping caused by thermal expansion and contraction.
- (b) Hangers include pipe and beam clamps, clips, brackets, rods, straps, chains, and other devices. They shall be proportioned for all required loads. Safe loads for threaded parts shall be based on the root area of the threads.
- (c) Sliding Supports. Sliding supports (or shoes) and brackets shall be designed to resist the forces due to friction in addition to the loads imposed by bearing. The dimensions of the support shall provide for the expected movement of the supported piping.

321.2.3 Resilient Supports ⁹

(a) Spring supports shall be designed to exert a supporting force, at the point of attachment to the pipe, equal to the load as determined by weight balance calculations. They shall be provided with means to prevent misalignment, buckling, or eccentric loading of the springs, and to prevent unintentional disengagement of the load.

⁹ Various types of inextensible (solid) and resilient supports are illustrated in MSS SP-58.

- (b) Constant-support spring hangers provide a substantially uniform supporting force throughout the range of travel. The use of this type of spring hanger is advantageous at locations subject to appreciable movement with thermal changes. Hangers of this type should be selected so that their travel range exceeds expected movements.
- (c) Means shall be provided to prevent overstressing spring hangers due to excessive deflections. It is recommended that all spring hangers be provided with position indicators.
- **321.2.4 Counterweight Supports.** Counterweights shall be provided with stops to limit travel. Weights shall be positively secured. Chains, cables, hangers, rocker arms, or other devices used to attach the counterweight load to the piping shall be subject to the requirements of para. 321.2.2.
- **321.2.5 Hydraulic Supports.** An arrangement utilizing a hydraulic cylinder may be used to give a constant supporting force. Safety devices and stops shall be provided to support the load in case of hydraulic failure.

321.3 Structural Attachments

External and internal attachments to piping shall be designed so that they will not cause undue flattening of the pipe, excessive localized bending stresses, or harmful thermal gradients in the pipe wall. It is important that attachments be designed to minimize stress concentration, particularly in cyclic services.

- **321.3.1 Nonintegral Attachments.** Nonintegral attachments, in which the reaction between the piping and the attachment is by contact, include clamps, slings, cradles, U-bolts, saddles, straps, and clevises. If the weight of a vertical pipe is supported by a clamp, it is recommended to prevent slippage that the clamp be located below a flange, fitting, or support lugs welded to the pipe.
- **321.3.2 Integral Attachments.** Integral attachments include plugs, ears, shoes, plates, trunnions, stanchions, structural shapes, and angle clips, cast on or welded to the piping. The material for integral attachments attached by welding shall be of good weldable quality. [See para. 321.1.4(e) for material requirements.] Preheating, welding, and heat treatment requirements shall be in accordance with Chapter V. Consideration shall be given to the localized stresses induced in the piping component by welding the integral attachment, as well as differential thermal displacement strains between the attachment and the component to which it is attached. Welds shall be proportioned so that the shear stresses meet the requirements of para. 302.3.1(b). If the allowed stress values differ between the piping component and the attachment material, the lower of the two values shall be used.

- (a) Integral reinforcement, complete encirclement reinforcement, or intermediate pads of suitable alloy and design may be used to reduce contamination or undesirable heat effects in alloy piping.
- (b) Intermediate pads, integral reinforcement, complete encirclement reinforcement, or other means of reinforcement may be used to distribute stresses.

321.4 Structural Connections

The load from piping and pipe supporting elements (including restraints and braces) shall be suitably transmitted to a pressure vessel, building, platform, support structure, foundation, or to other piping capable of bearing the load without deleterious effects. See Appendix F, para. F321.4.

PART 6 SYSTEMS

322 SPECIFIC PIPING SYSTEMS

322.3 Instrument Piping

- **322.3.1 Definition.** Instrument piping within the scope of this Code includes all piping and piping components used to connect instruments to other piping or equipment, and control piping used to connect air or hydraulically operated control apparatus. It does not include instruments, or permanently sealed fluid-filled tubing systems furnished with instruments as temperature or pressure responsive devices.
- **322.3.2 Requirements.** Instrument piping shall meet the applicable requirements of the Code and the following:
- (a) The design pressure and temperature for instrument piping shall be determined in accordance with para. 301. If more severe conditions are experienced during blowdown of the piping, they may be treated as occasional variations in accordance with para. 302.2.4.
- (b) Consideration shall be given to the mechanical strength (including fatigue) of small instrument connections to piping or apparatus (see para. 304.3.5).
- (c) Instrument piping containing fluids that are normally static and subject to freezing shall be protected by heat tracing or other heating methods, and insulation.
- (*d*) If it will be necessary to blow down (or bleed) instrument piping containing toxic or flammable fluids, consideration shall be given to safe disposal.

322.6 Pressure-Relieving Systems

Pressure-relieving systems within the scope of this Code shall conform to the following requirements. See also Appendix F, para. F322.6.

322.6.1 Stop Valves in Pressure Relief Piping. If one or more stop valves are installed between the piping being protected and its protective device or devices, or between the protective device or devices and the point

of discharge, they shall meet the requirements of (a) and either (b) or (c), below.

- (a) A full-area stop valve may be installed on the inlet side of a pressure-relieving device. A full area stop valve may be placed on the discharge side of a pressure-relieving device when its discharge is connected to a common header with other discharge lines from other pressure-relieving devices. Stop valves of less than full area may be used on both the inlet side and discharge side of pressure-relieving devices as outlined herein if the stop valves are of such type and size that the increase in pressure drop will not reduce the relieving capacity below that required, nor adversely affect the proper operation of the pressure-relieving device.
- (b) Stop valves to be used in pressure relief piping shall be so constructed or positively controlled that the closing of the maximum number of block valves possible at one time will not reduce the pressure-relieving capacity provided by the unaffected relieving devices below the required relieving capacity.
- (c) As an alternative to (b) above, stop valves shall be so constructed and arranged that they can be locked or sealed in either the open or closed position. See Appendix F, para. F322.6.
- **322.6.2 Pressure Relief Discharge Piping.** Discharge lines from pressure-relieving safety devices shall be designed to facilitate drainage. When discharging directly to the atmosphere, discharge shall not impinge on other piping or equipment and shall be directed away from platforms and other areas used by personnel. Reactions on the piping system due to actuation of safety relief devices shall be considered, and adequate strength shall be provided to withstand these reactions.

322.6.3 Pressure-Relieving Devices

- (a) Pressure-relieving devices required by para. 301.2.2(a) shall be in accordance with the BPV Code, Section VIII, Division 1, UG-125(c), UG-126, UG-127, and UG-132 through UG-136, excluding UG-135(e) and UG-136(c). The terms *design pressure* and *piping system* shall be substituted for *maximum allowable working pressure* and *vessel*, respectively, in these paragraphs. The required relieving capacity of any pressure-relieving device shall include consideration of all piping systems that it protects.
- (b) Relief set pressure¹¹ shall be in accordance with Section VIII, Division 1, with the exceptions stated in alternatives (1) and (2), below.
- (1) With the owner's approval the set pressure may exceed the limits in Section VIII, Division 1, provided that the limit on maximum relieving pressure stated in (c) below will not be exceeded.
- (2) For a liquid thermal expansion relief device that protects only a blocked-in portion of a piping system, the set pressure shall not exceed the lesser of the system test pressure or 120% of design pressure.
- (c) The maximum relieving pressure¹² shall be in accordance with Section VIII, Division 1, with the exception that the allowances in para. 302.2.4(f) are permitted, provided that all other requirements of para. 302.2.4 are also met.

 $^{^{10}}$ The *design pressure* for pressure relief is the maximum design pressure permitted, considering all components in the piping system.

¹¹ Set pressure is the pressure at which the device begins to relieve, e.g., lift pressure of a spring-actuated relief valve, bursting pressure of a rupture disk, or breaking pressure of a breaking pin device.

¹² Maximum relieving pressure is the maximum system pressure during a pressure relieving event.

Chapter III Materials

323 GENERAL REQUIREMENTS

Chapter III states limitations and required qualifications for materials based on their inherent properties. Their use in piping is also subject to requirements and limitations in other parts of this Code [see para. 300(d)]. See also para. 321.1.4 for support materials, and Appendix F, para. F323, for precautionary considerations.

323.1 Materials and Specifications

- **323.1.1 Listed Materials.** Any material used in pressure containing piping components shall conform to a listed specification except as provided in para. 323.1.2.
- **323.1.2 Unlisted Materials.** Unlisted materials may be used provided they conform to a published specification covering chemistry, physical and mechanical properties, method and process of manufacture, heat treatment, and quality control, and otherwise meet the requirements of this Code. See also ASME BPV Code Section II, Part D, Appendix 5. Allowable stresses shall be determined in accordance with the applicable allowable stress basis of this Code or a more conservative basis.
- **323.1.3 Unknown Materials.** Materials of unknown specification shall not be used for pressure-containing piping components.
- **323.1.4 Reclaimed Materials.** Reclaimed pipe and other piping components may be used, provided they are properly identified as conforming to a listed or published specification (para. 323.1.1 or 323.1.2) and otherwise meet the requirements of this Code. Sufficient cleaning and inspection shall be made to determine minimum wall thickness and freedom from imperfections that would be unacceptable in the intended service.

323.2 Temperature Limitations

The designer shall verify that materials that meet other requirements of the Code are suitable for service throughout the operating temperature range.

323.2.1 Upper Temperature Limits, Listed Materials. A listed material may be used at a temperature above the maximum for which a stress value or rating is shown, only if

- (a) there is no prohibition in Appendix A or elsewhere in the Code
- (b) the designer verifies the serviceability of the material in accordance with para. 323.2.4

323.2.2 Lower Temperature Limits, Listed (16) Materials. See Appendix F, para. F323.2.2.

- (a) A listed material may be used at any temperature not lower than the minimum shown in Table A-1 or Table A-1M, provided that the base metal, weld deposits, and heat-affected zone (HAZ) are qualified as required by the applicable entry in Column A of Table 323.2.2.
- (b) For carbon steels with a letter designation in the Min. Temp. column of Table A-1 or Table A-1M, the minimum temperature is defined by the applicable curve and Notes in Fig. 323.2.2A. If a design minimum temperature–thickness combination is on or above the curve, impact testing is not required.
- (c) A listed material may be used at a temperature lower than the minimum shown in Table A-1, Table A-1M, or Fig. 323.2.2A (including Notes), unless prohibited in Table 323.2.2, Table A-1, Table A-1M, or elsewhere in the Code, and provided that the base metal, weld deposits, and HAZ are qualified as required by the applicable entry in Column B of Table 323.2.2.
- (*d*) Figure 323.2.2B provides a further basis for the use of carbon steels covered by paras. 323.2.2(a) and (b), without impact testing, when all of the following apply:
- not in elevated temperature service
- not expected to experience shock loading or thermal bowing
- does not contain welds between dissimilar materials (e.g., austenitic welded to ferritic)
- stress ratio defined in Fig. 323.2.2B is less than one
- (1) For design minimum temperatures of −48°C (−55°F) and above, the lowest temperature without impact testing (exemption temperature) determined in paras. 323.2.2(a) or (b), for the given material and thickness, may be reduced by the amount of the temperature reduction provided in Fig. 323.2.2B for the applicable stress ratio. If the resulting temperature is lower than the design minimum temperature, impact testing of the material is not required. Where this is applied, the piping

	Type of Material	Co Design Minimum Temperature a Table A-1M,	Column B Design Minimum Temperature Below Min. Temp. in Table A-1, Table A-1M, or Fig. 323.2.2A	
	1 Gray iron	A-1 No additional requirements		B-1 No additional requirements
	2 Malleable and ductile iron; carbon steel in accordance with Note (1)	A-2 No additional requirements		B-2 Materials designated in Box 2 shall not be used.
		(a) Base Metal	(b) Weld Metal and Heat Affected Zone (HAZ) [Note (2)]	
Listed Materials	3 Other carbon steels, low and intermediate alloy steels, high alloy ferritic steels, duplex stainless steels	A-3 (a) No additional requirements	A-3 (b) Weld metal deposits shall be impact tested in accordance with para. 323.3 if design min. temp. <-29°C (-20°F), except as provided in Notes (3) and (4), and except as follows: for materials listed for Curves C and D of Fig. 323.2.2A, where corresponding welding consumables are qualified by impact testing at the design minimum temperature or lower in accordance with the applicable AWS specification, additional testing is not required.	B-3 Except as provided in Notes (3) and (4), heat treat base metal in accordance with applicable ASTM specification listed in para. 323.3.2; then impact test base metal, weld deposits, and HAZ in accordance with para. 323.3 [see Note (2)]. When materials are used at temperature below the assigned curve as permitted by Notes (2) and (3) of Fig. 323.2.2A, weld deposits and HAZ shall be impact tested [see Note (2)].
Liste	4 Austenitic stainless steels	A-4 (a) If: (1) carbon content by analysis >0.1%; or (2) material is not in solution heat treated condition; then, impact test in accordance with para. 323.3 for design min. temp. <-29°C (-20°F) except as provided in Notes (5) and (6)	A-4 (b) Weld metal deposits shall be impact tested in accordance with para. 323.3 if design min. temp. <-29°C (-20°F) except as provided in para. 323.2.2 and in Notes (5) and (6)	B-4 Base metal and weld metal deposits shall be impact tested in accordance with para. 323.3. See Notes (2), (5), and (6).
	5 Austenitic ductile iron, ASTM A571	A-5 (a) No additional requirements	A-5 (b) Welding is not permitted	B-5 Base metal shall be impact tested in accordance with para. 323.3. Do not use <-196°C (-320°F). Welding is not permitted.
	6 Aluminum, copper, nickel, and their alloys; unalloyed titanium	A-6 (a) No additional requirements	A-6 (b) No additional requirements unless filler metal composition is outside the range for base metal composition; then test in accordance with item B-6	B-6 Designer shall be assured by suitable tests [see Note (7)] that base metal, weld deposits, and HAZ are suitable at the design min. temp.
Unlisted Materials		ents for the corresponding listed mate	Where composition, heat treatment, and prival shall be met. Other unlisted materials	·

(16)

Table 323.2.2 Requirements for Low Temperature Toughness Tests for Metals (Cont'd)

NOTES:


- (1) Carbon steels conforming to the following are subject to the limitations in box B-2: plates in accordance with ASTM A36, A283, and A570; pipe in accordance with ASTM A134 when made from these plates; structural shapes in accordance with ASTM A992; and pipe in accordance with ASTM A53 Type F and API 5L Gr. A25 butt weld.
- (2) Impact tests that meet the requirements of Table 323.3.1, which are performed as part of the weld procedure qualification, will satisfy all requirements of para. 323.2.2, and need not be repeated for production welds.
- (3) For carbon steels, impact testing is not required if the design minimum temperature is at or above -104°C (-155°F), and the minimum temperature without impact testing is less than or equal to the design minimum temperature using the rules based on stress ratio defined in Fig. 323.2.2B.
- (4) Impact tests are not required when the maximum obtainable Charpy specimen has a width along the notch of less than 2.5 mm (0.098 in.). Under these conditions, and where the stress ratio defined in Fig. 323.2.2B exceeds 0.3, the design minimum temperature shall not be less than the lower of -48°C (-55°F) or the minimum temperature for the material in Table A-1 or Table A-1M.
- (5) Impact tests are not required when the maximum obtainable Charpy specimen has a width along the notch of less than 2.5 mm (0.098 in.).
- (6) For austenitic stainless steels, impact testing is not required if the design minimum temperature is greater than or equal to -104°C (-155°F) and the stress ratio as defined in Fig. 323.2.2B does not exceed 0.3.
- (7) Tests may include tensile elongation, sharp-notch tensile strength (to be compared with unnotched tensile strength), and/or other tests, conducted at or below design minimum temperature. See also para. 323.3.4.

NOTES:

- (1) Any carbon steel material may be used to a minimum temperature of -29°C (-20°F) for Category D Fluid Service.
- (2) X Grades of API 5L, and ASTM A381 materials, may be used in accordance with Curve B if normalized or quenched and tempered.
- (3) The following materials may be used in accordance with Curve D if normalized:
 - (a) ASTM A516 plate, all grades
 - (b) ASTM A671 pipe made from A516 plate, all grades
 - (c) ASTM A672 pipe made from A516 plate, all grades
- (4) A welding procedure for the manufacture of pipe or components shall include impact testing of welds and HAZ for any design minimum temperature below -29°C (-20°F), except as provided in Table 323.2.2, A-3(b).
- (5) Impact testing in accordance with para. 323.3 is required for any design minimum temperature below -48°C (-55°F), except as permitted by Note (3) in Table 323.2.2.
- (6) For blind flanges and blanks, \overline{T} shall be $\frac{1}{4}$ of the flange thickness.

Table 323.2.2A Tabular Values for Minimum Temperatures Without Impact Testing for Carbon Steel Materials (See Fig. 323.2.2A for Curves and Applicable Notes)

Nominal				L	owest Exempt	tion Temperature	е		
Thicl	kness, <i>T</i> ote (6)]	Curv [Note		Curv [Note		Curv [Note		Curv	e D
mm	in.	°C	°F	°C	°F	°C	°F	°C	°F
6.4	0.25	-9.4	15	-28.9	-20	-48.3	-55	-48.3	-55
7.9	0.3125	-9.4	15	-28.9	-20	-48.3	-55	-48.3	-55
9.5	0.375	-9.4	15	-28.9	-20	-48.3	-55	-48.3	-55
10.0	0.394	-9.4	15	-28.9	-20	-48.3	-55	-48.3	-55
11.1	0.4375	-6.7	20	-28.9	-20	-41.7	-43	-48.3	-55
12.7	0.5	-1.1	30	-28.9	-20	-37.8	-36	-48.3	-55
14.3	0.5625	2.8	37	-21.7	_7	-35.0	-31	-45.6	-50
15.9	0.625	6.1	43	-16.7	2	-32.2	-26	-43.9	-47
17.5	0.6875	8.9	48	-12.8	9	-29.4	-21	-41.7	-43
19.1	0.75	11.7	53	-9.4	15	-27.2	-17	-40.0	-40
20.6	0.8125	14.4	58	-6.7	20	-25.0	-13	-38.3	-37
22.2	0.875	16.7	62	-3.9	25	-23.3	-10	-36.7	-34
23.8	0.9375	18.3	65	-1.7	29	-21.7	-7	-35.6	-32
25.4	1.0	20.0	68	0.6	33	-19.4	-3	-34.4	-30
27.0	1.0625	22.2	72	2.2	36	-19.4 -18.3	-5 -1	-33.3	-30 -28
28.6	1.125	23.9	72 75	3.9	39	-16.7	2	-32.2	-26 -26
30.2	1.125	25.9	73 77	5.6	42	-16.7 -15.6	4	-30.6	-26 -23
31.8	1.16/5	26.7	80	6.7	42 44	-15.6 -14.4	6	-30.6 -29.4	-23 -21
33.3	1.3125	27.8	82	7.8	46	-13.3	8	-28.3	-19
34.9	1.375	28.9	84	8.9	48	-12.2	10	-27.8	-18
36.5	1.4375	30.0	86	9.4	49	-11.1	12	-26.7	-16
38.1	1.5	31.1	88	10.6	51	-10.0	14	-25.6	-14
39.7	1.5625	32.2	90	11.7	53	-8.9	16	-25.0	-13
41.3	1.625	33.3	92	12.8	55	-8.3	17	-23.9	-11
42.9	1.6875	33.9	93	13.9	57	-7.2	19	-23.3	-10
44.5	1.75	34.4	94	14.4	58	-6.7	20	-22.2	-8
46.0	1.8125	35.6	96	15.0	59	-5.6	22	-21.7	-7
47.6	1.875	36.1	97	16.1	61	-5.0	23	-21.1	-6
49.2	1.9375	36.7	98	16.7	62	-4.4	24	-20.6	-5
50.8	2.0	37.2	99	17.2	63	-3.3	26	-20.0	-4
51.6	2.0325	37.8	100	17.8	64	-2.8	27	-19.4	-3
54.0	2.125	38.3	101	18.3	65	-2.2	28	-18.9	-2
55.6	2.1875	38.9	102	18.9	66	-1.7	29	-18.3	-1
57.2	2.25	38.9	102	19.4	67	-1.1	30	-17.8	0
58.7	2.3125	39.4	103	20.0	68	-0.6	31	-17.2	1
60.3	2.375	40.0	104	20.6	69	0.0	32	-16.7	2
61.9	2.4375	40.6	105	21.1	70	0.6	33	-16.1	3
63.5	2.4373	40.6	105	21.7	71	1.1	34	-15.6	4
65.1	2.5625	41.1	106	21.7	71	1.7	35	-15.0	5
66.7	2.625	41.7	107	22.8	73	2.2	36	-14.4	6
68.3	2.6875	41.7	107	22.8	73	2.8	37	-13.9	7
69.9	2.6875	41.7	107	23.3	73 74	3.3	38	-13.9 -13.3	/ 8
71.4	2.75 2.8125	42.2 42.2	108	23.3	74 75	3.3 3.9	38 39	-13.3 -13.3	8
73.0	2.875	42.2	108	23.9	75 76	3.9 4.4	39 40	-13.3 -12.8	9
74.6	2.9375	42.8 42.8	109	25.0	76 77	4.4	40	-12.8 -12.2	10
76.2	3.0	43.3	110	25.0	77 77	5.0	41	-12.2 -11.7	11
70.2	٠.٠	43.3	110	25.0	//	5.0	41	-11./	11



GENERAL NOTES:

- (a) The stress ratio is defined as the maximum of the following:
 - (1) circumferential pressure stress for the condition under consideration (based on minimum pipe wall thickness less allowances) divided by the basic allowable stress at the condition under consideration.
 - (2) for piping components with pressure ratings, the pressure for the condition under consideration divided by the pressure rating at the condition under consideration.
 - (3) combined stress due to pressure, dead loads, live loads, and displacement strain for the condition under consideration divided by the basic allowable stress at the condition under consideration. In calculating this combined stress, the forces and moments in the piping system for these combined sustained loads and displacement strains shall be calculated using nominal dimensions, and the stresses shall be calculated using eqs. (23a) through (23d) with all of the stress indices taken as 1.0 ($l_a = l_i = l_o = l_t = 1.0$) and using section properties based on the nominal dimensions less corrosion, erosion, and mechanical allowances. Also see Appendix F, para. F323.2.2.
- (b) Impact testing is not required if the design minimum temperature is greater than or equal to -104 °C (-155 °F) and the stress ratio does not exceed 0.3.
- (c) For stress ratios greater than 0.3, the lowest design minimum temperature permitted is -48°C (-55°F).

Table 323.2.2B Tabular Values for Reduction in Lowest Exemption Temperature for Steels Without Impact Testing

(See Fig. 323.2.2B for Curve and Applicable Notes)

	Reduction in Exemption Temperature			Reduction in Exemption Temperatur	
Stress Ratio	°C	°F	Stress Ratio	°C	°F
1.00	0	0	0.64	20	36
0.99	1	1	0.63	21	37
0.98	1	2	0.62	21	38
0.97	2	3	0.61	22	40
0.96	2	4	0.60	23	41
0.95	3	5	0.59	23	42
0.94	3	6	0.58	24	44
0.93	4	7	0.57	26	46
0.92	4	8	0.56	26	47
0.91	5	9	0.55	27	49
0.90	6	10	0.54	28	51
0.89	6	11	0.53	29	53
0.88	7	12	0.52	31	56
0.87	7	13	0.51	33	59
0.86	8	14	0.50	34	61
0.85	8	15	0.49	36	65
0.84	9	16	0.48	38	68
0.83	9	17	0.47	40	72
0.82	10	18	0.46	42	76
0.81	11	19	0.45	44	80
0.80	11	20	0.44	47	85
0.79	12	21	0.43	50	90
0.78	12	22	0.42	53	96
0.77	13	23	0.41	56	101
0.76	13	24	0.40	60	108
0.75	14	25	0.39	64	115
0.74	14	26	0.38	68	122
0.73	15	27	0.37	72	130
0.72	16	28	0.36	77	138
0.71	16	29	0.35	82	147
0.70	17	30	0.34	87	156
0.69	17	31	0.33	92	166
0.68	18	32	0.32	98	177
0.67	18	33	0.31	104	188
0.66	18	33	0.30	111	200
0.65	19	34	0.30	120	217

(16)

system shall also comply with the following requirements:

- (-a) The piping shall be subjected to a leak test at no less than $1\frac{1}{2}$ times the design pressure.
- (-b) Except for piping with a nominal wall thickness of 13 mm ($^{1}\!\!/_{2}$ in.) or less, the piping system shall be safeguarded (see Appendix G) from external loads such as maintenance loads, impact loads, and thermal shock.
- (2) For design minimum temperatures lower than -48°C (-55°F), impact testing is required for all materials, except as provided by General Note (b) of Fig. 323.2.2B.
- (e) The allowable stress or component rating at any temperature below the minimum shown in Table A-1, Table A-1M, or Fig. 323.2.2A shall not exceed the stress value or rating at the minimum temperature in Table A-1, Table A-1M, or the component standard.
- (f) Impact testing is not required for the following combinations of weld metals and design minimum temperatures:
- (1) for austenitic stainless steel base materials having a carbon content not exceeding 0.10%, welded without filler metal, at design minimum temperatures of -101°C (-150°F) and higher
 - (2) for austenitic weld metal
- (-a) having a carbon content not exceeding 0.10%, and produced with filler metals conforming to AWS A5.4, A5.9, A5.11, A5.14, or A5.22¹ at design minimum temperatures of -101° C (-150° F) and higher, or
- (-b) having a carbon content exceeding 0.10%, and produced with filler metals conforming to AWS A5.4, A5.9, A5.11, A5.14, or A5.22¹ at design minimum temperatures of -48° C (-55° F) and higher
- **323.2.3 Temperature Limits, Unlisted Materials.** An unlisted material, acceptable under para. 323.1.2, shall be qualified for service at all temperatures within a stated range, from design minimum temperature to design maximum temperature, in accordance with para. 323.2.4.

323.2.4 Verification of Serviceability

(a) When an unlisted material is to be used, or when a listed material is to be used above the highest temperature for which stress values appear in Appendix A, the designer is responsible for demonstrating the validity of the allowable stresses and other limits used in design

- and of the approach taken in using the material, including the derivation of stress data and the establishment of temperature limits.
- (b) Data for the development of design limits shall be obtained from a sound scientific program carried out in accordance with recognized technology for both the material and the intended service conditions. Factors to be considered include
- (1) applicability and reliability of the data, especially for extremes of the temperature range
- (2) resistance of the material to deleterious effects of the fluid service and of the environment throughout the temperature range
- (3) determination of allowable stresses in accordance with para. 302.3

323.3 Impact Testing Methods and Acceptance Criteria

323.3.1 General. When impact testing is required by Table 323.2.2, provisions elsewhere in this Code, or the engineering design, it shall be done in accordance with Table 323.3.1 using the testing methods and acceptance criteria described in paras. 323.3.2 through 323.3.5.

323.3.2 Procedure. Impact testing of each product form of material for any specification (including welds in the components) shall be done using procedures and apparatus in accordance with ASTM A370. For material forms that are represented by the ASTM specifications listed below, impact tests shall be conducted in conformance with those requirements as well. When conflicts exist between the specific requirements of this Code and the requirements of those specifications, the requirements of this Code shall take precedence.

Product Form	ASTM Spec. No.
Pipe	A333
Tube	A334
Fittings	A420
Forgings	A350
Castings	A352
Bolting	A320
Plate	A20

GENERAL NOTE: Titles of referenced standards not listed in the Specifications Index for Appendix A are A20 General Requirements for Steel Plates for Pressure Vessels and A370 Test Methods and Definitions for Mechanical Testing of Steel Products.

323.3.3 Test Specimens. Each set of impact test specimens shall consist of three specimen bars. All impact tests shall be made using standard 10 mm (0.394 in.) square cross section Charpy V-notch specimen bars, except when the material shape or thickness does not permit. Charpy impact tests may be performed on specimens of full material thickness, which may be machined to remove surface irregularities. Alternatively, such material may be reduced in thickness to produce the largest possible Charpy subsize specimen. See Table 323.3.4.

¹ Titles of referenced AWS standards are as follows: AWS A5.4, Stainless Steel Electrodes for Shielded Metal Arc Welding; AWS A5.9, Bare Stainless Steel Welding Electrodes and Rods; AWS A5.11, Nickel and Nickel Alloy Welding Electrodes for Shielded Metal Arc Welding; AWS A5.14, Nickel and Nickel Alloy Bare Welding Electrodes and Rods; and AWS A5.22, Flux Cored Corrosion-Resisting Chromium and Chromium-Nickel Steel Electrodes.

Table 323.3.1 Impact Testing Requirements for Metals

	Test Characteristics	Column A Materials Tested by the Manufacturer [Note (1)] or Those in Table 323.2.2 Requiring Impact Tests Only on Welds	Column B Materials Not Tested by the Manufacturer or Those Tested But Heat Treated During or After Fabrication		
Tests on Materials	Number of tests	A-1 The greater of the number required by(a) the material specification or(b) the applicable specification listed in para. 323.3.2 [Note (2)]	B-1 The number required by the applicable specification listed in para. 323.3.2 [Note (2)]		
Fests or	Location and orientation of specimens	2 As required by the applicable specification listed	in para. 323.3.2.		
	Tests by	A-3 The manufacturer	B-3 The fabricator or erector		
	Test piece for prepara- tion of impact specimens	and for each flux to be used. Test pieces shall	n type of filler metal (i.e., AWS E-XXXX classification), be subjected to essentially the same heat treatment and cooling rate) as the erected piping will have		
Tests on Welds in Fabrication or Assembly	Number of test pieces [Note (3)]	 (a) One piece, thickness <i>T</i>, for each range of material thickness from <i>T</i>/2 to <i>T</i> + 6 mm (½ in.) (b) Unless required by the engineering design, pieces need not be made from each lot, nor from material for each job, provided that welds have been tested as required by Section 4 above, for the same type and grade of material (or for the same P-Number and Group Number in BPV Code, Section IX), and of the same thickness range, and that records of the tests are made available 	B-5 (a) One piece from each lot of material in each specification and grade including heat treatment [Note (4)] unless (b) Materials are qualified by the fabricator or erector as specified in items B-1 and 2 above, in which case the requirements of item A-5 apply		
	Location and orientation of specimens	 6 (a) Weld metal: across the weld, with notch in the weld metal; notch axis shall be normal to material surface, with one face of specimen ≤ 1.5 mm (¹/₁6 in.) from the material surface. (b) Heat affected zone (HAZ): across the weld and long enough to locate notch in the HAZ after etch ing; notch axis shall be approximately normal to material surface and shall include as much as possible of the HAZ in the fracture. 			
	Tests by	7 The fabricator or erector			

NOTES

- (1) A certified report of impact tests performed (after being appropriately heat treated as required by Table 323.2.2, item B-3) by the manufacturer shall be obtained as evidence that the material (including any welds used in its manufacture) meets the requirements of this Code and that
 - (a) the tests were conducted on specimens representative of the material delivered to and used by the fabricator or erector, or
 - (b) the tests were conducted on specimens removed from test pieces of the material which received heat treatment separately in the same manner as the material (including heat treatment by the manufacturer) so as to be representative of the finished piping
- (2) If welding is used in manufacture, fabrication, or erection, tests of the HAZ will suffice for the tests of the base material.
- (3) The test piece shall be large enough to permit preparing three specimens from the weld metal and three from the HAZ (if required) in accordance with para. 323.3. If this is not possible, preparation of additional test pieces is required.
- (4) For purposes of this requirement, "lot" means the quantity of material described under the "Number of tests" provision of the specification applicable to the product term (i.e., plate, pipe, etc.) listed in para. 323.3.2.

Actual Material Thickno [See Para. 323.3. or Charpy Impa Specimen Widt Along the Noto [Note (1)]	Tempei Reduc Below I Minin Tempei	ction Design num	
mm	in.	°C	°F
10 (full size standard bar)	0.394	0	0
9	0.354	0	0
8	0.315	0	0
7.5 ($\frac{3}{4}$ size bar)	0.295	2.8	5
7	0.276	4.4	8
6.67 ($\frac{2}{3}$ size bar)	0.262	5.6	10
6	0.236	8.3	15
5 ($\frac{1}{2}$ size bar)	0.197	11.1	20
4	0.157	16.7	30
3.33 ($\frac{1}{3}$ size bar)	0.131	19.4	35
3	0.118	22.2	40
2.5 ($\frac{1}{4}$ size bar)	0.098	27.8	50

GENERAL NOTE: These temperature reduction criteria do not apply when Table 323.3.5 specifies lateral expansion for minimum required values.

NOTE:

(1) Straight line interpolation for intermediate values is permitted.

323.3.4 Test Temperatures. For all Charpy impact tests, the test temperature criteria in para. 323.3.4(a) or (b) shall be observed. The test specimens, as well as the handling tongs, shall be cooled for a sufficient length of time to reach the test temperature.

(a) For Materials of Thickness Equal to or Greater Than 10 mm (0.394 in.). Where the largest attainable Charpy V-notch specimen has a width along the notch of at least 8 mm (0.315 in.), the Charpy test using such a specimen shall be conducted at a temperature not higher than the design minimum temperature. Where the largest possible test specimen has a width along the notch less than 8 mm, the test shall be conducted at a temperature lower than the design minimum temperature by the amount shown in Table 323.3.4 for that specimen width.

(b) For Materials With Thickness Less Than 10 mm (0.394 in.). Where the largest attainable Charpy V-notch specimen has a width along the notch of at least 80% of the material thickness, the Charpy test of such a specimen shall be conducted at a temperature not higher than the design minimum temperature. Where the largest possible test specimen has a width along the notch of less than 80% of the material thickness, the test shall be conducted at a temperature lower than the design minimum temperature by an amount equal to the difference (referring to Table 323.3.4) between the temperature

reduction corresponding to the actual material thickness and the temperature reduction corresponding to the Charpy specimen width actually tested.

323.3.5 Acceptance Criteria

(a) Minimum Energy Requirements. Except for bolting materials, the applicable minimum energy requirement for carbon and low alloy steels with specified minimum tensile strengths less than 656 MPa (95 ksi) shall be those shown in Table 323.3.5.

(b) Lateral Expansion Requirements. Other carbon and low alloy steels having specified minimum tensile strengths equal to or greater than 656 MPa (95 ksi), all bolting materials, and all high alloy steels (P-Nos. 6, 7, and 8) shall have a lateral expansion opposite the notch of not less than 0.38 mm (0.015 in.) for all specimen sizes. The lateral expansion is the increase in width of the broken impact specimen over that of the unbroken specimen measured on the compression side, parallel to the line constituting the bottom of the V-notch (see ASTM A370).

(c) Weld Impact Test Requirements. Where two base metals having different required impact energy values are joined by welding, the impact test energy requirements shall conform to the requirements of the base material having a specified minimum tensile strength most closely matching the specified minimum tensile strength of the weld metal.

(d) Retests

(1) For Absorbed Energy Criteria. When the average value of the three specimens equals or exceeds the minimum value permitted for a single specimen and the value for more than one specimen is below the required average value, or when the value for one specimen is below the minimum value permitted for a single specimen, a retest of three additional specimens shall be made. The value for each of these retest specimens shall equal or exceed the required average value.

(2) For Lateral Expansion Criterion. If the value of lateral expansion for one specimen in a group of three is below 0.38 mm (0.015 in.) but not below 0.25 mm (0.01 in.), and if the average value for three specimens equals or exceeds 0.38 mm (0.015 in.), a retest of three additional specimens may be made, each of which must equal or exceed the specified minimum value of 0.38 mm (0.015 in.). In the case of heat treated materials, if the required values are not obtained in the retest or if the values in the initial test are below the minimum allowed for retest, the material may be reheat treated and retested. After reheat treatment, a set of three specimens shall be made. For acceptance, the lateral expansion of each of the specimens must equal or exceed the specified minimum value of 0.38 mm (0.015 in.).

(3) For Erratic Test Results. When an erratic result is caused by a defective specimen or there is uncertainty in the test procedure, a retest will be allowed.

Table 323.3.5 Minimum Required Charpy V-Notch Impact Values

			Energy [Note (2)]				
Specified Minimum	No. of Specimens	Fully Deoxidized Steels		Other Than Fully Deoxidized Steels			
Tensile Strength	[Note (1)]	Joules	ft-lbf	Joules	ft-lbf		
(a) Carbon and Low Alloy Steels							
448 MPa (65 ksi) and less	Average for 3 specimens	18	13	14	10		
	Minimum for 1 specimen	14	10	10	7		
Over 448 to 517 MPa (75 ksi)	Average for 3 specimens	20	15	18	13		
	Minimum for 1 specimen	16	12	14	10		
Over 517 but not incl. 656 MPa (95 ksi)	Average for 3 specimens	27	20				
	Minimum for 1 specimen	20	15	• • •			
			Lateral E	xpansion			
656 MPa and over [Note (3)]	Minimum for 3 specimens		0.38 mm	(0.015 in.)			
(b) Steels in P-Nos. 6, 7, and 8	Minimum for 3 specimens		0.38 mm	(0.015 in.)			

NOTES:

- (1) See para. 323.3.5(d) for permissible retests.
- (2) Energy values in this Table are for standard size specimens. For subsize specimens, these values shall be multiplied by the ratio of the actual specimen width to that of a full-size specimen, 10 mm (0.394 in.).
- (3) For bolting of this strength level in nominal sizes M 52 (2 in.) and under, the impact requirements of ASTM A320 may be applied. For bolting over M 52, requirements of this Table shall apply.

323.4 Fluid Service Requirements for Materials

323.4.1 General. Requirements in para. 323.4 apply to pressure-containing parts. They do not apply to materials used for supports, gaskets, packing, or bolting. See also Appendix F, para. F323.4.

323.4.2 Specific Requirements

(a) Ductile Iron. Ductile iron shall not be used for pressure containing parts at temperatures below -29°C (-20°F) (except austenitic ductile iron) or above 343°C (650°F). Austenitic ductile iron conforming to ASTM A571 may be used at temperatures below -29°C (-20°F) down to the temperature of the impact test conducted in accordance with that specification but not below -196°C (-320°F).

Valves having bodies and bonnets or covers made of materials conforming to ASTM A395 and meeting the requirements of ASME B16.42 and additional requirements of ASME B16.34 Standard Class, API 594, API 599, or API 609 may be used within the pressure–temperature ratings given in ASME B16.42.

Welding shall not be performed in the fabrication or repair of ductile iron components nor in assembly of such components in a piping system.

(b) Other Cast Irons. The following shall not be used under severe cyclic conditions. If safeguarding is provided against excessive heat and thermal shock and mechanical shock and abuse, they may be used in other services subject to the following requirements.

- (1) Gray iron shall not be used above ground within process unit limits in hydrocarbon or other flammable fluid service at temperatures above 149°C (300°F) nor at gage pressures above 1 035 kPa (150 psi). In other locations the pressure limit shall be 2 760 kPa (400 psi).
- (2) Malleable iron shall not be used in any fluid service at temperatures below -29°C (-20°F) or above 343°C (650°F) and shall not be used in flammable fluid service at temperatures above 149°C (300°F) nor at gage pressures above 2 760 kPa (400 psi).
- (3) High silicon iron (14.5% Si) shall not be used in flammable fluid service. The manufacturer should be consulted for pressure–temperature ratings and for precautionary measures when using this material.
 - (c) Other Materials
- (1) If welding or thermal cutting is performed on aluminum castings, the stress values in Appendix A and component ratings listed in Table 326.1 are not applicable. It is the designer's responsibility to establish such stresses and ratings consistent with the requirements of this Code.
- (2) Lead and tin and their alloys shall not be used in flammable fluid services.
- **323.4.3 Cladding and Lining Materials.** Materials with metallic cladding or metallic lining may be used in accordance with the following provisions:
- (a) If piping components are made from integrally clad plate conforming to

- (1) ASTM A263, Corrosion-Resisting Chromium Steel Clad Plate, Sheet, and Strip
- (2) ASTM A264, Stainless Chromium-Nickel Steel Clad Plate, Sheet, and Strip
- (3) ASTM A265, Nickel and Nickel-Base Alloy Clad Plate, Sheet, and Strip

Then pressure design in accordance with rules in para. 304 may be based upon the total thickness of base metal and cladding after any allowance for corrosion has been deducted, provided that both the base metal and the cladding metal are acceptable for Code use under para. 323.1, and provided that the clad plate has been shear tested and meets all shear test requirements of the applicable ASTM specification. The allowable stress for each material (base and cladding) shall be taken from Appendix A, or determined in accordance with the rules in para. 302.3, provided, however, that the allowable stress used for the cladding portion of the design thickness shall never be greater than the allowable stress used for the base portion.

(b) For all other metallic clad or lined piping components, the base metal shall be an acceptable Code material as defined in para. 323.1 and the thickness used in pressure design in accordance with para. 304 shall not include the thickness of the cladding or lining. The allowable stress used shall be that for the base metal at the design temperature. For such components, the cladding or lining may be any material that, in the judgment of the user, is suitable for the intended service and for the method of manufacture and assembly of the piping component.

- (c) Except for components designed in accordance with provisions of para. 323 4.3(a), fluid service requirements for materials stated in this Code shall not restrict their use as cladding or lining in pipe or other components. Fluid service requirements for the outer material (including those for components and joints) shall govern, except that temperature limitations of both inner and outer materials, and of any bond between them, shall be considered.
- (*d*) Fabrication by welding of clad or lined piping components and the inspection and testing of such components shall be done in accordance with applicable provisions of the BPV Code, Section VIII, Division 1, UCL-30 through UCL-52, or the provisions of Chapters V and VI of this Code, whichever are more stringent.

323.5 Deterioration of Materials in Service

Selection of material to resist deterioration in service is not within the scope of this Code. See para. 300(c)(6). Recommendations based on experience are presented for guidance in Appendix F, para. F323.

325 MATERIALS — MISCELLANEOUS

325.1 Joining and Auxiliary Materials

When selecting materials such as adhesives, cements, solvents, solders, brazing materials, packing, and O-rings for making or sealing joints, the designer shall consider their suitability for the fluid service. (Consideration should also be given to the possible effects of the joining or auxiliary materials on the fluid handled.)

Chapter IV Standards for Piping Components

326 DIMENSIONS AND RATINGS OF COMPONENTS

326.1 Dimensional Requirements

326.1.1 Listed Piping Components. Dimensional standards¹ for piping components are listed in Table 326.1. Dimensional requirements contained in specifications listed in Appendix A shall also be considered requirements of this Code.

326.1.2 Unlisted Piping Components. Piping components not listed in Table 326.1 or Appendix A shall meet the pressure design requirements described in para. 302.2.3 and the mechanical strength requirements described in para. 302.5.

326.1.3 Threads. The dimensions of piping connection threads not otherwise covered by a governing component standard or specification shall conform to the

requirements of applicable standards listed in Table 326.1 or Appendix A.

326.2 Ratings of Components

326.2.1 Listed Components. The pressure–temperature ratings of components listed in Table 326.1 are accepted for pressure design in accordance with para. 303.

326.2.2 Unlisted Components. The pressure-temperature ratings of unlisted piping components shall conform to the applicable provisions of para. 304.

326.3 Reference Documents

The documents listed in Table 326.1 contain references to codes, standards, and specifications not listed in Table 326.1. Such unlisted codes, standards, and specifications shall be used only in the context of the listed documents in which they appear.

The design, materials, fabrication, assembly, examination, inspection, and testing requirements of this Code are not applicable to components manufactured in accordance with the documents listed in Table 326.1, unless specifically stated in this Code, or the listed document.

¹It is not practical to refer to a specific edition of each standard throughout the Code text. Instead, the approved edition references, along with the names and address of sponsoring organizations, are shown in Appendix E.

Table 326.1 Component Standards

Standard or Specification	Designation
Bolting	
Square and Hex Bolts and Screws (Inch Series)	ASME B18.2.1
Square and Hex Nuts (Inch Series)	ASME B18.2.2
Metallic Fittings, Valves, and Flanges	
Gray Iron Pipe Flanges and Flanged Fittings	ASME B16.1
Malleable Iron Threaded Fittings	ASME B16.3
Gray Iron Threaded Fittings	ASME B16.4
Pipe Flanges and Flanged Fittings	ASME B16.5 ASME B16.9
Face-to-Face and End-To-End Dimensions of Valves	ASME B16.10
Forged Fittings, Socket-Welding and Threaded	ASME B16.11
Ferrous Pipe Plugs, Bushings, and Locknuts With Pipe Threads	ASME B16.14
Cast Bronze Threaded Fittings, Class 125 and 250 [Note (1)]	ASME B16.15
Cast Copper Alloy Solder Joint Pressure Fittings	ASME B16.18
Wrought Copper and Copper Alloy Solder Joint Pressure Fittings	ASME B16.22
Cast Copper Alloy Pipe Flanges, Flanged Fittings, and Valves: Classes 150, 300, 600, 900, 1500, and 2500	ASME B16.24
Cast Copper Alloy Fittings for Flared Copper Tubes	ASME B16.26
Valves-Flanged, Threaded, and Welding End	ASME B16.34
Orifice Flanges, Class 300, 600, 900, 1500, and 2500	ASME B16.36
Malleable Iron Threaded Pipe Unions, Class 150, 250, and 300	ASME B16.39
Ductile Iron Pipe Flanges and Flanged Fittings, Class 150 and 300	ASME B16.42
Large Diameter Steel Flanges, NPS 26 Through NPS 60	ASME B16.47
Brazing Joints for Copper and Copper Alloy Pressure Fittings	ASME B16.48 ASME B16.50
Bioprocessing Equipment [Note (2)]	ASME BPE
Pipeline Valves [Note (3)]	API 6D
Flanged Steel Pressure-Relief Valves	API 526
Check Valves: Flanged, Lug, Wafer and Butt-welding	API 594
Metal Plug Valves—Flanged, Threaded, and Welding Ends	API 599
Bolted Bonnet Steel Gate Valves for Petroleum and Natural Gas Industries	API 600
Gate, Globe, and Check Valves for Sizes DN 100 and Smaller for the Petroleum and Natural Gas Industries	API 602
Corrosion-Resistant, Bolted Bonnet Gate Valves — Flanged and Butt-Welding Ends	API 603
Metal Ball Valves-Flanged, Threaded, and Welding End	API 608
Butterfly Valves: Double-flanged, Lug- and Wafer-type	API 609
Ductile-Iron and Gray-Iron Fittings, 3 Inch Through 48 Inch (75 mm Through 1200 mm), for Water and Other	ANADAVA C440
Liquids	AWWA C110
Steel Pipe Flanges for Waterworks Service, Sizes 4 inch Through 144 inch (100 mm Through 3,600 mm)	AWWA C115 AWWA C207
Dimensions for Fabricated Steel Water Pipe Fittings.	AWWA C207 AWWA C208
Metal-Seated Gate Valves for Water Supply Service	AWWA C200
Rubber-Seated Butterfly Valves	AWWA C504
Standard Finishes for Contact Faces of Pipe Flanges and Connecting-End Flanges of Valves and Fittings	MSS SP-6
Spot Facing for Bronze, Iron and Steel Flanges	MSS SP-9
Standard Marking Systems for Valves, Fittings, Flanges, and Unions	MSS SP-25
Class 150 (PN 20) Corrosion Resistant Gate, Globe, Angle and Check Valves With Flanged and Butt Weld Ends	MSS SP-42
Wrought Stainless Steel Butt-Welding Fittings Including Reference to Other Corrosion Resistant Materials [Note (4)]	MSS SP-43
Steel Pipeline Flanges	MSS SP-44
Bypass and Drain Connections	MSS SP-45
Class 150LW Corrosion Resistant Flanges and Cast Flanged Fittings	MSS SP-51
High Pressure Chemical Industry Flanges and Threaded Stubs for Use with Lens Gaskets	MSS SP-65
Gray Iron Gate Valves, Flanged and Threaded Ends	MSS SP-70 MSS SP-71
Ball Valves With Flanged or Buttwelding Ends for General Service	MSS SP-71 MSS SP-72
Specifications for High Test Wrought Buttwelding Fittings	MSS SP-72 MSS SP-75
	MSS SP-78
Grav Iron Pillg Valves. Flanged and Inreaded Finds	11100 01 7 0
Gray Iron Plug Valves, Flanged and Threaded Ends	MSS SP-79

Table 326.1 Component Standards (Cont'd)

Standard or Specification	Designation
Metallic Fittings, Valves, and Flanges (Cont'd)	
Stainless Steel, Bonnetless, Flanged, Knife Gate Valves Class 3000 Steel Pipe Unions, Socket-Welding and Threaded	MSS SP-83 MSS SP-85 MSS SP-88 MSS SP-95 MSS SP-97 MSS SP-105 MSS SP-106
Refrigeration Tube Fittings — General Specifications	SAE J513 SAE J514
Metallic Pipe and Tubes [Note (6)]	
Welded and Seamless Wrought Steel Pipe. Stainless Steel Pipe	ASME B36.19M AWWA C115 AWWA C150 AWWA C151
Miscellaneous	
Unified Inch Screw Threads (UN and UNR Thread Form) Pipe Threads, General Purpose (Inch) Dryseal Pipe Threads (Inch) Hose Coupling Screw Threads (Inch) Metallic Gaskets for Pipe Flanges — Ring: Joint, Spiral Wound, and Jacketed Nonmetallic Flat Gaskets for Pipe Flanges Buttwelding Ends Surface Texture (Surface Roughness, Waviness, and Lay) Thermowells [Note (7)]. Specification for Threading, Gaging and Thread Inspection of Casing, Tubing, and Line Pipe Threads	ASME B1.20.1 ASME B1.20.3 ASME B1.20.7 ASME B16.20 ASME B16.21 ASME B16.25 ASME B46.1 ASME PTC 19.3 TW
Rubber Gasket Joints for Ductile-Iron Pressure Pipe and Fittings. Grooved and Shouldered Joints [Note (8)]	AWWA C606 BS 6501, Part 1 MSS SP-58

GENERAL NOTES:

- (a) It is not practical to refer to a specific edition of each standard throughout the Code text. Instead, the approved edition references, along with the names and addresses of the sponsoring organizations, are shown in Appendix E.
- (b) Many of the listed standards allow the use of unlisted materials; see para. 323.1.2.

NOTES:

- (1) This standard allows straight pipe threads in sizes \leq DN 15 (NPS $\frac{1}{2}$); see para. 314.2.1(d).
- (2) Part DT of ASME BPE covers dimensions and tolerances for stainless steel automatic welding and hygienic clamp tube fittings and process components.
- (3) API 6D allows design and calculations for pressure-containing elements to be in accordance with various internationally recognized design codes or standards. Only API 6D valves with design and calculations for pressure-containing elements in accordance with ASME B16.34 are considered a "listed component" for the purpose of this Code.
- (4) Cautionary Note: See MSS SP-43 (Section 3) for specific pressure–temperature ratings of available thicknesses of Class CR fittings. The ratings for MSS SP-43 fittings cannot be calculated based on straight seamless pipe such as is done, for example, for ASME B16.9 buttwelding fittings.

Table 326.1 Component Standards (Cont'd)

NOTES (Cont'd):

- (5) MSS SP-119 includes three classes of fittings: MP, MARINE, and CR. Only the MP class fittings are considered a "Listed Component" for the purpose of this Code. *Cautionary Note*: See MSS SP-119 (Section 6) for special provisions concerning ratings. (In accordance with MSS SP-119, the pressure ratings for MP class fittings are 87.5% of those calculated for straight seamless pipe of *minimum* wall thickness.)
- (6) See also Appendix A.
- (7) ASME PTC 19.3 TW allows mechanical design of thermowells to be in accordance with various design codes. Only PTC 19.3 TW thermowells with design and calculations for pressure-containing elements in accordance with ASME B31.3 are considered a "listed component" for the purpose of this Code.
- (8) For use with this Code, the rated pressure of components covered by this standard shall be based on no greater than one-third the hydrostatic test failure pressure (the pressure at fracture or leakage), rather than one-half the hydrostatic test failure pressure specified in AWWA C606.
- (9) Welding and brazing to be in accordance with paras. 328 and 333, respectively in lieu of the referenced specifications in this standard.
- (10) This standard contains recommended materials of construction for certain chemical services; the responsibility for the ultimate selection of material is the responsibility of the Owner and is, therefore, not within the scope of this Code.

Chapter V Fabrication, Assembly, and Erection

327 GENERAL

Metallic piping materials and components are prepared for assembly and erection by one or more of the fabrication processes covered in paras. 328, 330, 331, 332, and 333. When any of these processes is used in assembly or erection, requirements are the same as for fabrication.

328 WELDING AND BRAZING

Welding and brazing shall conform to the requirements of this Chapter and the applicable requirements of para. 311.2.

328.1 Responsibility

Each employer is responsible for

- (a) the welding and brazing performed by personnel of its organization
- (*b*) conducting the qualification tests required to qualify the welding or brazing procedure specifications used by personnel in its organization, except as provided in paras. 328.2.1 and 328.2.2
- (c) conducting the qualification tests required to qualify the welders, brazers, and operators, except as provided in para. 328.2.3

328.2 Welding and Brazing Qualification

Welding and brazing procedure specifications (WPSs and BPSs) to be followed in production welding shall be prepared and qualified, and welders, brazers, and operators shall be qualified as required by the ASME BPV Code, Section IX except as modified by para. 333 for brazing of Category D Fluid Service piping and by the following subparagraphs.

- **328.2.1 Standard Welding Procedure Specifications.** Standard welding procedure specifications published by the American Welding Society and listed in Mandatory Appendix E of Section IX are permitted for Code construction within the limitations established by Article V of Section IX.
- **328.2.2 Procedure Qualification by Others.** In order to avoid duplication of effort and subject to the approval of the owner, WPSs and BPSs qualified by a technically competent group or agency may be used provided the following are met:
- (a) The procedures meet the requirements of Section IX and any additional qualification requirements of this Code.

- (b) The employer has qualified at least one welder, brazer, or operator following each WPS or BPS.
- (c) The employer's business name shall be shown on each WPS and BPS, and on each qualification record. In addition, qualification records shall be signed and dated by the employer, thereby accepting responsibility for the qualifications performed by others.

328.2.3 Performance Qualification by Others. In order to avoid duplication of effort and subject to the approval of the owner, an employer may accept the performance qualification of a welder, brazer, or operator made by a previous employer. This acceptance is limited to performance qualifications that were made on pipe or tube test coupons. The new employer shall have the WPS or BPS that was followed during qualification or an equivalent WPS or BPS that is within the limits of the essential variables set forth in Section IX. An employer accepting such qualification tests shall obtain a copy of the performance qualification test record from the previous employer. The record shall show the name of the employer by whom the welder, brazer, or operator was qualified and the date of that qualification. Evidence shall also be provided that the welder, brazer, or operator has maintained qualification in accordance with QW-322 and QB-322 of Section IX, except that this evidence may be provided by an employer responsible for the individual's welding or brazing performance even if not the original qualifying employer. The new employer's business name shall be shown on the qualification record, and it shall be signed and dated by the employer, thereby accepting responsibility for the qualifications performed by others.

328.2.4 Qualification Records. The employer shall maintain copies of the procedure and performance qualification records specified by Section IX that shall be available to the Inspector at the location where welding is being done.

328.3 Welding Materials

328.3.1 Electrodes and Filler Metal. Welding electrodes and filler metal, including consumable inserts, shall conform to the requirements of the ASME Boiler and Pressure Vessel Code, Section II, Part C. An electrode or filler metal not conforming to the above may be used provided the WPS and the welders who will follow the WPS have been qualified as required by ASME Section IX. Unless otherwise specified by the

Designer, welding electrodes and filler metals used shall produce weld metal that complies with the following:

- (a) The nominal tensile strength of the weld metal shall equal or exceed the minimum specified tensile strength of the base metals being joined, or the weaker of the two if base metals of two different strengths are being joined.
- (b) The nominal chemical analysis of the weld metal shall be similar to the nominal chemical analysis of the major alloying elements of the base metal (e.g., $2\frac{1}{4}$ % Cr, 1% Mo steels should be joined using $2\frac{1}{4}$ % Cr, 1% Mo filler metals).
- (c) If base metals of different chemical analysis are being joined, the nominal chemical analysis of the weld metal shall be similar to either base metal or an intermediate composition, except as specified below for austenitic steels joined to ferritic steels.
- (*d*) When austenitic steels are joined to ferritic steels, the weld metal shall have a predominantly austenitic microstructure.
- (e) For nonferrous metals, the weld metal shall be that recommended by the manufacturer of the nonferrous base metal or by industry associations for that metal.

328.3.2 Weld Backing Material. When backing rings are used, they shall conform to the following:

- (a) Ferrous Metal Backing Rings. These shall be of weldable quality. Sulfur content shall not exceed 0.05%.
- (b) If two abutting surfaces are to be welded to a third member used as a backing ring and one or two of the three members are ferritic and the other member or members are austenitic, the satisfactory use of such materials shall be demonstrated by welding procedure qualified as required by para. 328.2.

Backing rings may be of the continuous machined or split-band type. Some commonly used types are shown in Fig. 328.3.2.

- (c) Nonferrous and Nonmetallic Backing Rings. Backing rings of nonferrous or nonmetallic material may be used, provided the designer approves their use and the welding procedure using them is qualified as required by para. 328.2.
- **328.3.3 Consumable Inserts.** Consumable inserts may be used, provided they are of the same nominal composition as the filler metal, will not cause detrimental alloying of the weld metal, and the welding procedure using them is qualified as required by para. 328.2. Some commonly used types are shown in Fig. 328.3.2.

328.4 Preparation for Welding

328.4.1 Cleaning. Internal and external surfaces to be thermally cut or welded shall be clean and free from paint, oil, rust, scale, and other material that would be detrimental to either the weld or the base metal when heat is applied.

328.4.2 End Preparation


- (a) General
- (1) End preparation is acceptable only if the surface is reasonably smooth and true, and slag from oxygen or arc cutting is cleaned from thermally cut surfaces. Discoloration remaining on a thermally cut surface is not considered detrimental oxidation.
- (2) End preparation for groove welds specified in ASME B16.25, or any other that meets the WPS, is acceptable. [For convenience, the basic bevel angles of ASME B16.25 and some additional J-bevel angles are shown in Fig. 328.4.2, illustrations (a) and (b).]
 - (b) Circumferential Welds
- (1) If component ends are trimmed as shown in Fig. 328.3.2, illustration (a) or (b) to fit backing rings or consumable inserts, or as shown in Fig. 328.4.3, illustration (a) or (b) to correct internal misalignment, such trimming shall not reduce the finished wall thickness below the required minimum wall thickness, t_m .
- (2) Component ends may be bored to allow for a completely recessed backing ring, provided the remaining net thickness of the finished ends is not less than t_m .
- (3) It is permissible to size pipe ends of the same nominal size to improve alignment if wall thickness requirements are maintained.
- (4) Where necessary, weld metal may be deposited inside or outside of the component to permit alignment or provide for machining to ensure satisfactory seating of rings or inserts.
- (5) When a girth or miter groove weld joins components of unequal wall thickness and one is more than $1\frac{1}{2}$ times the thickness of the other, end preparation and geometry shall be in accordance with acceptable designs for unequal wall thickness in ASME B16.25.
- (6) Buttweld fittings manufactured in accordance with ASME B16.9 may be trimmed to produce an angular joint offset in their connections to pipe or to other buttweld fittings without being subject to design qualifications in accordance with para. 304.7.2 provided the total angular offset produced between the two jointed parts does not exceed 3 deg.

328.4.3 Alignment

(16)

- (a) Circumferential Welds
- (1) Inside surfaces of components at ends to be joined in girth or miter groove welds shall be aligned within the dimensional limits in the WPS and the engineering design.
- (2) If the external surfaces of the components are not aligned, the weld shall be tapered between them.
- (b) Longitudinal Welds. Alignment of longitudinal groove welds (not made in accordance with a standard listed in Table A-1, Table A-1M, or Table 326.1) shall conform to the requirements of para. 328.4.3(a).

Fig. 328.3.2 Typical Backing Rings and Consumable Inserts



NOTE:

(1) Refer to ASME B16.25 for detailed dimensional information on welding ends.

Fig. 328.4.2 Typical Butt Weld End Preparation





Fig. 328.4.4 Preparation for Branch Connections



g = root gap per welding specification m = the lesser of 3.2 mm ($^{1}/_{8}$ in.) or 0.5 \overline{T}_{b}

(c) Branch Connection Welds

- (1) Branch connections that abut the outside surface of the run pipe shall be contoured for groove welds that meet the WPS requirements [see Fig. 328.4.4, illustrations (a) and (b)].
- (2) Branch connections that are inserted through a run opening shall be inserted at least as far as the inside surface of the run pipe at all points [see Fig. 328.4.4, illustration (c)] and shall otherwise conform to para. 328.4.3(c)(1).
- (3) Run openings for branch connections shall not deviate from the required contour more than the dimension *m* in Fig. 328.4.4. In no case shall deviations of the shape of the opening cause the root spacing tolerance limits in the WPS to be exceeded. Weld metal may be added and refinished if necessary for compliance.
- (d) Spacing. The root opening of the joint shall be within the tolerance limits in the WPS.

328.5 Welding Requirements

328.5.1 General


- (a) Welds, including addition of weld metal for alignment [paras. 328.4.2(b)(4) and 328.4.3(c)(3)], shall be made in accordance with a qualified procedure and by qualified welders or welding operators.
- (b) Each qualified welder and welding operator shall be assigned an identification symbol. Unless otherwise specified in the engineering design, each pressurecontaining weld or adjacent area shall be marked with the identification symbol of the welder or welding operator. In lieu of marking the weld, appropriate records shall be filed.
- (c) Tack welds at the root of the joint shall be made with filler metal equivalent to that used in the root pass. Tack welds shall be made by a qualified welder or welding operator. Tack welds shall be fused with the root pass weld, except that those that have cracked shall be removed. Bridge tacks (above the weld) shall be removed.

- (*d*) Peening is prohibited on the root pass and final pass of a weld.
- (e) No welding shall be done if there is impingement on the weld area of rain, snow, sleet, or excessive wind, or if the weld area is frosted or wet.
- (f) Welding End Valves. The welding sequence and procedure and any heat treatment for a welding end valve shall be such as to preserve the seat tightness of the valve.
- **328.5.2 Fillet and Socket Welds.** Fillet welds (including socket welds) may vary from convex to concave. The size of a fillet weld is determined as shown in Fig. 328.5.2A.
- (a) Typical weld details for slip-on and socket welding flanges are shown in Fig. 328.5.2B; minimum welding dimensions for other socket welding components are shown in Fig. 328.5.2C or MSS SP-119.
- (b) If slip-on flanges are single welded, the weld shall be at the hub.
- **328.5.3 Seal Welds.** Seal welding shall be done by a qualified welder. Seal welds shall cover all exposed threads.

328.5.4 Welded Branch Connections

- (a) Figures 328.5.4A through 328.5.4F show acceptable details of branch connections with and without added reinforcement, in which the branch pipe is connected directly to the run pipe. The illustrations are typical and are not intended to exclude acceptable types of construction not shown.
- (b) Figure 328.5.4D shows basic types of weld attachments used in the fabrication of branch connections. The location and minimum size of attachment welds shall conform to the requirements herein. Welds shall be calculated in accordance with para. 304.3.3 but shall be not less than the sizes shown in Fig. 328.5.4D. Figure 328.5.4F shows the basic types of attachment welds used with integrally reinforced branch connection fittings. The


Fig. 328.5.2A Fillet Weld Size



GENERAL NOTE: The size of an equal leg fillet weld is the leg length of the largest inscribed isosceles right triangle (theoretical throat $= 0.707 \times \text{size}$).


GENERAL NOTE: The size of unequal leg fillet weld is the leg lengths of the largest right triangle which can be inscribed within the weld cross section [e.g., 13 mm \times 19 mm ($\frac{1}{2}$ in. \times $\frac{3}{4}$ in.)].

Fig. 328.5.2B Typical Details for Double-Welded Slip-On and Socket Welding Flange Attachment Welds



 X_{\min} = the lesser of 1.4 \overline{T} or the thickness of the hub

Fig. 328.5.2C Minimum Welding Dimensions for Socket Welding Components Other Than Flanges



Figs. 328.5.4A, B, C Typical Welded Branch Connections





Fig. 328.5.4D Acceptable Details for Branch Attachment Welds



GENERAL NOTE: These sketches show minimum acceptable welds. Welds may be larger than those shown here.

Fig. 328.5.4E Acceptable Details for Branch Attachment Suitable for 100% Radiography





Fig. 328.5.4F Acceptable Details for Integrally Reinforced Branch Connections



GENERAL NOTE: Welds shall be in accordance with para. 328.5.4(i). NOTES:

- (1) Cover fillet weld shall provide a smooth transition to the run pipe with an equal leg fillet at the longitudinal section to an equal leg fillet, unequal (oblique) leg fillet, or groove butt joint at the transverse section (depending on branch connection size).
- (2) Heat treatment requirements shall be in accordance with para. 331.1.3(a).
- (3) Cover fillet weld shall provide a smooth transition to the run pipe with an equal leg fillet at the crotch in the longitudinal section to an equal leg filet, unequal (oblique) leg fillet, or groove butt joint at the transverse section (depending on branch connection size) to nothing at the heel of the branch connection fitting in the longitudinal section.

location and the minimum size of the attachment welds shall conform to the requirements of subpara. (i) below.

(c) The nomenclature and symbols used herein, in Fig. 328.5.4D, and in Fig. 328.5.4F are

 \overline{T}_b = nominal thickness of branch

 \overline{T}_h = nominal thickness of header

- \overline{T}_m = nominal thickness of the branch weld for integrally reinforced branch connection fittings, either
 - (1) as specified by the manufacturer of the branch connection fitting
 - (2) the full depth of the resultant weld groove, after fit-up, if no manufacturer's weld thickness is specified
 - (3) as documented and specified in the engineering design in accordance with para. 300(c)(3), or
 - (4) calculated and documented in accordance with the requirements of para. 304.7.2

 \overline{T}_r = nominal thickness of reinforcing pad or saddle

 $t_c = \text{lesser of } 0.7\overline{T}_b \text{ or } 6 \text{ mm } (\frac{1}{4} \text{ in.})$

 $t_{\min} = \text{lesser of } \overline{T}_b \text{ or } \overline{T}_r$

- (*d*) Branch connections, including branch connection fittings (see paras. 300.2 and 304.3.2), that abut the outside of the run or that are inserted in an opening in the run shall be attached by fully penetrated groove welds. The welds shall be finished with cover fillet welds having a throat dimension not less than t_c . See Fig. 328.5.4D, illustrations (1) and (2).
- (e) A reinforcing pad or saddle shall be attached to the branch pipe by either
- (1) a fully penetrated groove weld finished with a cover fillet weld having a throat dimension not less than t_{cr} or
- (2) a fillet weld having a throat dimension not less than $0.7t_{\text{min}}$. See Fig. 328.5.4D, illustration (5).
- (f) The outer edge of a reinforcing pad or saddle shall be attached to the run pipe by a fillet weld having a throat dimension not less than $0.5\overline{T}_r$. See Fig. 328.5.4D, illustrations (3), (4), and (5).
- (g) Reinforcing pads and saddles shall have a good fit with the parts to which they are attached. A vent hole shall be provided at the side (not at the crotch) of any pad or saddle to reveal leakage in the weld between branch and run and to allow venting during welding and heat treatment. A pad or saddle may be made in more than one piece if joints between pieces have strength equivalent to pad or saddle parent metal, and if each piece has a vent hole.
- (h) Examination and any necessary repairs of the completed weld between branch and run shall be made before adding a pad or saddle.
- (i) Figure 328.5.4F shows additional integrally reinforced branch connections typical of MSS SP-97 fittings that abut the outside of the run attached by a full penetration groove weld. The welds shall be finished with

cover fillets having a throat dimension not less than t_c . The cover fillet weld shall fill and smoothly transition to the attachment weld and run pipe or fitting.

328.5.5 Fabricated Laps. Figure 328.5.5 shows typical fabricated laps. Fabrication shall be in accordance with the applicable requirements of para. 328.5.4.

328.5.6 Welding for Severe Cyclic Conditions. A welding procedure shall be employed that provides a smooth, regular, fully penetrated inner surface.

328.6 Weld Repair

A weld defect to be repaired shall be removed to sound metal. Repair welds shall be made using a welding procedure qualified in accordance with para. 328.2.1, recognizing that the cavity to be repaired may differ in contour and dimensions from the original joint. Repair welds shall be made by welders or welding operators qualified in accordance with para. 328.2.1. Preheating and heat treatment shall be as required for the original welding. See also para. 341.3.3.

328.7 Attachment Welds

Structural attachments may be made by complete penetration, partial penetration, or fillet welds.

Low energy capacitor discharge welding may be used for welding temporary attachments (e.g., thermocouples) and permanent nonstructural attachments without preheat above 10°C (50°F) or subsequent postweld heat treatment on P-No. 1 through P-No. 5B and P-No. 15E materials, provided

- (a) a Welding Procedure Specification is prepared, describing the low energy capacitor discharge equipment, the combination of materials to be joined, and the technique of application; qualification of the welding procedure is not required
- (b) the energy output of the welding process is limited to 125 W-sec
- (*c*) for P-No. 5A, P-No. 5B, and P-No. 15E materials, the maximum carbon content of the material is 0.15%
- (*d*) after thermocouples are removed, the areas shall be visually examined for evidence of defects to be repaired

330 PREHEATING

330.1 General

The preheat requirements herein apply to all types of welding, including tack welds, repair welds, and seal welds on threaded joints.

330.1.1 Requirements. Unless specified otherwise in the engineering design, the minimum preheat temperatures for materials of various P-Numbers are given in Table 330.1.1. The thickness intended in Table 330.1.1 is that of the nominal thickness of the thicker component [as defined in para. 331.1.3(c)]. Higher minimum preheat

GENERAL NOTE: Laps shall be machined (front and back) or trued after welding. Plate flanges in accordance with para. 304.5 or lap joint flanges in accordance with ASME B16.5 may be used. Welds may be machined to radius, as in sketch (e), if necessary to match ASME B16.5 lap joint flanges.

Table 330.1.1 Preheat Temperatures

				•			
Base Metal P-No.		Greater Material Thickness		Additional Limits	Required Minimum Temperature		
[Note (1)]	Base Metal Group	mm	in.	[Note (2)]	°C	°F	
1	Carbon steel	≤25	≤1	None	10	50	
		>25	>1	%C ≤ 0.30 [Note (3)]	10	50	
		>25	>1	%C > 0.30 [Note (3)]	95	200	
3	Alloy steel, $Cr \leq \frac{1}{2}\%$	≤13	$\leq^{1}/_{2}$	SMTS ≤ 450 MPa (65 ksi)	10	50	
		>13	$>^{1}/_{2}$	$SMTS \le 450 MPa (65 ksi)$	95	200	
		All	All	SMTS > 450 MPa (65 ksi)	95	200	
4	Alloy steel, $\frac{1}{2}\%$ < Cr \leq 2%	All	All	None	120	250	
5A	Alloy steel	All	All	SMTS ≤ 414 MPa (60 ksi)	150	300	
		All	All	SMTS > 414 MPa (60 ksi)	200	400	
5B	Alloy steel	All	All	SMTS ≤ 414 MPa (60 ksi)	150	300	
		All	All	SMTS > 414 MPa (60 ksi)	200	400	
		≤13	$\leq^{1}/_{2}$	%Cr > 6.0 [Note (3)]	200	400	
6	Martensitic stainless steel	All	All	None	200 [Note (4)]	400 [Note (4)]	
9A	Nickel alloy steel	All	All	None	120	250	
9B	Nickel alloy steel	All	All	None	150	300	
101	27Cr steel	All	All	None	150 [Note (5)]	300 [Note (5)]	
15E	9Cr-1Mo-V CSEF steel	All	All	None	200	400	
	All other materials			None	10	50	

NOTES:

- (1) P-Nos. and Group Nos. from BPV Code, Section IX, QW/QB-422.
- (2) SMTS = Specified Minimum Tensile Strength.
- (3) Composition may be based on ladle or product analysis or in accordance with specification limits.
- (4) Maximum interpass temperature 315°C (600°F).
- (5) Maintain interpass temperature between 150°C and 230°C (300°F and 450°F).

(16)

temperatures may be required by the WPS or by the engineering design.

330.1.2 Unlisted Materials. Preheat requirements for an unlisted material shall be specified in the WPS.

330.1.3 Preheat Temperature Verification

- (a) Preheat temperature shall be checked by use of temperature indicating crayons, thermocouple pyrometers, or other suitable means to ensure that the temperature specified in the WPS is obtained prior to and maintained during welding.
- (b) Thermocouples may be temporarily attached directly to pressure-containing parts using the low energy capacitor discharge method of welding in accordance with para. 328.7.
- **330.1.4 Preheat Zone.** The preheat zone shall be at or above the specified minimum temperature in all directions from the point of welding for a distance of the larger of 75 mm (3 in.) or 1.5 times the greater nominal thickness.

The base metal temperature for tack welds shall be at or above the specified minimum temperature for a distance not less than 25 mm (1 in.) in all directions from the point of welding.

330.2 Specific Requirements

- **330.2.1 Different P-No. Materials.** When welding two different P-No. materials, the preheat temperature shall be the higher temperature for the material being welded as shown in Table 330.1.1.
- **330.2.2 Interruption of Welding.** After welding commences, the minimum preheat temperature shall be maintained until any required PWHT is performed on P-Nos. 3, 4, 5A, 5B, 6, and 15E, except when all of the following conditions are satisfied:
- (a) A minimum of at least 10 mm ($\frac{3}{8}$ in.) thickness of weld is deposited or 25% of the welding groove is filled, whichever is less (the weld shall be sufficiently supported to prevent overstressing the weld if the weldment is to be moved or otherwise loaded). Caution is advised that the surface condition prior to cooling should be smooth and free of sharp discontinuities.
- (b) For P-Nos. 3, 4, and 5A materials, the weld is allowed to cool slowly to room temperature.
- (c) For P-Nos. 5B, 6, and 15E materials, the weld is subjected to an adequate intermediate heat treatment with a controlled rate of cooling. The preheat temperature may be reduced to 95°C (200°F) (minimum) for the purpose of root examination without performing an intermediate heat treatment. Intermediate heat treatment for P-No. 5B or P-No. 15E materials may be omitted when using low-hydrogen electrodes and filler metals classified by the filler metal specification with an optional supplemental diffusible-hydrogen designator of H4 or lower and suitably controlled by maintenance

- procedures to avoid contamination by hydrogenproducing sources. The surface of the base metal prepared for welding shall be free of contaminants.
- (*d*) After cooling and before welding is resumed, visual examination of the weld shall be performed to assure that no cracks have formed.
- (e) Required preheat shall be applied before welding is resumed.

331 HEAT TREATMENT

331.1 General

331.1.1 Postweld Heat Treatment Requirements

- (a) PWHT shall be in accordance with the material groupings (P-Nos. and Group Nos.) and ranges in Table 331.1.1 except as provided in Table 331.1.2 and Table 331.1.3. The P-Numbers and Group Numbers are defined in ASME BPV Code, Section IX, Table QW/QB-422. (Note that the P-Nos. are also listed in Appendix A.)
- (b) The PWHT to be used after production welding shall be specified in the WPS and shall be used in qualifying the welding procedure.
- (c) The engineering design shall specify the examination and/or other production quality control (not less than the requirements of this Code) to ensure that the final welds are of adequate quality.

331.1.2 Other Heat Treatments

- (a) Heat treatment for bending and forming shall be in accordance with para. 332.4.
- (b) See Table 302.3.5 for special heat treatment requirements for longitudinal or spiral (helical seam) welds in Elevated Temperature Fluid Service.

331.1.3 Definition of Thicknesses Governing PWHT

- (a) The term control thickness as used in Table 331.1.1 and Table 331.1.3 is the lesser of
 - (1) the thickness of the weld
- (2) the thickness of the materials being joined at the weld or the thickness of the pressure-containing material if the weld is attaching a nonpressurecontaining material to a pressure-containing material.
- (*b*) Thickness of the weld, which is a factor in determining the control thickness, is defined as follows:
- (1) groove welds (girth and longitudinal) the thicker of the two abutting ends after weld preparation, including I.D. machining
 - (2) fillet welds the throat thickness of the weld
- (3) partial penetration welds the depth of the weld groove
- (4) material repair welds the depth of the cavity to be repaired
- (5) branch welds the dimension existing in the plane intersecting the longitudinal axes, calculated as indicated for each detail using the thickness through the weld for the details shown in Fig. 328.5.4D and

Table 331.1.1 Postweld Heat Treatment

P-No. and Group No.	Holding Temperature Range,	Minimum Holding Time at Temperature for Control Thickness [Note (2)]			
(BPV Code Section IX, QW/QB-420)	°C (°F) [Note (1)]	Up to 50 mm (2 in.)	Over 50 mm (2 in.)		
P-No. 1, Group Nos. 1–3	595 to 650 (1,100 to 1,200)	1 h/25 mm (1 hr/in.);	2 hr plus 15 min for each		
P-No. 3, Group Nos. 1 and 2	595 to 650 (1,100 to 1,200)	15 min min.	additional 25 mm (in.)		
P-No. 4, Group Nos. 1 and 2	650 to 705 (1,200 to 1,300)		over 50 mm (2 in.)		
P-No. 5A, Group No. 1	675 to 760 (1,250 to 1,400)				
P-No. 5B, Group No. 1	675 to 760 (1,250 to 1,400)				
P-No. 6, Group Nos. 1-3	760 to 800 (1,400 to 1,475)				
P-No. 7, Group Nos. 1 and 2 [Note (3)]	730 to 775 (1,350 to 1,425)				
P-No. 8, Group Nos. 1-4	PWHT not required unless required by WPS				
P-No. 9A, Group No. 1	595 to 650 (1,100 to 1,200)				
P-No. 9B, Group No. 1	595 to 650 (1,100 to 1,200)				
P-No. 10H, Group No. 1	PWHT not required unless required by WPS. If done, see Note (4).				
P-No. 10I, Group No. 1 [Note (3)]	730 to 815 (1,350 to 1,500)				
P-No. 11A	550 to 585 (1,025 to 1,085) [Note (5)]				
P-No. 15E, Group No. 1	705 to 775 (1,300 to 1,425) [Notes (6) and (7)]	1 h/25 mm (1 hr/in.); 30 min min.	1 h/25 mm (1 hr/in.) up to 125 mm (5 in.) plus 15 min for each addi- tional 25 mm (in.) over 125 mm (5 in.)		
P-No. 62	540 to 595 (1,000 to 1,100)		See Note (8)		
All other materials	PWHT as required by WPS	In accordance with WPS	In accordance with WPS		

GENERAL NOTE: The exemptions for mandatory PWHT are defined in Table 331.1.3.

NOTES:

- (1) The holding temperature range is further defined in para. 331.1.6(c) and Table 331.1.2.
- (2) The control thickness is defined in para. 331.1.3.
- (3) Cooling rate shall not be greater than 55°C (100°F) per hour in the range above 650°C (1,200°F), after which the cooling rate shall be sufficiently rapid to prevent embrittlement.
- (4) If PWHT is performed after welding, it shall be within the following temperature ranges for the specific alloy, followed by rapid cooling: Alloys S31803 and S32205 1 020°C to 1 100°C (1,870°F to 2,010°F)

Alloy S32550 - 1 040°C to 1 120°C (1,900°F to 2,050°F)

Alloy S32750 - 1 025°C to 1 125°C (1,880°F to 2,060°F)

All others -980° C to 1 040°C (1,800°F to 1,900°F).

- (5) Cooling rate shall be >165°C (300°F)/h to 315°C (600°F)/h.
- (6) The minimum PWHT holding temperature may be 675°C (1,250°F) for nominal material thicknesses [see para. 331.1.3(c)] ≤13 mm (½ in.).
- (7) The Ni + Mn content of the filler metal shall not exceed 1.2% unless specified by the designer, in which case the maximum temperature to be reached during PWHT shall be the A_1 (lower transformation or lower critical temperature) of the filler metal, as determined by analysis and calculation or by test, but not exceeding 800°C (1,470°F). If the 800°C (1,470°F) limit was not exceeded but the A_1 of the filler metal was exceeded or if the composition of the filler metal is unknown, the weld must be removed and replaced. It shall then be rewelded with compliant filler metal and subjected to a compliant PWHT. If the 800°C (1,470°F) limit was exceeded, the weld and the entire area affected by the PWHT will be removed and, if reused, shall be renormalized and tempered prior to reinstallation.
- (8) Heat treat within 14 days after welding. Hold time shall be increased by 1.2 h for each 25 mm (1 in.) over 25 mm (1 in.) thickness. Cool to 425°C (800°F) at a rate ≤280°C (500°F).

Table 331.1.2 Alternate Postweld Heat Treatment Requirements for Carbon and Low Alloy Steels, P-Nos. 1 and 3

Decrease in Specified Minimum Temperature, °C (°F)	Minimum Holding Time at Decreased Temperature, h [Note (1)]
30 (50)	2
55 (100)	4
85 (150) [Note (2)]	10
110 (200) [Note (2)]	20

NOTES:

- (1) Times shown apply to thicknesses ≤25 mm (1 in.). Add 15 min/25 mm (15 min/in.) of thickness for control thicknesses >25 mm (1 in.) (see para. 331.1.3).
- (2) A decrease >55°C (100°F) below the minimum specified temperature is allowable only for P-No. 1, Group Nos. 1 and 2 materials.

Fig. 328.5.4F. This thickness shall be computed using the following formulas:

illustration (1) =
$$\overline{T}_b + t_c$$

illustration (2) = $\overline{T}_h + t_c$
illustration (3) = greater of $\overline{T}_b + t_c$ or $\overline{T}_r + t_c$
illustration (4) = $\overline{T}_h + \overline{T}_r + t_c$
illustration (5) = $\overline{T}_b + t_c$

- (-b) for Fig. 328.5.4F use $\overline{T}_m + t_c$ for all illustrations (c) The term *nominal material thickness* as used in Table 331.1.3 is the thicker of the materials being joined at the weld.
- **331.1.4 Heating and Cooling.** The heating method shall provide the required metal temperature, metal temperature uniformity, and temperature control, and may include an enclosed furnace, local flame heating, electric resistance, electric induction, or exothermic chemical reaction. Above 315°C (600°F), the rate of heating and cooling shall not exceed 335°C/h (600°F/hr) divided by one-half the maximum material thickness in inches at the weld, but in no case shall the rate exceed 335°C/h (600°F/hr). See Table 331.1.1 for cooling rate requirements for P-Nos. 7, 10I, 11A, and 62 materials.
- **331.1.6 Temperature Verification.** Heat treatment temperature shall be checked by thermocouple pyrometers or other suitable methods to ensure that the WPS requirements are met. See para. 328.7 for attachment of thermocouples by the low energy capacitor discharge method of welding.
- (a) If used, the heat treatment furnace shall be calibrated such that the PWHT can be controlled within the required temperature range.

- (b) Any required PWHT shall be as required by the qualified WPS.
- (c) For welds that require PWHT in accordance with Table 331.1.1, the temperature of the material during PWHT shall be within the range specified. However, if specified by the designer, the range may be extended as permitted by Table 331.1.2, provided the lower critical temperature of the material is not exceeded.

331.2 Specific Requirements

Where warranted by experience or knowledge of service conditions, alternative methods of heat treatment or exceptions to the basic heat treatment provisions of para. 331.1 may be adopted as provided in paras. 331.2.1 and 331.2.2.

331.2.1 Alternative Heat Treatment. Normalizing, or normalizing and tempering, or annealing may be applied in lieu of the required heat treatment after welding, bending, or forming, provided that the mechanical properties of any affected weld and base metal meet specification requirements after such treatment and that the substitution is approved by the designer.

331.2.2 Exceptions to Basic Requirements. As indicated in para. 331, the basic practices therein may require modification to suit service conditions in some cases. In such cases, the designer may specify more stringent requirements in the engineering design, including heat treatment and hardness limitations for lesser thickness, or may specify less stringent heat treatment and hardness requirements, including none.

When provisions less stringent than those in para. 331 are specified, the designer must demonstrate to the owner's satisfaction the adequacy of those provisions by comparable service experience, considering service temperature and its effects, frequency and intensity of thermal cycling, flexibility stress levels, probability of brittle failure, and other pertinent factors. In addition, appropriate tests shall be conducted, including WPS qualification tests.

331.2.3 Dissimilar Materials

- (a) Heat treatment of welded joints between dissimilar ferritic metals or between ferritic metals using dissimilar ferritic filler metal shall be at the higher of the temperature ranges in Table 331.1.1 for the materials in the joint. This may require the use of material transition joint designs.
- (b) Heat treatment of welded joints including both ferritic and austenitic components and filler metals shall be as required for the ferritic material or materials unless otherwise specified in the engineering design.
- **331.2.4 Delayed Heat Treatment.** If a weldment is allowed to cool prior to heat treatment, the rate of cooling shall be controlled or other means shall be used to prevent detrimental effects in the piping.

 Table 331.1.3
 Exemptions to Mandatory Postweld Heat Treatment

P-No. and Group No. (BPV Code Section IX, QW/QB-420) [Note (1)]	Control Thickness, mm (in.) [Note (2)]	Type of Weld	Additional Limitations Required for Exemption From PWHT [Notes (3)–(5)]
P-No. 1, all Group Nos.	All	All	A preheat of 95°C (200°F) is applied prior to welding on any nominal mate rial thickness >25 mm (1 in.) Multiple layer welds are used when the nominal material thickness >5 mm (3/16 in.) [Note (6)]
P-No. 3, Group Nos. 1 and 2	≤16 mm (⁵ / ₈ in.)	All	A preheat of 95°C (200°F) is applied prior to welding on any nominal mate rial thickness >13 mm (½ in.) A specified carbon content of the base materials ≤0.25% Multiple layer welds are used when the nominal material thickness >5 mm (⅔/16 in.) [Note (6)]
P-No. 4, Group No. 1	≤16 mm (⁵ / ₈ in.)	Groove	Mandatory preheat has been applied Specified carbon content of the base materials ≤0.15% Multiple layer welds are used when the nominal material thickness >5 mm (⅔/16 in.) [Note (6)]
	≤16 mm (⁵ / ₈ in.) except the thickness of a socket weld fitting or flange need not be considered	Socket and fillet welds	Mandatory preheat has been applied Throat thickness of the fillet weld or the socket weld ≤13 mm (½ in.) Specified carbon content of the pipe material ≤0.15% Nominal material thickness of the pipe ≤16 mm (⅓ in.) Multiple layer welds are used when the nominal material thickness >5 mm (⅔ in.) [Note (6)]
	≤16 mm (5/ ₈ in.)	Seal welds and non-load-carrying attachments [Note (7)]	Mandatory preheat has been applied Multiple layer welds are used when the nominal material thickness >5 mm (3/16 in.) [Note (6)]
P-No. 5A, Group No. 1	≤16 mm (⁵ / ₈ in.)	Groove	Mandatory preheat has been applied Specified carbon content of the base materials ≤0.15% Multiple layer welds are used when the nominal material thickness
	≤16 mm (⁵ / ₈ in.) except the thickness of a socket weld fitting or flange need not be considered	Socket and fillet welds	>5 mm (³ / ₁₆ in.) [Note (6)] Mandatory preheat has been applied Throat thickness of the fillet weld or the socket weld ≤13 mm (¹ / ₂ in.) Specified carbon content of the pipe material ≤0.15% Nominal thickness of the pipe ≤5 mm (³ / ₁₆ in.) Multiple layer welds are used when the nominal material thickness
	≤16 mm (⁵ / ₈ in.)	Seal welds and non-load-carrying attachments [Note (7)]	>5 mm (³ / ₁₆ in.) [Note (6)] Mandatory preheat has been applied Multiple layer welds are used when the nominal material thickness >5 mm (³ / ₁₆ in.) [Note (6)]
P-No. 5B, Group No. 1		•••	No exemptions from PWHT

Table 331.1.3 Exemptions to Mandatory Postweld Heat Treatment (Cont'd)

P-No. and Group No. (BPV Code Section IX, QW/QB-420) [Note (1)]	Control Thickness, mm (in.) [Note (2)]	Type of Weld	Additional Limitations Required for Exemption From PWHT [Notes (3)–(5)]
P-No. 6, Group Nos. 1–3	All	All	Specified carbon content of the base materials ≤0.08% Nominal material thickness ≤10 mm (3/8 in.) Weld filler metal is A-No. 8, A-No. 9, or F-No. 43 composition [Note (8)]
P-No. 7, Group No. 1	All	All	Specified carbon content of the base materials \leq 0.08% Nominal material thickness \leq 10 mm ($^3/_8$ in.) Weld filler metal is A-No. 8, A-No. 9, or F-No. 43 composition [Note (8)]
P-No. 7, Group No. 2		•••	No exemptions from PWHT
P-No. 8, all Group Nos.	All	All	PWHT neither required nor prohibited
P-No. 9A, Group No. 1	All	All	Specified carbon content of the pipe material ≤0.15% Nominal material thickness ≤13 mm (½ in.) Mandatory preheat has been applied
P-No. 9B, Group No. 1	All	All	Nominal material thickness ≤16 mm (5/g in.) and the WPS has been qualified using a material of equal or greater thickness than used in the production weld
P-No. 10H, Group No. 1	All	All	PWHT neither required nor prohibited
P-No. 10l, Group No. 1	All	All	PWHT neither required nor prohibited for nominal material thickness ≤ 13 mm ($\frac{1}{2}$ in.)
P-No. 11A	≤50 mm (2 in.)	All	•••
P-No. 15E	•••	• • •	No exemptions from PWHT
P-No. 62			No exemptions from PWHT

NOTES:

- (1) If differences with the P-No. listed in Appendix A are found, the P-No. listed in ASME BPV Code Section IX, Table QW/QB-422 applies.
- (2) The control thickness is defined in para. 331.1.3.
- (3) The nominal material thickness is defined in para. 331.1.3(c).
- (4) No exemptions are permitted for PWHTs required by the designer or the WPS.
- (5) Additional exemptions for welds made in accordance with para. 328.7 may be taken for the materials addressed.
- (6) Single-layer or single-pass welds may be exempted from PWHT, provided the WPS has been qualified using single-pass welds with ±10% heat input and that all other conditions for exemption are met.
- (7) Non-load-carrying attachments are defined as items where no pressure loads or significant mechanical loads are transmitted through the attachment to the pipe or pressure-containing material.
- (8) The A-Nos. and the F-Nos. are found in ASME BPV Code Section IX, Tables QW-442 and QW-432, respectively.

ing assembly to be heat treated cannot be fitted into the furnace, it is permissible to heat treat in more than one heat, provided there is at least 300 mm (1 ft) overlap between successive heats, and that parts of the assembly outside the furnace are protected from harmful temperature gradients. This method may not be used for austenitizing heat treatments for ferritic materials.

331.2.6 Local Heat Treatment. Welds may be locally postweld heat treated by heating a circumferential band around the entire component with the weld located in the center of the band. The width of the band heated to the specified temperature range shall be at least three times the wall thickness at the weld of the thickest part being joined. For nozzle and attachment welds, the width of the band heated to the specified temperature range shall extend beyond the nozzle weld or attachment weld on each side at least two times the run pipe thickness, and shall extend completely around the run pipe. Guidance for the placement of thermocouples on circumferential butt welds is provided in AWS D10.10, Sections 5, 6, and 8. Special consideration shall be given to the placement of thermocouples when heating welds adjacent to large heat sinks such as valves or fittings, or when joining parts of different thicknesses. No part of the materials subjected to the heat source shall exceed the lower critical temperature of the material except as permitted by para. 331.2.1. Particular care must be exercised when the applicable PWHT temperature is close to the material's lower critical temperature, such as for P-No. 15E materials or when materials of different P-Nos. are being joined. This method may not be used for austenitizing heat treatments.

332 BENDING AND FORMING

(16) 332.1 General

Pipe may be bent and components may be formed by any hot or cold method that is suitable for the material, the fluid service, and the severity of the bending or forming process. The finished surface shall be free of cracks and substantially free from buckling. Thickness after bending or forming shall be not less than that required by the design.

332.2 Bending

332.2.1 Bend Flattening. Flattening of a bend, the difference between maximum and minimum diameters at any cross section, shall not exceed 8% of nominal outside diameter for internal pressure and 3% for external pressure. Removal of metal shall not be used to achieve these requirements.

332.2.2 Bending Temperature

- (a) Cold bending of ferritic materials shall be done at a temperature below the transformation range.
- (b) Hot bending shall be done at a temperature above the transformation range and in any case within a temperature range consistent with the material and the intended service.
- **332.2.3 Corrugated and Other Bends.** Dimensions and configuration shall conform to the design qualified in accordance with para. 306.2.2.

332.3 Forming

The temperature range for forming shall be consistent with material, intended service, and specified heat treatment.

332.4 Required Heat Treatment

Heat treatment shall be performed in accordance with para. 331.1.1 when required by the following.

- **332.4.1 Hot Bending and Forming.** After hot bending and forming, heat treatment is required for P-Nos. 3, 4, 5, 6, and 10A materials in all thicknesses. Durations and temperatures shall be in accordance with para. 331.
- **332.4.2 Cold Bending and Forming.** After cold bending and forming, heat treatment is required (for all thicknesses, and with temperature and duration as given in Table 331.1.1) when any of the following conditions exist:
- (a) for P-Nos. 1 through 6 materials, where the maximum calculated fiber elongation after bending or forming exceeds 50% of specified basic minimum elongation (in the direction of severest forming) for the applicable specification, grade, and thickness. This requirement may be waived if it can be demonstrated that the selection of pipe and the choice of bending or forming process provide assurance that, in the finished condition, the most severely strained material retains at least 10% elongation.
- (b) for any material requiring impact testing, where the maximum calculated fiber elongation after bending or forming will exceed 5%.
 - (c) when specified in the engineering design.

333 BRAZING AND SOLDERING

333.1 Qualification

- **333.1.1 Brazing Qualification.** The qualification of brazing procedures, brazers, and brazing operators shall be in accordance with para. 328.2. For Category D Fluid Service at design temperature not over 93°C (200°F), such qualification is not required unless specified in the engineering design.
- **333.1.2 Soldering Qualification.** The qualification of solderers shall be in accordance with the requirements of ASTM B828, Standard Practice for Making Capillary

¹ For pipe bending, PFI Standard ES-24, Pipe Bending Methods, Tolerances, Process and Material Requirements, may be used as a guide.

Joints by Soldering of Copper and Copper Alloy Tube and Fittings.

333.2 Brazing and Soldering Materials

333.2.1 Brazing Filler Metal and Flux. Brazing filler metal and flux shall comply with AWS A5.8, Specification for Filler Metals for Brazing and Braze Welding, and AWS A5.31, Specification for Fluxes for Brazing and Braze Welding, respectively, or other filler metals and fluxes that have been qualified in accordance with ASME Section IX.

333.2.2 Soldering Filler Metal and Flux. Soldering filler metal and flux shall comply with ASTM B32, Standard Specification for Solder Metal, and ASTM B813, Standard Specification for Liquid and Paste Fluxes for Soldering of Copper and Copper Alloy Tube, respectively.

333.3 Preparation and Cleaning

333.3.1 Surface Preparation. The surfaces to be brazed or soldered shall be clean and free from grease, oxides, paint, scale, and dirt of any kind. A suitable chemical or mechanical cleaning method shall be used if necessary to provide a clean wettable surface.

333.3.2 Joint Clearance. The clearance between surfaces to be joined by soldering or brazing shall be no larger than necessary to allow complete capillary distribution of the filler metal.

333.3.3 Flux Removal. Residual flux shall be removed.

335 ASSEMBLY AND ERECTION

335.1 Alignment

(a) Piping Distortions. Any distortion of piping to bring it into alignment for joint assembly that introduces a detrimental strain in equipment or piping components is prohibited.

(b) Cold Spring. Before assembling any joints to be cold sprung, guides, supports, and anchors shall be examined for errors that might interfere with desired movement or lead to undesired movement. The gap or overlap of piping prior to assembly shall be checked against the drawing and corrected if necessary. Heating shall not be used to help in closing the gap because it defeats the purpose of cold springing.

- (c) Flanged Joints. Unless otherwise specified in the engineering design, flanged joints shall be aligned as described in subparas. (1) or (2), and (3).
- (1) Before bolting, mating gasket contact surfaces shall be aligned to each other within 1 mm in 200 mm ($\frac{1}{16}$ in./ft), measured across any diameter.
- (2) The flanged joint shall be capable of being bolted such that the gasket contact surfaces bear uniformly on the gasket.

(3) Flange bolt holes shall be aligned within 3 mm ($\frac{1}{8}$ in.) maximum offset.

335.2 Flanged Joints

335.2.1 Preparation for Assembly. Any damage to the gasket seating surface that would prevent gasket seating shall be repaired, or the flange shall be replaced.

335.2.2 Bolting Torque

- (a) In assembling flanged joints, the gasket shall be uniformly compressed to the proper design loading.
- (b) Special care shall be used in assembling flanged joints in which the flanges have widely differing mechanical properties. Tightening to a predetermined torque is recommended.
- **335.2.3 Bolt Length.** Bolts shall extend through their nuts such that there is complete thread engagement for the full depth of the nut.

335.2.4 Gaskets. No more than one gasket shall be used between contact faces in assembling a flanged joint.

335.2.5 Flanged Joint Assembly. Assembly requirements for bolted flanged joints and flanged joint assembler qualifications shall be considered in the engineering design. For guidance, see ASME PCC-1, Guidelines for Pressure Boundary Bolted Flange Joint Assembly, and the BPV Code, Section VIII, Division 1, Nonmandatory Appendix S.

335.3 Threaded Joints

335.3.1 Thread Compound or Lubricant. Any compound or lubricant used on threads shall be suitable for the service conditions and shall not react unfavorably with either the service fluid or the piping material.

335.3.2 Joints for Seal Welding. A threaded joint to be seal welded shall be made up without thread compound. A joint containing thread compound that leaks during leak testing may be seal welded in accordance with para. 328.5.3, provided all compound is removed from exposed threads.

335.3.3 Straight Threaded Joints. Typical joints using straight threads, with sealing at a surface other than the threads, are shown in Fig. 335.3.3, illustrations (a), (b), and (c). Care shall be taken to avoid distorting the seat when incorporating such joints into piping assemblies by welding, brazing, or bonding.

335.4 Tubing Joints

335.4.1 Flared Tubing Joints. The sealing surface of the flare shall be examined for imperfections before assembly and any flare having imperfections shall be rejected.

335.4.2 Flareless and Compression Tubing Joints.

Where the manufacturer's instructions call for a specified number of turns of the nut, these shall be counted from the point at which the nut becomes finger tight. (16)

Gasket

Threads are ASME B1.1 straight threads.

(a) (b) (c)

Fig. 335.3.3 Typical Threaded Joints Using Straight Threads

335.5 Caulked Joints

Caulked joints shall be installed and assembled in accordance with the manufacturer's instructions, as modified by the engineering design. Care shall be taken to ensure adequate engagement of joint members.

335.6 Expanded Joints and Special Joints

335.6.1 General. Expanded joints and special joints (as defined in para. 318) shall be installed and assembled in accordance with the manufacturer's instructions, as modified by the engineering design. Care shall be taken to ensure adequate engagement of joint members.

335.6.2 Packed Joints. Where a packed joint is used to absorb thermal expansion, proper clearance shall be provided at the bottom of the socket to permit this movement.

335.9 Cleaning of Piping

This Code does not prescribe mandatory procedures for flushing and cleaning. However, for potential hazards that may result from performing such procedures refer to Appendix F, para. F335.9 for precautionary considerations.

335.10 Identification of Piping

See Appendix F, para. F335.10.

Chapter VI Inspection, Examination, and Testing

340 INSPECTION

340.1 General

This Code distinguishes between examination (see para. 341) and inspection. Inspection applies to functions performed for the owner by the owner's Inspector or the Inspector's delegates. References in this Code to the "Inspector" are to the owner's Inspector or the Inspector's delegates.

340.2 Responsibility for Inspection

It is the owner's responsibility, exercised through the owner's Inspector, to verify that all required examinations and testing have been completed and to inspect the piping to the extent necessary to be satisfied that it conforms to all applicable examination requirements of the Code and of the engineering design.

340.3 Rights of the Owner's Inspector

The owner's Inspector and the Inspector's delegates shall have access to any place where work concerned with the piping installation is being performed. This includes manufacture, fabrication, heat treatment, assembly, erection, examination, and testing of the piping. They shall have the right to audit any examination, to inspect the piping using any examination method specified by the engineering design, and to review all certifications and records necessary to satisfy the owner's responsibility stated in para. 340.2.

340.4 Qualifications of the Owner's Inspector

- (a) The owner's Inspector shall be designated by the owner and shall be the owner, an employee of the owner, an employee of an engineering or scientific organization, or of a recognized insurance or inspection company acting as the owner's agent. The owner's Inspector shall not represent nor be an employee of the piping manufacturer, fabricator, or erector unless the owner is also the manufacturer, fabricator, or erector.
- (b) The owner's Inspector shall meet one of the following requirements:
- (1) have at least 10 years of experience in the design, fabrication, or examination of industrial pressure piping. Each 20% of satisfactorily completed work toward an accredited engineering degree shall be considered equivalent to 1 year of experience, up to 5 years total.
- (2) have a professional engineering registration or nationally recognized equivalent with at least 5 years of

experience in the design, fabrication, or examination of industrial pressure piping.

- (3) be a certified welding inspector or a senior certified welding inspector as defined in AWS QC1, Standard for AWS Certification of Welding Inspectors, or nationally recognized equivalent with at least 5 years of experience in the design, fabrication, or examination of industrial pressure piping.
- (4) be an authorized piping inspector as defined in API 570, Piping Inspection Code: In-service Inspection, Rating, Repair, and Alteration of Piping Systems, with at least 5 years of experience in the design, fabrication, or examination of industrial pressure piping.
- (c) In delegating performance of inspection, the owner's Inspector is responsible for determining that a person to whom an inspection function is delegated is qualified to perform that function.

341 EXAMINATION

341.1 General

Examination applies to quality control functions performed by the manufacturer (for components only), fabricator, or erector. Reference in this Code to an examiner is to a person who performs quality control examinations.

341.2 Responsibility for Examination

Inspection does not relieve the manufacturer, the fabricator, or the erector of the responsibility for

- (a) providing materials, components, and workmanship in accordance with the requirements of this Code and of the engineering design [see para. 300(b)(3)]
 - (b) performing all required examinations
- (c) preparing suitable records of examinations and tests for the Inspector's use

341.3 Examination Requirements

341.3.1 General. Prior to initial operation each piping installation, including components and workmanship, shall be examined in accordance with the applicable requirements of para. 341. The type and extent of any additional examination required by the engineering design, and the acceptance criteria to be applied, shall be specified. Joints not included in examinations required by para. 341.4 or by the engineering design are accepted if they pass the leak test required by para. 345.

- (a) For P-Nos. 3, 4, 5A, 5B, 5C, and 15E materials, examinations shall be performed after completion of heat treatment. However, examinations need not be repeated on welds or portions of welds that are subjected to additional heat treatments and have not been repaired by welding.
- (b) For a welded branch connection the examination of and any necessary repairs to the pressure-containing weld shall be completed before any reinforcing pad or saddle is added.
- **341.3.2 Acceptance Criteria.** Acceptance criteria shall be as stated in the engineering design and shall at least meet the applicable requirements stated below.
 - (a) Welds

(16)

- (1) For radiography and visual, see Table 341.3.2.
- (2) For magnetic particle, see para. 344.3.2.
- (3) For liquid penetrant, see para. 344.4.2.
- (4) For ultrasonic, see para. 344.6.2.
- (b) Castings. Acceptance criteria for castings are specified in para. 302.3.3.

(16) 341.3.3 Defective Components and Workmanship.

Defects (imperfections of a type or magnitude not acceptable by the criteria specified in para. 341.3.2) shall be repaired, or the defective item or work shall be replaced. Discontinuities detected outside the area required to be examined during weld joint examinations should be evaluated and resolved in a manner acceptable to the owner and designer.

Examination shall be as follows:

- (a) When the defective item or work is repaired, the repaired portion of the item or work shall be examined. The examination shall use the same methods and acceptance criteria employed for the original examination. See also para. 341.3.1(a).
- (b) When the defective item or work is replaced, the new item or work used to replace the defective item or work shall be examined. The examination shall use any method and applicable acceptance criteria that meet the requirements for the original examination. See also para. 341.3.1(a).

341.3.4 Progressive Sampling for Examination.

When required spot or random examination reveals a defect, then

- (a) two additional samples of the same kind (if welded or bonded joints, by the same welder, bonder, or operator) from the original designated lot shall be given the same type of examination
- (b) if the items examined as required by (a) above are acceptable, the defective item shall be repaired or replaced and reexamined as specified in para. 341.3.3, and all items represented by these two additional samples shall be accepted, but
- (c) if any of the items examined as required by (a) above reveals a defect, two further samples of the same

kind shall be examined for each defective item found by that sampling

- (d) if all the items examined as required by (c) above are acceptable, the defective item(s) shall be repaired or replaced and reexamined as specified in para. 341.3.3, and all items represented by the additional sampling shall be accepted, but
- (e) if any of the items examined as required by (c) above reveals a defect, all items represented by the progressive sampling shall be either
- (1) repaired or replaced and reexamined as required, or
- (2) fully examined and repaired or replaced as necessary, and reexamined as necessary to meet the requirements of this Code
- (f) If any of the defective items are repaired or replaced, reexamined, and a defect is again detected in the repaired or replaced item, continued progressive sampling in accordance with (a), (c), and (e) is not required based on the new defects found. The defective item(s) shall be repaired or replaced and reexamined until acceptance as specified in para. 341.3.3. Spot or random examination (whichever is applicable) is then performed on the remaining unexamined joints.

341.4 Extent of Required Examination

- **341.4.1 Examination Normal Fluid Service.** Piping in Normal Fluid Service shall be examined to the extent specified herein or to any greater extent specified in the engineering design. Acceptance criteria are as stated in para. 341.3.2 and in Table 341.3.2, for Normal Fluid Service unless otherwise specified.
- (a) Visual Examination. At least the following shall be examined in accordance with para. 344.2:
- (1) sufficient materials and components, selected at random, to satisfy the examiner that they conform to specifications and are free from defects.
- (2) at least 5% of fabrication. For welds, each welder's and welding operator's work shall be represented.
- (3) 100% of fabrication for longitudinal welds, except those in components made in accordance with a listed specification. See para 341.5.1(a) for examination of longitudinal welds required to have a joint factor, E_j , of 0.90.
- (4) random examination of the assembly of threaded, bolted, and other joints to satisfy the examiner that they conform to the applicable requirements of para. 335. When pneumatic testing is to be performed, all threaded, bolted, and other mechanical joints shall be examined.
- (5) random examination during erection of piping, including checking of alignment, supports, and cold spring.
- (6) examination of erected piping for evidence of defects that would require repair or replacement, and for other evident deviations from the intent of the design.

82

Table 341.3.2 Acceptance Criteria for Welds — Visual and Radiographic Examination

		Criteria (A	to M) for Typ	es of Welds	and for Serv	ice Conditior	ns [Note (1)]				1	ination hods
Normal	and Category Service	/ M Fluid	Sever	e Cyclic Cond	litions		Category D	Fluid Service				
	Type of Weld	i		Type of Weld	l		Туре с	f Weld				
Girth, Miter Groove & Branch Connection [Note (2)]	Longitudinal Groove [Note (3)]	Fillet [Note (4)]	Girth, Miter Groove & Branch Connection [Note (2)]	Longitudinal Groove [Note (3)]	Fillet [Note (4)]	Girth and Miter Groove	Longitudinal Groove [Note (3)]	Fillet [Note (4)]	Branch Connection [Note (2)]	Weld Imperfection	Visual	Radiography
A	A	А	А	А	А	А	А	А	А	Crack	1	1
Α	A	А	A	A	А	С	А	N/A	A	Lack of fusion	1	1
В	A	N/A	A	A	N/A	С	A	N/A	В	Incomplete penetration	1	1
Е	E	N/A	D	D	N/A	N/A	N/A	N/A	N/A	Rounded Indications		1
G	G	N/A	F	F	N/A	N/A	N/A	N/A	N/A	Elongated indications		1
Н	A	н	A	A	А	1	A	Н	н	Undercutting	1	1
Α	A	A	A	A	A	A	A	A	A	Surface porosity or exposed slag inclusion [Note (5)]	1	
N/A	N/A	N/A	J	J	J	N/A	N/A	N/A	N/A	Surface finish	1	
K	К	N/A	К	K	N/A	К	К	N/A	К	Concave surface, concave root, or burn-through	1	1
L	L	L	L	L	L	М	М	М	М	Weld reinforcement or internal protrusion	1	•••

GENERAL NOTES:

- (a) Weld imperfections are evaluated by one or more of the types of examination methods given, as specified in paras. 341.4.1, 341.4.2, 341.4.3, and M341.4, or by the engineering design.
- (b) "N/A" indicates the Code does not establish acceptance criteria or does not require evaluation of this kind of imperfection for this type of weld.
- (c) Check (/) indicates examination method generally used for evaluating this kind of weld imperfection.
- (d) Ellipsis (...) indicates examination method not generally used for evaluating this kind of weld imperfection.

(16)

83

Criterion Value Notes for Table 341.3.2 Criterion Symbol Measure Acceptable Value Limits [Note (6)] Α Extent of imperfection Zero (no evident imperfection) В Cumulative length of incomplete penetration ≤38 mm (1.5 in.) in any 150 mm (6 in.) weld length or 25% of total weld length, whichever is less C Cumulative length of lack of fusion and incomplete ≤38 mm (1.5 in.) in any 150 mm (6 in.) weld length or 25% of total weld length, whichever is less penetration D Size and distribution of rounded indications See BPV Code, Section VIII, Division 1, Appendix 4 [Note (10)] For $\overline{T}_W \le 6$ mm ($\frac{1}{4}$ in.), limit is same as D [Note (10)] Ε Size and distribution of rounded indications For $\overline{T}_w > 6$ mm ($\frac{1}{4}$ in.), limit is 1.5 × D [Note (10)] F **Elongated indications** $\leq \overline{T}_w/3$ Individual length $\leq 2.5 \text{ mm } (\sqrt[3]{_{32} \text{ in.}}) \text{ and } \leq \overline{T}_w/3$ Individual width Cumulative length $\leq \overline{T}_w$ in any $12\overline{T}_w$ weld length [Note (10)] G Elongated indications $\leq 2\overline{T}_w$ Individual length Individual width ≤ 3 mm ($\frac{1}{8}$ in.) and $\leq \overline{T}_w/2$ $\leq 4\overline{T}_{w}$ in any 150 mm (6 in.) weld length [Note (10)] Cumulative length ≤ 1 mm ($\frac{1}{32}$ in.) and $\leq \overline{T}_w/4$ Н Depth of undercut Cumulative length of internal and external undercut ≤38 mm (1.5 in.) in any 150 mm (6 in.) weld length or 25% of total weld length, whichever is less $\leq 1.5 \text{ mm } (\frac{1}{16} \text{ in.}) \text{ and } \leq [\overline{T}_w/4 \text{ or } 1 \text{ mm } (\frac{1}{32} \text{ in.})]$ Τ Depth of undercut ≤38 mm (1.5 in.) in any 150 mm (6 in.) weld length Cumulative length of internal and external undercut or 25% of total weld length, whichever is less \leq 12.5 µm (500 µin.) R_a in accordance with ASME B46.1 Surface roughness Κ Total joint thickness, incl. weld reinf., $\geq \overline{T}_{w}$ [Notes (7) and (11)] Depth of surface concavity, root concavity, or burn-through For \overline{T}_w , mm (in.) L Height of reinforcement or internal protrusion [Note (8)] in Height, mm (in.) any plane through the weld shall be within limits of ≤6 (½) $\leq 1.5 \, \binom{1}{16}$ the applicable height value in the tabulation at right, $>6 (\frac{1}{4}), \leq 13 (\frac{1}{2})$ $\leq 3 (\frac{1}{8})$ except as provided in Note (9). Weld metal shall merge $\leq 4 \left(\frac{5}{32} \right)$ >13 $(\frac{1}{2})$, \leq 25 (1) smoothly into the component surfaces. >25 (1) $\leq 5 \left(\frac{3}{16}\right)$ Μ Height of reinforcement or internal protrusion [Note (8)] Limit is twice the value applicable for L above as described in L. Note (9) does not apply.

Notes follow on next page


(16)

Table 341.3.2 Acceptance Criteria for Welds — Visual and Radiographic Examination (Cont'd)

NOTES:


- (1) Criteria given are for required examination. More stringent criteria may be specified in the engineering design. See also paras. 341.5 and 341.5.3.
- (2) Branch connection weld includes pressure containing welds in branches and fabricated laps.
- (3) Longitudinal groove weld includes straight and spiral (helical) seam. Criteria are not intended to apply to welds made in accordance with a standard listed in Table A-1, Table A-1M, or Table 326.1. Alternative Leak Test requires examination of these welds; see para. 345.9.
- (4) Fillet weld includes socket and seal welds, and attachment welds for slip-on flanges, branch reinforcement, and supports.
- (5) These imperfections are evaluated only for welds ≤ 5 mm ($\frac{3}{16}$ in.) in nominal thickness.
- (6) Where two limiting values are separated by "and," the lesser of the values determines acceptance. Where two sets of values are separated by "or," the larger value is acceptable. \overline{I}_w is the nominal wall thickness of the thinner of two components joined by a butt weld.
- (7) For circumferential groove welded joints in pipe, tube, and headers made entirely without the addition of filler metal, external concavity shall not exceed the lesser of 1 mm ($\frac{1}{32}$ in.) or 10% of the joint nominal thickness. The contour of the concavity shall blend smoothly with the base metal. The total joint thickness, including any reinforcement, shall not be less than the minimum wall thickness, t_m .
- (8) For groove welds, height is the lesser of the measurements made from the surfaces of the adjacent components; both reinforcement and internal protrusion are permitted in a weld. For fillet welds, height is measured from the theoretical throat, Fig. 328.5.2A; internal protrusion does not apply.
- (9) For welds in aluminum alloy only, internal protrusion shall not exceed the following values:
 - (a) 1.5 mm ($\frac{1}{16}$ in.) for thickness ≤ 2 mm ($\frac{5}{64}$ in.)
 - (b) 2.5 mm ($\frac{3}{32}$ in.) for thickness >2 mm and \leq 6 mm ($\frac{1}{4}$ in.)
 - For external reinforcement and for greater thicknesses, see the tabulation for symbol L.
- (10) Porosity and inclusions such as slag or tungsten are defined as rounded indications where the maximum length is three times the width or less. These indications may be circular, elliptical, or irregular in shape; may have tails; and may vary in density. Indications where the length is greater than three times the width are defined as elongated indications and may also be slag, porosity, or tungsten.
- (11) For radiography, acceptability may be determined by comparing the density of the image through the affected area to the density through the adjacent base metal (\overline{T}_w). If digital radiography is used, brightness comparison may be utilized. A density or brightness darker than the adjacent base metal is cause for rejection.

Fig. 341.3.2 Typical Weld Imperfections




Incomplete filling at root on one side only

(c) Incomplete Penetration due to Internal Misalignment




(d) Incomplete Penetration of Weld Groove




Root bead fused to both inside surfaces but center of root slightly below inside surface of pipe (not incomplete penetration)

(e) Concave Root Surface (Suck-Up)



(f) Undercut



(g) Excess External Reinforcement

(b) Other Examination

- (1) Not less than 5% of circumferential butt and miter groove welds shall be examined fully by random radiography in accordance with para. 344.5 or by random ultrasonic examination in accordance with para. 344.6. The welds to be examined in each designated lot shall include the work product of each welder or welding operator whose welds are part of the lot. The work of welders depositing only tack welds need not be represented as part of the lot. Welds shall also be selected to maximize coverage of intersections with longitudinal joints. When a circumferential weld with an intersecting longitudinal weld(s) is examined, at least the adjacent 38 mm ($1\frac{1}{2}$ in.) of each intersecting weld shall be examined. In-process examination in accordance with para. 344.7 may be substituted for all or part of the radiographic or ultrasonic examination on a weldfor-weld basis if specified in the engineering design or specifically authorized by the Inspector.
- (2) Not less than 5% of all brazed joints shall be examined by in-process examination in accordance with para. 344.7, the joints to be examined being selected to ensure that the work of each brazer making the production joints is included.
- (c) Certifications and Records. The examiner shall be assured, by examination of certifications, records, and other evidence, that the materials and components are of the specified grades and that they have received required heat treatment, examination, and testing. The examiner shall provide the Inspector with a certification that all the quality control requirements of the Code and of the engineering design have been carried out.

341.4.2 Examination — Category D Fluid Service.

Piping and piping elements for Category D Fluid Service as designated in the engineering design shall be visually examined in accordance with para. 344.2 to the extent necessary to satisfy the examiner that components, materials, and workmanship conform to the requirements of this Code and the engineering design. Acceptance criteria are as stated in para. 341.3.2 and in Table 341.3.2, for Category D fluid service, unless otherwise specified.

341.4.3 Examination — Severe Cyclic Conditions.

Piping to be used under severe cyclic conditions shall be examined to the extent specified herein or to any greater extent specified in the engineering design. Acceptance criteria are as stated in para. 341.3.2 and in Table 341.3.2, for severe cyclic conditions, unless otherwise specified.

- (a) Visual Examination. The requirements of para. 341.4.1(a) apply with the following exceptions:
 - (1) All fabrication shall be examined.
- (2) All threaded, bolted, and other joints shall be examined.

- (3) All piping erection shall be examined to verify dimensions and alignment. Supports, guides, and points of cold spring shall be checked to ensure that movement of the piping under all conditions of startup, operation, and shutdown will be accommodated without undue binding or unanticipated constraint.
- (b) Other Examination. All circumferential butt and miter groove welds and all fabricated branch connection welds comparable to those shown in Fig. 328.5.4E shall be examined by 100% radiography in accordance with para. 344.5, or (if specified in the engineering design) by 100% ultrasonic examination in accordance with para. 344.6. Socket welds and branch connection welds that are not radiographed shall be examined by magnetic particle or liquid penetrant methods in accordance with para. 344.3 or 344.4.
- (c) In-process examination in accordance with para. 344.7, supplemented by appropriate nondestructive examination, may be substituted for the examination required in (b) above on a weld-for-weld basis if specified in the engineering design or specifically authorized by the Inspector.
- (d) Certification and Records. The requirements of para. 341.4.1(c) apply.

341.4.4 Examination — **Elevated Temperature Fluid Service.** Piping in Elevated Temperature Fluid Service shall be examined to the extent specified herein or to any greater extent specified in the engineering design. Acceptance criteria are as stated in para. 341.3.2 and in Table 341.3.2, for Normal Fluid Service, unless the requirements for severe cyclic conditions apply or otherwise specified.

- (a) Visual Examination. The requirements of para. 341.4.1(a) apply with the following exceptions:
 - (1) All fabrication shall be examined.
- (2) All threaded, bolted, and other joints shall be examined.
- (3) All piping erection shall be examined to verify dimensions and alignment. Supports, guides, and points of cold spring shall be checked to ensure that movement of the piping under all conditions of startup, operation, and shutdown will be accommodated without undue binding or unanticipated constraint.
- (b) Additional Examination. The examination requirements of para. 341.4.1(b) apply with the following exceptions:
- (1) Fabrication for longitudinal and spiral (helical seam) welds in P-No. 4 and P-No. 5 materials, except those in components made in accordance with a listed specification, shall be examined by 100% radiography in accordance with para. 344.5, or by 100% ultrasonic examination in accordance with para. 344.6.
- (2) Socket welds and branch connection welds in P-No. 4 and P-No. 5 materials that are not radiographed

or ultrasonically examined shall be examined by magnetic particle or liquid penetrant methods in accordance with para. 344.3 or 344.4.

- (c) Additional Examination Required for Autogenous Welds, Without Filler Metal, in Austenitic Stainless Steel and Austenitic High Nickel Alloys. Autogenously welded pipe shall receive nondestructive examination in accordance with the material specification. Autogenously welded expansion joint bellows shall be examined in accordance with para. X302.2.2(c).
- (d) Certification and Records. The requirements of para. 341.4.1(c) apply.

341.5 Supplementary Examination

Any of the methods of examination described in para. 344 may be specified by the engineering design to supplement the examination required by para. 341.4. The extent of supplementary examination to be performed and any acceptance criteria that differ from those in para. 341.3.2 shall be specified in the engineering design.

341.5.1 Spot Radiography

- (a) Longitudinal Welds. Spot radiography for longitudinal groove welds required to have a weld joint factor E_j of 0.90 requires examination by radiography in accordance with para. 344.5 of at least 300 mm (1 ft) in each 30 m (100 ft) of weld for each welder or welding operator. Acceptance criteria are those stated in Table 341.3.2 for radiography under Normal Fluid Service.
- (b) Circumferential Butt Welds and Other Welds. It is recommended that the extent of examination be not less than one shot on one in each 20 welds for each welder or welding operator. Unless otherwise specified, acceptance criteria are as stated in Table 341.3.2 for radiography under Normal Fluid Service for the type of joint examined.
- (c) Progressive Sampling for Examination. The provisions of para. 341.3.4 are applicable.
- (d) Welds to Be Examined. The locations of welds and the points at which they are to be examined by spot radiography shall be selected or approved by the Inspector.
- (16) **341.5.2 Hardness Tests.** Hardness tests are not required to verify proper heat treatment except as otherwise specified in the engineering design.
 - **341.5.3 Examinations to Resolve Uncertainty.** Any method may be used to resolve doubtful indications. Acceptance criteria shall be those for the required examination.

342 EXAMINATION PERSONNEL

342.1 Personnel Qualification and Certification

Personnel performing nondestructive examination to the requirements of this Code shall be qualified and certified for the method to be utilized following a procedure as described in BPV Code, Section V, Article 1, T-120(e) or (f).

342.2 Specific Requirement

For in-process examination, the examinations shall be performed by personnel other than those performing the production work.

343 EXAMINATION PROCEDURES

(16)

Any examination shall be performed in accordance with a written procedure that conforms to one of the methods specified in para. 344, including special methods (see para. 344.1.2). Procedures shall be written as required in the BPV Code, Section V, Article 1, T-150. The employer shall make the examination procedures employed available to the Inspector.

344 TYPES OF EXAMINATION

344.1 General

344.1.1 Methods. Except as provided in para. 344.1.2, any examination required by this Code, by the engineering design, or by the Inspector shall be performed in accordance with one of the methods specified herein.

344.1.2 Special Methods. If a method not specified herein is to be used, it and its acceptance criteria shall be specified in the engineering design in enough detail to permit qualification of the necessary procedures and examiners.

344.1.3 Definitions. The following terms apply to any type of examination:

100% examination: complete examination of all of a specified kind of item in a designated lot of piping¹

random examination:² complete examination of a percentage of a specified kind of item in a designated lot of piping¹

spot examination:² a specified partial examination of each of a specified kind of item in a designated lot of

¹ A designated lot is that quantity of piping to be considered in applying the requirements for examination in this Code. The quantity or extent of a designated lot should be established by agreement between the contracting parties before the start of work. More than one kind of designated lot may be established for different kinds of piping work. See Pipe Fabrication Institute Standard ES-48, Random Examination, for examples of lot selection

² Random or spot examination will not ensure a fabrication product of a prescribed quality level throughout. Items not examined in a lot of piping represented by such examination may contain defects that further examination could disclose. Specifically, if all radiographically disclosable weld defects must be eliminated from a lot of piping, 100% radiographic examination must be specified.

piping, 1 e.g., of part of the length of all shop-fabricated welds in a lot of jacketed piping

random spot examination:² a specified partial examination of a percentage of a specified kind of item in a designated lot of piping¹

344.2 Visual Examination

344.2.1 Definition. Visual examination is observation of the portion of components, joints, and other piping elements that are or can be exposed to view before, during, or after manufacture, fabrication, assembly, erection, examination, or testing. This examination includes verification of Code and engineering design requirements for materials, components, dimensions, joint preparation, alignment, welding, bonding, brazing, bolting, threading, or other joining method, supports, assembly, and erection.

344.2.2 Method. Visual examination shall be performed in accordance with the BPV Code, Section V, Article 9. Records of individual visual examinations are not required, except for those of in-process examination as specified in para. 344.7.

344.3 Magnetic Particle Examination

344.3.1 Method. Examination of castings is covered in para. 302.3.3. Magnetic particle examination of welds and of components other than castings shall be performed in accordance with BPV Code, Section V, Article 7.

344.3.2 Acceptance Criteria. Magnetic particle indications are caused by the attraction of the test media to surface or near-surface discontinuities in the area under test. However, all such indications are not necessarily imperfections, since excessive roughness, magnetic permeability variations, etc., may produce nonrelevant indications. Inadvertent accumulation of particles not related to magnetic attraction is classified as a false indication. Indications shall be verified as being relevant, nonrelevant, or false. Additional surface preparation and/or other test methods may be used as needed to verify the relevance of an indication.

An indication of an imperfection may be larger than the imperfection that causes it; however, the size of the indication is the basis for acceptance evaluation. Only indications that have any dimension greater than 1.5 mm ($\frac{1}{16}$ in.) shall be considered relevant.

(a) Indications

- (1) A linear indication is one having a length greater than three times its width.
- (2) A rounded indication is one of circular or elliptical shape with a length equal to or less than three times its width.
- (b) Examination. All surfaces to be examined shall be free of
 - (1) relevant linear indications

- (2) relevant rounded indications >5.0 mm ($\frac{3}{16}$ in.)
- (3) four or more relevant rounded indications in a line separated by 1.5 mm ($\frac{1}{16}$ in.) or less, edge to edge

344.4 Liquid Penetrant Examination

344.4.1 Method. Examination of castings is covered in para. 302.3.3. Liquid penetrant examination of welds and of components other than castings shall be performed in accordance with BPV Code, Section V, Article 6.

344.4.2 Acceptance Criteria. Liquid penetrant indications are caused by the bleed-out of a visible or fluorescent dye from a surface discontinuity in the area under test. However, all such indications are not necessarily imperfections, since excessive roughness, poor surface preparation, etc., may produce nonrelevant indications. Inadvertent evidence of penetrant not related to actual bleed-out is classified as a false indication. Indications shall be verified as being relevant, nonrelevant, or false. Additional surface preparation and/or other test methods may be used as needed to verify the relevance of an indication.

An indication of an imperfection may be larger than the imperfection that causes it; however, the size of the indication is the basis for acceptance evaluation. Only indications that have any dimension greater than $1.5\,\mathrm{mm}$ (${}^{1}\!\!{}_{16}$ in.) shall be considered relevant.

(a) Indications

- (1) A linear indication is one having a length greater than three times its width.
- (2) A rounded indication is one of circular or elliptical shape with a length equal to or less than three times its width.
- (b) Examination. All surfaces to be examined shall be free of
 - (1) relevant linear indications
 - (2) relevant rounded indications >5.0 mm ($\frac{3}{16}$ in.)
- (3) four or more relevant rounded indications in a line separated by 1.5 mm ($\frac{1}{16}$ in.) or less, edge to edge

344.5 Radiographic Examination

344.5.1 Method. Radiography of castings is covered in para. 302.3.3. Radiography of welds and of components other than castings shall be performed in accordance with BPV Code, Section V, Article 2.

344.5.2 Extent of Radiography

- (a) 100% Radiography. This applies only to girth and miter groove welds and to fabricated branch connection welds comparable to Fig. 328.5.4E, unless otherwise specified in the engineering design.
- (b) Random Radiography. This applies only to girth and miter groove welds.
- (c) Spot Radiography. This requires a single exposure radiograph in accordance with para. 344.5.1 at a point

within a specified extent of welding. For girth, miter, and branch groove welds the minimum requirement is

- (1) for sizes \leq DN 65 (NPS $2\frac{1}{2}$), a single elliptical exposure encompassing the entire weld circumference
- (2) for sizes >DN 65, the lesser of 25% of the inside circumference or 152 mm (6 in.)

For longitudinal welds the minimum requirement is 152 mm (6 in.) of weld length.

344.6 Ultrasonic Examination

- **344.6.1 Method.** Examination of castings is covered in para. 302.3.3; other product forms are not covered. Ultrasonic examination of welds shall be performed in accordance with BPV Code, Section V, Article 4, except that the alternative specified in (a) and (b) below is permitted for basic calibration blocks specified in T-434.2.1 and T-434.3.
- (a) When the basic calibration blocks have not received heat treatment in accordance with T-434.1.5, transfer methods shall be used to correlate the responses from the basic calibration block and the component. Transfer is accomplished by noting the difference between responses received from the same reference reflector in the basic calibration block and in the component and correcting for the difference.
- (b) The reference reflector may be a V-notch (which must subsequently be removed), an angle beam search unit acting as a reflector, or any other reflector that will aid in accomplishing the transfer.
- (c) When the transfer method is chosen as an alternative, it shall be used, at the minimum
- (1) for sizes \leq DN 50 (NPS 2), once in each 10 welded joints examined
- (2) for sizes >DN 50 and ≤DN 450 (NPS 18), once in each 1.5 m (5 ft) of welding examined
- (3) for sizes >DN 450, once for each welded joint examined
- (*d*) Each type of material and each size and wall thickness shall be considered separately in applying the transfer method. In addition, the transfer method shall be used at least twice on each type of weld joint.
- (e) The reference level for monitoring discontinuities shall be modified to reflect the transfer correction when the transfer method is used.
- **344.6.2 Acceptance Criteria.** Acceptance criteria shall be as described in (a) or (b).
 - (a) A linear-type discontinuity is unacceptable if the amplitude of the indication exceeds the reference level and its length exceeds
 - (1) 6 mm ($\frac{1}{4}$ in.) for $\overline{T}_w \le 19$ mm ($\frac{3}{4}$ in.)
 - (2) $\overline{T}_w/3$ for 19 mm $<\overline{T}_w \le 57$ mm $(2\frac{1}{4}$ in.)
 - (3) 19 mm ($\frac{3}{4}$ in.) for $\overline{T}_w > 57$ mm ($2\frac{1}{4}$ in.)
 - (b) The fracture mechanics ultrasonic acceptance criteria in Appendix R may be used if all requirements of Appendix R are met.

344.7 In-Process Examination

- **344.7.1 Definition.** In-process examination comprises examination of the following, as applicable:
 - (a) joint preparation and cleanliness
 - (b) preheating
- (c) fit-up, joint clearance, and internal alignment prior to joining
- (d) variables specified by the joining procedure, including filler material
 - (1) (for welding) position and electrode
- (2) (for brazing) position, flux, brazing temperature, proper wetting, and capillary action
- (e) (for welding) condition of the root pass after cleaning external and, where accessible, internal aided by liquid penetrant or magnetic particle examination when specified in the engineering design
- (f) (for welding) slag removal and weld condition between passes
 - (g) appearance of the finished joint
- **344.7.2 Method.** The examination is visual, in accordance with para. 344.2, unless additional methods are specified in the engineering design.

345 TESTING

345.1 Required Leak Test

Prior to initial operation, and after completion of the applicable examinations required by para. 341, each piping system shall be tested to ensure tightness. The test shall be a hydrostatic leak test in accordance with para. 345.4 except as provided herein.

- (a) At the owner's option, a piping system in Category D fluid service may be subjected to an initial service leak test in accordance with para. 345.7, in lieu of the hydrostatic leak test.
- (b) Where the owner considers a hydrostatic leak test impracticable, either a pneumatic test in accordance with para. 345.5 or a combined hydrostatic-pneumatic test in accordance with para. 345.6 may be substituted, recognizing the hazard of energy stored in compressed gas.
- (c) Where the owner considers both hydrostatic and pneumatic leak testing impracticable, the alternative specified in para. 345.9 may be used if both of the following conditions apply:
 - (1) a hydrostatic test would
 - (a) damage linings or internal insulation
- (b) contaminate a process that would be hazardous, corrosive, or inoperative in the presence of moisture
- (c) require significant support modifications for the hydrostatic test load or
- (d) present the danger of brittle fracture due to low metal temperature during the test
 - (2) a pneumatic test would
- (a) present an undue hazard of possible release of energy stored in the system or

- (b) present the danger of brittle fracture due to low metal temperature during the test
- (*d*) Unless specified in the engineering design, lines open to the atmosphere, such as vents or drains downstream of the last shutoff valve, need not be leak tested.

345.2 General Requirements for Leak Tests

Requirements in para. 345.2 apply to more than one type of leak test.

(16) 345.2.1 Limitations on Pressure

- (a) Reduced Test Pressure. If the test pressure would produce a circumferential or longitudinal stress (based on minimum pipe wall thickness) in excess of yield strength at test temperature or is greater than 1.5 times the component rating at test temperature, the test pressure may be reduced to the maximum pressure that will not exceed the lesser of the yield strength or 1.5 times a component rating at test temperature. [See paras. 302.3.2(e) and (f).] For metallic bellows expansion joints, see Appendix X, para. X302.2.3(a).
- (b) Test Fluid Expansion. If a pressure test is to be maintained for a period of time and the test fluid in the system is subject to thermal expansion, precautions shall be taken to avoid excessive pressure.
- (c) Preliminary Pneumatic Test. A preliminary test using air at no more than 170 kPa (25 psi) gage pressure may be made prior to hydrostatic testing to locate major leaks.

345.2.2 Other Test Requirements

- (a) Examination for Leaks. The leak test pressure shall be maintained for at least 10 min and then all joints and connections shall be examined for leaks. The test pressure may be reduced to not less than the design pressure while performing this examination.
- (b) Heat Treatment. Leak tests shall be conducted after any heat treatment has been completed.
- (c) Low Test Temperature. The possibility of brittle fracture shall be considered when conducting leak tests at metal temperatures near the ductile-brittle transition temperature.

(16) 345.2.3 Special Provisions for Testing

- (a) Piping Components and Subassemblies. Piping components and subassemblies may be tested either separately or as assembled piping.
- (b) Flanged Joints. Flanged joints used to connect piping components and subassemblies that have previously been tested, and flanged joints at which a blank or blind is used to isolate equipment or other piping during a test, need not be leak tested in accordance with para. 345.1.
- (c) Closure Welds. The final weld connecting piping systems or components that have been successfully tested in accordance with para. 345 need not be leak tested provided the weld is examined in-process in accordance with para. 344.7 and passes with 100% radiographic examination in accordance with para. 344.5 or

- 100% ultrasonic examination in accordance with para. 344.6.
- (d) Instrument Connections. Threaded joints, tubing joints, or a combination of these joints used to connect instruments to previously leak tested piping need not be leak tested in accordance with para. 345.1.
 - (e) See also Appendix F, para. F345.2.3.

345.2.4 Externally Pressured Piping

- (*a*) Except as provided in (b) below, piping systems subject to external pressure shall be tested at an internal gage pressure 1.5 times the external differential pressure, but not less than 105 kPa (15 psi).
- (b) As an alternative to leak testing under internal pressure, piping systems designed for vacuum service only may be subjected to a vacuum leak test method, technique, and acceptance criteria specified by the owner. The vacuum leak test shall be performed following a written procedure complying with the applicable technical requirements of the BPV Code, Section V, Article 10. Leak-testing personnel shall be qualified and certified as required by Section V, Article 1, T-120(e) or (f).

345.2.5 Jacketed Piping

- (a) The internal line shall be leak tested on the basis of the internal or external design pressure, whichever is critical. This test must be performed before the jacket is completed if it is necessary to provide visual access to joints of the internal line as required by para. 345.3.1.
- (*b*) The jacket shall be leak tested in accordance with para. 345.1 on the basis of the jacket design pressure unless otherwise specified in the engineering design.
- **345.2.6 Repairs or Additions After Leak Testing.** If repairs or additions are made following the leak test, the affected piping shall be retested, except that for minor repairs or additions the owner may waive retest requirements when precautionary measures are taken to assure sound construction.
- **345.2.7 Test Records.** Records shall be made of each piping system during the testing, including
 - (a) date of test
 - (b) identification of piping system tested
 - (c) test fluid
 - (d) test pressure
 - (e) certification of results by examiner

These records need not be retained after completion of the test if a certification by the Inspector that the piping has satisfactorily passed pressure testing as required by this Code is retained.

345.3 Preparation for Leak Test

345.3.1 Joints Exposed

(a) Except as provided in (b) and (c) below, all joints, welds (including structural attachment welds to pressure-containing components), and bonds shall be left

(16)

(16)

uninsulated and exposed for examination during leak testing.

- (b) Joints previously tested in accordance with this Code may be insulated or covered.
- (c) At the owner's option, joints in Category D Fluid Service that are subject to a hydrostatic leak test (para. 345.4) or an initial service leak test (para. 345.7) may be insulated and have protective weather sheathing installed prior to leak testing. Consideration shall be given to increasing the test period to allow time for possible leakage to pass through the insulation and weather sheathing.
- (d) All joints may be primed and painted prior to leak testing unless a sensitive leak test (para. 345.8) is required.

345.3.2 Temporary Supports. Piping designed for vapor or gas shall be provided with additional temporary supports, if necessary, to support the weight of test liquid.

345.3.3 Piping With Expansion Joints

- (a) Unrestrained expansion joints depend on external main anchors to resist pressure thrust forces. Except as limited in para. 345.3.3(c), a piping system containing unrestrained expansion joints shall be leak tested without any temporary restraints in accordance with para. 345 up to 150% of the expansion joint design pressure. If the required test pressure exceeds 150% of the expansion joint design pressure and the main anchors are not designed to resist the pressure thrust forces at the required test pressure, for that portion of the test when the pressure exceeds 150% of the expansion joint design pressure, the expansion joint shall either be temporarily removed or temporary restraints shall be added to resist the pressure thrust forces.
- (b) Self-restrained metallic bellows expansion joints (i.e., tied, hinged, pressure balanced, etc.) have restraint hardware designed to resist the pressure thrust forces. Except as limited in para. 345.3.3(c), a piping system containing self-restrained expansion joints shall be leak tested in accordance with para. 345. A self-restrained expansion joint previously shop tested by the manufacturer in accordance with Appendix X may be excluded from the system to be leak tested, except when a sensitive leak test in accordance with para. 345.8 is required. Restraint hardware for all types of expansion joints shall be designed for the pressure thrust forces at the test pressure.
- (c) When a metallic bellows expansion joint is installed in the piping system subject to a leak test and the leak test pressure determined in accordance with para. 345 exceeds the pressure of the test performed by the manufacturer in accordance with Appendix X, the required leak test pressure shall be reduced to the manufacturer's test pressure.

345.3.4 Limits of Tested Piping. Equipment that is not to be tested shall be either disconnected from the piping or isolated by blinds or other means during the test. A valve may be used provided the valve (including its closure mechanism) is suitable for the test pressure.

345.4 Hydrostatic Leak Test

345.4.1 Test Fluid. The fluid shall be water unless there is the possibility of damage due to freezing or to adverse effects of water on the piping or the process (see para. F345.4.1). In that case another suitable nontoxic liquid may be used. If the liquid is flammable, its flash point shall be at least 49°C (120°F), and consideration shall be given to the test environment.

345.4.2 Test Pressure. Except as provided in para. 345.4.3, the hydrostatic test pressure at every point in a metallic piping system shall be as follows:

- (a) not less than 1.5 times the design pressure.
- (b) when the design temperature is greater than the test temperature, the minimum test pressure, at the point under consideration, shall be calculated using eq. (24).

$$P_T = 1.5 \ PS_T/S$$
 (24)

where

P = internal design gage pressure

 P_T = minimum test gage pressure

- S = allowable stress at component design temperature for the prevalent pipe material; see
 Table A-1 or Table A-1M
- S_T = allowable stress at test temperature for the prevalent pipe material; see Table A-1 or Table A-1M
- (c) in those cases where the piping system may not include pipe itself, any other component in the piping system, other than pipe-supporting elements and bolting, may be used to determine the S_T/S ratio based on the applicable allowable stresses obtained from Table A-1 or Table A-1M. In those cases where the piping system may be made up of equivalent lengths of more than one material, the S_T/S ratio shall be based on the minimum calculated ratio of the included materials.

345.4.3 Hydrostatic Test of Piping With Vessels as a System 3

- (a) Where the test pressure of piping attached to a vessel is the same as or less than the test pressure for the vessel, the piping may be tested with the vessel at the piping test pressure.
- (b) Where the test pressure of the piping exceeds the vessel test pressure, and it is not considered practicable to isolate the piping from the vessel, the piping and the vessel may be tested together at the vessel test pressure,

(16)

³ The provisions of para. 345.4.3 do not affect the pressure test requirements of any applicable vessel code.

provided the owner approves and the vessel test pressure is not less than 77% of the piping test pressure calculated in accordance with para. 345.4.2(b).

345.5 Pneumatic Leak Test

- **345.5.1 Precautions.** Pneumatic testing involves the hazard of released energy stored in compressed gas. Particular care must therefore be taken to minimize the chance of brittle failure during a pneumatic leak test. Test temperature is important in this regard and must be considered when the designer chooses the material of construction. See para. 345.2.2(c) and Appendix F, paras. F323.4 and F345.5.1.
- **345.5.2 Pressure Relief Device.** A pressure relief device shall be provided, having a set pressure not higher than the test pressure plus the lesser of 345 kPa (50 psi) or 10% of the test pressure.
- **345.5.3 Test Fluid.** The gas used as test fluid, if not air, shall be nonflammable and nontoxic.
- **345.5.4 Test Pressure.** The test pressure shall be not less than 1.1 times the design pressure and shall not exceed the lesser of
 - (a) 1.33 times the design pressure

(16)

- (*b*) the pressure that would exceed 90% of the pressure described in para. 345.2.1(a)
- **345.5.5 Procedure.** The pressure shall be gradually increased until a gage pressure that is the lesser of one-half the test pressure or 170 kPa (25 psi) is attained, at which time a preliminary check shall be made, including examination of joints in accordance with para. 341.4.1(a). Thereafter, the pressure shall be gradually increased in steps until the test pressure is reached, holding the pressure at each step long enough to equalize piping strains. The pressure shall then be reduced to the design pressure before examining for leakage in accordance with para. 345.2.2(a).

345.6 Hydrostatic-Pneumatic Leak Test

If a combination hydrostatic-pneumatic leak test is used, the requirements of para. 345.5 shall be met, and the pressure in the liquid filled part of the piping shall not exceed the limits stated in para. 345.4.2.

345.7 Initial Service Leak Test

This test is applicable only to piping in Category D Fluid Service, at the owner's option. See para. 345.1(a).

- **345.7.1 Test Fluid.** The test fluid is the service fluid.
- **345.7.2 Procedure.** During or prior to initial operation, the pressure shall be gradually increased in steps until the operating pressure is reached, holding the pressure at each step long enough to equalize piping strains. A preliminary check shall be made as described in para. 345.5.5 if the service fluid is a gas or vapor.

345.7.3 Examination for Leaks. The examination for leaks required by para. 345.2.2(a) shall be conducted while the system is at operating pressure. It is permissible to omit examination for leaks of joints and connections previously tested in accordance with this Code.

345.8 Sensitive Leak Test

The test shall be the Bubble Test — Direct Pressure Technique in accordance with the BPV Code, Section V, Article 10, Appendix I or another leak test method that has a demonstrated sensitivity not less than 10^{-3} std ml/s under test conditions.

When the Bubble Test — Direct Pressure Technique is used

- (a) the test pressure shall be at least the lesser of 105 kPa (15 psi) gage or 25% of the design pressure.
- (b) the pressure shall be gradually increased until a gage pressure equal to the lesser of one-half the test pressure or 170 kPa (25 psi) is attained, at which time a preliminary check shall be made. Then the pressure shall be gradually increased in steps until the test pressure is reached, the pressure being held long enough at each step to equalize piping strains.

345.9 Alternative Leak Test

The following procedures and leak test method may be used only under the conditions stated in para. 345.1(c).

- **345.9.1 Examination of Welds.** Welds, including those used in the manufacture of welded pipe and fittings, that have not been subjected to hydrostatic or pneumatic leak tests in accordance with this Code, shall be examined as follows:
- (a) Circumferential, longitudinal, and spiral (helical seam) groove welds shall be 100% radiographed in accordance with para. 344.5 or 100% ultrasonically examined in accordance with para. 344.6.
- (b) All welds, including structural attachment welds, not covered in (a) above, shall be examined using the liquid penetrant method (para. 344.4) or, for magnetic materials, the magnetic particle method (para. 344.3).
- **345.9.2 Flexibility Analysis.** A flexibility analysis of the piping system shall have been made in accordance with the requirements of para. 319.4.2 (b), if applicable, or (c) and (d).
- **345.9.3 Test Method.** The system shall be subjected to a sensitive leak test in accordance with para. 345.8.

346 RECORDS

346.2 Responsibility

It is the responsibility of the piping designer, the manufacturer, the fabricator, and the erector, as applicable, to

prepare the records required by this Code and by the engineering design.

(16) 346.3 Retention of Records

Unless otherwise specified by the engineering design, the following records shall be retained for at least 5 years after the record is generated for the project:

- (a) examination procedures
- (b) examination personnel qualifications
- (c) examination reports

Chapter VII Nonmetallic Piping and Piping Lined With Nonmetals

A300 GENERAL STATEMENTS

- (a) Chapter VII pertains to nonmetallic piping and to piping lined with nonmetals.
- (b) The organization, content, and paragraph designations of this Chapter correspond to those of the first six Chapters (the base Code). The prefix A is used.
- (c) Provisions and requirements of the base Code apply only as stated in this Chapter.
- (*d*) Metallic piping that provides the pressure containment for a nonmetallic lining shall conform to the requirements of Chapters I through VI, and to those in Chapter VII not limited to nonmetals.
- (e) This Chapter makes no provision for piping to be used under severe cyclic conditions.
- (f) With the exceptions stated above, Chapter I applies in its entirety.

PART 1 CONDITIONS AND CRITERIA

A301 DESIGN CONDITIONS

Paragraph 301 applies in its entirety, with the exception of paras. 301.2 and 301.3. See below.

A301.2 Design Pressure

Paragraph 301.2 applies in its entirety, except that references to paras. A302.2.4 and A304 replace references to paras. 302.2.4 and 304, respectively.

A301.3 Design Temperature

Paragraph 301.3 applies with the following exceptions.

A301.3.1 Design Minimum Temperature.

Paragraph 301.3.1 applies; but see para. A323.2.2, rather than para. 323.2.2.

A301.3.2 Uninsulated Components. The component design temperature shall be the fluid temperature, unless a higher temperature will result from solar radiation or other external heat sources.

A302 DESIGN CRITERIA

Paragraph A302 states pressure–temperature ratings, stress criteria, design allowances, and minimum design values, together with permissible variations of these factors as applied to the design of piping.

A302.1 General

The designer shall be satisfied as to the adequacy nonmetallic material and its manufacture, considering at least the following:

- (a) tensile, compressive, flexural, and shear strength, and modulus of elasticity, at design temperature (long term and short term)
 - (b) creep rate at design conditions
 - (c) design stress and its basis
 - (d) ductility and plasticity
 - (e) impact and thermal shock properties
 - (f) temperature limits
- (g) transition temperature melting and vaporization
 - (h) porosity and permeability
 - (i) testing methods
 - (j) methods of making joints and their efficiency
 - (k) possibility of deterioration in service

A302.2 Pressure-Temperature Design Criteria

Ratings. Paragraph 302.2.1 applies, except that reference to Table A326.1 replaces reference to Table 326.1.

Ratings. Nonmetallic piping components for which design stresses have been developed in accordance with para. A302.3, but which do not have specific pressure-temperature ratings, shall be rated by rules for pressure design in para. A304, within the range of temperatures for which stresses are shown in Appendix B, modified as applicable by other rules of this Code.

Piping components that do not have allowable stresses or pressure–temperature ratings shall be qualified for pressure design as required by para. A304.7.2.

A302.2.3 Unlisted Components. Paragraph 302.2.3 applies, except that references to Table A326.1 and paras. A304 and A304.7.2 replace references to Table 326.1 and paras. 304 and 304.7.2, respectively.

A302.2.4 Allowances for Pressure and Temperature Variations

(a) Nonmetallic Piping. Allowances for variations of pressure or temperature, or both, above design conditions are not permitted. The most severe conditions of coincident pressure and temperature shall be used to determine the design conditions for a piping system. See paras. 301.2 and 301.3.

(b) Metallic Piping With Nonmetallic Lining. Allowances for pressure and temperature variations provided in para. 302.2.4 are permitted only if the suitability of the lining material for the increased conditions is established through prior successful service experience or tests under comparable conditions.

A302.2.5 Rating at Junction of Different Services.

When two services that operate at different pressure– temperature conditions are connected, the valve segregating the two services shall be rated for the more severe service condition.

A302.3 Allowable Stresses and Other Design Limits

A302.3.1 General

- (a) Table B-1 contains hydrostatic design stresses (HDS). Tables B-2 and B-3 provide listings of specifications that meet the criteria of paras. A302.3.2(b) and (c), respectively. Tables B-4 and B-5 contain allowable pressures. These HDS values, allowable stress criteria, and pressures shall be used in accordance with the Notes to Appendix B, and may be used in design calculations (where the allowable stress *S* means the appropriate design stress) except as modified by other provisions of this Code. Use of hydrostatic design stresses for calculations other than pressure design has not been verified. The bases for determining allowable stresses and pressures are outlined in para. A302.3.2.
- (b) The stresses and allowable pressures are grouped by materials and listed for stated temperatures. Straightline interpolation between temperatures is permissible.

(16) A302.3.2 Bases for Allowable Stresses and Pressures ¹

- (a) Thermoplastics. The method of determining HDS is described in ASTM D2837. HDS values are given in Table B-1 for those materials and temperatures for which sufficient data have been compiled to substantiate the determination of stress.
- (b) Reinforced Thermosetting Resin (Laminated). The design stress (DS) values for materials listed in Table B-2

 $^{\rm 1}$ Titles of ASTM Specifications and AWWA Standards referenced herein are as follows:

ASTM C14, Concrete Sewer, Storm Drain, and Culvert Pipe ASTM C301, Method of Testing Vitrified Clay Pipe

ASTM C582, Contact-Molded Reinforced Thermosetting Plastic (RTP) Laminates for Corrosion Resistant Equipment

ASTM D2321, Practice for Underground Installation of Thermoplastic Pipe for Sewers and Other Gravity-Flow Applications

ASTM D2837, Test Method for Obtaining Hydrostatic Design Basis for Thermoplastic Pipe Materials or Pressure Design Basis for Thermoplastic Pipe Products

ASTM D2992, Practice for Obtaining Hydrostatic or Pressure Design Basis for "Fiberglass" (Glass-Fiber-RTR) Pipe and Fittings ASTM D3839, Underground Installation of Fiberglass Pipe AWWA C900, PVC Pressure Pipe, 4-inch through 12-inch, for Water AWWA C950, Glass-Fiber-Reinforced Thermosetting Resin

Pressure Pipe

shall be one-tenth of the minimum tensile strengths specified in ASTM C582 and are valid only in the temperature range from -29°C (-20°F) through 82°C (180°F).

- (c) Reinforced Thermosetting Resin and Reinforced Plastic Mortar (Filament Wound and Centrifugally Cast). The hydrostatic design basis stress (HDBS) values for materials listed in Table B-3 shall be obtained by the procedures in ASTM D2992 and are valid only at 23°C (73°F). HDS shall be obtained by multiplying the HDBS by a service (design) factor² selected for the application, in accordance with procedures described in ASTM D2992, within the following limits:
- (1) When using the cyclic HDBS, the service (design) factor *F* shall not exceed 1.0.
- (2) When using the static HDBS, the service (design) factor *F* shall not exceed 0.5.
- (*d*) Other Materials. Allowable pressures in Tables B-4 and B-5 have been determined conservatively from physical properties of materials conforming to the listed specifications, and have been confirmed by extensive experience. Use of other materials shall be qualified as required by para. A304.7.2.

A302.3.3 Limits of Calculated Stresses Due to Sustained Loads $^{\rm 1}$

- (a) Internal Pressure Stresses. Limits of stress due to internal pressure are covered in para. A304.
- (b) External Pressure Stresses. Stresses due to uniform external pressure shall be considered safe when the wall thickness of the component and its means of stiffening have been qualified as required by para. A304.7.2.
- (c) External Loading Stresses. Design of piping under external loading shall be based on the following:
- (1) Thermoplastic $\ \ Piping. \ ASTM \ \ D2321 \ \ or \ AWWA C900.$
- (2) Reinforced Thermosetting Resin (RTR) and Reinforced Plastic Mortar (RPM) Piping. ASTM D3839 or Appendix A of AWWA C950.
- (3) Strain and possible buckling shall be considered when determining the maximum allowable deflection in (1) or (2) above, but in no case shall the allowable diametral deflection exceed 5% of the pipe inside diameter.
- (4) Nonmetallic piping not covered in (1) or (2) above shall be subjected to a crushing or three-edge bearing test in accordance with ASTM C14 or C301; the allowable load shall be 25% of the minimum value obtained.

A302.3.4 Limits of Calculated Stresses Due to Occasional Loads

(a) Operation. The sum of the stresses in any component in a piping system due to sustained loads, such as

² The service (design) factor, *F*, should be selected by the designer after evaluating fully the service conditions and the engineering properties of the specific material under consideration. Aside from the limits in paras. A302.3.2(c)(1) and (2), it is not the intent of this Code to specify service (design) factors.

pressure and weight, and of the stresses produced by occasional loads, such as wind or earthquake, shall not exceed the limits in the applicable part of para. A302.3.3. Wind and earthquake forces need not be considered as acting concurrently.

(b) Test. Stresses due to test conditions are not subject to the limitations in para. A302.3.3. It is not necessary to consider other occasional loads, such as wind and earthquake, as occurring concurrently with test loads.

A302.4 Allowances

Paragraph 302.4 applies in its entirety.

PART 2 PRESSURE DESIGN OF PIPING COMPONENTS

A303 GENERAL

Paragraph 303 applies, except that references to Table A326.1 and para. A302.2.1 replace references to Table 326.1 and para. 302.2.1. For nonmetallic components, reference to para. A304 replaces reference to para. 304.

A304 PRESSURE DESIGN OF PIPING COMPONENTS

A304.1 Straight Pipe

A304.1.1 General

(a) The required thickness of straight sections of pipe shall be determined by eq. (25).

$$t_m = t + c \tag{25}$$

The minimum thickness T for the pipe selected, considering manufacturer's minus tolerance, shall be not less than t_m .

- (b) The following nomenclature is used in the equations for pressure design of straight pipe:
 - c = the sum of mechanical allowances (thread or groove depth) plus corrosion and erosion allowance. For threaded components, the nominal thread depth (dimension h of ASME B1.20.1 or equivalent) shall apply. For machined surfaces or grooves where the tolerance is not specified, the tolerance shall be assumed to be 0.5 mm (0.02 in.) in addition to the specified depth of the cut.

D =outside diameter of pipe

F = service (design) factor. See para. A302.3.2(c).

P = internal design gage pressure

S =design stress from applicable Table in Appendix B

T = pipe wall thickness (measured or minimum in accordance with the purchase specification)

t = pressure design thickness, as calculated in accordance with para. A304.1.2 for internal

pressure or as determined in accordance with para. A304.1.3 for external pressure

 t_m = minimum required thickness, including mechanical, corrosion, and erosion allowances

A304.1.2 Straight Nonmetallic Pipe Under Internal Pressure. The internal pressure design thickness, *t*, shall be not less than that calculated by one of the following equations, using stress values listed in or derived from the appropriate table in Appendix B:

(a) Thermoplastic Pipe [See Para. A302.3.2(a)]

$$t = \frac{PD}{2S + P} \text{ (Table B-1)} \tag{26a}$$

(b) RTR (Laminated) Pipe [See Para. A302.3.2(b)]

$$t = \frac{PD}{2S + P} \text{ (Table B-2)} \tag{26b}^3$$

(c) RTR (Filament Wound) and RPM (Centrifugally Cast) Pipe [See Para. A302.3.2(c)]

$$t = \frac{PD}{2SF + P} \text{ (Table B-3)}$$
 (26c)³

A304.1.3 Straight Pipe Under External Pressure

- (a) Nonmetallic Pipe. The external pressure design thickness, *t*, shall be qualified as required by para. A304.7.2.
 - (b) Metallic Pipe Lined With Nonmetals
- (1) The external pressure design thickness, *t*, for the base (outer) material shall be determined in accordance with para. 304.1.3.
- (2) The external pressure design thickness, *t*, for the lining material shall be qualified as required by para. A304.7.2.

A304.2 Curved and Mitered Segments of Pipe

- **A304.2.1 Pipe Bends.** The minimum required thickness, t_m , of a bend, after bending, shall be determined as for straight pipe in accordance with para. A304.1.
- **A304.2.2 Elbows.** Manufactured elbows not in accordance with para. A303 shall be qualified as required by para. A304.7.2.
- **A304.2.3 Miter Bends.** Miter bends shall be qualified as required by para. A304.7.2.

A304.3 Branch Connections

A304.3.1 General. A pipe having a branch connection is weakened by the opening that must be made in it and, unless the wall thickness of the pipe is sufficiently in excess of that required to sustain the pressure, it is necessary to provide added reinforcement. The amount

 $^{^3}$ The internal design pressure thickness t shall not include any thickness of the pipe wall reinforced with less than 20% by weight of reinforcing fibers.

of reinforcement shall be qualified as required by para. A304.7.2 except as provided in para. A304.3.2.

A304.3.2 Branch Connections Using Fittings. It may be assumed without calculation that a branch connection has adequate strength to sustain the internal and external pressure that will be applied to it if it utilizes a fitting (a tee, lateral, or cross) in accordance with para. A303.

A304.3.3 Additional Design Considerations. The requirements of paras. A304.3.1 and A304.3.2 are intended to assure satisfactory performance of a branch connection subjected only to internal or external pressure. The designer shall also consider paras. 304.3.5(a), (c), and (d).

A304.4 Closures

Closures not in accordance with para. A303 shall be qualified as required by para. A304.7.2.

A304.5 Pressure Design of Nonmetallic Flanges

(16) A304.5.1 General

- (*a*) Flanges not in accordance with para. A303, or A304.5.1(b) or (d) shall be qualified as required by para. A304.7.2.
- (b) Flanges for use with flat ring gaskets may be designed in accordance with the BPV Code, Section VIII, Division 1, Appendix 2, except that the allowable stresses and temperature limits of this Code shall govern. Nomenclature shall be as defined in the BPV Code, except for the following:
 - P = design gage pressure
 - S_a = bolt design stress at atmospheric temperature⁴
 - S_b = bolt design stress at design temperature⁴
 - S_f = allowable stress for flange material from Table B-1, B-2, or B-3
- (c) The rules in (b) above are not applicable to a flanged joint having a gasket that extends outside the bolts (usually to the outside diameter of the flange).
- (d) For flanges that make solid contact outside the bolts, Section VIII, Division 1, Appendix Y should be used.

A304.5.2 Blind Flanges. Blind flanges not in accordance with para. A303 may be designed in accordance with para. 304.5.2, except that allowable stress S shall be taken from Tables in Appendix B. Otherwise, they shall be qualified as required by para. A304.7.2.

A304.6 Reducers

Reducers not in accordance with para. A303 shall be qualified as required by para. A304.7.2.

A304.7 Pressure Design of Other Components

A304.7.1 Listed Components. Other pressure containing components, manufactured in accordance with standards in Table A326.1 but not covered elsewhere in para. A304, may be utilized in accordance with para. A303.

A304.7.2 Unlisted Components. Pressure design of unlisted components and joints, to which the rules elsewhere in para. A304 do not apply, shall be based on calculations consistent with the design criteria of this Code. Calculations shall be substantiated by one or both of the means stated in (a) and (b) below, considering applicable ambient and dynamic effects in paras. 301.4 through 301.11.

- (a) extensive, successful service experience under comparable design conditions with similarly proportioned components made of the same or like material
- (b) performance test under design conditions including applicable dynamic and creep effects, continued for a time period sufficient to determine the acceptability of the component or joint for its design life

For (a) or (b) above, the designer may interpolate between sizes, wall thicknesses, and pressure classes, and may determine analogies among related materials.

A304.7.3 Nonmetallic Components With Metallic Pressure Parts. Components not covered by standards in Table A326.1, in which both nonmetallic and metallic parts contain the pressure, shall be evaluated by applicable requirements of para. 304.7.2 as well as those of para. A304.7.2.

PART 3 FLUID SERVICE REQUIREMENTS FOR PIPING COMPONENTS

A305 PIPE

Listed pipe may be used in Normal Fluid Service, subject to the limitations of the pressure-containing material and para. A323.4. Unlisted pipe may be used only in accordance with para. A302.2.3.

A306 FITTINGS, BENDS, MITERS, LAPS, AND BRANCH CONNECTIONS

General. Fittings, bends, miters, laps, and branch connections may be used in accordance with paras. A306.1 through A306.5. Pipe and other materials used in such components shall be suitable for the manufacturing process and the fluid service.

A306.1 Pipe Fittings

A306.1.1 Listed Fittings. Listed fittings may be used in Normal Fluid Service subject to limitations on materials.

 $^{^4}$ Bolt design stresses shall not exceed those in Table A-2 or Table A-2M.

A306.1.2 Unlisted Fittings. Unlisted fittings may be used only in accordance with para. A302.2.3.

A306.2 Pipe Bends

A306.2.1 General. A bend made in accordance with para. A332 and verified for pressure design in accordance with para. A304.2.1 shall be suitable for the same service as the pipe from which it is made.

A306.2.2 Corrugated and Other Bends. Bends of other designs (such as creased or corrugated) shall be qualified for pressure design as required by para. A304.7.2.

A306.3 Miter Bends

Except as specified in para. 306.3.2, a miter bend that conforms to para. A304.2.3 may be used in Normal Fluid Service.

A306.4 Fabricated or Flared Laps

The following requirements do not apply to fittings conforming to para. A306.1.

A306.4.1 Fabricated Laps

- (a) The requirements in paras. 306.4.1(a) and (b) shall be met.
- (*b*) Lap material shall be suitable for the service conditions. Pressure design shall be qualified as required by para. A304.7.2.

A306.4.2 Flared Laps. Flared laps shall not be used in nonmetallic piping.

A306.5 Fabricated Branch Connections

The following requirements do not apply to fittings conforming to para. A306.1.

A306.5.1 General. A fabricated branch connection made by bonding the branch pipe directly to the header pipe, with or without added reinforcement as stated in para. 328.5.4, and shown in Fig. 328.5.4, may be used in Normal Fluid Service, provided that pressure design is qualified as required by para. A304.7.2.

A306.5.2 Specific Requirements. Fabricated branch connections shall be made as specified in para. A328.5.

A307 VALVES AND SPECIALTY COMPONENTS

Paragraph 307 applies in its entirety, except that in para. 307.1.2 reference to paras. A302.2.3 and A304.7.2 replaces reference to paras. 302.2.3 and 304.7.2, respectively.

A308 FLANGES, BLANKS, FLANGE FACINGS, AND GASKETS

A308.1 General

Paragraph 308.1 applies, except that in para. 308.1.2 reference to para. A302.2.3 replaces reference to para. 302.2.3.

A308.2 Nonmetallic Flanges

A308.2.1 General

- (a) Flanges shall be adequate, with suitable facing, gasketing, and bolting, to develop the full rating of the joint and to withstand expected external loadings.
- (b) The designer should consult the manufacturer for ratings of flanges.

A308.2.2 Threaded Flanges. Threaded flanges are subject to the requirements for threaded joints in para. A314.

A308.3 Flange Facings

Paragraph 308.3 applies in its entirety.

A308.4 Limitations on Gaskets

See also Appendix F, para. F308.4.

A308.4.1 Lining Used as Facing or Gasket. Lining material extended over the flange face and used as a gasket shall conform to para. 308.4.

A309 BOLTING

Bolting includes bolts, bolt studs, studs, cap screws, nuts, and washers. See Appendix F, para. F309.

A309.1 General

Paragraph 309.1 applies in its entirety.

A309.2 Specific Bolting

Any bolting that meets the requirements of para. 309.1 may be used with any combination of flange materials and flange facings. Joint assembly shall conform to the requirements of para. A335.2.

A309.3 Tapped Holes in Nonmetallic Components

Tapped holes for pressure-retaining bolting in piping components may be used provided pressure design is qualified as required by para. A304.7.2.

PART 4 FLUID SERVICE REQUIREMENTS FOR PIPING JOINTS A310 GENERAL

Paragraph 310 applies in its entirety.

A311 BONDED JOINTS IN PLASTICS

A311.1 General

Bonding shall be in accordance with para. A328 and examination shall be in accordance with para. A341.4.1 for use in Normal Fluid Service, subject to the limitations of the material.

A311.2 Specific Requirements

A311.2.1 Fillet Bonds. A fillet bond may be used only in conjunction with a qualified hot gas welding procedure for bonding (see para. A328.5.2).

A311.2.2 Seal Bonds. A seal bond may be used only to prevent leakage of a threaded joint and only if it has been demonstrated that there will be no deleterious effect on the materials bonded.

A311.2.3 Joints Limited to Category D Fluid Service.

Joints that have been examined in accordance with para. 341.4.2 may be used only for Category D Fluid Service.

A312 FLANGED JOINTS

The designer should consult the manufacturer for ratings of flanged joints in nonmetallic piping and in piping lined with nonmetals.

A313 EXPANDED JOINTS

Paragraph 313 applies in its entirety.

A314 THREADED JOINTS

A314.1 General

A threaded joint is suitable for use in Normal Fluid Service, subject to the limitations of the material and requirements elsewhere in para. A314. A joint conforming to para. 314.1(d) shall not be used.

A314.2 Specific Requirements

A314.2.1 Thermoplastic Piping

- (a) Polyethylene (PE) pipe and tubing shall not be joined by threaded joints.
- (*b*) Threaded joints in other thermoplastic piping shall conform to all of the following:
- (1) The pipe wall shall be at least as thick as Schedule 80 as defined in ASTM D1785.
- (2) Threads shall be NPT, and shall conform to ASME B1.20.1 or ASTM F1498.
- (3) Threads shall conform to applicable standards in Table A326.1.
 - (4) A suitable thread sealant shall be used.

A314.2.2 Reinforced Thermosetting Resin Piping.

Threaded joints in reinforced thermosetting resin (RTR) piping shall conform to the following:

- (a) External threads shall be factory cut or molded on special thick-walled pipe ends.
- (b) Matching internal threads shall be factory cut or molded in the fittings.
- (c) Threading of plain ends of RTR pipe is not permitted, except where such threads are limited to the function of a mechanical lock to matching internal threads

factory cut or molded in the bottom portions of fittings with deep sockets.

(d) Factory cut or molded threaded nipples, couplings, or adapters, bonded to plain-end RTR pipe and fittings, may be used where it is necessary to provide connections to threaded metallic piping.

A314.2.3 Reinforced Plastic Mortar Piping.

Threaded joints are not permitted in reinforced plastic mortar (RPM) piping.

A315 TUBING JOINTS

Paragraph 315 applies in its entirety, subject to material limitations, exclusion of 315.2(b) regarding severe cyclic conditions, and replacement of reference to Table 326.1 and para. 304.7.2 with reference to Table A326.1 and para. A304.7.2, respectively.

A316 CAULKED JOINTS

Paragraph 316 applies in its entirety.

A318 SPECIAL JOINTS

Special joints are those not covered elsewhere in Chapter VII, Part 4, such as bell type and packed gland type joints.

A318.1 General

Paragraph 318.1 applies in its entirety, except that, in para. 318.1.2, reference to para. A304.7.2 replaces reference to para. 304.7.2.

A318.2 Specific Requirements

Paragraph 318.2 applies with the exception of para. 318.2.3.

A318.3 Piping Lined With Nonmetals

A318.3.1 Welding of Metallic Piping

- (a) General. Joints made in accordance with the rules in para. A329.1 may be used in Normal Fluid Service, subject to material limitations.
- (b) Specific Requirements. Welds shall be limited to those that do not affect the serviceability of the lining.

A318.3.2 Flared Linings

- (a) General. Flared ends of linings made in accordance with the rules in para. A329.2 may be used in Normal Fluid Service, subject to material limitations.
- (b) Specific Requirements. Flaring shall be limited to applications that do not affect the serviceability of the lining.

Flexible elastomeric seals conforming to the following may be used in Normal Fluid Service, subject to material limitations:

- (a) Seals for joints in thermoplastic piping shall conform to ASTM D3139.
- (b) Seals for joints in RTR and RPM piping shall conform to ASTM D4161.

PART 5 FLEXIBILITY AND SUPPORT

A319 FLEXIBILITY OF NONMETALLIC PIPING

A319.1 Requirements

A319.1.1 Basic Requirements. Piping systems shall be designed to prevent thermal expansion or contraction, pressure expansion, or movement of piping supports and terminals from causing

- (a) failure of piping or supports from overstrain or fatigue
 - (b) leakage at joints
- (c) detrimental stresses or distortion in piping or in connected equipment (pumps, for example), resulting from excessive thrusts and moments in the piping

A319.1.2 Specific Requirements

- (a) In para. A319, guidance, concepts, and data are given to assist the designer in assuring adequate flexibility in piping systems. No specific stress-limiting criteria or methods of stress analysis are presented since stress-strain behavior of most nonmetals differs considerably from that of metals covered by para. 319 and is less well defined for mathematical analysis.
- (b) Piping systems should be designed and laid out so that flexural stresses resulting from displacement due to expansion, contraction, and other movement are minimized. This concept requires special attention to supports, terminals, and other restraints, as well as to the techniques outlined in para. A319.7. See also para. A319.2.2(b).
- (c) Further information on design of thermoplastic piping can be found in PPI Technical Report TR-21.

A319.2 Concepts

A319.2.1 Displacement Strains. The concepts of strain imposed by restraint of thermal expansion or contraction, and by external movement, described in para. 319.2.1, apply in principle to nonmetals. Nevertheless, the assumption that stresses throughout the piping system can be predicted from these strains because of fully elastic behavior of the piping materials is not generally valid.

(a) In thermoplastics and some RTR and RPM piping, displacement strains are not likely to produce immediate failure but may result in detrimental distortion. Especially in thermoplastic piping, progressive deformation

may occur upon repeated thermal cycling or on prolonged exposure to elevated temperature.

(b) In brittle piping (such as porcelain, glass, etc.) and some RTR and RPM piping, the materials show rigid behavior and develop high displacement stresses up to the point of sudden breakage due to overstrain.

A319.2.2 Displacement Stresses

- (a) Elastic Behavior. The assumption that displacement strains will produce proportional stress over a sufficiently wide range to justify an elastic stress analysis often is not valid for nonmetals. In brittle piping, strains initially will produce relatively large elastic stresses. The total displacement strain must be kept small, however, since overstrain results in failure rather than plastic deformation. In thermoplastic and thermosetting resin piping, strains generally will produce stresses of the overstrained (plastic) type, even at relatively low values of total displacement strain. If a method of flexibility analysis that assumes elastic behavior is selected, the designer must be able to demonstrate its validity for the piping system under consideration, and shall establish safe limits for computed stresses.
- (b) Overstrained Behavior. Stresses cannot be considered proportional to displacement strains throughout a piping system in which an excessive amount of strain may occur in localized portions of the piping [an unbalanced system; see para. 319.2.2(b)] or in which elastic behavior of the piping material cannot be assumed. Overstrain shall be minimized by system layout and excessive displacements shall be minimized by special joints or expansion devices (see para. A319.7).

A319.2.3 Cold Spring. Cold spring is the intentional deformation of piping during assembly to produce a desired initial displacement or reaction. Cold spring may be beneficial in serving to balance the magnitude of the reaction under initial and extreme displacement conditions. When cold spring is properly applied, there is less likelihood of overstrain during initial operation. There is also less deviation from as-installed dimensions during initial operation, so that hangers will not be displaced as far from their original settings. No credit for cold spring is permitted in stress range calculations, or in calculating thrusts and moments.

A319.3 Properties for Flexibility Analysis

A319.3.1 Thermal Expansion Data. Appendix C lists coefficients of thermal expansion for several nonmetals. More precise values in some instances may be obtainable from manufacturers of components. If these values are to be used in stress analysis, the thermal displacements shall be determined as stated in para. 319.3.1.

A319.3.2 Modulus of Elasticity. Appendix C lists representative data on the tensile modulus of elasticity, *E*, for several nonmetals as obtained under typical laboratory rate of strain (loading) conditions. More precise

(16)

values of the short-term and working estimates of effective moduli of elasticity for given conditions of loading and temperature may be obtainable from the manufacturer. For materials and temperatures not listed, refer to ASTM or PPI documents, or to manufacturer's data.

- (a) Because of their viscoelasticity, the effective moduli of thermoplastics under actual conditions of use will depend on both the specific course of the strain (or load) with time and the specific characteristics of the thermoplastic.
- (b) The modulus may also vary with the orientation of the specimen. Because the reinforcement plays a significant role in developing the physical properties for RTR and RPM piping, the modulus may vary with the type and orientation of the reinforcement.
- (16) A319.3.3 Poisson's Ratio. Poisson's ratio varies widely depending upon material and temperature. For that reason, simplified formulas used in stress analysis for metals may not be valid for nonmetals. For RTR and RPM piping, Poisson's ratio varies with the orientation of the reinforcement.

A319.3.4 Dimensions. Nominal thicknesses and outside diameters of pipe and fittings shall be used in flexibility calculations.

A319.4 Analysis

A319.4.1 Formal Analysis Not Required. No formal analysis is required for a piping system that

- (a) duplicates, or replaces without significant change, a system operating with a successful service record
- (b) can readily be judged adequate by comparison with previously analyzed systems, or
- (c) is laid out with a conservative margin of inherent flexibility, or employs joining methods or expansion joint devices, or a combination of these methods, in accordance with manufacturers' instructions

A319.4.2 Formal Analysis Requirements. For a piping system that does not meet the above criteria, the designer shall demonstrate adequate flexibility by simplified, approximate, or comprehensive stress analysis, using a method that can be shown to be valid for the specific case. If substantially elastic behavior can be demonstrated for the piping system [see para. A319.2.2(a)], methods outlined in para. 319.4 may be applicable.

A319.5 Reactions

Paragraph 319.5 may be applicable if a formal stress analysis can be shown to be valid for the specific case.

A319.6 Movements

Special attention shall be given to movement (displacement or rotation) of piping with respect to supports and points of close clearance. Movements of the run pipe at the junction of a small branch connection shall be considered in determining the need for flexibility in the branch pipe.

A319.7 Means of Increasing Flexibility

Piping layout often provides adequate inherent flexibility through changes in direction, wherein displacements produce chiefly bending and torsional strains of low magnitude. The amount of tension or compression strain (which can produce larger reactions) usually is small.

Where piping lacks inherent flexibility or is unbalanced, additional flexibility shall be provided by one or more of the following means: bends, loops, or offsets; swivel or flexible joints; corrugated, bellows, or slip-joint expansion joints; or other devices permitting angular, rotational, or axial movement. Suitable anchors, ties, or other devices shall be provided as necessary to resist end forces produced by fluid pressure, frictional resistance to movement, and other causes.

A321 PIPING SUPPORT

Paragraph 321 applies in its entirety.

A321.5 Supports for Nonmetallic Piping

- **A321.5.1 General.** In addition to other applicable requirements of para. 321, supports, guides, and anchors shall be selected and applied to comply with the principles and requirements of para. A319 and the following:
- (a) Piping shall be supported, guided, and anchored in such a manner as to prevent damage to the piping. Point loads and narrow areas of contact between piping and supports shall be avoided. Suitable padding shall be placed between piping and supports where damage to piping may occur.
- (b) Valves and equipment that would transmit excessive loads to the piping shall be independently supported to prevent such loads.
- (c) Consideration shall be given to mechanical guarding in traffic areas.
- (d) Manufacturers' recommendations for support shall be considered.

A321.5.2 Supports for Thermoplastic, RTR, and RPM

Piping. Supports shall be spaced to avoid excessive sag or deformation at the design temperature and within the design life of the piping system. Decreases in the modulus of elasticity with increasing temperature and creep of material with time shall be considered when applicable. The coefficient of thermal expansion shall be considered in the design and location of supports.

A321.5.3 Supports for Brittle Piping. Brittle piping, such as glass, shall be well supported but free of hindrance to expansion or other movement. Not more than one anchor shall be provided in any straight run without an expansion joint.

PART 6 SYSTEMS

A322 SPECIFIC PIPING SYSTEMS

A322.3 Instrument Piping

Paragraph 322.3 applies in its entirety, except that references to paras. A301 and A302.2.4 replace references to paras. 301 and 302.2.4, respectively.

A322.6 Pressure-Relieving Systems

Paragraph 322.6 applies in its entirety, except for para. 322.6.3. See para. A322.6.3.

A322.6.3 Overpressure Protection. Paragraph 322.6.3 applies, except that maximum relieving pressure shall be in accordance with para. A302.2.4.

PART 7 MATERIALS

A323 GENERAL REQUIREMENTS

A323.1 Materials and Specifications

Paragraph 323.1 applies except for para. 323.1.4. See para. A323.1.4.

A323.1.4 Reclaimed Materials. Reclaimed piping components may be used, provided they are properly identified as conforming to a listed or published specification (see para. 323.1.1) and otherwise meet the requirements of this Code. The user shall verify that components are suitable for the intended service. Sufficient cleaning, examination, and testing shall be performed to determine the minimum available wall thickness and freedom from any of the following to an extent that would be unacceptable in the intended service:

- (a) imperfections
- (b) reduction of mechanical properties, or
- (c) absorption of deleterious substances

A323.2 Temperature Limitations

The designer shall verify that materials that meet other requirements of the Code are suitable for service throughout the operating temperature range. Also see the Notes for Tables B-1 through B-5 in Appendix B.

A323.2.1 Upper Temperature Limits, Listed Materials

- (a) Except as provided in (b) below, a listed material shall not be used at a design temperature higher than the maximum for which a stress value or rating is shown, or higher than the maximum recommended temperature in Table A323.4.2C for RTR materials and in Table A323.4.3 for thermoplastics used as linings.
- (b) A listed material may be used at a temperature higher than the maximum stated in (a) above if there is no prohibition in Appendix B or elsewhere in the Code,

and if the designer verifies the serviceability of the material in accordance with para. 323.2.4.

A323.2.2 Lower Temperature Limits, Listed Materials

- (a) Materials for use at design minimum temperatures below certain limits must usually be tested to determine that they have suitable toughness for use in Code piping. Table A323.2.2 sets forth those requirements.
- (b) When materials are qualified for use at temperatures below the minimum temperature listed in Appendix B, the allowable stresses or pressures shall not exceed the values for the lowest temperatures shown.
- (c) See also the recommended limits in Table A323.4.2C for reinforced thermosetting resin pipe and in Table A323.4.3 for thermoplastics used as linings.

A323.2.3 Temperature Limits, Unlisted Materials. Paragraph 323.2.3 applies.

A323.2.4 Verification of Serviceability. When an unlisted material is to be used, or when a listed material is to be used above or below the limits in Appendix B or Table A323.4.2C or Table A323.4.3, the designer shall comply with the requirements of para. 323.2.4.

A323.4 Fluid Service Requirements for Nonmetallic Materials

A323.4.1 General

- (a) Nonmetallic materials shall be safeguarded against excessive temperature, shock, vibration, pulsation, and mechanical abuse in all fluid services.
- (b) Requirements in para. A323.4 apply to pressure-containing parts. They do not apply to materials used for supports, gaskets, or packing. See also Appendix F, para. FA323.4.

A323.4.2 Specific Requirements

- (a) Thermoplastics
- (1) They shall not be used in flammable fluid service above ground, unless all of the following are met:
- (a) The size of the piping does not exceed DN 25 (NPS 1).
 - (b) Owner's approval is obtained.
- (c) Safeguarding in accordance with Appendix G is provided.
- (*d*) The precautions of Appendix F, paras. F323.1(a) through (c) are considered.
- (2) They shall be safeguarded when used in other than Category D Fluid Service.
- (3) PVC and CPVC shall not be used in compressed air or other compressed gas service.
- (b) Reinforced Plastic Mortars (RPM) Piping. This piping shall be safeguarded when used in other than Category D Fluid Service.

Table A323.2.2 Re	auirements for Lov	v Temperature	Toughness	Tests for	Nonmetals
-------------------	--------------------	---------------	-----------	-----------	-----------

Type of Material	Column A At or Above Listed Minimum Temperature	Column B Below Listed Minimum Temperature
Listed nonmetallic materials	No added requirement	The designer shall have test results at or below the lowest expected service temperature, which assure that the materials and bonds will have adequate toughness and are suitable at the design minimum temperature.
Unlisted materials	An unlisted material shall conform to a published specification. Where composition, properties, and product form are comparable to those of a listed material, requirements for the corresponding listed material shall be met. Other unlisted materials shall be qualified as required in Column B.	

GENERAL NOTE: These requirements are in addition to the requirements of the material specification.

Table A323.4.2C Recommended Temperature Limits for Reinforced Thermosetting Resin Pipe

			Recommended To	emperature Limits	
Materials		Min	imum	Max	imum
Resin	Reinforcing	°C	°F	°C	°F
Ероху	Glass fiber	-29	-20	149	300
Phenolic	Glass fiber	-29	-20	149	300
Furan	Carbon	-29	-20	93	200
Furan	Glass fiber	-29	-20	93	200
Polyester	Glass fiber	-29	-20	93	200
Vinyl ester	Glass fiber	-29	-20	93	200

GENERAL NOTE: These temperature limits apply only to materials listed and do not reflect evidence of successful use in specific fluid services at these temperatures. The designer should consult the manufacturer for specific applications, particularly as the temperature limits are approached.

- (c) Reinforced Thermosetting Resins (RTR) Piping. This piping shall be safeguarded when used in toxic or flammable fluid services. Table A323.4.2C gives the recommended temperature limits for reinforced thermosetting resins.
 - (d) Borosilicate Glass and Porcelain
- (1) They shall be safeguarded when used in toxic or flammable fluid services.
- (2) They shall be safeguarded against large, rapid temperature changes in fluid services.

A323.4.3 Piping Lined With Nonmetals

- (a) Metallic Piping Lined With Nonmetals. Fluid service requirements for the base (outer) material in para. 323.4 govern except as stated in (d) below.
- (b) Nonmetallic Piping Lined With Nonmetals. Fluid service requirements for the base (outer) material in para. A323.4.2 govern, except as stated in (d) below.
- (c) Nonmetallic Lining Materials. The lining may be any material that, in the judgment of the user, is suitable for the intended service and for the method of manufacture and assembly of the piping. Fluid service requirements in para. A323.4.2 do not apply to materials used as linings.

(*d*) Properties of both the base and lining materials, and of any bond between them, shall be considered in establishing temperature limitations. Table A323.4.3 gives recommended temperature limits for thermoplastic materials used as linings.

A323.5 Deterioration of Materials in Service

Paragraph 323.5 applies in its entirety.

A325 MATERIALS — MISCELLANEOUS

Paragraph 325 applies in its entirety.

PART 8 STANDARDS FOR PIPING COMPONENTS

A326 DIMENSIONS AND RATINGS OF COMPONENTS

A326.1 Requirements

Paragraph 326 applies in its entirety except that references to Table A326.1 and Appendix B replace references to Table 326.1 and Appendix A, respectively.

Table A323.4.3 Recommended Temperature Limits for
Thermoplastics Used as Linings

Materials	Mini	mum	Maxi	mum
[Note (1)]	°C	°F	°C	°F
PFA	-198	-325	260	500
PTFE	-198	-325	260	500
FEP	-198	-325	204	400
ECTFE	-198	-325	171	340
ETFE	-198	-325	149	300
PVDF	-18	0	135	275
PP	-18	0	107	225
PVDC	-18	0	79	175

GENERAL NOTE: These temperature limits are based on material tests and do not necessarily reflect evidence of successful use as piping component linings in specific fluid services at these temperatures. The designer should consult the manufacturer for specific applications, particularly as temperature limits are approached.

NOTE:

(1) See para. A326.4 for definitions of materials.

(16) A326.4 Abbreviations in Table A326.1 and Appendix B

The abbreviations tabulated below are used in this Chapter to replace lengthy phrases in the text, in the titles of standards in Table A326.1, and in the Specification Index for Appendix B. Those marked with an asterisk (*) are in accordance with ASTM D1600, Standard Terminology for Abbreviated Terms Relating to Plastics. Those items marked with a dagger (†) are in accordance with ASTM F412, Standard Terminology Relating to Plastic Piping Systems.

Abbreviation	Term
ABS*†	Acrylonitrile-butadiene-styrene plastics
BPS	Bonding Procedure Specification
CPVC*†	Chlorinated poly(vinyl chloride) plastics
DR†	Dimension ratio
DS	Design stress
E-CTFE*	Ethylene-chlorotrifluoroethylene
ETFE*	Ethylene-tetrafluoroethylene copolymer
FEP*	Perfluoro (ethylene-propylene) copolymer
HDBS	Hydrostatic Design Basis Stress
HDS†	Hydrostatic Design Stress
PB*†	Polybutylene-1
PE*†	Polyethylene
PEX	Cross-linked polyethylene
PFA*	Perfluoro (alkoxyalkane)
PP*†	Polypropylene
PQR	Procedure Qualification Record
PR†	Pressure rating
PTFE*	Polytetrafluoroethylene
PVC*†	Poly(vinyl chloride)
PVDC*	Poly(vinylidene chloride)
PVDF*	Poly(vinylidene fluoride)
RPM	Reinforced plastic mortar
RTP	Reinforced thermosetting plastic
RTR	Reinforced thermosetting resin
SDR†	Standard dimension ratios
SIDR†	Standard inside diameter dimension ratio
WPS	Welding Procedure Specification

PART 9 FABRICATION, ASSEMBLY, AND ERECTION

A327 GENERAL

Piping materials and components are prepared for assembly and erection by one or more of the fabrication processes in paras. A328, A329, A332, and A334. When any of these processes is used in assembly and erection, requirements are the same as for fabrication.

A328 BONDING OF PLASTICS

Paragraph A328 applies only to joints in thermoplastic, RTR, and RPM piping. Bonding shall conform to paras. A328.1 through A328.7 and the applicable requirements of para. A311.

A328.1 Bonding Responsibility

Each employer is responsible for the bonding done by personnel of his organization and, except as provided in paras. A328.2.2 and A328.2.3, shall conduct the required performance qualification tests to qualify bonding procedure specifications (BPS) and bonders or bonding operators.

A328.2 Bonding Qualifications

A328.2.1 Qualification Requirements

(a) Qualification of the BPS to be used, and of the performance of bonders and bonding operators, is required. To qualify a BPS, all tests and examinations specified therein and in para. A328.2.5 shall be completed successfully.

Table A326.1 Component Standards

Socket-Type ABS Plastic Pipe Fittings, Sch 40 ASTM D2468 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 Plastic Insert Fittings for Pt Plastic Pipe ASTM D2609 Socket-Type PE Fittings for Outside Diameter-Controlled PE Pipe and Tubing ASTM D2609 Socket-Type PE Fittings for Outside Diameter Outrolled PE Pipe and Tubing ASTM D2608 ASTM D2608 ASTM D28046/D2846M Butt Heat Fusion PE Plastic Fittings for PE Plastic Pipe and Tubing. ASTM D3840 ASTM D8412 Fiberglass Rr Pipe Fittings for Nonpriessure Applications [Note (11)]. ASTM D3840 ASTM D3840 ASTM D8412 Fiberglass Pressure Pipe Fittings ASTM D8412 Fiberglass Pressure Pipe Fittings ASTM D8412 ASTM D5421 Fiberglass Pressure Pipe Fittings, Sch 80 ASTM D8412 Fiberglass Pressure Pipe Fittings, Sch 40. ASTM F1840 CPVC Plastic Pipe Fittings, Sch 40. ASTM F1840 ASTM P494 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1840 ASTM F1854 Pressure-Rated Polypropylene (PP) Piping Systems ASTM F1848 Plastic Industrial Ball Valves [Notes (2) and (3)] ASTM F1848 Pressure-Rated Polypropylene (PP) Piping Systems ASTM F1840 ASTM F1	Standard or Specification	Designation
Threaded PVC Plastic Pipe Fittings, Sch 80. ASTM D2466 PVC Plastic Pipe Fittings, Sch 40. ASTM D2467 Socket-Type ABS Plastic Pipe Fittings, Sch 40. ASTM D2467 Socket-Type ABS Plastic Pipe Fittings, Sch 40. ASTM D2467 Socket-Type ABS Plastic Pipe Fittings, Sch 40. ASTM D2467 Socket-Type ABS Plastic Pipe, Tubing, and Fittings ASTM D2457 Plastic Index Reinings For Plastic Pipe ASTM D2517 Plastic Insert Fittings for D2512 Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2533 CPVC Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2533 CPVC Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2536 PPP Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2536 PPP Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2536 PPP Plastic Hot- and Cold-Water D1stribution Systems. ASTM D25369 Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2540 A	Nonmetallic Fittings, Valves, and Flanges	
Threaded PVC Plastic Pipe Fittings, Sch 80. ASTM D2466 PVC Plastic Pipe Fittings, Sch 40. ASTM D2467 Socket-Type ABS Plastic Pipe Fittings, Sch 40. ASTM D2467 Socket-Type ABS Plastic Pipe Fittings, Sch 40. ASTM D2467 Socket-Type ABS Plastic Pipe Fittings, Sch 40. ASTM D2467 Socket-Type ABS Plastic Pipe, Tubing, and Fittings ASTM D2457 Plastic Index Reinings For Plastic Pipe ASTM D2517 Plastic Insert Fittings for D2512 Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2533 CPVC Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2533 CPVC Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2536 PPP Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2536 PPP Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2536 PPP Plastic Hot- and Cold-Water D1stribution Systems. ASTM D25369 Plastic Hot- and Cold-Water D1stribution Systems. ASTM D2540 A	Process Glass Pine and Fittings	ASTM C599
PVC Plastic Pipe Fittings, Sch 80 . ASTM D2467 Socket-Type ABS Plastic Pipe Fittings, Sch 40 . ASTM D2468 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings . ASTM D2517 Plasto Insert Fittings for Pc Plastic Pipe . ASTM D2517 Plasto Insert Fittings for Pc Plastic Pipe . ASTM D2517 Plasto Insert Fittings for Pc Plastic Pipe . ASTM D2517 Plasto Insert Fittings for Pc Plastic Pipe . ASTM D2687 ASTM D2687 ASTM D2687 ASTM D2687 Plastic Hot- and Cold-Water Distribution Systems . ASTM D2680 ASTM D2684/D2846M Butt Heat Fusion Pc Plastic Fittings for Pc Plastic Pipe and Tubing. ASTM D2684/D2846M Butt Heat Fusion Pc Plastic Fittings for Pc Plastic Pipe and Tubing. ASTM D309 Fiberglass RTR Pipe Fittings for Pc Plastic Pipe and Tubing. ASTM D309 Fiberglass RTR Pipe Fittings for Pc Plastic Pipe Resident Pipe Resi		
PVC Plastic Pipe Fittings, Sch 80 . ASTM D2467 Socket-Type ABS Plastic Pipe Fittings, Sch 40 . ASTM D2468 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings . ASTM D2517 Plasto Insert Fittings for Pc Plastic Pipe . ASTM D2517 Plasto Insert Fittings for Pc Plastic Pipe . ASTM D2517 Plasto Insert Fittings for Pc Plastic Pipe . ASTM D2517 Plasto Insert Fittings for Pc Plastic Pipe . ASTM D2687 ASTM D2687 ASTM D2687 ASTM D2687 Plastic Hot- and Cold-Water Distribution Systems . ASTM D2680 ASTM D2684/D2846M Butt Heat Fusion Pc Plastic Fittings for Pc Plastic Pipe and Tubing. ASTM D2684/D2846M Butt Heat Fusion Pc Plastic Fittings for Pc Plastic Pipe and Tubing. ASTM D309 Fiberglass RTR Pipe Fittings for Pc Plastic Pipe and Tubing. ASTM D309 Fiberglass RTR Pipe Fittings for Pc Plastic Pipe Resident Pipe Resi	PVC Plastic Pipe Fittings, Sch 40	ASTM D2466
Socket-Type ABS Plastic Pipe Fittings, Sch 40 ASTM D2468 Thermoplastic Gas Pressure Pipe, Jubing, and Fittings ASTM D2517 Plastic Insert Fittings for PE Plastic Pipe ASTM D2609 ASTM D2606 ASTM D3606 ASTM D4606 ASTM D2606 ASTM D2		ASTM D2467
Reinforced Epoxy Resin Gas Pressure Pipe and Fittings Plastic Insert Fittings for PE Plastic Pipe ASTM D2609 Socket-Type PE Fittings for Outside Diameter-Controlled PE Pipe and Tubing ASTM D2603 CPVC Plastic Hot- and Cold-Water Distribution Systems ASTM D2846/D2846M Butt Heat Fusion PE Plastic Fittings for PE Plastic Pipe and Tubing. ASTM D3061 PP Plastic Hot- and Cold-Water Distribution Systems ASTM D3069 Fiberglass RTR Pipe Fittings for PE Plastic Pipe and Tubing. ASTM D3061 Fiberglass RTR Pipe Fittings for Nonpressure Applications [Note (1)] ASTM D3061 Fiberglass RTR Pipe Fittings for Nonpressure Applications [Note (1)] ASTM D3062 Contact Molded Fiberglass RTR Flanges [Note (1)] ASTM D3062 Threaded CPVC Plastic Pipe Fittings, Sch 80 ASTM D3063 Threaded CPVC Plastic Pipe Fittings, Sch 80 ASTM D3063 Threaded CPVC Plastic Pipe Fittings, Sch 80 ASTM F437 CPVC Plastic Pipe Fittings, Schedule 80 ASTM F438 CPVC Plastic Pipe Fittings, Schedule 80 ASTM F439 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1054 Pastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] ASTM F1054 Pressure-Rated Polypropriene (PPP Piping Systems ASTM F1045 Pressure-Rated Polypropriene (PPP Piping Systems ASTM F1045 Pressure-Rated Polypropriene (PPP Piping Systems ASTM C3061 Process Glass Pipe and Fittings ASTM C3061 Process Glass Pipe and Fittings ASTM C3061 Process Glass Pipe and Fittings ASTM C3061 Process Glass Pipe, Sch 40 and 80 ASTM D2107 PVC Plastic Pipe, Sch 40 and 80 ASTM D2310 PVC Plastic Pipe, Sch 40 and 80 ASTM D2330 PPC Plastic Pipe (SiDR-PR) ASTM D2330 PPC Plastic Pipe, Sch 40 a 80, Based on Outside Diameter. ASTM D2330 PPC Plastic Pipe, Sch 40 a 80, Based on Outside Diameter. ASTM D2330 PPC Plastic Pipe, Sch 40 a 80, Based on Outside Diameter. ASTM D2330 PP Plastic Pipe, Sch 40 a 80, Based on Outside Diameter. ASTM D2330 PP Plastic Pipe (SiDR-PR) ASTM D2306 ASTM D2310 PP Plastic Pipe (SiDR-PR) ASTM D2407 ASTM D2407 PPC Plastic Pipe (SiDR-PR) ASTM D2407 ASTM D2406 AS		ASTM D2468
Plastic Insert Fittings for DE Plastic Pipe Socket-Type PE Fittings for Outside Diameter-Controlled PE Pipe and Tubing ASTM D2683 CPVC Plastic Hot- and Cold-Water Distribution Systems ASTM D26846/D2846M Butt Heat Fusion PE Plastic Fittings for PE Plastic Pipe and Tubing. ASTM D3693 Elberglass RTR Pipe Fittings for Nonpressure Applications (Note (1)) ASTM D3840 Machine Made "Fiberglass" (Glass-Fiber-Reinforced Thermosetting Resin) Flanges ASTM D3840 Machine Made "Fiberglass" (Glass-Fiber-Reinforced Thermosetting Resin) Flanges ASTM D471 Fiberglass Pressure Pipe Fittings (Note (1)) ASTM D472 Fiberglass Pressure Pipe Fittings, Sch 80 ASTM D472 Fiberglass Pressure Pipe Fittings, Sch 80 ASTM D472 Fiberglass Pressure Pipe Fittings, Sch 40 ASTM D472 Fiberglass Pressure Pipe Fittings, Sch 40 ASTM P473 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing Electrofusion Type PE Fittings, and Flanges (Notes (2) and (3)) ASTM P473 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges (Notes (2) and (3)) ASTM P473 Plastic Industrial Ball Valves (Notes (2) and (3)] Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Low Pressure Fated Pulypropylene (Pp) Piping Systems ASTM D473 ASTM D473 ASTM D474 ASTM D474 ASTM D474 ASTM D475 ASTM D476 AST	Thermoplastic Gas Pressure Pipe, Tubing, and Fittings	ASTM D2513
Socket-Type PE Fittings for Outside Diameter-Controlled PE Pipe and Tubing. Butt Heat Fusion PE Plastic Hot- and Cold-Water Distribution Systems. ASTM D2846/D2846M Butt Heat Fusion PE Plastic Fittings for PE Plastic Pipe and Tubing. Butt Heat Fusion PE Plastic Fittings for PE Plastic Pipe and Tubing. PP Plastic Hot- and Cold-Water Distribution Systems. ASTM D3309 Fiberglass RTR Pipe Fittings for Nonpressure Applications [Note (11)]. ASTM D3840 ASTM D3840 ASTM D3840 ASTM D474 Contact Molded Fiberglass RTR Flanges [Note (1)]. ASTM D5421 Fiberglass Pressure Pipe Fittings ASTM D5421 Fiberglass Pressure Pipe Fittings, Sch 80. ASTM D5421 Fiberglass Pressure Pipe Fittings, Sch 40. ASTM F1386 CPVC Plastic Pipe Fittings, Sch 40. ASTM F1386 CPVC Plastic Pipe Fittings, Sch 40. ASTM F1386 ASTM P439 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1365 Pressure-Rated Polypropylene (PP) Piping Systems. ASTM F1365 Pressure-Rated Polypropylene (PP) Piping Systems. ASTM F1365 Nonmetallic Pipes and Tubes PE Line Pipe. API 15LE Low Pressure Fiberglass Line Pipe. API 15LE Low Pressure Fiberglass Line Pipe. API 15LE Low Pressure Fiberglass Line Pipe. API 15LE ASTM C599 ASSTM C599 ASSTM D1367 ASSTM D1367 ASSTM D2367 ASSTM D2367 ASSTM D2367 ASSTM D2367 ASSTM D2370 ASSTM D2370 ASSTM D2310 PP Plastic Pipe, Sch 40 and 80. ASSTM D2310 PP Plastic Pipe, Sch 40, 80 and 120. ASSTM D2310 PP Plastic Pipe, Sch 40, 80 and 120. ASSTM D2320 ASSTM D2320 ASSTM D23210 PP Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASSTM D2310 PE Plastic Pipe (SDR-PR). ASSTM D23210 PE Plastic Pipe (SDR-PR). ASSTM D23210 PP Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASSTM D23210 PP Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASSTM D23210 ASSTM D23210 ASSTM D23210 PE Plastic Pipe (SDR-PR). ASSTM D23267 PP Plastic Pipe (SDR-PR). ASSTM D23267 PP Plastic Pipe (SDR-PR). ASSTM D23667 ASSTM D23667 ASSTM D23667 ASSTM D2367 ASSTM	Reinforced Epoxy Resin Gas Pressure Pipe and Fittings	ASTM D2517
CPVC Plastic Hot- and Cold-Water Distribution Systems. ASTM D2846/D2846M Butt Heat Fusion PE Plastic Fittings for PE Plastic Pipe and Tubing. ASTM D3261 PB Plastic Hot- and Cold-Water Distribution Systems ASTM D3309 Fiberglass RFR pipe Fittings for Nonpressure Applications [Note (1)]. ASTM D3840 Machine Made "Fiberglass" (Glass-Fiber-Reinforced Thermosetting Resin) Flanges ASTM D4024 Contact Molded Fiberglass RFR Flanges [Note (1)]. ASTM D5431 Fiberglass Pressure Pipe Fittings ASTM D5685 Threaded CPVC Plastic Pipe Fittings, Sch 80. ASTM P437 Socket-Type CPVC Plastic Pipe Fittings, Sch 40. ASTM F437 Socket-Type CPVC Plastic Pipe Fittings, Sch 40. ASTM F438 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. Electrofusion Type PE Fittings, Sch 80. ASTM F438 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] ASTM F1345 Pressure-Rated Polypropylene (PP) Piping Systems ASTM F1345 Pressure-Rated Polypropylene (PP) Piping Systems ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. ASTM F2389 Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings ASTM D1527 ASTM D2539 ASTM D2539 ASTM D2539 ASTM D2399 PVC Plastic Pipe, Sch 40, and 80. ASTM D2547 ASTM D2239 PVC Plastic Pipe, Sch 40, 80, Based on Controlled Inside Diameter. ASTM D2310 PP Plastic Pipe, Sch 40, 80, Based on Outside Diameter. ASTM D2310 PP Plastic Pipe, Sch 40, 8, 80, Based on Outside Diameter. ASTM D2310 PP Plastic Pipe, Sch 40, 8, 80, Based on Outside Diameter. ASTM D2317 PP Plastic Pipe, Sch 40, 8, 80, Based on Outside Diameter. ASTM D2317 PP Plastic Pipe, Sch 40, 8, 80, Based on Outside Diameter. ASTM D2317 PP Plastic Pipe, Sch 40, 8, 80, Based on Outside Diameter. ASTM D2317 PP Plastic Pipe, Sch 40, 8, 80, Based on Outside Diameter. ASTM D2366 ASTM D2367 PP Plastic Pipe, Sch 40, 8, 80, Based on Outside Diameter. ASTM D2366 ASTM D2367 PP Plastic		ASTM D2609
Butt Heat Fusion PE Plastic Fittings for PE Plastic Pipe and Tubing. PB Plastic Hot- and Cold-Water Distribution Systems ASTM D3309 Fiberglass RIR Pipe Fittings for Nonpressure Applications [Note (1)]. ASTM D3309 Fiberglass RIR Pipe Fittings for Nonpressure Applications [Note (1)]. ASTM D3840 ASTM D4024 Contact Molded Fiberglass RIR Flanges [Note (1)]. ASTM D5421 Fiberglass Pressure Pipe Fittings ASTM D5421 Fiberglass Pressure Pipe Fittings, Sch 80. ASTM D5421 Fiberglass Pressure Pipe Fittings, Sch 80. ASTM P5436 Socket-Type CPVC Plastic Pipe Fittings, Sch 40. ASTM F437 Socket-Type CPVC Plastic Pipe Fittings, Sch 40. ASTM F438 CPVC Plastic Pipe Fittings, Sch 40. ASTM F439 Electrofusion Type PE Fittings, Sch 40. ASTM F1439 Electrofusion Type PE Fittings, Sch 40. ASTM F1439 Electrofusion Type PE Fittings, ASTM P1055 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] ASTM F1545 Plastic-lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] ASTM F1545 Plastic-lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] ASTM F1549 Plastic Industrial Ball Valves [Notes (2) and (3)]. Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LF Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings. ASTM D1547 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1547 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1247 ASTM D2239 PVC Plastic Pipe, Sch 40, 80, Based on Outside Diameter. ASTM D2310 PE Plastic Pipe (SDR-PR). ASTM D2328 Classification for Machine-Made RTR Pipe ASTM D2330 PE Plastic Pipe (SDR-PR). ASTM D2347 ASTM D2351 Reinforced Epoxy Resin Gas Pressure Pipe, Tubing, and Fittings ASTM D2351 Reinforced Epoxy Resin Gas Pressure Pipe, Tubing, and Fittings ASTM D2366 Joints for IPS PVC Pipe Using Solvent Cement ASTM D2866 Joints for IPS PVC Pipe Using Solvent Cement ASTM D2866 Joints for IPS PVC Pipe Using Sol		ASTM D2683
PB Plastic Hot- and Cold-Water Distribution Systems Fiberglass RTR Pipe Fittings for Nonpressure Applications (Note (1)) ASTM D3809	CPVC Plastic Hot- and Cold-Water Distribution Systems	ASTM D2846/D2846M
PB Plastic Hot- and Cold-Water Distribution Systems Fiberglass RTR Pipe Fittings for Nonpressure Applications (Note (1)) ASTM D3809	Butt Heat Fusion PE Plastic Fittings for PE Plastic Pipe and Tubing	ASTM D3261
Fiberglass RTR Pipe Fittings for Nonpressure Applications (Note (1)). ASTM D8404 Contact Molded Fiberglass "(Glass-Fiber-Reinforced Thermostling Resin) Flanges ASTM D4024 Contact Molded Fiberglass RTR Flanges [Note (1)]. Fiberglass Pressure Pipe Fittings ASTM D5421 Fiberglass Pressure Pipe Fittings ASTM D5685 Threaded CPVC Plastic Pipe Fittings, Sch 80. ASTM F437 Socket-Fype CPVC Plastic Pipe Fittings, Sch 40. ASTM F437 Socket-Fype CPVC Plastic Pipe Fittings, Sch 40. ASTM F437 Socket-Fype CPVC Plastic Pipe Fittings, Sch 40. ASTM F439 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F439 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1055 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges (Notes (2) and (3)] ASTM F1389 Plastic Industrial Ball Valves [Notes (2) and (3)]. ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. ASTM F2389 PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Pipe Fiberglass Line Pipe API 15LE ASTM C599 ASS Plastic Pipe, Sch 40 and 80 ASTM D1527 PVC Plastic Pipe, Sch 40 and 80 ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1239 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D2282 Classification for Machine-Made RTR Pipe ASTM D2382 PPC Plastic Pipe, Sch 40, 80, Based on Outside Diameter ASTM D2467 PP Plastic Pipe, Sch 40, 80, Based on Outside Diameter ASTM D2467 PP Plastic Tubing, ASTM D2662 PP Plastic Tubing, ASTM D2667 PP Plastic Tubing, ASTM D2667 PPC Plastic Tubing, ASTM D2667 PPC Plastic Tubing, ASTM D2966 Filament-Wound Fiberglass RTR Pipe [Note (1)].		
Machine Made "Fiberglass" (Glass-Fiber-Reinforced Thermosetting Resin) Flanges ASTM DA024 Contact Molded Fiberglass RTR Flanges [Note (1)]. ASTM D5421 Fiberglass Pressure Pipe Fittings. ASTM D5685 ASTM D5685 Threaded CPVC Plastic Pipe Fittings, Sch 80. ASTM F437 Socket-Type CPVC Plastic Pipe Fittings, Sch 40. ASTM F438 CPVC Plastic Pipe Fittings, Sch 40. ASTM F438 CPVC Plastic Pipe Fittings, Schedule 80 ASTM F438 CPVC Plastic Pipe Fittings, Schedule 80 ASTM F439 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1055 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] ASTM F1545 Pressure-Rated Polypropylene (PP) Piping Systems ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. MS5 SP-122 Nonmetallic Pipes and Tubes PE Line Pipe AP 15LE Low Pressure Fiberglass Line Pipe AP 15LE Low Pressure Fiberglass Line Pipe AP 15LE Process Glass Pipe and Fittings ASTM C599 ASS Plastic Pipe, Sch 40 and 80 ASTM C599 ASS Plastic Pipe, Sch 40, 80 and 120 ASTM C599 ASS Plastic Pipe, Sch 40, 80 and 120 ASTM D1378 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1362 ASTM D2341 ASS Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter ASTM D2341 ASS Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter ASTM D2341 ASS Plastic Pipe (SIDR-PR) ASTM D2342 ASS Plastic Pipe (SIDR-PR) ASTM D2343 ASS Plastic Pipe (SIDR-PR) ASTM D2344 ASS Plastic Pipe (SIDR-PR) ASTM D2343 ASTM D2343 ASS Plastic Pipe (SIDR-PR). ASTM D2344 ASS Plastic Pipe (SIDR-PR). ASTM D2343 ASS Plastic Pipe (SIDR-PR). ASTM D2344 ASS Plastic Pipe (SIDR-PR). ASTM D2345 ASSM D2345 ASSM D2345 ASSM D2345 ASSM D2345 ASSM D		ASTM D3840
Contact Molded Fiberglass RTR Flanges [Note (1)] . ASTM D5425 [iberglass Pressure Pipe Fittings . ASTM D5685 [iberglass Pressure Pipe Fittings, Sch 80 . ASTM F437 Socket-Type CPVC Plastic Pipe Fittings, Sch 80 . ASTM F438 CPVC Plastic Pipe Fittings, Sch 40 . ASTM F438 CPVC Plastic Pipe Fittings, Sch 40 . ASTM F438 CPVC Plastic Pipe Fittings, Schedule 80 . ASTM F438 CPVC Plastic Pipe Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1055 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] . ASTM F1055 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] . ASTM F1368 Pressure-Rated Polypropylene (PP) Piping Systems . ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)] . MSS SP-122 Nonmetallic Pipes and Tubes PE Line Pipe . API 15LE Low Pressure Fiberglass Line Pipe . API 15LE Low Pressure Fiberglass Line Pipe . API 15LE Low Pressure Fiberglass Line Pipe . ASTM C361 Process Glass Pipe and Fittings . ASTM D2529 PVC Plastic Pipe, Sch 40 and 80 . ASTM D1785 PL Plastic Pipe, Sch 40, 80 and 120 . ASTM D1785 PPC Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter . ASTM D2239 PVC Plastic Pipe, Sch 40, 80, Based on Controlled Inside Diameter . ASTM D2231 PVC Plastic Pipe, Sch 40, 80, Based on Outside Diameter . ASTM D2241 ABS Plastic Pipe (SDR-PR) . ASTM D2241 ABS Plastic Pipe (SDR-PR) . ASTM D2310 PE Plastic Pipe (SDR-PR) . ASTM D2313 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings . ASTM D2313 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings . ASTM D2662 PB Plastic Tubing . ASTM D2662 PB Plastic Tubing . ASTM D2664 [Dints for IPS PVC Pipe Using Solvent Cement . ASTM D2666 [Dints for IPS PVC Pipe Using Solvent Cement . ASTM D2666 [Dints for IPS PVC Pipe Using Solvent Cement . ASTM D2666 [Dints for IPS PVC Pipe Using Solvent Cement . ASTM D2666 [Dints for IPS PVC Pipe Using Solvent Cement . ASTM D266		ASTM D4024
Fiberglass Pressure Pipe Fittings		ASTM D5421
Socket-Type CPVC Plastic Pipe Fittings, Sch 40. ASTM F438 CPVC Plastic Pipe Fittings, Schedule 80. ASTM F439 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1365 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] ASTM F1345 Pressure-Rated Polyproplyene (PP) Piping Systems ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. MSS SP-122 Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings. ASTM C361 Process Glass Pipe and Fittings. ASTM C361 PVC Plastic Pipe, Sch 40 and 80. ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120. ASTM D1527 PVC Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D2399 PVC Plastic Pipe (SDR-PR). ASTM D2390 PVC Plastic Pipe (SDR-PR). ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2517 PB Plastic Tubing. ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement ASTM D26467 PE Plastic Hot- and Cold-Water Distribution System ASTM D2986 Filament-Wound Fiberglass RTR Pipe (Note (1)). ASTM D2986 Filament-Wound Fiberglass RTR Pipe (Note (1)).		ASTM D5685
Socket-Type CPVC Plastic Pipe Fittings, Sch 40. ASTM F438 CPVC Plastic Pipe Fittings, Schedule 80. ASTM F439 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1365 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] ASTM F1345 Pressure-Rated Polyproplyene (PP) Piping Systems ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. MSS SP-122 Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings. ASTM C361 Process Glass Pipe and Fittings. ASTM C361 PVC Plastic Pipe, Sch 40 and 80. ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120. ASTM D1527 PVC Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D2399 PVC Plastic Pipe (SDR-PR). ASTM D2390 PVC Plastic Pipe (SDR-PR). ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter. ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2517 PB Plastic Tubing. ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement ASTM D26467 PE Plastic Hot- and Cold-Water Distribution System ASTM D2986 Filament-Wound Fiberglass RTR Pipe (Note (1)). ASTM D2986 Filament-Wound Fiberglass RTR Pipe (Note (1)).	Threaded CPVC Plastic Pipe Fittings, Sch 80	ASTM F437
CPVC Plastic Pipe Fittings, Schedule 80 ASTM F439 Electrofusion Type PE Fittings for Outside Diameter Controlled PE Pipe and Tubing. ASTM F1055 Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)]. ASTM F1345 Pressure-Rated Polypropylene (PP) Piping Systems ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. MSS SP-122 Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LR Reinforced Concrete Low-Head Pressure Pipe ASTM C361 ASTM C361 ASTM C369 ABS Plastic Pipe, Sch 40 and 80 ASTM 01527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM 01527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D2239 PVC Plastic Pipe (SDR-PR) Based on Controlled Inside Diameter. ASTM D2239 PVC Plastic Pipe (SDR-PR) ASTM D2230 PVC Plastic Pipe, Sch 40 & 80, Based on Outside Diameter PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2513 PB Plastic Pipe (SDR-PR) ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement ASTM D2672 PE Plastic Tubing ASTM D2846/D2846M Filament-Wound fiberglass RTR Pipe [Note (1)]. ASTM D29466 ASTM D2946		
Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] Pressure-Rated Polypropylene (PP) Piping Systems ASTM F1545 Pressure-Rated Polypropylene (PP) Piping Systems ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LR Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings ASTM C361 Process Glass Pipe and Fittings ASTM C361 PVC Plastic Pipe, Sch 40 and 80 ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1527 PVC Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D239 PVC Plastic Pipe (SDR-PR) ASTM D2310 PE Plastic Pipe (SDR-PR) ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2311 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2662 PB Plastic Tubing. ASTM D2666 Dints for IPS PVC Pipe Using Solvent Cement ASTM D2737 CPVC Plastic Tubing. ASTM D2737 CPVC Plastic Tubing. ASTM D2846/D2846M Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2846		
Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)] Pressure-Rated Polypropylene (PP) Piping Systems ASTM F1545 Pressure-Rated Polypropylene (PP) Piping Systems ASTM F2389 Plastic Industrial Ball Valves [Notes (2) and (3)]. Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LR Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings ASTM C361 Process Glass Pipe and Fittings ASTM C361 PVC Plastic Pipe, Sch 40 and 80 ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1527 PVC Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D239 PVC Plastic Pipe (SDR-PR) ASTM D2310 PE Plastic Pipe (SDR-PR) ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2311 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2662 PB Plastic Tubing. ASTM D2666 Dints for IPS PVC Pipe Using Solvent Cement ASTM D2737 CPVC Plastic Tubing. ASTM D2737 CPVC Plastic Tubing. ASTM D2846/D2846M Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2846	Flectrofusion Type PF Fittings for Outside Diameter Controlled PF Pipe and Tubing	ASTM F1055
Pressure-Rated Polypropylene (PP) Piping Systems Plastic Industrial Ball Valves [Notes (2) and (3)]. Nonmetallic Pipes and Tubes PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LF Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings ASTM C361 Process Glass Pipe and Fittings ASTM D1527 PVC Plastic Pipe, Sch 40 and 80 ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1785 PE Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D2239 PVC Plastic Pressure-Rated Pipe (SDR Series) ASTM D2239 PVC Plastic Pipe (SDR-PR) ASTM D2241 ASTM D2282 Classification for Machine-Made RTR Pipe ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2662 PB Plastic Tubing ASTM D2662 PB Plastic Tubing ASTM D2672 PE Plastic Tubing ASTM D2673 CPVC Plastic Hot- and Cold-Water Distribution System ASTM D2846/D2846M Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2896		
Plastic Industrial Ball Valves [Notes (2) and (3)]. Nonmetallic Pipes and Tubes PE Line Pipe		
PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LR Reinforced Concrete Low-Head Pressure Pipe API 15LR Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings ASTM C361 Process Glass Pipe and Fittings ASTM C599 ABS Plastic Pipe, Sch 40 and 80 ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1785 PE Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D2239 PVC Plastic Pressure-Rated Pipe (SDR Series) ASTM D2241 ABS Plastic Pipe (SDR-PR) ASTM D2282 Classification for Machine-Made RTR Pipe ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 PB Plastic Pipe (SDR-PR) ASTM D2562 PB Plastic Tubing ASTM D2662 PB Plastic Tubing ASTM D2662 PB Plastic Tubing Solvent Cement ASTM D2672 PE Plastic Tubing ASTM D2846/D2846M Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2996		
PE Line Pipe API 15LE Low Pressure Fiberglass Line Pipe API 15LR Reinforced Concrete Low-Head Pressure Pipe API 15LR Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings ASTM C361 Process Glass Pipe and Fittings ASTM C599 ABS Plastic Pipe, Sch 40 and 80 ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1785 PE Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D2239 PVC Plastic Pressure-Rated Pipe (SDR Series) ASTM D2241 ABS Plastic Pipe (SDR-PR) ASTM D2282 Classification for Machine-Made RTR Pipe ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 PB Plastic Pipe (SDR-PR) ASTM D2562 PB Plastic Tubing ASTM D2662 PB Plastic Tubing ASTM D2662 PB Plastic Tubing Solvent Cement ASTM D2672 PE Plastic Tubing ASTM D2846/D2846M Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2996		
Low Pressure Fiberglass Line PipeAPI 15LRReinforced Concrete Low-Head Pressure PipeASTM C361Process Glass Pipe and FittingsASTM C599ABS Plastic Pipe, Sch 40 and 80ASTM D1527PVC Plastic Pipe, Sch 40, 80 and 120ASTM D1785PE Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter.ASTM D2239PVC Plastic Pressure-Rated Pipe (SDR Series)ASTM D2241ABS Plastic Pipe (SDR-PR)ASTM D2282Classification for Machine-Made RTR PipeASTM D2310PE Plastic Pipe, Sch 40 & 80, Based on Outside DiameterASTM D2447Thermoplastic Gas Pressure Pipe, Tubing, and FittingsASTM D2513Reinforced Epoxy Resin Gas Pressure Pipe and FittingsASTM D2517PB Plastic Pipe (SDR-PR)ASTM D2517PB Plastic TubingASTM D2662PB Plastic TubingASTM D2672PE Plastic TubingASTM D2672PE Plastic TubingASTM D2672PE Plastic TubingASTM D2846/D2846MFilament-Wound Fiberglass RTR Pipe [Note (1)]ASTM D2846/D2846MFilament-Wound Fiberglass RTR Pipe [Note (1)]ASTM D2996	Nonmetallic Pipes and Tubes	
Reinforced Concrete Low-Head Pressure Pipe ASTM C361 Process Glass Pipe and Fittings ASTM C599 ABS Plastic Pipe, Sch 40 and 80 ASTM D1527 PVC Plastic Pipe, Sch 40, 80 and 120 ASTM D1785 PE Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D2239 PVC Plastic Pressure-Rated Pipe (SDR Series) ASTM D2241 ABS Plastic Pipe (SDR-PR) ASTM D2282 Classification for Machine-Made RTR Pipe ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe, Tubing, and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2662 PB Plastic Tubing ASTM D2662 PB Plastic Tubing ASTM D2672 PE Plastic Tubing ASTM D2672 PE Plastic Tubing ASTM D2846/D2846M Filament-Wound Fiberglass RTR Pipe [Note (1)].		API 15LE
Process Glass Pipe and Fittings . ASTM C599 ABS Plastic Pipe, Sch 40 and 80		API 15LR
ABS Plastic Pipe, Sch 40 and 80		ASTM C361
PVC Plastic Pipe, Sch 40, 80 and 120 PE Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D2239 PVC Plastic Pressure-Rated Pipe (SDR Series) ASTM D2241 ABS Plastic Pipe (SDR-PR) Classification for Machine-Made RTR Pipe ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2662 PB Plastic Tubing ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement ASTM D2737 CPVC Plastic Hot- and Cold-Water Distribution System ASTM D2996	Process Glass Pipe and Fittings	ASTM C599
PE Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter. ASTM D2239 PVC Plastic Pressure-Rated Pipe (SDR Series) ASTM D2241 ABS Plastic Pipe (SDR-PR) Classification for Machine-Made RTR Pipe ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2662 PB Plastic Tubing ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement ASTM D2672 PE Plastic Tubing ASTM D2737 CPVC Plastic Hot- and Cold-Water Distribution System Filament-Wound Fiberglass RTR Pipe [Note (1)].	ABS Plastic Pipe, Sch 40 and 80	ASTM D1527
PVC Plastic Pressure-Rated Pipe (SDR Series) ASTM D2241 ABS Plastic Pipe (SDR-PR) Classification for Machine-Made RTR Pipe ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR) ASTM D2662 PB Plastic Tubing ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement ASTM D2672 PE Plastic Tubing ASTM D2737 CPVC Plastic Hot- and Cold-Water Distribution System Filament-Wound Fiberglass RTR Pipe [Note (1)].	PVC Plastic Pipe, Sch 40, 80 and 120	ASTM D1785
ASTM D2282 Classification for Machine-Made RTR Pipe ASTM D2310 PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter ASTM D2447 Thermoplastic Gas Pressure Pipe, Tubing, and Fittings ASTM D2513 Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2662 PB Plastic Tubing. ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement ASTM D2672 PE Plastic Tubing. ASTM D2737 CPVC Plastic Hot- and Cold-Water Distribution System ASTM D2846/D2846M Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2996		ASTM D2239
Classification for Machine-Made RTR Pipe		ASTM D2241
PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter		ASTM D2282
Thermoplastic Gas Pressure Pipe, Tubing, and Fittings Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2662 PB Plastic Tubing. ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement. ASTM D2672 PE Plastic Tubing. ASTM D2737 CPVC Plastic Hot- and Cold-Water Distribution System Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2996	Classification for Machine-Made RTR Pipe	ASTM D2310
Thermoplastic Gas Pressure Pipe, Tubing, and Fittings Reinforced Epoxy Resin Gas Pressure Pipe and Fittings ASTM D2517 PB Plastic Pipe (SDR-PR). ASTM D2662 PB Plastic Tubing. ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement. ASTM D2672 PE Plastic Tubing. ASTM D2737 CPVC Plastic Hot- and Cold-Water Distribution System Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2996	PE Plastic Pipe, Sch 40 & 80, Based on Outside Diameter	ASTM D2447
PB Plastic Pipe (SDR-PR). ASTM D2662 PB Plastic Tubing. ASTM D2666 Joints for IPS PVC Pipe Using Solvent Cement. PE Plastic Tubing. ASTM D2672 PE Plastic Tubing. ASTM D2737 CPVC Plastic Hot- and Cold-Water Distribution System Filament-Wound Fiberglass RTR Pipe [Note (1)]. ASTM D2996	Thermoplastic Gas Pressure Pipe, Tubing, and Fittings	ASTM D2513
PB Plastic Tubing	Reinforced Epoxy Resin Gas Pressure Pipe and Fittings	ASTM D2517
Joints for IPS PVC Pipe Using Solvent Cement ASTM D2672 PE Plastic Tubing ASTM D2737 CPVC Plastic Hot- and Cold-Water Distribution System ASTM D2846/D2846M Filament-Wound Fiberglass RTR Pipe [Note (1)] ASTM D2996		ASTM D2662
PE Plastic Tubing	<u>e</u>	ASTM D2666
CPVC Plastic Hot- and Cold-Water Distribution System	Joints for IPS PVC Pipe Using Solvent Cement	ASTM D2672
CPVC Plastic Hot- and Cold-Water Distribution System	PE Plastic Tubing	ASTM D2737
Filament-Wound Fiberglass RTR Pipe [Note (1)]		ASTM D2846/D2846M
		ASTM D2997

Table A326.1 Component Standards (Cont'd)

Standard or Specification	Designation
Nonmetallic Pipes and Tubes (Cont'd)	
PB Plastic Pipe (SDR-PR) Based on Outside Diameter	ASTM D3000
PE Plastic Pipe (DR-PR) Based on Controlled Outside Diameter	ASTM D3035
PB Plastic Hot- and Cold-Water Distribution Systems	ASTM D3309
Fiberglass RTR Pressure Pipe [Note (1)]	ASTM D3517
Fiberglass RTR Sewer and Industrial Pressure Pipe [Note (1)]	ASTM D3754
CPVC Plastic Pipe, Sch 40 and 80	ASTM F441/F441M
CPVC Plastic Pipe (SDR-PR)	ASTM F442/F442M
Crosslinked Polyethylene/Aluminum/Crosslinked Polyethylene (PEX-AL-PEX) Pressure Pipe	ASTM F1281
Polyethylene/Aluminum/Polyethylene (PE-AL-PE) Composite Pressure Pipe	ASTM F1282
Polyolefin Pipe and Fittings for Corrosive Waste Drainage Systems [Notes (2) and (3)]	ASTM F1412
Plastic-Lined Ferrous Metal Pipe, Fittings, and Flanges [Notes (2) and (3)]	ASTM F1545
PVDF Corrosive Waste Drainage Systems	ASTM F1673
Pressure-Rated Polypropylene (PP) Piping Systems	ASTM F2389
Metric and Inch-sized Crosslinked Polyethylene (PEX) Pipe	ASTM F2788/F2788M
Reinforced Concrete Pressure Pipe, Steel Cylinder Type, for Water and Other Liquids	AWWA C300
Prestressed Concrete Pressure Pipe, Steel Cylinder Type, for Water and Other Liquids	AWWA C301
Reinforced Concrete Pressure Pipe, Noncylinder Type	AWWA C302
PVC Pressure Pipe, 4-inch through 12-inch, for Water	AWWA C900
Fiberglass Pressure Pipe	AWWA C950
Miscellaneous	
Contact-Molded RTP Laminates for Corrosion Resistant Equipment	ASTM C582
Threads for Fiberglass RTR Pipe (60 deg stub) [Note (1)]	ASTM D1694
Solvent Cements for ABS Plastic Pipe and Fittings	ASTM D2235
Solvent Cements for PVC Plastic Piping Systems	ASTM D2564
Joints for Plastic Pressure Pipes Using Flexible Elastomeric Seals	ASTM D3139
Fiberglass RTR Pipe Joints Using Flexible Elastomeric Seals [Note (1)]	ASTM D4161
Design and Construction of Nonmetallic Enveloped Gaskets for Corrosive Service	ASTM F336
Solvent Cements for CPVC Plastic Pipe and Fittings	ASTM F493
Taper Pipe Threads 60° for Thermoplastic Pipe and Fittings	ASTM F1498
Crosslinked Polyethylene Composite Pressure Pipe	ASTM F1974

GENERAL NOTE: It is not practical to refer to a specific edition of each standard throughout the Code text. Instead, the approved edition references, along with the names and addresses of the sponsoring organizations, are shown in Appendix E.

- (1) The term fiberglass RTR takes the place of the ASTM designation fiberglass (glass-fiber-reinforced thermosetting resin).
- (2) This Standard allows the use of unlisted materials; see para. 323.1.2.
- (3) This Standard contains no pressure-temperature ratings.

- (*b*) In addition to the procedure for making the bonds, the BPS shall specify at least the following:
- (1) all materials and supplies (including storage requirements)
- (2) tools and fixtures (including proper care and handling)
- (3) environmental requirements (e.g., temperature, humidity, and methods of measurement)
 - (4) joint preparation
 - (5) dimensional requirements and tolerances
 - (6) cure time
 - (7) protection of work
- (8) tests and examinations other than those required by para. A328.2.5
- (9) acceptance criteria for the completed test assembly
- **A328.2.2 Procedure Qualification by Others.** Subject to the specific approval of the Inspector, a BPS qualified by others may be used provided that
- (a) the Inspector satisfies him/herself that the proposed qualified BPS has been prepared and executed by a responsible recognized organization with expertise in the field of bonding
- (b) by signature, the employer accepts both the BPS and procedure qualification record (PQR) as his own
- (c) the employer has at least one currently employed bonder who, while in his employ, has satisfactorily passed a performance qualification test using the proposed qualified BPS

A328.2.3 Performance Qualification by Others.

Without the Inspector's specific approval, an employer shall not accept a performance qualification test made by a bonder or bonding operator for another employer. If approval is given, it is limited to work on piping using the same or equivalent BPS. An employer accepting such performance qualification tests shall obtain a copy of the performance qualification test record from the previous employer showing the name of the employer by whom the bonder or bonding operator was qualified, the date of such qualification, and the date the bonder or bonding operator last bonded pressure piping under such performance qualification.

A328.2.4 Qualification Records. The employer shall maintain a self-certified record, available to the owner or owner's agent and to the Inspector, of the BPS used and the bonders or bonding operators employed by him/her, and showing the dates and results of BPS qualifications and bonding performance qualifications.

A328.2.5 Qualification Tests. Tests, as specified in para. A328.2.1(a), shall be performed to qualify each BPS and the performance of each bonder and bonding operator. Test assemblies shall conform to (a) below and the test method shall be in accordance with either (b) or (c).

- (a) Test Assembly. The assembly shall be fabricated in one pipe size in accordance with the BPS and shall contain at least one of each different type of joint identified in the BPS. More than one test assembly may be prepared if necessary to accommodate all of the joint types or to assure that at least one of each joint type is loaded in both circumferential and longitudinal directions. The size of pipe and fittings in the assembly shall be as follows:
- (1) When the largest size to be qualified is DN 100 (NPS 4) or smaller, the test assembly shall be the largest size qualified.
- (2) When the largest size to be qualified is greater than DN 100 (NPS 4), the size of the test assembly shall be between 25% and 100% of the largest piping size qualified, but shall be a minimum of DN 100 (NPS 4).
- (b) Burst Test Method. The test assembly shall be subjected to a burst test in accordance with the applicable sections of ASTM D1599.⁵ The time to burst in this standard may be extended. The test is successful if failure initiates outside of any bonded joint.
- (c) Hydrostatic Test Method. The test assembly shall be subjected to hydrostatic pressure of at least P_T for not less than 1 hr with no leakage or separation of joints.
- (1) For thermoplastics, P_T shall be determined in accordance with eq. (27)

$$P_T = 0.80\overline{T} \left(\frac{S_S + S_H}{D - \overline{T}} \right) \tag{27}$$

where

D = outside diameter of pipe

 S_H = mean long term hydrostatic strength (LTHS) in accordance with ASTM D2837. Use twice the 23°C (73°F) HDB design stress from Table B-1 if listed, or use manufacturer's data.

 S_S = mean short term burst stress in accordance with ASTM D1599,⁵ from Table B-1 if listed, otherwise from manufacturer's data

 \overline{T} = nominal thickness of pipe

- (2) For RTR (laminated and filament-wound) and RPM, P_T shall be three times the manufacturer's allowable pressure for the components being joined.
- (3) The test shall be conducted so that the joint is loaded in both the circumferential and longitudinal directions.

A328.2.6 Performance Requalification. Renewal of a bonding performance qualification is required when

⁵ Titles of referenced standards and specifications are listed in Table A326.1, except ASTM D1599, Test Method for Resistance to Short-Time Hydraulic Pressure of Plastic Pipe, Tubing, and Fittings; ASTM D2657, Practice for Heat Fusion Joining of Polyolefin Pipe and Fittings; ASTM D2855, Practice for Making Solvent-Cemented Joints with PVC Pipe and Fittings; and ASTM F1290, Practice for Electrofusion Joining Polyolefin Pipe and Fittings.

- (a) a bonder or bonding operator has not used the specific bonding process for a period of 6 mo or more, or
- (b) there is specific reason to question the individual's ability to make bonds that meet the BPS

A328.3 Bonding Materials and Equipment

A328.3.1 Materials. Bonding materials that have deteriorated by exposure to air or prolonged storage, or will not spread smoothly, shall not be used in making joints.

A328.3.2 Equipment. Fixtures and tools used in making joints shall be in such condition as to perform their functions satisfactorily.

A328.4 Preparation for Bonding

Preparation shall be defined in the BPS and shall specify such requirements as

- (a) cutting
- (b) cleaning
- (c) preheat
- (d) end preparation
- (e) fit-up

A328.5 Bonding Requirements

A328.5.1 General

- (a) Production joints shall be made only in accordance with a written bonding procedure specification (BPS) that has been qualified in accordance with para. A328.2. Manufacturers of piping materials, bonding materials, and bonding equipment should be consulted in the preparation of the BPS.
- (b) Production joints shall be made only by qualified bonders or bonding operators who have appropriate training or experience in the use of the applicable BPS and have satisfactorily passed a performance qualification test that was performed in accordance with a qualified BPS.
- (c) Each qualified bonder and bonding operator shall be assigned an identification symbol. Unless otherwise specified in the engineering design, each pressure-containing bond or adjacent area shall be stenciled or otherwise suitably marked with the identification symbol of the bonder or bonding operator. Identification stamping shall not be used and any marking paint or ink shall not be detrimental to the piping material. In lieu of marking the bond, appropriate records may be filed.
- (d) Qualification in one BPS does not qualify a bonder or bonding operator for any other bonding procedure.
 - (e) Longitudinal joints are not covered in para. A328.

A328.5.2 Hot Gas Welded Joints in Thermoplastic Piping $^{\rm 5}$

(a) Preparation. Surfaces to be hot gas welded together shall be cleaned of any foreign material. For butt welds, the joining edges should be beveled at 20 deg to 40 deg with 1 mm ($\frac{1}{32}$ in.) root face and root gap.

- (*b*) *Procedure.* Joints shall be made in accordance with the qualified BPS.
- (c) Branch Connections. A fabricated branch connection shall be made by inserting the branch pipe in the hole in the run pipe. Dimensions of the joint shall conform to Fig. 328.4.4 sketch (c). The hole in the run pipe shall be beveled at 45 deg. Alternatively, a fabricated branch connection shall be made using a manufactured full reinforcement saddle with integral socket.

A328.5.3 Solvent Cemented Joints in Thermoplastic Piping 5

- (a) Preparation. Thermoplastic pipe and fitting surfaces shall be prepared in accordance with ASTM D2855 for PVC, ASTM F493 for CPVC, and ASTM D2235 for ABS. A dry fit test of each joint is required before solvent cementing. The pipe shall enter the fitting socket between one-third and two-thirds of the full socket depth when assembled by hand.
- (b) Procedure. Joints shall be made in accordance with the qualified BPS. ASTM D2855 provides a suitable basis for development of such a procedure. Solvent cements for PVC, CPVC, and ABS shall conform to ASTM D2564, D2846, and D2235, respectively. Application of cement to both surfaces to be joined and assembly of these surfaces shall produce a continuous bond between them with visual evidence of cement at least flush with the outer end of the fitting bore around the entire joint perimeter. See Fig. A328.5.3.
- (c) Branch Connections. A fabricated branch connection shall be made using a manufactured full reinforcement saddle with integral branch socket. The reinforcement saddle shall be solvent cemented to the run pipe over its entire contact surface.

A328.5.4 Heat Fusion Joints in Thermoplastic Piping 5

- (a) Preparation. Surfaces to be heat fused together shall be cleaned of all foreign material.
- (b) Procedure. Joints shall be made in accordance with the qualified BPS. The general procedures in ASTM D2657, Techniques I Socket Fusion, II Butt Fusion, and III Saddle Fusion, provide a suitable basis for development of such a procedure. Uniform heating of both surfaces to be joined and assembly of these surfaces shall produce a continuous homogeneous bond between them and shall produce a small fillet of fused material at the outer limits of the joint. See Fig. A328.5.4 for typical heat fusion joints. Fixtures shall be used to align components when joints are made.
- (c) Branch Connections. A fabricated branch connection is permitted only where molded fittings are unavailable.

A328.5.5 Electrofusion Joints in Thermoplastic Piping ⁵

(a) Preparation. Surfaces to be heat fused together shall be cleaned of all foreign material.

Fig. A328.5 Typical Plastic Piping Joints




FIG. A328.5.3 THERMOPLASTIC SOLVENT CEMENTED JOINT

FIG. A328.5.4 THERMOPLASTIC HEAT FUSION JOINTS




FIG. A328.5.5 THERMOPLASTIC ELECTROFUSION JOINTS




FIG. A328.5.6 FULLY TAPERED THERMOSETTING ADHESIVE JOINT

FIG. A328.5.7 THERMOSETTING WRAPPED JOINTS

(b) Procedure. Joints shall be made in accordance with the qualified BPS. The general procedures in ASTM F1290, Technique I — Coupling Procedure and Technique II — Saddle Procedure provide a suitable basis for the development of such a procedure. See Fig. A328.5.5.

A328.5.6 Adhesive Joints in RTR and RPM Piping

- (a) Procedure. Joints shall be made in accordance with the qualified BPS. Application of adhesive to the surfaces to be joined and assembly of these surfaces shall produce a continuous bond between them and shall seal over all cuts to protect the reinforcement from the service fluid. See Fig. A328.5.6.
- (b) Branch Connections. A fabricated branch connection shall be made using a manufactured full reinforcement saddle having a socket or integral length of branch pipe suitable for a nozzle or coupling. The hole in the run pipe shall be made with a hole saw; the cut edges of the hole shall be sealed with adhesive at the time the saddle is bonded to the run pipe.

A328.5.7 Butt-and-Wrapped Joints in RTR and RPM Piping 5

- (a) Procedure. Joints shall be made in accordance with the qualified BPS. Application of plies of reinforcement saturated with catalyzed resin to the surfaces to be joined shall produce a continuous structure with them. Cuts shall be sealed to protect the reinforcement from the service fluid. See Fig. A328.5.7.
- (b) Branch Connections. For a fabricated branch connection made by inserting the branch pipe into a hole in the run pipe, the hole shall be made with a hole saw.

A328.6 Bonding Repair

Defective material, joints, and other workmanship that fails to meet the requirements of this Code and of the engineering design shall be repaired or replaced. See also para. 341.3.3.

A328.7 Seal Bonds

If threaded joints are to be seal bonded in accordance with para. A311.2.2, the work shall be done by qualified bonders and all exposed threads shall be covered by the seal bond.

A329 FABRICATION OF PIPING LINED WITH NONMETALS

A329.1 Welding of Metallic Piping

A329.1.1 General

- (a) Paragraph A329.1 applies only to welding subassemblies of metallic piping that have previously been lined with nonmetals.
- (b) Welding that conforms to para. A329.1 may be used in accordance with para. A318.3.1.

- **A329.1.2 Specific Welding Requirements.** Welding shall conform to the requirements of para. 328 and the following additional requirements:
- (a) Modifications made in preparation for welding to suit manufacturer's recommendations shall be specified in the engineering design.
- (*b*) Welding shall be performed so as to maintain the continuity of the lining and its serviceability.
- (c) If a lining has been damaged, it shall be repaired or replaced.
- (d) Qualification to one WPS for a specific lining material does not qualify a welder or welding operator for any other welding procedure involving different lining materials.

A329.2 Flaring of Nonmetallic Linings

A329.2.1 General

- (a) Paragraph A329.2 applies only to the flaring of linings in pipe that has previously been lined with nonmetals
- (*b*) Flaring that conforms to para. A329.2 may be used in accordance with para. A318.3.2.
- (c) Flaring shall be performed only in accordance with a written flaring procedure specification, and only by qualified operators who have appropriate training or experience in the use of the applicable flaring procedure specification.

A332 BENDING AND FORMING

A332.1 General

Paragraph 332.1 applies in its entirety.

A332.2 Bending

Paragraph 332.2 applies, except para. 332.2.2.

A332.3 Forming

Paragraph 332.3 applies, except for heat treatment.

A334 JOINING NONPLASTIC PIPING

A334.1 Borosilicate Glass Piping

Short unflanged pieces used to correct for differences between fabrication drawings and field dimensions may be cut to length and finished in the field.

A334.2 Repair of Defects

Defective material, joints, and other workmanship in nonplastic piping that fail to meet the requirements of para. A334 or of the engineering design shall be repaired or replaced.

Completed repairs and replacements shall be examined, subject to the same limitations on imperfections as the original work.

A335 ASSEMBLY AND ERECTION

A335.1 Alignment

Paragraph 335.1 applies in its entirety.

A335.2 Flanged and Mechanical Joints

Paragraph 335.2 applies in its entirety.

(16) A335.2.5 Nonmetallic Bolted Joints

- (a) Bolted joints in nonmetallic piping may be assembled with any combination of flange material and flange facings, except that the following apply when other than flat face flanges and full face gaskets are used:
- (1) consideration shall be given to the strength of the flanges, and to sustained loads, displacement strains, and occasional loads described in paras. A302.3.3 and A302.3.4
- (2) an appropriate bolt-up sequence shall be specified
- (b) Appropriate limits shall be specified for bolt-up torque, and those limits shall not be exceeded.
- (c) Flat washers shall be used under bolt heads and nuts.

A335.2.6 Metallic Piping Lined With Nonmetals. In assembling mechanical joints in metallic piping lined with nonmetals, consideration shall be given to means for maintaining electrical continuity between pipe sections, where static sparking could cause ignition of flammable vapors. See Appendix F, para. FA323.4(a).

A335.3 Threaded Joints

Paragraph 335.3 applies except for para. 335.3.2. See para. A335.3.2.

A335.3.2 Joints for Seal Bonding. A threaded joint to be seal bonded shall be made up without thread compound. A joint containing thread compound that leaks during leak testing may be seal bonded in accordance with para. A328.6, provided all compound is removed from exposed threads.

A335.3.4 Tools, Nonmetallic Piping. Either strap wrenches or other full circumference wrenches shall be used to tighten threaded pipe joints. Tools and other devices used to hold or apply forces to the pipe shall be such that the pipe surface is not scored or deeply scratched.

A335.3.5 RTR and RPM Piping. In assembling threaded joints in RTR and RPM piping, where threads may be exposed to fluids that can attack the reinforcing material, threads shall be coated with sufficient resin to cover the threads and completely fill the clearance between the pipe and the fitting.

A335.4 Tubing Joints

A335.4.1 Flared Joints in Thermoplastic Tubing. In addition to preparation in accordance with para. 335.4.1,

the end of the tubing shall be cut perpendicular to the tube centerline, preferably with a tubing cutter specially made for thermoplastic tubing. No cuts, scratches, dirt, or surface damage to either inside or outside diameter are permitted on the pipe end to be flared.

A335.4.2 Flareless and Compression Tubing Joints. Paragraph 335.4.2 applies.

A335.5 Caulked Joints

Paragraph 335.5 applies.

A335.6 Special Joints

Paragraph 335.6 applies, except that expanded joints are not permitted.

- **A335.6.3 Flexible Elastomeric Sealed Joints.** Assembly of flexible elastomeric sealed joints shall be in accordance with the manufacturer's recommendations and the following:
- (a) Seal and bearing surfaces shall be free from injurious imperfections.
- (b) Any lubricant used to facilitate joint assembly shall be compatible with the joint components and the intended service.
- (c) Proper joint clearances and piping restraints (if not integral in the joint design) shall be provided to prevent joint separation when expansion can occur due to thermal and/or pressure effects.

A335.8 Assembly of Brittle Piping

A335.8.1 General. Care shall be used to avoid scratching of brittle nonmetallic piping in handling and supporting. Any scratched or chipped components shall be replaced. Care shall be used in handling glass-lined and cement-lined metal pipe because the lining can be injured or broken by blows that do not dent or break the pipe.

A335.8.2 Borosilicate Glass Piping. In addition to the precaution in para. A335.8.1, borosilicate glass piping components shall be protected from weld spatter. Any component so damaged shall be replaced. Flanges and cushion inserts shall be carefully fitted and aligned to pipe, fittings, and valve ends. Gaskets shall be of the construction recommended for the joint. Installation and torquing of bolts shall be in accordance with the manufacturer's recommendations.

A335.9 Cleaning of Piping

See Appendix F, para. F335.9.

PART 10 INSPECTION, EXAMINATION, AND TESTING A340 INSPECTION

Paragraph 340 applies in its entirety.

Table A341.3.2 Acceptance Criteria for Bonds

Kind		RTR and RPM [Note (1)]		
of Imperfection	Hot Gas Welded	Solvent Cemented	Heat Fusion	Adhesive Cemented
Cracks	None permitted	Not applicable	Not applicable	Not applicable
Unfilled areas in joint	None permitted	None permitted	None permitted	None permitted
Unbonded areas in joint	Not applicable	None permitted	None permitted	None permitted
Inclusions of charred material	None permitted	Not applicable	Not applicable	Not applicable
Unfused filler material inclusions	None permitted	Not applicable	Not applicable	Not applicable
Protrusion of material into pipe bore, % of pipe wall thickness	Not applicable	Cement, 50%	Fused material, 25%	Adhesive, 25%

NOTE:

(1) RTR = reinforced thermosetting resin; RPM = reinforced plastic mortar.

A341 EXAMINATION

A341.1 General

Paragraph 341.1 applies.

A341.2 Responsibility for Examination

Paragraph 341.2 applies in its entirety.

A341.3 Examination Requirements

A341.3.1 Responsibility for Examination.

Paragraph 341.3.1 applies, except for (a) and (b), which apply only for metals.

A341.3.2 Acceptance Criteria. Acceptance criteria shall be as stated in the engineering design and shall at least meet the applicable requirements for bonds in Table A341.3.2 and requirements elsewhere in the Code.

A341.3.3 Defective Components and Workmanship.

Paragraph 341.3.3 applies in its entirety.

A341.3.4 Progressive Sampling for Examination. Paragraph 341.3.4 applies in its entirety.

A341.4 Extent of Required Examination

- **A341.4.1 Examination Normally Required.** Piping in Normal Fluid Service shall be examined to the extent specified herein or to any greater extent specified in the engineering design. Acceptance criteria are as stated in para. A341.3.2 unless otherwise specified.
- (a) Visual Examination. At least the following shall be examined in accordance with para. 344.2:
- (1) materials and components in accordance with para. 341.4.1(a)(1).
- (2) at least 5% of fabrication. For bonds, each type of bond made by each bonder and bonding operator shall be represented.

- (3) 100% of fabrication for bonds other than circumferential, except those in components made in accordance with a listed specification.
- (4) assembly and erection of piping in accordance with paras. 341.4.1(a)(4), (5), and (6).
- (b) Other Examination. Not less than 5% of all bonded joints shall be examined by in-process examination in accordance with para. 344.7, the joints to be examined being selected to ensure that the work of each bonder and bonding operator making the production joints is examined.
- (c) Certifications and Records. Paragraph 341.4.1(c) applies.

A341.4.2 Examination — Category D Fluid Service.

Piping and piping elements for Category D Fluid Service as designated in the engineering design shall be visually examined to the extent necessary to satisfy the examiner that components, materials, and workmanship conform to the requirements of this Code and the engineering design.

A341.5 Supplementary Examination

A341.5.1 General. Any applicable method of examination described in para. 344 may be specified by the engineering design to supplement the examination required by para. A341.4. The extent of supplementary examination to be performed and any acceptance criteria that differ from those in para. A341.3.2 shall be specified in the engineering design.

A341.5.2 Examinations to Resolve Uncertainty. Paragraph 341.5.3 applies.

A342 EXAMINATION PERSONNEL

Paragraph 342 applies in its entirety.

A343 EXAMINATION PROCEDURES

Paragraph 343 applies in its entirety.

A344 TYPES OF EXAMINATION

A344.1 General

Paragraph 344.1 applies in its entirety.

A344.2 Visual Examination

Paragraph 344.2 applies in its entirety.

A344.5 Radiographic Examination

Radiographic examination may be used in accordance with para. 344.1.2.

A344.6 Ultrasonic Examination

Ultrasonic examination may be used in accordance with para. 344.1.2.

A344.7 In-Process Examination

Paragraph 344.7 applies in its entirety.

A345 TESTING

A345.1 Required Leak Test

- (a) Prior to initial operation, each piping system shall be tested to ensure tightness. The test shall be a hydrostatic leak test in accordance with para. A345.4, except as provided herein.
 - (b) Paragraphs 345.1(a) and (b) apply.

A345.2 General Requirements for Leak Test

Requirements in para. A345.2 apply to more than one type of leak test.

A345.2.1 Limitations on Pressure. Paragraphs 345.2.1(b) and (c) apply.

A345.2.2 Other Test Requirements

- (a) Paragraph 345.2.2(a) applies.
- (b) The possibility of brittle fracture shall be considered when conducting leak tests on brittle materials or at low temperature.
 - (c) Paragraphs 345.2.3 through 345.2.7 apply.

A345.3 Preparation for Leak Test

Paragraph 345.3 applies in its entirety, considering bonds in place of welds, and excluding expansion joints.

A345.4 Hydrostatic Leak Test

A345.4.1 Test Fluid. Paragraph 345.4.1 applies.

A345.4.2 Test Pressure

(16)

- (a) Nonmetallic Piping. Except as provided in para. A345.4.3, the hydrostatic test pressure at any point in a nonmetallic piping system shall be not less than 1.5 times the design pressure, but shall not exceed 1.5 times the maximum rated pressure of the lowest-rated component in the system.
- (b) Thermoplastic Piping. For piping systems in which the design temperature is above the test temperature, para. 345.4.2(b) applies, except that S and S_T shall be from Table B-1 instead of Table A-1 or Table A-1M.
- (c) Metallic Piping with Nonmetallic Lining. Paragraph 345.4.2 applies.

A345.4.3 Hydrostatic Test of Piping With Vessels as a System. Paragraph 345.4.3 applies.

A345.5 Pneumatic Leak Test

A345.5.1 Precautions. In addition to the requirements of para. 345.5.1, a pneumatic test of nonmetallic piping is permitted only with the owner's approval, and precautions in Appendix F, para. FA323.4 should be considered.

A345.5.2 Other Requirements

- (a) Paragraphs 345.5.2 through 345.5.5 apply.
- (b) PVC and CPVC piping shall not be pneumatically tested.

A345.6 Hydrostatic-Pneumatic Leak Test

If a combined hydrostatic-pneumatic leak test is used, the requirements of para. A345.5 shall be met, and the pressure in the liquid-filled part of the piping shall not exceed the values calculated in accordance with para. A345.4.2 or 345.4.2, as applicable.

A345.7 Initial Service Leak Test

Paragraph 345.7 applies in its entirety for Category D Fluid Service only.

A345.8 Sensitive Leak Test

Paragraph 345.8 applies.

A346 RECORDS

Paragraph 346 applies in its entirety.

Chapter VIII Piping for Category M Fluid Service

M300 GENERAL STATEMENTS

- (a) Chapter VIII pertains to piping designated by the owner as being in Category M Fluid Service. See para. 300(b)(1) and Appendix M.
- (b) The organization, content, and paragraph designations of this Chapter correspond to those of the base Code (Chapters I through VI) and Chapter VII. The prefix M is used.
- (c) Provisions and requirements of the base Code and Chapter VII apply only as stated in this Chapter.
- (d) Consideration shall be given to the possible need for engineered safeguards as described in Appendix G, para. G300.3, in addition to the inherent safeguards described in paras. G300.1 and G300.2.
- (e) This Chapter makes no provision for piping to be used under severe cyclic conditions. If it is not feasible to eliminate the severe cyclic conditions, the engineering design shall specify any necessary provisions in accordance with para. 300(c)(5).
 - (f) Chapter I applies in its entirety.

PART 1 CONDITIONS AND CRITERIA

M301 DESIGN CONDITIONS

Paragraph 301 applies in its entirety, with the exceptions of paras. 301.3 and 301.5. See paras. M301.3 and M301.5.

M301.3 Design Temperature, Metallic Piping

Use of any temperature other than the fluid temperature as the design temperature shall be substantiated by heat transfer calculations confirmed by tests or by experimental measurements.

M301.5 Dynamic Effects

Paragraph 301.5 applies with the exception of paras. 301.5.1 and 301.5.4. See paras. M301.5.1 and M301.5.4.

M301.5.1 Impact. Design, layout, and operation of piping shall be conducted so as to minimize impact and shock loads. In the event that such loadings are unavoidable, para. 301.5.1 applies.

M301.5.4 Vibration. Suitable dynamic analysis, such as computer simulation, shall be made where necessary to avoid or minimize conditions that lead to detrimental vibration, pulsation, or resonance effects in the piping.

M302 DESIGN CRITERIA

M302.1 General

Paragraph M302 pertains to pressure—temperature ratings, stress criteria, design allowances, and minimum design values, together with permissible variations of these factors as applied to piping design. Paragraph 302 applies in its entirety, with the exception of para. 302.2.4. See para. M302.2.4.

M302.2.4 Allowance for Pressure and Temperature Variations, Metallic Piping. Use of allowances in para. 302.2.4 is not permitted.

PART 2 PRESSURE DESIGN OF METALLIC PIPING COMPONENTS

M303 GENERAL

Paragraph 303 applies in its entirety.

M304 PRESSURE DESIGN OF METALLIC COMPONENTS

Paragraph 304 applies in its entirety.

PART 3 FLUID SERVICE REQUIREMENTS FOR METALLIC PIPING COMPONENTS

M305 PIPE

M305.1 General

Listed pipe may be used in accordance with para. M305.2. Unlisted pipe may be used only as provided in para. 302.2.3.

M305.2 Specific Requirements for Metallic Pipe

Pipe listed in para. 305.2.2 shall not be used. The provision for severe cyclic conditions in para. 305.2.3 does not apply [see para. M300(e)].

M306 METALLIC FITTINGS, BENDS, MITERS, LAPS, AND BRANCH CONNECTIONS

General. Fittings, bends, miters, laps, and branch connections may be used in accordance with paras. M306.1 through M306.6. Pipe and other materials used in such

components shall be suitable for the manufacturing process and the fluid service.

M306.1 Pipe Fittings

Paragraph 306.1 applies in its entirety, with the exception of paras. 306.1.3 and 306.1.4. See para. M306.1.3.

M306.1.3 Specific Fittings

- (*a*) Proprietary welding branch outlet fittings that have been design proof tested successfully as prescribed in ASME B16.9, MSS SP-97, or the BPV Code, Section VIII, Division 1, UG-101 may be used within their established ratings.
- (b) Fittings conforming to MSS SP-43 and MSS SP-119 shall not be used.
- (c) Proprietary "Type C" lap-joint stub-end buttwelding fittings shall not be used.

M306.2 Pipe Bends

Paragraph 306.2 applies, except that bends designed as creased or corrugated shall not be used.

M306.3 Miter Bends

A miter bend shall conform to para. 306.3.1 and shall not make a change in direction at a single joint (angle α in Fig. 304.2.3) greater than 22.5 deg. Paragraph 306.3.3 does not apply [see para. M300(e)].

M306.4 Fabricated or Flared Laps

M306.4.1 General. The following requirements do not apply to fittings conforming to para. M306.1, nor to laps integrally forged on pipe ends. Paragraph 306.4.1 applies.

M306.4.2 Flared Laps. Flared laps shall not be used.

M306.5 Fabricated Branch Connections

The following requirements do not apply to fittings conforming to para. M306.1. Paragraph 306.5.1 applies, with the following exceptions:

- (a) Of the methods listed in para. 304.3.1(a), the one in subpara. (3) may be used only if those in (1) and (2) are unavailable.
- (*b*) Of the branch connections described in paras. 304.3.2(b) and (c), those having threaded outlets are permitted only in accordance with para. M314 and those having socket welding outlets are permitted only in accordance with para. M311.2.

M306.6 Closures

The following requirements do not apply to blind flanges or to fittings conforming to para. M306.1. Of the closures described in para. 304.4, flat closures in accordance with the BPV Code, Section VIII, Division 1, UG-34 and UW-13, and conical closures without transition knuckles [UG-32(g) and UG-33(f)], may be used only if others are not available. The requirements in

M306.5 apply to openings in closures [see also para. 304.4.2(b)].

M307 METALLIC VALVES AND SPECIALTY COMPONENTS

The following requirements for valves shall also be met as applicable by other pressure-containing piping components, e.g., traps, strainers, and separators. See also Appendix F, paras. F301.4 and F307.

M307.1 General

Paragraph 307.1 applies, subject to the requirements in para. M307.2.

M307.2 Specific Requirements

- (a) Paragraph 307.2.2 applies.
- (b) Valves having threaded bonnet joints (other than union joints) shall not be used.
- (c) Only metallic valves conforming to the following requirements may be used:
- (1) Special consideration shall be given to valve design to prevent stem leakage to the environment.
- (2) Bonnet or cover plate closures and body joints shall be flanged, secured by at least four bolts with gasketing conforming to para. 308.4; or proprietary, attached by bolts, lugs, or other substantial means, and having a gasket design that increases gasket compression as fluid pressure increases; or secured with a full penetration weld made in accordance with para. M311; or secured by a straight thread sufficient for mechanical strength, a metal-to-metal seat, and a seal weld made in accordance with para. M311, all acting in series.

M308 FLANGES, BLANKS, FLANGE FACINGS, AND GASKETS

Paragraph 308.1 applies in its entirety.

M308.2 Specific Requirements for Metallic Flanges

Paragraph 308.2.4 does not apply [see para. M300(e)]. The following shall not be used:

- (a) single-welded slip-on flanges
- (b) expanded-joint flanges
- (c) slip-on flanges used as lapped flanges unless the requirements in para. 308.2.1(c) are met
- (d) threaded metallic flanges, except those employing lens rings or similar gaskets and those used in lined pipe where the liner extends over the gasket face

M308.3 Flange Facings

Paragraph 308.3 applies in its entirety.

M308.4 Gaskets

Paragraph 308.4 applies in its entirety.

M308.5 Blanks

All blanks shall be marked with material, rating, and size.

M309 BOLTING

Paragraph 309 applies, except for para. 309.2.4 [see para. M300(e)].

PART 4 FLUID SERVICE REQUIREMENTS FOR METALLIC PIPING JOINTS

M310 METALLIC PIPING, GENERAL

Paragraph 310 applies in its entirety.

M311 WELDED JOINTS IN METALLIC PIPING

Welded joints may be made in any metal for which it is possible to qualify welding procedures, welders, and welding operators in accordance with para. M328.

M311.1 General

Paragraph 311.1 applies with the following exceptions:

- (a) Split backing rings shall not be used.
- (b) Socket welded joints greater than DN 50 (NPS 2) are not permitted.
- (c) Examination shall be in accordance with para. M341.4.

M311.2 Specific Requirements

Paragraphs 311.2.4(a); 311.2.5(a), (b), and (d); 311.2.6; and 311.2.7 apply.

M312 FLANGED JOINTS IN METALLIC PIPING

Paragraph 312 applies in its entirety.

M313 EXPANDED JOINTS IN METALLIC PIPING

Expanded joints shall not be used.

M314 THREADED JOINTS IN METALLIC PIPING M314.1 General

Paragraphs 314.1(a), (b), and (c) apply.

M314.2 Specific Requirements

M314.2.1 Taper-Threaded Joints. Paragraph 314.2.1 applies except that only components suitable for Normal Fluid Service in sizes $8 \le DN \le 25$ ($\frac{1}{4} \le NPS \le 1$) are permitted (see Table 314.2.1). Sizes smaller than DN 20 (NPS $\frac{3}{4}$) shall be safeguarded (see Appendix G).

M314.2.2 Straight-Threaded Joints. Paragraph 314.2.2 applies. In addition, components shall have adequate mechanical strength and the joint shall have a

confined seating surface not subject to relative rotation as or after the joint is tightened. [See Fig. 335.3.3 sketches (b) and (c) for acceptable construction.]

M315 TUBING JOINTS IN METALLIC PIPING

Paragraph 315 applies, except for para. 315.2(b).

M316 CAULKED JOINTS

Caulked joints shall not be used.

M317 SOLDERED AND BRAZED JOINTS

Soldered, brazed, and braze welded joints shall not be used.

M318 SPECIAL JOINTS IN METALLIC PIPING

Paragraph 318 applies, with the exception that adhesive joints and bell type joints shall not be used.

PART 5 FLEXIBILITY AND SUPPORT OF METALLIC PIPING M319 FLEXIBILITY OF METALLIC PIPING

Paragraph 319 applies, with the exception that the simplified rules in para. 319.4.1(c) do not apply.

M320 ANALYSIS OF SUSTAINED LOADS

Paragraph 320 applies.

M321 PIPING SUPPORT

Paragraph 321 applies, except that supporting elements welded to the piping shall be of listed material.

PART 6 SYSTEMS

M322 SPECIFIC PIPING SYSTEMS

M322.3 Instrument Piping

Paragraph 322.3 applies, with the exception that for signal tubing in contact with process fluids and process temperature–pressure conditions

- (a) tubing shall be not larger than 16 mm ($\frac{5}{8}$ in.) O.D. and shall be suitable for the service
- (*b*) an accessible block valve shall be provided to isolate the tubing from the pipeline
- (c) joining methods shall conform to the requirements of para. M315

M322.6 Pressure-Relieving Systems

Paragraph 322.6 applies, except for para. 322.6.3. See para. M322.6.3.

M322.6.3 Overpressure Protection

- (a) Paragraph 322.6.3(a) applies.
- (b) Relief set pressure shall be in accordance with BPV Code, Section VIII, Division 1.
- (c) The maximum relieving pressure shall be in accordance with Section VIII, Division 1.

PART 7 METALLIC MATERIALS

M323 GENERAL REQUIREMENTS

M323.1 Materials and Specifications

Paragraph 323.1.1 applies. See paras. M323.1.2, M323.1.3, and M323.1.4.

M323.1.2 Unlisted Materials. Paragraph 323.1.2 applies, with the additional requirement that the designer shall fully document the determination of allowable stresses as part of the engineering design.

M323.1.3 Unknown Materials. Materials of unknown specification shall not be used.

M323.1.4 Reclaimed Metallic Materials. Reclaimed materials may be used when the material certification records are available for the specific materials employed, and the designer is assured that the material is sound and free from harmful defects.

(16) M323.2 Temperature Limitations

Paragraph 323.2 applies with the exception that, in regard to lower temperature limits, the relaxation of minimum temperature limits stated in Notes (3) and (6) of Table 323.2.2 and in para. 323.2.2(d) is not permitted.

M323.3 Impact Testing Methods and Acceptance Criteria

Paragraph 323.3 applies in its entirety.

M323.4 Fluid Service Requirements for Metallic Materials

Paragraph 323.4.1 applies.

M323.4.2 Specific Requirements. Paragraph 323.4.2 applies, except that cast irons other than ductile iron shall not be used for pressure-containing parts, and lead and tin shall be used only as linings.

M323.4.3 Metallic Cladding and Lining Materials.

In addition to the requirements of para. 323.4.3, where materials covered in paras. 323.4.2(c)(2) and 323.4.3 are used as cladding or lining in which the cladding or lining also serves as a gasket or as part of the flange facing, consideration shall be given to the design of the flanged joint to prevent leakage to the environment.

M323.5 Deterioration of Materials in Service

Paragraph 323.5 applies in its entirety.

M325 MATERIALS — MISCELLANEOUS

M325.1 Joining and Auxiliary Materials

In applying para. 325, materials such as solvents, brazes, and solders shall not be used. Nonmetallic materials used as gaskets and packing materials shall be suitable for the fluid service.

PART 8 STANDARDS FOR PIPING COMPONENTS

M326 DIMENSIONS AND RATINGS OF COMPONENTS

Paragraph 326.1.3 applies.

M326.1 Dimensional Requirements

M326.1.1 Listed Piping Components. Except for prohibitions and restrictions stated elsewhere in Chapter VIII, components made in accordance with standards and specifications listed in Table 326.1 may be used in Category M service.

M326.1.2 Unlisted Piping Components.

Paragraph 326.1.2 applies, except that dimensions of unlisted components shall be governed by requirements in paras. 303 and 304.

M326.2 Ratings of Components

Paragraph 326.2 applies in its entirety.

M326.3 Reference Documents

Paragraph 326.3 applies in its entirety.

PART 9 FABRICATION, ASSEMBLY, AND ERECTION OF METALLIC PIPING

M327 GENERAL

Metallic piping materials and components are prepared for assembly and erection by one or more of the fabrication processes in paras. M328, M330, M331, and M332. When any of these processes is used in assembly and erection, requirements are the same as for fabrication.

M328 WELDING OF METALS

Welding shall be in accordance with paras. M311.1 and 328, except see para. M328.3.

M328.3 Welding Materials

Paragraph 328.3 applies in its entirety, except that split backing rings shall not be used, and removable backing rings and consumable inserts may be used only where their suitability has been demonstrated by procedure qualification.

M330 PREHEATING OF METALS

Paragraph 330 applies in its entirety.

M331 HEAT TREATMENT OF METALS

Paragraph 331 applies in its entirety, with the exception that no requirements less stringent than those of Table 331.1.1 shall be specified.

M332 BENDING AND FORMING OF METALS

Paragraph 332 applies in its entirety, except that bending that conforms to para. 332.2.3 is not permitted.

M335 ASSEMBLY AND ERECTION OF METALLIC PIPING

M335.1 General

M335.1.1 Alignment. In addition to the requirements of para. 335.1.1, any bending or forming required for alignment and fit-up shall be heat treated if required by para. 332.4.

M335.2 Flanged Joints

Paragraph 335.2 applies in its entirety.

M335.3 Threaded Joints

Paragraphs 335.3.1 and 335.3.2 apply. See paras. M335.3.3 and M335.3.4.

M335.3.3 Straight-Threaded Joints. The requirements of para. 335.3.3 are subject to the limitations in para. M322.

M335.3.4 Condition of Threads. Taper-threaded components and threaded ends permitted under para. M314.2.1 shall be examined before assembly for cleanliness and continuity of threads and shall be rejected if not in conformance with ASME B1.20.1 or other applicable standards.

M335.4 Tubing Joints

M335.4.1 Flared Tubing Joints. The requirements of para. 335.4.1 apply; however, see para. M322 for limitations associated with specific piping systems.

M335.4.2 Flareless and Compression Tubing Joints.

The requirements of para. 335.4.2 apply; however, see para. M322 for limitations associated with specific piping systems.

M335.6 Special Joints

Special joints shall be in accordance with paras. M318 and 335.6.1.

M335.9 Cleaning of Piping

See Appendix F, para. F335.9.

M335.10 Identification of Piping

See Appendix F, para. F335.10.

PART 10 INSPECTION, EXAMINATION, TESTING, AND RECORDS OF METALLIC PIPING

M340 INSPECTION

Paragraph 340 applies in its entirety.

M341 EXAMINATION

Paragraphs 341.1, 341.2, 341.3, and 341.5 apply in their entirety. See para. M341.4.

M341.4 Extent of Required Examination

(16)

Paragraph 341.4.1 applies with the following exceptions:

- (a) Visual Examination
 - (1) All fabrication shall be examined.
- (2) All threaded, bolted, and other mechanical joints shall be examined.
- (b) Other Examination. The radiography/ultrasonic examination requirements of para. 341.4.1(b)(1) apply, except that 100% of circumferential butt and miter welds and of fabricated lap and branch connection welds comparable to those shown in Fig. 328.5.4E; Fig. 328.5.4F; and Fig. 328.5.5, illustrations (d) and (e), shall be examined.

M342 EXAMINATION PERSONNEL

Paragraph 342 applies.

M343 EXAMINATION PROCEDURES

Paragraph 343 applies.

M344 TYPES OF EXAMINATION

Paragraph 344 applies in its entirety.

M345 TESTING

Paragraph 345 applies, except that

- (a) a sensitive leak test in accordance with para. 345.8 shall be included in the required leak test (para. 345.1)
- (b) the initial service leak test (para. 345.7) does not apply

M346 RECORDS

Paragraph 346 applies in its entirety.

PARTS 11 THROUGH 20, CORRESPONDING TO CHAPTER VII

See para. M300(b).

MA300 GENERAL STATEMENTS

Paragraphs MA300 through MA346 apply to nonmetallic piping and piping lined with nonmetals, based on Chapter VII. Paragraph A300(d) applies.

PART 11 CONDITIONS AND CRITERIA MA301 DESIGN CONDITIONS

Paragraph A301 applies in its entirety.

MA302 DESIGN CRITERIA

Paragraphs A302.1 and A302.4 apply. See paras. MA302.2 and MA302.3.

MA302.2 Pressure-Temperature Design Criteria

Paragraph A302.2 applies, with the exception of para. A302.2.4. See para. MA302.2.4.

MA302.2.4 Allowances for Pressure and Temperature **Variation.** Paragraph A302.2.4(a) applies to both nonmetallic piping and to metallic piping with nonmetallic lining.

MA302.3 Allowable Stresses and Other Design Limits

Paragraph A302.3 applies.

MA302.4 Allowances

Paragraph 302.4 applies in its entirety.

PART 12 PRESSURE DESIGN OF NONMETALLIC PIPING COMPONENTS

MA303 GENERAL

Paragraph A303 applies in its entirety.

MA304 PRESSURE DESIGN OF NONMETALLIC COMPONENTS

Paragraph A304 applies in its entirety.

PART 13 FLUID SERVICE REQUIREMENTS FOR NONMETALLIC PIPING COMPONENTS

MA305 PIPE

Paragraph A305 applies in its entirety.

MA306 NONMETALLIC FITTINGS, BENDS, MITERS, LAPS, AND BRANCH CONNECTIONS

Paragraphs A306.1 and A306.2 apply. See para. MA306.3.

MA306.3 Miter Bends

Miter bends not designated as fittings conforming to para. A306.1 shall not be used.

MA306.4 Fabricated Laps

Fabricated laps shall not be used.

MA306.5 Fabricated Branch Connections

Nonmetallic fabricated branch connections shall not be used.

MA307 VALVES AND SPECIALTY COMPONENTS

Paragraph A307 applies, except that nonmetallic valves and specialty components shall not be used.

MA308 FLANGES, BLANKS, FLANGE FACINGS, AND GASKETS

Paragraphs A308.1, 308.3, and A308.4 apply in their entirety. See para. MA308.2.

MA308.2 Nonmetallic Flanges

Threaded nonmetallic flanges shall not be used.

MA309 BOLTING

Paragraph A309 applies in its entirety.

PART 14 FLUID SERVICE REQUIREMENTS FOR NONMETALLIC PIPING JOINTS

MA310 GENERAL

Paragraph 310 applies in its entirety.

MA311 BONDED JOINTS

MA311.1 General

Paragraph A311.1 applies in its entirety.

MA311.2 Specific Requirements

Hot gas welded, heat fusion, solvent cemented, and adhesive bonded joints are not permitted except in linings.

MA312 FLANGED JOINTS

Paragraph 312 applies in its entirety.

MA313 EXPANDED JOINTS

Expanded joints shall not be used.

MA314 THREADED JOINTS

MA314.1 General

Threaded joints shall not be used.

MA315 TUBING JOINTS IN NONMETALLIC PIPING

Paragraph A315 applies in its entirety.

MA316 CAULKED JOINTS

Caulked joints shall not be used.

MA318 SPECIAL JOINTS

Paragraph A318 applies in its entirety.

PART 15 FLEXIBILITY AND SUPPORT OF NONMETALLIC PIPING

MA319 PIPING FLEXIBILITY

Paragraph A319 applies in its entirety.

MA321 PIPING SUPPORT

Paragraph A321 applies in its entirety.

PART 16 NONMETALLIC AND NONMETALLIC LINED SYSTEMS MA322 SPECIFIC PIPING SYSTEMS

Paragraph A322 applies in its entirety.

PART 17 NONMETALLIC MATERIALS

MA323 GENERAL REQUIREMENTS

Paragraph A323.1 applies with the additional requirement described in para. MA323.1.2. Paragraph A323.2 applies in its entirety. See para. MA323.4.

MA323.1.2 Unlisted Materials. Paragraph 323.1.2 applies with the additional requirement that the designer shall fully document the determination of allowable stresses as part of the engineering design.

MA323.4 Fluid Service Requirements for Nonmetallic Materials

Paragraph A323.4.1 applies. See paras. MA323.4.2 and MA323.4.3.

MA323.4.2 Specific Requirements. Paragraph A323.4.2 applies, except that materials listed under paras. A323.4.2(a), (b), and (d) may be used only as linings. Thermoplastics may be used as gaskets in accordance with paras. M325.1 and MA323.4.3.

MA323.4.3 Nonmetallic Lining Materials.

Paragraph A323.4.3 applies with the additional requirement that where a material in para. A323.4.2 is used as a lining that also serves as a gasket or as part of the flange facing, consideration shall be given to design of the flanged joint to prevent leakage to the environment.

PART 18 STANDARDS FOR NONMETALLIC AND NONMETALLIC LINED PIPING COMPONENTS

MA326 DIMENSIONS AND RATINGS OF COMPONENTS

Paragraph A326 applies in its entirety. Table A326.1 applies, except for components and systems prohibited or restricted elsewhere in this Chapter.

PART 19 FABRICATION, ASSEMBLY, AND ERECTION OF NONMETALLIC AND NONMETALLIC LINED PIPING MA327 GENERAL

Paragraph A327 applies in its entirety.

MA328 BONDING OF PLASTICS

Paragraph A328 applies in its entirety.

MA329 FABRICATION OF PIPING LINED WITH NONMETALS

Paragraph A329 applies in its entirety.

MA332 BENDING AND FORMING

Paragraph A332 applies in its entirety.

MA334 JOINING NONPLASTIC PIPING

Paragraph A334 applies in its entirety.

MA335 ASSEMBLY AND ERECTION

Paragraph A335 applies in its entirety.

PART 20 INSPECTION, EXAMINATION, TESTING, AND RECORDS OF NONMETALLIC AND NONMETALLIC LINED PIPING

MA340 INSPECTION

Paragraph 340 applies in its entirety.

MA341 EXAMINATION

Paragraph A341 applies in its entirety.

MA341.1 General

Paragraphs 341.1, 341.2, A341.3, and A341.5 apply in their entirety. See para. MA341.4.

MA341.4 Extent of Required Examination

Paragraph A341.4.1 applies, except as follows:

- (a) Visual Examination
 - (1) All fabrication shall be visually examined.
- (2) All bolted and other mechanical joints shall be examined.

MA342 EXAMINATION PERSONNEL

Paragraph 342 applies in its entirety.

MA343 EXAMINATION PROCEDURES

Paragraph 343 applies in its entirety.

MA344 TYPES OF EXAMINATION

Paragraph A344 applies in its entirety.

MA345 TESTING

Paragraph A345 applies except that

- (a) a sensitive leak test in accordance with para. 345.8 shall be included in the required leak test (para. A345.1)
- (*b*) the initial service leak test (para. A345.7) does not apply

MA346 RECORDS

Paragraph 346 applies in its entirety.

Chapter IX High Pressure Piping

K300 GENERAL STATEMENTS

- (a) Applicability. This Chapter pertains to piping designated by the owner as being in High Pressure Fluid Service. Its requirements are to be applied in full to piping so designated. High pressure is considered herein to be pressure in excess of that allowed by the ASME B16.5 Class 2500 rating for the specified design temperature and material group. However, there are no specified pressure limitations for the application of these rules.
- (b) Responsibilities. In addition to the responsibilities stated in para. 300(b),
- (1) for each piping system designated as being in High Pressure Fluid Service, the owner shall provide all information necessary to perform the analyses and testing required by this Chapter
- (2) the designer shall make a written report to the owner summarizing the design calculations and certifying that the design has been performed in accordance with this Chapter
- (c) The identification, intent, and Code requirements in paras. 300(a), (c), (d), (e), and (f) apply.
- (*d*) The organization, content, and, wherever possible, paragraph designations of this Chapter correspond to those of the first six Chapters (the base Code). The prefix K is used.
- (e) Provisions and requirements of the base Code apply only as stated in this Chapter.

K300.1 Scope

- **K300.1.1 Content and Coverage.** Paragraph 300.1.1 applies with the exceptions stated in paras. K300.1.3 and K300.1.4.
- **K300.1.2 Packaged Equipment Piping.** Interconnecting piping as described in para. 300.1.2 shall conform to the requirements of this Chapter.
- **K300.1.3 Exclusions.** In addition to the exclusions stated in para. 300.1.3, this Chapter excludes nonmetallic and nonmetallic-lined piping.
- **K300.1.4 Category M Fluid Service.** This Chapter makes no provision for piping in Category M Fluid Service. If such piping is required by the owner, the engineering design shall be developed as provided in para. 300(c)(5).

K300.2 Definitions

Paragraph 300.2 applies except for terms relating only to nonmetals and severe cyclic conditions.

The term allowable stress is used in lieu of basic allowable stress.

The term safeguarding and other terms characterizing hazardous fluid services are not used in this Chapter but should be taken into account in design.

K300.3 Nomenclature

Paragraph 300.3 applies.

K300.4 Status of Appendices

Paragraph 300.4 and Table 300.4 apply, except for Appendices A, B, H, L, V, and X.

PART 1 CONDITIONS AND CRITERIA

K301 DESIGN CONDITIONS

Paragraph 301 applies with the exceptions of paras. 301.1, 301.2, 301.3, and 301.5.

K301.1 General

Paragraph 301.1 applies but refer to para. K301 instead of para. 301.

K301.2 Design Pressure

K301.2.1 General. Paragraph 301.2.1(a) applies except that reference to para. 302.2.4 is not applicable. Paragraphs 301.2.1(b) and (c) apply, but refer to para. K304 instead of para. 304.

K301.2.2 Required Pressure Containment or Relief.

Paragraphs 301.2.2(a) and (b) apply, but refer to para. K322.6.3 instead of para. 322.6.3. Paragraph 301.2.2(c) is not applicable.

K301.3 Design Temperature

Paragraph 301.3 applies with the exceptions of paras. 301.3.1 and 301.3.2 and the following exceptions in the text:

- (a) Refer to para. K301.2 instead of para. 301.2.
- (b) Refer to para. K301.3.2 instead of para. 301.3.2.

K301.3.1 Design Minimum Temperature. Paragraph 301.3.1 applies, but refer to para. K323.2.2 instead of para. 323.2.2.

K301.3.2 Uninsulated Components. The fluid temperature shall be used as the component temperature.

K301.5 Dynamic Effects

Paragraph 301.5 applies with the exception of para. 301.5.4.

K301.5.4 Vibration. Suitable dynamic analysis shall be made where necessary, to avoid or minimize conditions that lead to detrimental vibration, pulsation, or resonance effects in the piping.

K302 DESIGN CRITERIA

K302.1 General

In para. K302, pressure–temperature ratings, stress criteria, design allowances, and minimum design values are stated, and permissible variations of these factors as applied to design of high pressure piping systems are formulated.

The designer shall be satisfied as to the adequacy of the design, and of materials and their manufacture, considering at least the following:

- (a) tensile, compressive, flexural, and shear strength at design temperature
 - (b) fatigue strength
 - (c) design stress and its basis
 - (d) ductility and toughness
- (e) possible deterioration of mechanical properties in service
 - (f) thermal properties
 - (g) temperature limits
 - (h) resistance to corrosion and erosion
 - (i) fabrication methods
 - (j) examination and testing methods
 - (k) hydrostatic test conditions
 - (1) bore imperfections

K302.2 Pressure-Temperature Design Criteria

K302.2.1 Listed Components Having Established

Ratings. Pressure–temperature ratings for certain piping components have been established and are contained in some of the standards in Table K326.1. Unless limited elsewhere in this Chapter, those ratings are acceptable for design pressures and temperatures under this Chapter. With the owner's approval, the rules and limits of this Chapter may be used to extend the pressure–temperature ratings of a component beyond the ratings of the listed standard, but not beyond the limits stated in para. K323.2.

K302.2.2 Listed Components Not Having Specific Ratings

(a) Piping components for which design stresses have been developed in accordance with para. K302.3, but that do not have specific pressure–temperature ratings, shall be rated by rules for pressure design in para. K304,

within the range of temperatures for which stresses are shown in Table K-1, modified as applicable by other rules of this Chapter.

(b) Piping components that do not have allowable stresses or pressure–temperature ratings shall be qualified for pressure design as required by para. K304.7.2.

K302.2.3 Unlisted Components

- (a) Piping components not listed in Table K326.1 or Table K-1, but that conform to a published specification or standard, may be used subject to the following requirements:
- (1) The designer shall determine that composition, mechanical properties, method of manufacture, and quality control are comparable to the corresponding characteristics of listed components.
- (2) Pressure design shall be verified in accordance with para. K304, including the fatigue analysis required by para. K304.8.
- (*b*) Other unlisted components shall be qualified for pressure design as required by para. K304.7.2.

K302.2.4 Allowance for Pressure and Temperature **Variations.** Variations in pressure above the design pressure at the coincident temperature, except for accumulation during pressure relieving (see para. K322.6.3), are not permitted for any piping system.

K302.2.5 Ratings at Junction of Different Services. Paragraph 302.2.5 applies.

K302.3 Allowable Stresses and Other Design Limits

K302.3.1 General. The allowable stresses defined below shall be used in design calculations unless modified by other provisions of this Chapter.

(a) Tension. Allowable stresses in tension for use in design in accordance with this Chapter are listed in Table K-1, except that maximum allowable stress values and design stress intensity values for bolting, respectively, are listed in the BPV Code, Section II, Part D, Tables 3 and 4.

The tabulated stress values in Table K-1 are grouped by materials and product form and are for stated temperatures up to the limit provided for the materials in para. K323.2.1. Straight line interpolation between temperatures to determine the allowable stress for a specific design temperature is permissible. Extrapolation is not permitted.

- (b) Shear and Bearing. Allowable stress in shear shall be 0.80 times the allowable stress in tension tabulated in Table K-1. Allowable stress in bearing shall be 1.60 times the allowable stress in tension.
- (c) Compression. Allowable stress in compression shall be no greater than the allowable stress in tension tabulated in Table K-1. Consideration shall be given to structural stability.
- (d) Fatigue. Allowable values of stress amplitude, which are provided as a function of design life in the

BPV Code, Section VIII, Division 2, Part 3, para. 3.15; or Division 3, Article KD-3; as applicable, may be used in fatigue analysis in accordance with para. K304.8.

- (16) **K302.3.2 Bases for Allowable Stresses.** The bases for establishing allowable stress values for materials in this Chapter are as follows:
 - (a) Bolting Materials. The criteria of Section II, Part D, Appendix 2, para. 2-120 or 2-130, or Section VIII, Division 3, Article KD-6, para. KD-620, as applicable, apply.
 - (b) Other Materials. For materials other than bolting materials, the following rules apply:
 - (1) Except as provided in (b)(2) below, allowable stress values at design temperature for materials shall not exceed the lower of two-thirds of S_Y and two-thirds of S_{yt} . S_{yt} is determined in accordance with eq. (31)

$$S_{yt} = S_Y R_Y \tag{31}$$

where

- R_Y = ratio of the average temperature dependent trend curve value of yield strength to the room temperature yield strength
- S_Y = specified minimum yield strength at room temperature
- S_{yt} = yield strength at temperature
- (2) For solution heat treated austenitic stainless steels and certain nickel alloys with similar stress-strain behavior, allowable stress values shall not exceed the lower of two-thirds of S_Y and 90% of S_{yt} .

Application of stress values so determined is not recommended for flanged joints and other components in which slight deformation can cause leakage or malfunction. [These values are shown in *italics* or **boldface** in Table K-1, as explained in Note (12) to Appendix K table.] Instead, either 75% of the stress value in Table K-1 or two-thirds of the yield strength at temperature listed in Section II, Part D, Table Y-1, as applicable, should be used.

- (c) Unlisted Materials. For a material that conforms to para. K323.1.2, allowable stress values at design temperature shall not exceed the lower of two-thirds of S_Y and two-thirds of S_{yt} .
- (1) Except as provided in (c)(2) below, S_{yt} shall be determined in accordance with eq. (31).
- (2) If the yield strength at temperature for an unlisted material is contained in Section II, Part D, Table Y-1, that yield strength at temperature value may be used directly in the determination of allowable stress.

- (d) Cyclic Stresses. Allowable values of alternating stress or equipment alternating stress, as applicable, shall be in accordance with Section VIII, Division 2, Part 3, para. 3.15 and Part 5; or Division 3, Article KD-3; respectively.
- **K302.3.3 Casting Quality Factor**. The casting quality factor, E_c , shall be 1.00 by conformance to all of the following supplementary requirements:
- (a) All surfaces shall have a roughness average, R_a , not greater than 6.3 μ m R_a (250 μ in. R_a); see ASME B46.1 for a definition of R_a .
- (b) All nonferromagnetic surfaces shall be examined using the liquid penetrant method in accordance with ASTM E165, with acceptability judged in accordance with MSS SP-93, Table 1. All ferromagnetic surfaces shall be examined using either the liquid penetrant method or the magnetic particle method, in accordance with ASTM E165 or ASTM E709, respectively. Acceptability of imperfections, including those in weld repairs, shall be judged in accordance with MSS SP-93, Table 1 or MSS SP-53, Table 1, respectively.
- (c) Each casting shall be fully examined either ultrasonically in accordance with ASTM E114 or radiographically in accordance with ASTM E94. Cracks and hot tears (Category D and E discontinuities in accordance with the standards listed in Table K302.3.3D) and imperfections whose depths exceed 3% of nominal wall thickness are not permitted. Acceptable severity levels for radiographic examination of castings shall be in accordance with Table K302.3.3D.
- **K302.3.4 Weld Joint Quality Factor.** Piping components containing welds shall have a weld joint quality factor $E_j = 1.00$ (see Table 302.3.4), except that the acceptance criteria for these welds shall be in accordance with para. K341.3.2. Spiral (helical seam) welds are not permitted.

K302.3.5 Limits of Calculated Stresses Due to Sustained Loads and Displacement Strains

- (a) Internal Pressure Stresses. Stresses due to internal pressure shall be considered safe when the wall thickness of the piping component, and its means of stiffening, meet the requirements of para. K304.
- (b) External Pressure Stresses. Stresses due to external pressure shall be considered safe when the wall thickness of the piping component, and its means of stiffening, meet the requirements of para. K304.
- (c) Longitudinal Stresses, S_L . The sum of the longitudinal stresses S_L in any component in a piping system due to sustained loads, such as pressure and weight, shall not exceed S_h in (d) below. The thickness of pipe used in calculating S_L shall be the nominal thickness minus mechanical, corrosion, and erosion allowance, c.

 $^{^{\}rm 1}$ See Notes to Tables 302.3.3C and 302.3.3D for titles of standards referenced herein.

Thickness Examined, mm (in.)	Applicable Standards	Acceptable Severity Level	Acceptable Discontinuity Categories	
$\overline{T} \le 51 \ (2)$	ASTM E446	1	A, B, C	
$51 < \overline{T} \le 114 \ (4.5)$	ASTM E186	1	A, B, C	
$114 < \overline{T} \le 305 (12)$	ASTM E280	1	A, B, C	

(d) Allowable Displacement Stress Range, S_A . The computed displacement stress range, S_E , in a piping system (see para. 319.4.4) shall not exceed the allowable displacement stress range, S_A (see para. 319.2.3), calculated by

$$S_A = 1.25S_c + 0.25S_h \tag{32}$$

where

- S_c = allowable stress from Table K-1 at minimum metal temperature expected during the displacement cycle under analysis
- S_h = allowable stress from Table K-1 at maximum metal temperature expected during the displacement cycle under analysis

K302.3.6 Limits of Calculated Stresses Due to Occasional Loads

- (a) Operation. The sum of the longitudinal stresses, S_L , due to sustained loads, such as pressure and weight, and of the stresses produced by occasional loads, such as wind or earthquake, may be as much as 1.2 times the allowable stress given in Table K-1. Where the allowable stress value in Table K-1 exceeds two-thirds of S_{yt} , S_L shall not exceed 90% of S_{yt} listed in the BPV Code, Section II, Part D, Table Y-1. Wind and earthquake forces need not be considered as acting concurrently.
- (b) Test. Stresses due to test conditions are not subject to the limitations in para. K302.3. It is not necessary to consider other occasional loads, such as wind and earthquake, as occurring concurrently with test loads.

K302.4 Allowances

In determining the minimum required thickness of a piping component, allowances shall be included for corrosion, erosion, and thread or groove depth. See the definition of c in para. K304.1.1(b).

(16) K302.5 Mechanical Strength

Paragraph 302.5 applies.

PART 2 PRESSURE DESIGN OF PIPING COMPONENTS K303 GENERAL

Components manufactured in accordance with standards listed in Table K326.1 shall be considered suitable

for use at pressure–temperature ratings in accordance with para. K302.2.

K304 PRESSURE DESIGN OF HIGH PRESSURE COMPONENTS

K304.1 Straight Pipe

K304.1.1 General

(a) The required wall thickness of straight sections of pipe shall be determined in accordance with eq. (33).

$$t_m = t + c \tag{33}$$

The minimum wall thickness, T, for the pipe selected, considering manufacturer's minus tolerance, shall be not less than t_m .

- (b) The following nomenclature is used in the equation for pressure design of straight pipe:
 - $c = c_i + c_o$
 - = the sum of mechanical allowances² (thread or groove depth) plus corrosion and erosion allowances (where c_i = the sum of *internal* allowances and c_o = the sum of *external* allowances). For threaded components, the nominal thread depth (dimension h of ASME B1.20.1 or equivalent) shall apply, except that for straight threaded connections, the external thread groove depth need not be considered provided
 - (a) it does not exceed 20% of the wall thickness:
 - (*b*) the ratio of outside to inside diameter, D/d, is greater than 1.1;
 - (c) the internally threaded attachment provides adequate reinforcement; and
 - (*d*) the thread plus the undercut area, if any, does not extend beyond the reinforcement for a distance more than the nominal wall thickness of the pipe.
 - t = pressure design wall thickness, as calculated in para. K304.1.2 for internal pressure, or in accordance with the procedure listed in para. K304.1.3 for external pressure

 $^{^2}$ For machined surfaces or grooves where the tolerance is not specified, the tolerance shall be assumed to be 0.5 mm (0.02 in.) in addition to the specified depth of the cut.

 t_m = minimum required wall thickness, including mechanical, corrosion, and erosion allowances

Adequate reinforcement by the attachment is defined as that necessary to ensure that the static burst pressure of the connection will equal or exceed that of the unthreaded portion of the pipe. The adequacy of the reinforcement shall be substantiated as required by para. K304.7.2.

K304.1.2 Straight Pipe Under Internal Pressure

(a) Except as provided in (b) below for solution heat treated austenitic stainless steels and certain nickel alloys with similar stress—strain behavior, the internal pressure design wall thickness, *t*, shall be not less than that calculated in accordance with eq. (34a) for pipe with a specified outside diameter and minimum wall thickness, or eq. (34b) for pipe with a specified inside diameter and minimum wall thickness.

$$t = \frac{D - 2c_o}{2} \left[1 - \exp\left(\frac{-P}{S}\right) \right]$$
 (34a)^{3, 4, 5}

or

$$t = \frac{d + 2c_i}{2} \left[\exp\left(\frac{P}{S}\right) - 1 \right]$$
 (34b)^{3, 4, 5}

Alternatively, the internal design gage pressure, *P*, may be calculated by eq. (35a) or (35b).

$$P = S \times \ln \left[\frac{D - 2c_o}{D - 2(T - c_i)} \right]$$
 (35a)^{4, 5}

or

$$P = S \times \ln \left[\frac{d + 2(T - c_o)}{d + 2c_i} \right]$$
 (35b)^{4, 5}

where

- D = outside diameter of pipe. For design calculations in accordance with this Chapter, the outside diameter of the pipe is the maximum value allowable under the specifications.
- d = inside diameter of pipe. For design calculations in accordance with this Chapter, the inside diameter of the pipe is the maximum value allowable under the specifications.

P = internal design gage pressure

S = allowable stress from Table K-1

T = pipe wall thickness (measured or minimum in accordance with the purchase specification)

(b) At design temperatures where allowable stress, *S*, values in Table K-1 are in **boldface** (solution heat treated austenitic stainless steels and certain nickel alloys with similar stress–strain behavior only), the internal pressure design wall thickness, *t*, shall be not less than that calculated in accordance with eq. (34c) for pipe with a specified outside diameter and minimum wall thickness, or eq. (34d) for pipe with a specified inside diameter and minimum wall thickness.

$$t = \frac{D - 2c_o}{2} \left[1 - \exp\left(\frac{-1.155P}{S}\right) \right]$$
 (34c)^{4, 5}

or

$$t = \frac{d + 2c_i}{2} \left[\exp\left(\frac{1.155P}{S}\right) - 1 \right]$$
 (34d)^{4, 5}

Alternatively, the internal design gage pressure, *P*, may be calculated by eq. (35c) or (35d).

$$P = \frac{S}{1.155} \ln \left[\frac{D - 2c_o}{D - 2(T - c_i)} \right]$$
 (35c)^{4, 5}

or

$$P = \frac{S}{1.155} \ln \left[\frac{d + 2(T - c_o)}{d + 2c_i} \right]$$
 (35d)^{4, 5}

K304.1.3 Straight Pipe Under External Pressure.

The pressure design thickness for straight pipe under external pressure shall be determined in accordance with para. K304.1.2 for pipe where D/t < 3.33, if at least one end of the pipe is exposed to full external pressure, producing a compressive axial stress. For $D/t \ge 3.33$, and for D/t < 3.33 where external pressure is not applied to at least one end of the pipe, the pressure design wall thickness shall be determined in accordance with para. 304.1.3 except that the stress values shall be taken from Table K-1.

K304.2 Curved and Mitered Segments of Pipe

K304.2.1 Pipe Bends. The minimum required wall thickness t_m of a bend, after bending, may be determined as for straight pipe in accordance with para. K304.1, provided that the bend radius of the pipe centerline is equal to or greater than ten times the nominal pipe outside diameter and the tolerances and strain limits of para. K332 are met. Otherwise the design shall be qualified as required by para. K304.7.2.

K304.2.2 Elbows. Manufactured elbows not in accordance with para. K303 and pipe bends not in accordance with para. K304.2.1 shall be qualified as required by para. K304.7.2.

³ An exponential [e.g., the term exp (-P/S)] represents the base of natural logarithms e raised to the stated power (i.e., -P/S).

⁴ The intent of this equation is to provide a factor of not less than 1.732 (or $\sqrt{3}$) on the pressure required, according to the von Mises theory, to initiate yielding on the outside surface of a cylinder made from an elastic-perfectly plastic material. For solution heat treated austenitic stainless steels and certain nickel alloys with similar stress–strain behavior, this factor is as low as approximately 1.5 at elevated temperatures.

⁵ Any mechanical, corrosion, or erosion allowance, c, not specified as internal, c_i , or external, c_o , shall be assumed to be internal, i.e., $c = c_i$ and $c_o = 0$.

K304.2.3 Miter Bends. Miter bends are not permitted.

K304.2.4 Curved Segments of Pipe Under External Pressure. The wall thickness of curved segments of pipe subjected to external pressure may be determined as specified for straight pipe in para. K304.1.3 provided the design length *L* is the running centerline length between any two sections that are stiffened in accordance with para. 304.1.3.

K304.3 Branch Connections

K304.3.1 General. Acceptable branch connections include a fitting in accordance with para. K303, an extruded outlet in accordance with para. 304.3.4, or a branch connection fitting (see para. 300.2) similar to that shown in Fig. K328.5.4.

K304.3.2 Strength of Branch Connections

- (a) The opening made for a branch connection reduces both static and fatigue strength of the run pipe. There shall be sufficient material in the branch connection to contain pressure and meet reinforcement requirements.
- (b) Static pressure design of a branch connection not in accordance with para. K303 shall conform to para. 304.3.4 for an extruded outlet or shall be qualified as required by para. K304.7.2.
- **K304.3.3 Reinforcement of Welded Branch Connections.** Branch connections made as provided in para. 304.3.3 are not permitted.

K304.4 Closures

- (a) Closures not in accordance with para. K303 or (b) below shall be qualified as required by para. K304.7.2.
- (b) Closures may be designed in accordance with the methods, allowable stresses, and temperature limits of the BPV Code, Section VIII, Division 2 or Division 3, and Section II, Part D.

K304.5 Pressure Design of Flanges and Blanks

K304.5.1 Flanges — General

- (a) Flanges not in accordance with para. K303 or (b) below shall be qualified as required by para. K304.7.2.
- (*b*) A flange may be designed in accordance with the methods, allowable stresses, and temperature limits of Section VIII, Division 2, Part 4, para. 4.16, or Part 5, or Division 3, Article KD-6, and Section II, Part D.

K304.5.2 Blind Flanges

- (a) Blind flanges not in accordance with para. K303 or (b) or (c) below shall be qualified as required by para. K304.7.2.
- (*b*) A blind flange may be designed in accordance with eq. (36). The thickness of the flange selected shall be not less than t_m (see para. K304.1.1 for nomenclature), considering manufacturing tolerance

$$t_m = t + c \tag{36}$$

The methods, allowable stresses, and temperature limits of Section VIII, Division 2, Part 4, para. 4.6 may be used, with the following changes in nomenclature, to calculate t_m :

- c = sum of mechanical allowances, defined in para. K304.1.1
- t = pressure design thickness as calculated for the given style of blind flange using the appropriate equation of Part 4, para. 4.6
- (c) A blind flange may be designed in accordance with the rules, allowable stresses, and temperature limits of Section VIII, Division 3, Article KD-6 and Section II, Part D.
- **K304.5.3 Blanks.** Design of blanks shall be in accordance with para. 304.5.3(b), except that E shall be 1.00 and the definitions of S and c shall be in accordance with para. K304.1.1.

K304.6 Reducers

Reducers not in accordance with para. K303 shall be qualified as required by para. K304.7.2.

K304.7 Pressure Design of Other Components

K304.7.1 Listed Components. Other pressure-containing components manufactured in accordance with standards in Table K326.1 may be utilized in accordance with para. K303.

K304.7.2 Unlisted Components. Pressure design of unlisted components to which the rules elsewhere in para. K304 do not apply shall be based on the pressure design criteria of this Chapter. The designer shall ensure that the pressure design has been substantiated through one or more of the means stated in (a), (b), and (c) below. Note that designs are also required to be checked for adequacy of mechanical strength as described in para. K302.5.

- (a) extensive, successful service experience under comparable design conditions with similarly proportioned components made of the same or like material.
- (b) performance testing sufficient to substantiate both the static pressure design and fatigue life at the intended operating conditions. Static pressure design may be substantiated by demonstrating that failure or excessive plastic deformation does not occur at a pressure equivalent to two times the internal design pressure, P. The test pressure shall be two times the design pressure multiplied by the ratio of allowable stress at test temperature to the allowable stress at design temperature, and by the ratio of actual yield strength to the specified minimum yield strength at room temperature from Table K-1.
- (c) detailed stress analysis (e.g., finite element method) with results evaluated as described in Section VIII, Division 3, Article KD-2, except that for linear elastic analyses

- (1) $S_y/1.5$ in Division 3 shall be replaced by S from Table K-1, and
- (2) the Division 3 stress intensity limits due to sustained loads may be increased by the same factor applied in para. K302.3.6(a) when wind or earthquake loads are included. However, this limit shall not exceed 90% of S_{yt} listed in the BPV Code, Section II, Part D, Table Y-1.
- (d) for (a), (b), and (c) above, interpolations supported by analysis are permitted between sizes, wall thicknesses, and pressure classes, as well as analogies among related materials with supporting material property data. Extrapolation is not permitted.

K304.7.3 Components With Nonmetallic Parts.

Except for gaskets and packing, nonmetallic parts are not permitted.

K304.7.4 Bellows Type Expansion Joints. Bellows type expansion joints are not permitted.

K304.8 Fatigue Analysis

- (16) **K304.8.1 General.** A fatigue analysis shall be performed on each piping system, including all components⁶ and joints therein, and considering the stresses resulting from attachments, to determine its suitability for the cyclic operating conditions⁷ specified in the engineering design. Except as permitted in (a) and (b) below, or in paras. K304.8.4 and K304.8.5, this analysis shall be in accordance with the BPV Code, Section VIII, Division 2 or Division 3.⁸ The cyclic conditions shall include pressure variations as well as thermal variations or displacement stresses. The requirements of para. K304.8 are in addition to the requirements for a flexibility analysis stated in para. K319. No formal fatigue analysis is required in systems that
 - (a) are duplicates of successfully operating installations or replacements without significant change of systems with a satisfactory service record or
 - (b) can readily be judged adequate by comparison with previously analyzed systems

K304.8.2 Amplitude of Alternating Stress

- (a) Fatigue Analysis Based Upon Section VIII, Division 2. The value of the alternating stress amplitude for comparison with design fatigue curves shall be determined in accordance with Part 5. The allowable amplitude of alternating stress shall be determined from the applicable design fatigue curve in Part 3, para. 3.15.
 - (b) Fatigue Analysis Based Upon Section VIII, Division 3
- (1) The values of the alternating stress intensity, the associated mean stress, and the equivalent alternating

- stress intensity shall be determined in accordance with Articles KD-2 and KD-3. The allowable amplitude of the equivalent alternating stress shall be determined from the applicable design fatigue curve in Article KD-3.
- (2) If it can be shown that the piping component will fail in a leak-before-burst mode, the number of design cycles (design fatigue life) may be calculated in accordance with either Article KD-3 or Article KD-4. If a leak-before-burst mode of failure cannot be shown, the fracture mechanics evaluation outlined in Article KD-4 shall be used to determine the number of design cycles of the component.
- (c) Additional Considerations. The designer is cautioned that the considerations listed in para. K302.1 may reduce the fatigue life of the component below the value predicted by para. (a) or (b) above.

K304.8.3 Pressure Stress Evaluation for Fatigue Analysis

(a) For fatigue analysis of straight pipe, eq. (37) may be used to calculate the stress intensity⁹ at the inside surface due only to internal pressure.

$$S = \frac{PD^2}{2(T-c)[D-(T-c)]}$$
 (37)

- (b) For fatigue analysis of curved pipe, eq. (37) may be used, with the dimensions of the straight pipe from which it was formed, to calculate the maximum stress intensity at the inside surface due only to internal pressure, provided that the centerline bend radius is not less than ten times the nominal outside diameter of the pipe, and that the tolerance and strain limits of para. K332 are met. Bends of smaller radius shall be qualified as required by para. K304.7.2.
- (c) If the value of S calculated by eq. (37) exceeds three times the allowable stress from Table K-1 at the average temperature during the loading cycle, an inelastic analysis is required.
- **K304.8.4 Fatigue Evaluation by Test.** With the owner's approval, the design fatigue life of a component may be established by destructive testing in accordance with para. K304.7.2 in lieu of the above analysis requirements.
- **K304.8.5 Extended Fatigue Life.** The design fatigue life of piping components may be extended beyond that determined by Section VIII, Division 2, Part 3, para. 3.15 and Part 5; or Division 3, Article KD-3; as applicable, by the use of one of the following methods, provided that the component is qualified in accordance with para. K304.7.2:
- (a) surface treatments, such as improved surface finish
- (b) prestressing methods, such as autofrettage, shot peening, or shrink fit

⁶ Bore imperfections may reduce fatigue life.

 $^{^{7}}$ If the range of temperature change varies, equivalent full temperature cycles N may be computed using eq. (1d) in para. 302.3.5.

⁸ Fatigue analysis in accordance with Section VIII, Division 2 or Division 3, requires that stress concentration factors be used in computing the cyclic stresses.

⁹ The term stress intensity is defined in Section VIII, Division 3.

Table K305.1.2 Required Ultrasonic or Eddy Current Examination of Pipe and Tubing for Longitudinal Defects

Diameter, mm (in.)	Examination Required	Paragraph Reference	
$d < 3.2 \binom{1}{8}$ or $D < 6.4 \binom{1}{4}$	None		
3.2 $\binom{1}{8} \le d \le 17.5 \binom{11}{16}$ and 6.4 $\binom{1}{4} \le D \le 25.4 (1)$	Eddy current (ET) [Note (1)] or ultrasonic (UT)	K344.8 or K344.6	
$d > 17.5 \binom{11}{16}$ or $D > 25.4 \binom{11}{16}$	Ultrasonic (UT)	K344.6	

NOTE:

 This examination is limited to cold drawn austenitic stainless steel pipe and tubing.

The designer is cautioned that the benefits of prestress may be reduced due to thermal, strain softening, or other effects.

PART 3 FLUID SERVICE REQUIREMENTS FOR PIPING COMPONENTS

K305 PIPE

Pipe includes components designated as "tube" or "tubing" in the material specification, when intended for pressure service.

K305.1 Requirements

K305.1.1 General. Pipe and tubing shall be either seamless or longitudinally welded with straight seam and a joint quality factor $E_j = 1.00$, examined in accordance with Note (2) of Table K341.3.2. Spiral (helical seam) welds are not permitted.

K305.1.2 Additional Examination. Pipe and tubing shall have passed a 100% examination for longitudinal defects in accordance with Table K305.1.2. This examination is in addition to acceptance tests required by the material specification.

K305.1.3 Heat Treatment. Heat treatment, if required, shall be in accordance with para. K331.

K305.1.4 Unlisted Pipe and Tubing. Unlisted pipe and tubing may be used only in accordance with para. K302.2.3.

K306 FITTINGS, BENDS, AND BRANCH CONNECTIONS

Pipe and other materials used in fittings, bends, and branch connections shall be suitable for the manufacturing or fabrication process and otherwise suitable for the service.

K306.1 Pipe Fittings

K306.1.1 General. All castings shall have a casting quality factor $E_c = 1.00$, with examination and acceptance criteria in accordance with para. K302.3.3. All welds shall have a weld quality factor $E_j = 1.00$, with examination and acceptance criteria in accordance with paras. K341 through K344. Spiral (helical seam) welds are not permitted. Listed fittings may be used in accordance with para. K303. Unlisted fittings may be used only in accordance with para. K302.2.3.

K306.1.2 Specific Fittings

- (a) Socket welding fittings are not permitted.
- (*b*) Threaded fittings are permitted only in accordance with para. K314.
- (c) Branch connection fittings (see para. 300.2) whose design has been performance tested successfully as required by para. K304.7.2(b) may be used within their established ratings.

K306.2 Pipe Bends

K306.2.1 General. A bend made in accordance with para. K332.2 and verified for pressure design in accordance with para. K304.2.1 shall be suitable for the same service as the pipe from which it is made.

K306.2.2 Corrugated and Other Bends. Bends of other design (such as creased or corrugated) are not permitted.

K306.3 Miter Bends

Miter bends are not permitted.

K306.4 Fabricated or Flared Laps

Only forged laps are permitted.

K306.5 Fabricated Branch Connections

Fabricated branch connections constructed by welding shall be fabricated in accordance with para. K328.5.4 and examined in accordance with para. K341.4.

K307 VALVES AND SPECIALTY COMPONENTS

The following requirements for valves shall also be met, as applicable, by other pressure-containing piping components, such as traps, strainers, and separators.

K307.1 General

Pressure design of unlisted valves shall be qualified as required by para. K304.7.2.

K308 FLANGES, BLANKS, FLANGE FACINGS, AND GASKETS

K308.1 General

Pressure design of unlisted flanges shall be verified in accordance with para. K304.5.1 or qualified as required by para. K304.7.2.

K308.2 Specific Flanges

K308.2.1 Threaded Flanges. Threaded flanges may be used only within the limitations on threaded joints in para. K314.

K308.2.2 Other Flange Types. Slip-on, socket welding, and expanded joint flanges, and flanges for flared laps, are not permitted.

K308.3 Flange Facings

The flange facing shall be suitable for the service and for the gasket and bolting employed.

K308.4 Gaskets

Gaskets shall be selected so that the required seating load is compatible with the flange rating and facing, the strength of the flange, and its bolting. Materials shall be suitable for the service conditions. Mode of gasket failure shall be considered in gasket selection and joint design.

K308.5 Blanks

Blanks shall have a marking, identifying material, pressure–temperature rating, and size, that is visible after installation.

K309 BOLTING

Bolting, including bolts, bolt studs, studs, cap screws, nuts, and washers, shall meet the requirements of the BPV Code, Section VIII, Division 2, Part 3, para. 3.7; Part 4, para. 4.16; and Part 5, para. 5.7. See also Appendix F, para. F309, of this Code.

PART 4 FLUID SERVICE REQUIREMENTS FOR PIPING JOINTS K310 GENERAL

Joints shall be suitable for the fluid handled, and for the pressure–temperature and other mechanical loadings expected in service.

Factors such as assembly and disassembly (if applicable), cyclic loading, vibration, shock, bending, and thermal expansion and contraction of joints shall be considered in the engineering design.

K311 WELDED JOINTS

K311.1 General

Welds shall conform to the following:

- (a) Welding shall be in accordance with para. K328.
- (b) Preheating and heat treatment shall be in accordance with paras. K330 and K331, respectively.
- (c) Examination shall be in accordance with para. K341.4, with acceptance criteria as shown in Table K341.3.2.

K311.2 Specific Requirements

K311.2.1 Backing Rings and Consumable Inserts.

Backing rings shall not be used. Consumable inserts shall not be used in butt welded joints except when specified by the engineering design.

K311.2.2 Fillet Welds. Fillet welds may be used only for structural attachments in accordance with the requirements of paras. K321 and K328.5.2.

K311.2.3 Other Weld Types. Socket welds and seal welds are not permitted.

K312 FLANGED JOINTS

Flanged joints shall be selected for leak tightness, considering the requirements of para. K308, flange facing finish, and method of attachment. See also para. F312.

K312.1 Joints Using Flanges of Different Ratings

Paragraph 312.1 applies.

K313 EXPANDED JOINTS

Expanded joints are not permitted.

K314 THREADED JOINTS

K314.1 General

Except as provided in paras. K314.2 and K314.3, threaded joints are not permitted.

- (a) Layout of piping shall be such as to minimize strain on threaded joints that could adversely affect sealing.
- (b) Supports shall be designed to control or minimize strain and vibration on threaded joints and seals.

K314.2 Taper-Threaded Joints

- (a) Taper-threaded joints shall be used only for instrumentation, vents, drains, and similar purposes, and shall be not larger than DN 15 (NPS $\frac{1}{2}$).
- (*b*) External-threaded components shall be at least Schedule 160 in nominal wall thickness. The nominal thickness of Schedule 160 piping is listed in ASME B36.10M for DN 15 (NPS $\frac{1}{2}$) and in ASME B16.11 for sizes smaller than DN 15 (NPS $\frac{1}{2}$).

K314.3 Straight-Threaded Joints

K314.3.1 Joints With Seal Formed by Projecting

Pipe. Threaded joints where the threads are used to attach flanges or fittings, and in which the pipe end projects through the flange or fitting and is machined to form the sealing surface with a lens ring, cone ring, the mating pipe end, or other similar sealing device, may be used. Such joints shall be qualified in accordance with para. K304.7.2(a) or (b).

K314.3.2 Other Straight-Threaded Joints

- (a) Other Joints Using Components Conforming to Listed Standards. Joints made up using straight-threaded fittings covered by standards listed in Table K326.1 may be used, provided the fittings and joints are suitable for the pipe with which they are to be used (considering piping tolerances and other characteristics), are used within the pressure–temperature limitations of the fitting, and comply with para. K302.2.1.
- (b) Other Joints Using Components Not Conforming to Listed Standards. Other straight-threaded joints (e.g., a union comprising external and internal ends joined with a threaded union nut, or other constructions shown typically in Fig. 335.3.3) may be used. Such joints shall be qualified by performance testing in accordance with para. K304.7.2(b). Testing shall be conducted for each material type/grade and heat treatment condition, component configuration (e.g., elbow), size (e.g., NPS), and pressure rating. Performance testing of joints in which the process of making up the joint involves significant uncontrolled loads (e.g., hammer unions) shall include testing designed to simulate actual loads.

K315 TUBING JOINTS

K315.1 Flared Type Joints

Joints of the flared type are not permitted.

K315.2 Flareless Joints Using Components Conforming to Listed Standards

Joints made up using flareless type fittings covered by listed standards in Table K326.1 may be used, provided that the fittings

- (a) do not rely on friction to carry loads from the tubing to the fitting
- (b) are suitable for the tubing or pipe with which they are to be used (considering piping tolerances and other characteristics)
- (c) are used within the pressure–temperature limitations of the fitting and the joint
 - (d) comply with para. K302.2.1

K315.3 Flareless Joints Using Components Not Conforming to Listed Standards

Joints made up using flareless type fittings not listed in Table K326.1 may be used, provided that the type of fitting selected is adequate for the design pressure, other loadings, and the design temperature, and does not rely on friction to restrain the axial load. The design shall also be qualified by performance testing in accordance with para. K304.7.2(b). Testing shall be conducted for each material type/grade and heat treatment condition, component configuration (e.g., elbow), size (e.g., NPS), and pressure rating.

K316 CAULKED JOINTS

Caulked joints are not permitted.

K317 SOLDERED AND BRAZED JOINTS

K317.1 Soldered Joints

Soldered joints are not permitted.

K317.2 Brazed Joints

- (a) Braze welded joints and fillet joints made with brazing filler metal are not permitted.
- (b) Brazed joints shall be made in accordance with para. K333 and shall be qualified as required by para. K304.7.2. Such application is the owner's responsibility. The melting point of brazing alloys shall be considered when exposure to fire is possible.

K318 SPECIAL JOINTS

Special joints include coupling, mechanical, and gland nut and collar types of joints.

K318.1 General

Joints may be used in accordance with para. 318.2 and the requirements for materials and components in this Chapter.

K318.2 Specific Requirements

K318.2.1 Prototype Tests. A prototype joint shall have been subjected to performance tests in accordance with para. K304.7.2(b) to determine the safety of the joint under test conditions simulating all expected service conditions. Testing shall include cyclic simulation.

K318.2.2 Prohibited Joints. Bell type and adhesive joints are not permitted.

PART 5 FLEXIBILITY AND SUPPORT

K319 FLEXIBILITY

(16)

Flexibility analysis shall be performed for each piping system. Paragraphs 319.1 through 319.7 apply, except for para. 319.4.1(c). The computed displacement stress range shall be within the allowable displacement stress range in para. K302.3.5 and shall also be included in the fatigue analysis in accordance with para. K304.8.

K321 PIPING SUPPORT

Piping supports and methods of attachment shall be in accordance with para. 321 except as modified below, and shall be detailed in the engineering design.

K321.1 General

K321.1.1 Objectives. Paragraph 321.1.1 applies, but substitute "Chapter" for "Code" in (a).

K321.1.4 Materials. Paragraph 321.1.4 applies, but replace (e) with the following:

(e) Attachments welded to the piping shall be of a material compatible with the piping and the service. Other requirements are specified in paras. K321.3.2 and K323.4.2(b).

K321.3 Structural Attachments

K321.3.2 Integral Attachments. Paragraph 321.3.2 applies, but substitute "K321.1.4(e)" for "321.1.4(e)" and "Chapter IX" for "Chapter V."

PART 6 SYSTEMS

K322 SPECIFIC PIPING SYSTEMS

K322.3 Instrument Piping

K322.3.1 Definition. Instrument piping within the scope of this Chapter includes all piping and piping components used to connect instruments to high pressure piping or equipment. Instruments, permanently sealed fluid-filled tubing systems furnished with instruments as temperature- or pressure-responsive devices, and control piping for air or hydraulically operated control apparatus (not connected directly to the high pressure piping or equipment) are not within the scope of this Chapter.

K322.3.2 Requirements. Instrument piping within the scope of this Chapter shall be in accordance with para. 322.3.2 except that the design pressure and temperature shall be determined in accordance with para. K301, and the requirements of para. K310 shall apply. Instruments, and control piping not within the scope of this Chapter, shall be designed in accordance with para. 322.3.

K322.6 Pressure-Relieving Systems

Paragraph 322.6 applies, except for para. 322.6.3.

- **K322.6.3 Overpressure Protection.** Overpressure protection for high pressure piping systems shall conform to the following:
- (a) The cumulative capacity of the pressure-relieving devices shall be sufficient to prevent the pressure from rising more than 10% above the piping design pressure at the operating temperature during the relieving condition for a single relieving device or more than 16% above the design pressure when more than one device is provided, except as provided in (c) below.
- (b) System protection must include one relief device set at or below the design pressure at the operating temperature for the relieving condition, with no device set to operate at a pressure greater than 105% of the design pressure, except as provided in (c) below.
- (c) Supplementary pressure-relieving devices provided for protection against overpressure due to fire or

other unexpected sources of external heat shall be set to operate at a pressure not greater than 110% of the design pressure of the piping system and shall be capable of limiting the maximum pressure during relief to no more than 121% of the design pressure.

PART 7 MATERIALS

K323 GENERAL REQUIREMENTS

- (a) Paragraph K323 states limitations and required qualifications for materials based on their inherent properties. Their use is also subject to requirements elsewhere in Chapter IX and in Table K-1.
- (b) Specific attention should be given to the manufacturing process to ensure uniformity of properties throughout each piping component.
 - (c) See para. K321.1.4 for support materials.

K323.1 Materials and Specifications

K323.1.1 Listed Materials

- (a) Any material used in a pressure-containing piping component shall conform to a listed specification, except as provided in (b) below or in para. K323.1.2.
- (b) Materials manufactured to specification editions different from those listed in Appendix E may be used, provided
- (1) the requirements for chemical composition and heat-treatment condition in the edition of the specification to which the material was manufactured meet the requirements of the listed edition
- (2) the specified minimum tensile and yield strengths, and, if applicable, the specified maximum tensile and yield strengths, required by the two editions of the specification are the same, and
- (3) the material has been tested and examined in accordance with the requirements of the listed edition of the specification

A material that does not meet the requirements of paras. K323.1.1(b)(1), (2), and (3) may be evaluated as an unlisted material in accordance with para. K323.1.2.

- **K323.1.2 Unlisted Materials.** An unlisted material may be used, provided it conforms to a published specification covering chemistry, physical and mechanical properties, method and process of manufacture, heat treatment, and quality control, and otherwise meets the requirements of this Chapter. Allowable stresses shall be determined in accordance with the applicable allowable stress basis of this Chapter or a more conservative basis.
- **K323.1.3 Unknown Materials.** Materials of unknown specification, type, or grade are not permitted.
- **K323.1.4 Reclaimed Materials.** Reclaimed pipe and other piping components may be used provided they are properly identified as conforming to a listed specification, have documented service history for the material

and fatigue life evaluation, and otherwise meet the requirements of this Chapter. Sufficient cleaning and inspection shall be made to determine minimum wall thickness and freedom from defects that would be unacceptable in the intended service.

K323.1.5 Product Analysis. Conformance of materials to the product analysis chemical requirements of the applicable specification shall be verified, and certification shall be supplied. Requirements for product analysis are defined in the applicable materials specification.

- **K323.1.6 Repair of Materials by Welding.** A material defect may be repaired by welding, provided that all of the following criteria are met:
- (a) The material specification provides for weld repair.
- (b) The welding procedure and welders or welding operators are qualified as required by para. K328.2.
- (c) The repair and its examination are performed in accordance with the material specification and with the owner's approval.

K323.2 Temperature Limitations

The designer shall verify that materials that meet other requirements of this Chapter are suitable for service throughout the operating temperature range. Attention is directed to Note (4) in Appendix K, and para. K323.2.1 following.

K323.2.1 Upper Temperature Limits, Listed Materials. A listed material shall not be used at a temperature above the maximum for which a stress value is shown in Appendix K, Table K-1, except as provided in Note (9) of that table.

(16) K323.2.2 Lower Temperature Limits, Listed Materials

- (a) The lowest permitted service temperature for a component or weld shall be the impact test temperature determined in accordance with para. K323.3.4(a), except as provided in (b) or (c) below.
- (b) For a component or weld subjected to a longitudinal or circumferential stress ≤ 41 MPa (6 ksi), the lowest service temperature shall be the lower of -46°C (-50°F) or the impact test temperature determined in para. K323.3.4(a).
- (c) For materials exempted from Charpy testing by Note (2) of Table K323.3.1, the service temperature shall not be lower than -46° C (-50° F).

K323.2.3 Temperature Limits, Unlisted Materials.

An unlisted material acceptable under para. K323.1.2 shall be qualified for service at all temperatures within a stated range from design minimum temperature to design (maximum) temperature, in accordance with para. K323.2.4. However, the upper temperature limit shall be less than the temperature for which an allowable stress, determined in accordance with para. 302.3.2, is

governed by the creep or stress rupture provisions of that paragraph.

K323.2.4 Verification of Serviceability

- (a) When an unlisted material is used, or when otherwise required by Appendix K, Table K-1, Note (9), the designer is responsible for demonstrating the validity of the allowable stresses and other design limits, and of the approach taken in using the material, including the derivation of stress data and the establishment of temperature limits.
- (*b*) Paragraph 323.2.4(b) applies except that allowable stress values shall be determined in accordance with para. K302.3.

K323.3 Impact Testing Methods and Acceptance Criteria

K323.3.1 General. Except as provided in (16) Table K323.3.1, Note (2), piping components used in High Pressure Fluid Service shall be subjected to Charpy V-notch impact testing. The testing shall be performed in accordance with Table K323.3.1 on representative samples using the testing methods described in paras. K323.3.2, K323.3.3, and K323.3.4. Acceptance criteria are described in para. K323.3.5.

K323.3.2 Procedure. Paragraph 323.3.2 applies.

K323.3.3 Test Specimens

(16)

- (a) Each set of impact test specimens shall consist of three specimen bars. Impact tests shall be made using standard 10 mm (0.394 in.) square cross section Charpy V-notch specimen bars oriented in the transverse direction.
- (b) Where component size and/or shape does not permit specimens as specified in (a) above, standard 10 mm square cross-section longitudinal Charpy specimens may be prepared.
- (c) Where component size and/or shape does not permit specimens as specified in (a) or (b) above, subsize longitudinal Charpy specimens may be prepared. Test temperature shall be reduced in accordance with Table 323.3.4. See also Table K323.3.1, Note (2).
- (*d*) If necessary in (a), (b), or (c) above, corners of specimens parallel to and on the side opposite the notch may be as shown in Fig. K323.3.3.
- **K323.3.4 Test Temperatures.** For all Charpy impact tests, the test temperature criteria in (a) or (b) below shall be observed.
- (a) Charpy impact tests shall be conducted at a temperature no higher than the lower of the following:
 - (1) 20°C (70°F)
- (2) the lowest metal temperature at which a piping component or weld will be subjected to a stress greater than 41 MPa (6 ksi). In specifying the lowest metal temperature, the following shall be considered:
 - (a) range of operating conditions

Table K323.3.1 Impact Testing Requirements


	Test haracteristics	Column A Pipe, Tubes, and Components Made From Pipe or Tubes	Column B Other Components, Fittings, Etc.	Column C Bolts		
	Number of tests As required by the material specification, or one test set per lot [see Note (1)], whichever is greater, experimental permitted by Note (2).					
Tests on Materials	Location and orientation of specimens [see Note (3)]	 (a) Transverse to the longitudinal axis, with notch parallel to axis. [See Note (4).] (b) Where component size and/ or shape does not permit specimens as specified in (a) above, paras. K323.3.3(b), (c), and (d) apply as needed. 	 (a) Transverse to the direction of maximum elongation during rolling or to direction of major working during forging. Notch shall be oriented parallel to direction of maximum elongation or major working. (b) If there is no single identifiable axis, e.g., for castings or triaxial forgings, specimens shall either meet the longitudinal values of Table K323.3.5, or three sets of orthogonal specimens shall be prepared, and the lowest impact values obtained from any set shall meet the transverse values of Table K323.3.5. (c) Where component size and/or shape does not permit specimens as specified in (a) or (b) above, paras. K323.3.3(c) and (d) apply as needed. 	 (a) Bolts ≤ 52 mm (2 in.) nominal size made in accordance with ASTM A 320 shall meet the impact requirements of that specification. (b) For all other bolts, longitudinal specimens shall be taken. The impact values obtained shall meet the transverse values of Table K323.3.5. 		
Test pieces [see Note (5)] Test pieces for preparation of impact specimens shall be made for each welding procedure, ty or filler metal (i.e., AWS E-XXXX classification) and each flux to be used. All test pieces shall heat treatment, including cooling rates and aggregate time at temperature or temperatures, same as the heat treatment which the finished component will have received.						
in Fabrication or Assembly	Number of test pieces [see Note (6)]	 (1) One test piece with a thickness T for each range of material thicknesses which can vary from ½T to T + 6 mm (¼ in.). (2) Unless otherwise specified in this Chapter [see Note (4)] or the engineering design, test pieces need not be made from individual material lots, or from material for each job, provided welds in other certified material of the same thickness ranges and to the same specification (type and grade, not heat or lot) have been tested as required and the records of those tests are made available. 				
Tests on Welds in Fa	Location and orientation of specimens	 (1) Weld metal impact specimens shall be taken across the weld with the notch in the weld metal. Each specimen shall be oriented so that the notch axis is normal to the surface of the material and one face of the specimen shall be within 1.5 mm (½,6 in.) of the surface of the material. (2) Heat affected zone impact specimens shall be taken across the weld and have sufficient length to locate the notch in the heat affected zone, after etching. The notch shall be cut approximately normal to the material surface in such a manner as to include as much heat affected zone material as possible in the resulting fracture. (3) The impact values obtained from both the weld metal and heat affected zone specimens shall be compared to the transverse values in Table K323.3.5 for the determination of acceptance criteria. 				

Table K323.3.1 Impact Testing Requirements (Cont'd)

NOTES:

- (1) A lot shall consist of pipe or components of the same nominal size, made from the same heat of material, and heat treated together. If a continuous type furnace is used, pipe or components may be considered to have been heat treated together if they are processed during a single continuous time period at the same furnace conditions.
- (2) Impact tests are not required when the maximum obtainable longitudinal Charpy specimen has a width along the notch less than 2.5 mm (0.098 in.). See para. K323.2.2(c).
- (3) Impact tests shall be performed on a representative sample of material after completion of all heat treatment and forming operations involving plastic deformation, except that cold bends made in accordance with para. K304.2.1 need not be tested after bending.
- (4) For longitudinally welded pipe, specimens shall be taken from the base metal, weld metal, and the heat affected zone.
- (5) For welds in the fabrication or assembly of piping or components, including repair welds.
- (6) The test piece shall be large enough to permit preparing the number of specimens required by para. K323.3. If this is not possible, additional test pieces shall be prepared.

Fig. K323.3.3 Example of an Acceptable Impact Test Specimen



GENERAL NOTE: This Figure illustrates how an acceptable transverse Charpy specimen can be obtained from a tubing or component shape too small for a full length standard specimen in accordance with ASTM A370. The corners of a longitudinal specimen parallel to and on the side opposite the notch may be as shown.

NOTE:

 Corners of the Charpy specimen [see para. K323.3.3(d)] may follow the contour of the component within the dimension limits shown.

Table K323.3.5 Minimum Required Charpy V-Notch Impact Values

	Pipe Wall or Component Thickness, mm (in.)		Energy, J (ft-lbf) [Note (2)] Specified Minimum Yield Strength, MPa (ksi)		
Specimen		No. of Specimens [Note (1)]			
Orientation			≤932 (≤135)	>932 (>135)	
Transverse	≤25 (≤ 1)	Average for 3 Minimum for 1	27 (20) 20 (15)	34 (25) 27 (20)	
	>25 and ≤51 (>1 and ≤2)	Average for 3 Minimum for 1	34 (25) 27 (20)	41 (30) 33 (24)	
	>51 (> 2)	Average for 3 Minimum for 1	41 (30) 33 (24)	47 (35) 38 (28)	
Longitudinal	≤25 (≤1)	Average for 3 Minimum for 1	54 (40) 41 (30)	68 (50) 54 (40)	
	>25 and ≤51 (>1 and ≤2)	Average for 3 Minimum for 1	68 (50) 54 (40)	81 (60) 65 (48)	
	>51 (>2)	Average for 3 Minimum for 1	81 (60) 65 (48)	95 (70) 76 (56)	

NOTES:

- (1) See para. K323.3.5(c) for permissible retests.
- (2) Energy values in this Table are for standard size specimens. For subsize specimens, these values shall be multiplied by the ratio of the actual specimen width to that of a full-size specimen, 10 mm (0.394 in.).
- (b) upset conditions
- (c) ambient temperature extremes
- (d) required leak test temperature
- (b) Where the largest possible test specimen has a width along the notch less than the lesser of 80% of the material thickness or 8 mm (0.315 in.), the test shall be conducted at a reduced temperature in accordance with Table 323.3.4, considering the temperature as reduced below the test temperature required by (a) above.

K323.3.5 Acceptance Criteria

- (a) Minimum Energy Requirements for Materials Other Than Bolting. The applicable minimum impact energy requirements for materials shall be those shown in Table K323.3.5. Lateral expansion shall be measured in accordance with ASTM A370 (for title see para. 323.3.2). The results shall be included in the impact test report.
- (b) Minimum Energy Requirements for Bolting Materials. The applicable minimum energy requirements shall be those shown in Table K323.3.5 except as provided in Table K323.3.1.
- (c) Weld Impact Test Requirements. Where two base metals having different required impact energy values are joined by welding, the impact test energy requirements shall equal or exceed the requirements of the base material having the lower required impact energy.
 - (d) Retests

- (1) Retest for Absorbed Energy Criteria. When the average value of the three specimens equals or exceeds the minimum value permitted for a single specimen, and the value for more than one specimen is below the required average value, or when the value for one specimen is below the minimum value permitted for a single specimen, a retest of three additional specimens shall be made. The value for each of these retest specimens shall equal or exceed the required average value.
- (2) Retest for Erratic Test Results. When an erratic result is caused by a defective specimen or uncertainty in the test, a retest will be allowed. The report giving test results shall specifically state why the original specimen was considered defective or which step of the test procedure was carried out incorrectly.

K323.4 Requirements for Materials

K323.4.1 General. Requirements in para. K323.4 apply to pressure-containing parts, not to materials used as supports, gaskets, packing, or bolting. See also Appendix F, para. F323.4.

K323.4.2 Specific Requirements

- (a) Ductile iron and other cast irons are not permitted.
- (b) Zinc-coated materials are not permitted for pressure containing components and may not be attached to pressure-containing components by welding.

K323.4.3 Metallic Clad and Lined Materials. Materials with metallic cladding or lining may be used in accordance with the following provisions:

- (a) For metallic clad or lined piping components, the base metal shall be an acceptable material as defined in para. K323, and the thickness used in pressure design in accordance with para. K304 shall not include the thickness of the cladding or lining. The allowable stress used shall be that for the base metal at the design temperature. For such components, the cladding or lining may be any material that, in the judgment of the user, is suitable for the intended service and for the method of manufacture and assembly of the piping component.
- (b) Fabrication by welding of clad or lined piping components and the inspection and testing of such components shall be done in accordance with applicable provisions of the BPV Code, Section VIII, Division 1, UCL-30 through UCL-52, and the provisions of this Chapter.
- (c) If a metallic liner also serves as a gasket or as part of the flange facing, the requirements and limitations in para. K308.4 apply.

K323.5 Deterioration of Materials in Service

Paragraph 323.5 applies.

K325 MISCELLANEOUS MATERIALS

Paragraph 325 applies.

PART 8 STANDARDS FOR PIPING COMPONENTS

K326 REQUIREMENTS FOR COMPONENTS

K326.1 Dimensional Requirements

- **K326.1.1 Listed Piping Components.** Dimensional standards for piping components are listed in Table K326.1. Dimensional requirements contained in specifications listed in Appendix K shall also be considered requirements of this Code.
- (16) K326.1.2 Unlisted Piping Components. Piping components not listed in Table K326.1 or Appendix K shall meet the pressure design requirements described in para. K302.2.3 and the mechanical strength requirements described in para. K302.5.
 - **K326.1.3 Threads.** The dimensions of piping connection threads not otherwise covered by a governing component standard or specification shall conform to the requirements of applicable standards listed in Table K326.1 or Appendix K.

K326.2 Ratings of Components

K326.2.1 Listed Components. The pressuretemperature ratings of components listed in Table K326.1

are accepted for pressure design in accordance with para. K303.

K326.2.2 Unlisted Components. The pressure–temperature ratings of unlisted piping components shall conform to the applicable provisions of para. K304.

K326.3 Reference Documents

The documents listed in Table K326.1 contain references to codes, standards, and specifications not listed in Table K326.1. Such unlisted codes, standards, and specifications shall be used only in the context of the listed documents in which they appear.

The design, materials, fabrication, assembly, examination, inspection, and testing requirements of this Chapter are not applicable to components manufactured in accordance with the documents listed in Table K326.1, unless specifically stated in this Chapter or in the listed document.

K326.4 Repair of Piping Components by Welding

A defect in a component listed in Table K326.1 or in an unlisted component in accordance with para. K302.2.3(a) may be repaired by welding, provided that all of the following criteria are met:

- (a) The component specification provides for weld repair.
- (b) The welding procedure and welders or welding operators are qualified as required by para. K328.2.
- (c) The repair and its examination are performed in accordance with the component specification and with the owner's approval.

PART 9 FABRICATION, ASSEMBLY, AND ERECTION

K327 GENERAL

Piping materials and components are prepared for assembly and erection by one or more of the fabrication processes covered in paras. K328, K330, K331, K332, and K333. When any of these processes is used in assembly or erection, requirements are the same as for fabrication.

K328 WELDING

Welding that conforms to the requirements of para. K328 may be used in accordance with para. K311.

K328.1 Welding Responsibility

Each employer is responsible for the welding done by the personnel of his organization and shall conduct the tests required to qualify welding procedures, and to qualify and as necessary requalify welders and welding operators.

Table K326.1 Component Standards

Standard or Specification	Designation
Bolting	
Square and Hex Bolts and Screws, Inch Series; Including Hex Cap Screws and Lag Screws	ASME B18.2.1 ASME B18.2.2
Metallic Fittings, Valves, and Flanges	
Pipe Flanges and Flanged Fittings [Note (1)]	ASME B16.5 ASME B16.9 ASME B16.11 ASME B16.34 ASME B16.48 MSS SP-25 MSS SP-65
Metallic Pipe and Tubes	
Welded and Seamless Wrought Steel Pipe [Note (1)]	ASME B36.10M ASME B36.19M
Miscellaneous	
Threading, Gauging, and Thread Inspection of Casing, Tubing, and Line Pipe Threads Unified Inch Screw Threads (UN and UNR Thread Form) Pipe Threads, General Purpose (Inch) Metallic Gaskets for Pipe Flanges. Buttwelding Ends Surface Texture (Surface Roughness, Waviness, and Lay).	API 5B ASME B1.1 ASME B1.20.1 ASME B16.20 ASME B16.25 ASME B46.1

GENERAL NOTE: The approved edition dates of these standards and specifications, along with the names and addresses of the sponsoring organizations, are shown in Appendix E.

NOTE:

- (1) The use of components made in accordance with these standards is permissible, provided they are
 - (a) examined and leak tested in accordance with the requirements of paras. K341 and K345, respectively.
 - (b) impact tested in accordance with the methods described in paras. K323.3.1 through K323.3.4, and meet the acceptance criteria specified in para. K323.3.5. Note that such impact testing may require the destruction of one component from the same lot as the component to be used in service [see Table K323.3.1, Note (1)].

K328.2 Welding Qualifications

- **K328.2.1 Qualification Requirements.** Qualification of the welding procedures to be used and of the performance of welders and welding operators shall comply with the requirements of the BPV Code, Section IX, except as modified herein.
- (a) Impact tests shall be performed for all procedure qualifications in accordance with para. K323.3.
- (b) Test weldments shall be made using the same specification and type or grade of base metal(s), and the same specification and classification of filler metal(s) as will be used in production welding.
- (c) Test weldments shall be subjected to essentially the same heat treatment, including cooling rate and cumulative time at temperature, as the production welds.
- (d) When tensile specimens are required by Section IX, the yield strength shall also be determined, using the method required for the base metal. The yield strength of each test specimen shall be not less than the specified minimum yield strength at room temperature (S_Y) for the base metals joined. Where two base metals having different S_Y values are joined by welding, the yield strength of each test specimen shall be not less than the lower of the two S_Y values.
- (e) Mechanical testing is required for all performance qualification tests.
- (f) Qualification on pipe or tubing shall also qualify for plate, but qualification on plate does not qualify for pipe or tubing.
- (g) For thickness greater than 51 mm (2 in.), the procedure test coupon shall be at least 75% as thick as the thickest joint to be welded in production.

K328.2.3 Performance Qualification by Others.

Welding performance qualification by others is not permitted.

K328.2.4 Qualification Records. Paragraph 328.2.4 applies.

K328.3 Materials

K328.3.1 Filler Metal. Filler metal shall be specified in the engineering design and shall conform to the requirements of the BPV Code, Section IX. A filler metal not yet incorporated in Section IX may be used with the owner's approval if a procedure qualification test, including an all-weld-metal test, is first successfully made.

K328.3.2 Weld Backing Material. Backing rings shall not be used.

K328.3.3 Consumable Inserts. Paragraph 328.3.3 applies, except that procedures shall be qualified as required by para. K328.2.

K328.4 Preparation for Welding

K328.4.1 Cleaning. Paragraph 328.4.1 applies.

K328.4.2 End Preparation

- (a) General
- (1) Butt weld end preparation is acceptable only if the surface is machined or ground to bright metal.
- (2) Butt welding end preparation contained in ASME B16.25 or any other end preparation that meets the procedure qualification is acceptable. [For convenience, the basic bevel angles taken from B16.25, with some additional J-bevel angles, are shown in Fig. 328.4.2 sketches (a) and (b).]
 - (b) Circumferential Welds
- (1) If components ends are trimmed as shown in Fig. 328.4.2 sketch (a) or (b) to accommodate consumable inserts, or as shown in Fig. K328.4.3 to correct internal misalignment, such trimming shall not result in a finished wall thickness before welding less than the required minimum wall thickness, t_m .
- (2) It is permissible to size pipe ends of the same nominal size to improve alignment, if wall thickness requirements are maintained.
- (3) Where necessary, weld metal may be deposited on the inside or outside of the component to permit alignment or provide for machining to ensure satisfactory seating of inserts.
- (4) When a butt weld joins sections of unequal wall thickness and the thicker wall is more than $1\frac{1}{2}$ times the thickness of the other, end preparation and geometry shall be in accordance with acceptable designs for unequal wall thickness in ASME B16.5.

K328.4.3 Alignment

- (a) Girth Butt Welds
- (1) Inside diameters of components at the ends to be joined shall be aligned within the dimensional limits in the welding procedure and the engineering design, except that no more than 1.5 mm ($\frac{1}{16}$ in.) misalignment is permitted as shown in Fig. K328.4.3.
- (2) If the external surfaces of the two components are not aligned, the weld shall be tapered between the two surfaces with a slope not steeper than 1:4.
- (b) Longitudinal Butt Joints. Preparation for longitudinal butt welds (not made in accordance with a standard listed in Table K-1 or Table K326.1) shall conform to the requirements of para. K328.4.3(a).
 - (c) Branch Connection Welds
- (1) The dimension m in Fig. K328.5.4 shall not exceed ± 1.5 mm ($\frac{1}{16}$ in.).
- (2) The dimension *g* in Fig. K328.5.4 shall be specified in the engineering design and the welding procedure.

K328.5 Welding Requirements

K328.5.1 General. The requirements of paras. 328.5.1(b), (d), (e), and (f) apply in addition to the requirements specified below.

- (a) All welds, including tack welds, repair welds, and the addition of weld metal for alignment [paras. K328.4.2(b)(3) and K328.4.3(c)(1)], shall be made by qualified welders or welding operators, in accordance with a qualified procedure.
- (b) Tack welds at the root of the joint shall be made with filler metal equivalent to that used for the root pass. Tack welds shall be fused with the root pass weld, except that those that have cracked shall be removed. Bridge tacks (above the root) shall be removed.
- **K328.5.2 Fillet Welds.** Fillet welds, where permitted (see para. K311.2.2), shall be fused with and shall merge smoothly into the component surfaces.

K328.5.3 Seal Welds. Seal welds are not permitted.

K328.5.4 Welded Branch Connections. Branch connection fittings (see para. 300.2), attached by smoothly contoured full penetration groove welds of a design that permits 100% interpretable radiographic examination are the only types acceptable.

Figure K328.5.4 shows acceptable details of welded branch connections. The illustrations are typical and are not intended to exclude acceptable types of construction not shown.

K328.5.5 Fabricated Laps. Fabricated laps are not permitted.

K328.6 Weld Repair

Paragraph 328.6 applies, except that procedures and performance shall be qualified as required by para. K328.2.1. See also para. K341.3.3.

-- Control of the con

Fig. K328.4.3 Pipe Bored for Alignment: Trimming and Permitted Misalignment





Fig. K328.5.4 Some Acceptable Welded Branch Connections Suitable for 100% Radiography



K330 PREHEATING

K330.1 General

Paragraph 330.1 applies, except that seal welds are not permitted in this Chapter.

K330.1.1 Requirements. Paragraph 330.1.1 applies.

K330.1.2 Unlisted Materials. Paragraph 330.1.2 applies.

K330.1.3 Temperature Verification. Paragraph 330.1.3(a) applies. Temperature-indicating materials and techniques shall not be detrimental to the base metals.

K330.1.4 Preheat Zone. Paragraph 330.1.4 applies.

K330.2 Specific Requirements

Paragraph 330.2 applies in its entirety.

K331 HEAT TREATMENT

The text introducing para. 331 applies.

(16) K331.1 General

- **K331.1.1 Heat Treatment Requirements.** The provisions of para. 331 and Table 331.1.1 apply, except as specified below.
- (a) Heat treatment is required for all thicknesses of P-Nos. 4 and 5 materials.
- (b) For welds other than longitudinal in quenched and tempered materials, when heat treatment is required by the engineering design, the temperature shall not be higher than 28°C (50°F) below the tempering temperature of the material.
- (c) Longitudinal welds in quenched and tempered material shall be heat treated in accordance with the applicable material specification.
- **K331.1.3 Governing Thickness.** When components are joined by welding, the thickness to be used in applying the heat treatment provisions of Table 331.1.1 shall be that of the thicker component measured at the joint, except as follows:

In the case of fillet welds used for attachment of external nonpressure parts, such as lugs or other pipe-supporting elements, heat treatment is required when the thickness through the weld and base metal in any plane is more than twice the minimum material thickness requiring heat treatment (even though the thickness of the components at the joint is less than that minimum thickness) except as follows:

- (a) not required for P-No. 1 materials when weld throat thickness is 16 mm ($\frac{5}{8}$ in.) or less, regardless of base metal thickness.
- (b) not required for P-Nos. 3, 4, 5, 10A, and 10B materials when weld throat thickness is 6 mm ($\frac{1}{4}$ in.) or less, regardless of base metal thickness, provided that not less than the recommended minimum preheat is applied

and the specified minimum tensile strength of the base metal is less than 490 MPa (71 ksi).

(c) not required for ferritic materials when welds are made with filler metal that does not air harden. Austenitic welding materials may be used for welds to ferritic materials when the effects of service conditions, such as differential thermal expansion due to elevated temperature, or corrosion, will not adversely affect the weldment.

K331.1.4 Heating and Cooling. Paragraph 331.1.4 applies.

K331.1.6 Temperature Verification. Heat treatment temperature shall be checked by thermocouple pyrometers or other suitable methods to ensure that the WPS requirements are met. Temperature-indicating materials and techniques shall not be detrimental to the base metals.

K331.2 Specific Requirements

Paragraph 331.2 applies in its entirety.

K332 BENDING AND FORMING

K332.1 General

Pipe shall be hot or cold bent in accordance with a written procedure to any radius that will result in surfaces free of cracks and free of buckles. The procedure shall address at least the following, as applicable:

- (a) material specification and range of size and thickness
 - (b) range of bend radii and fiber elongation
- (c) minimum and maximum metal temperature during bending
 - (d) method of heating and maximum hold time
- (e) description of bending apparatus and procedure to be used
- (f) mandrels or material and procedure used to fill the bore
- (g) method for protection of thread and machined surfaces
 - (h) examination to be performed
 - (i) required heat treatment
- (j) postheat treatment dimensional adjustment technique

K332.2 Bending

K332.2.1 Bend Flattening. The difference between the maximum and the minimum diameters at any cross section of a bend shall not exceed 8% of nominal outside diameter for internal pressure and 3% for external pressure.

K332.2.2 Bending Temperature. Paragraph 332.2.2 applies, except that in cold bending of quenched and tempered ferritic materials, the temperature shall be at least 28°C (50°F) below the tempering temperature.

K332.3 Forming

Piping components shall be formed in accordance with a written procedure. The temperature range shall be consistent with material characteristics, end use, and specified heat treatment. The thickness after forming shall be not less than required by design. The procedure shall address at least the following, as applicable:

- (a) material specification and range of size and thickness
- (b) maximum fiber elongation expected during forming
- (c) minimum and maximum metal temperature during bending
 - (d) method of heating and maximum hold time
- (e) description of forming apparatus and procedure to be used
- (f) materials and procedures used to provide internal support during forming
 - (g) examination to be performed
 - (h) required heat treatment

K332.4 Required Heat Treatment

K332.4.1 Hot Bending and Forming. After hot bending and forming, heat treatment is required for all thicknesses of P-Nos. 3, 4, 5, 6, 10A, and 10B materials that are not quenched and tempered. Times and temperatures shall be in accordance with para. 331. Quenched and tempered materials shall be reheat treated to the original material specification.

K332.4.2 Cold Bending and Forming

- (a) After cold bending and forming, heat treatment in accordance with (b) below is required, regardless of thickness, when specified in the engineering design or when the maximum calculated fiber elongation exceeds 5% strain or 50% of the basic minimum specified longitudinal elongation for the applicable specification, grade, and thickness for P-Nos. 1 through 6 materials (unless it has been demonstrated that the selection of the pipe and the procedure for making the components provide assurance that the most severely formed portion of the material has retained an elongation of not less than 10%).
- (b) Heat treatment is required regardless of thickness and shall conform to the temperatures and durations given in Table 331.1.1, except that for quenched and tempered materials, the stress relieving temperature shall not exceed a temperature 28°C (50°F) below the tempering temperature of the material.

K333 BRAZING AND SOLDERING

Brazing shall be in accordance with para. 333. The owner shall specify examination requirements for brazed joints.

K335 ASSEMBLY AND ERECTION

K335.1 General

Paragraph 335.1 applies.

K335.2 Flanged Joints

Paragraph 335.2 applies, except that bolts shall extend completely through their nuts.

K335.3 Threaded Joints

Paragraph 335.3 applies, except that threaded joints shall not be seal welded.

K335.4 Special Joints

Special joints (as defined in para. K318) shall be installed and assembled in accordance with the manufacturer's instructions, as modified by the engineering design. Care shall be taken to ensure full engagement of joint members.

K335.5 Cleaning of Piping

See Appendix F, para. F335.9.

PART 10 INSPECTION, EXAMINATION, AND TESTING

K340 INSPECTION

Paragraphs 340.1 through 340.4 apply.

K341 EXAMINATION

Paragraphs 341.1 and 341.2 apply.

K341.3 Examination Requirements

- **K341.3.1 General.** Prior to initial operation, each piping installation, including components and workmanship, shall be examined in accordance with para. K341.4 and the engineering design. If heat treatment is performed, examination shall be conducted after its completion.
- **K341.3.2 Acceptance Criteria.** Acceptance criteria shall be as stated in the engineering design and shall at least meet the applicable requirements stated in (a) and (b) below, and elsewhere in this Chapter.
- (a) Table K341.3.2 states acceptance criteria (limits on imperfections) for welds. See Fig. 341.3.2 for typical weld imperfections.
- (b) Acceptance criteria for castings are specified in para. K302.3.3.

K341.3.3 Defective Components and Workmanship.

Defects (imperfections of a type or magnitude not acceptable by the criteria specified in para. K341.3.2) shall be repaired, or the defective item or work shall be replaced.

Table K341.3.2 Acceptance Criteria for Welds

Criteria (A-F) for Types of Welds, and for Required Examination Methods [Note (1)]

	Type of Methods		f Weld			
			Longitudin	Longitudinal		Branch
Type of Imperfection	Visual	Ultrasonics or Radiography	Girth Groove	Groove [Note (2)]	Fillet [Note (3)]	Connection [Note (4)]
Crack	\checkmark	\checkmark	Α	Α	Α	Α
Lack of fusion	/	√ ·	Α	Α	Α	Α
Incomplete penetration	/	√ ·	Α	Α	Α	Α
Internal porosity			В	В	N/A	В
Internal slag inclusion, tungsten inclusion, or elongated indication	•••	, 	С	С	N/A	С
Undercutting	\checkmark	\checkmark	Α	Α	Α	Α
Surface porosity or exposed slag inclusion	, /		Α	Α	Α	Α
Concave root surface (suck-up)	<i>,</i>	\checkmark	D	D	N/A	D
Surface finish	/		Е	Е	E	E
Reinforcement or internal protrusion	<i>,</i>		F	F	F	F

GENERAL NOTES:

- (a) Weld imperfections are evaluated by one or more of the types of examination methods given, as specified in paras. K341.4.1 and K341.4.2.
- (b) "N/A" indicates this Chapter does not establish acceptance criteria or does not require evaluation of this kind of imperfection for this type of weld.

Criterion Value Notes for Table K341.3.2

- (c) Check (,/) indicates examination method generally used for evaluating this kind of weld imperfection.
- (d) Ellipsis (...) indicates examination method not generally used for evaluating this kind of weld imperfection.

Criterion Acceptable Value Limits [Note (5)] Symbol Measure Extent of imperfection Α Zero (no evident imperfection) В Size and distribution of internal porosity See BPV Code, Section VIII, Division 1, Appendix 4 C Internal slag inclusion, tungsten inclusion, or elongated indication. Indications are unacceptable if the amplitude exceeds the reference level, or indications have lengths that exceed Individual length [Note (6)] 6 mm ($\frac{1}{4}$ in.) for $\overline{T}_w \le 19$ mm ($\frac{3}{4}$ in.) \overline{T}_w /3 for 19 mm ($\frac{3}{4}$ in.) < $\overline{T}_w \le$ 57 mm (2 $\frac{1}{4}$ in.) 19 mm ($\frac{3}{4}$ in.) for $\overline{T}_w > 57$ mm ($2\frac{1}{4}$ in.) Cumulative length $\leq \overline{T}_w$ in any 12 \overline{T}_w weld length Wall Thickness, D Depth of root surface concavity Depth of Surface Concavity, \overline{T}_w , mm (in.) mm (in.) ≤13 (½) ≤1.5 (¹/₁₆) >13 $\binom{1}{2}$ and \leq 51 (2) $\leq 3 \quad (\frac{1}{8})$ >51 (2) $\leq 4 \quad (\frac{5}{32})$ and total joint thickness including weld reinforcement Ε Surface roughness \leq 12.5 µm (500 µin.) R_a (see ASME B46.1 for definition of roughness average, R_a) Height of reinforcement or internal protrusion [Note (7)] External Weld Reinforcement in any plane through the weld shall be within the Wall Thickness, or Internal Weld Protrusion, \overline{T}_w , mm (in.) limits of the applicable height value in the tabulamm (in.) tion at the right. Weld metal shall be fused with and $\leq 13 \, \binom{1}{2}$ $\leq 1.5 \; (\frac{1}{16})$ merge smoothly into the component surfaces.

>13 $\binom{1}{2}$ and \leq 51 (2)

>51 (2)

≤3 (¹/₈)

<4

 $(\frac{5}{32})$

Table K341.3.2 Acceptance Criteria for Welds (Cont'd)

NOTES:

- (1) Criteria given are for required examination. More stringent criteria may be specified in the engineering design.
- (2) Longitudinal welds include only those permitted in paras. K302.3.4 and K305. The criteria shall be met by all welds, including those made in accordance with a standard listed in Table K326.1 or in Appendix K.
- (3) Fillet welds include only those permitted in para. K311.2.2.
- (4) Branch connection welds include only those permitted in para. K328.5.4.
- (5) Where two limiting values are given, the lesser measured value governs acceptance. \overline{T}_w is the nominal wall thickness of the thinner of two components joined by a butt weld.
- (6) For ultrasonic examination, refer to para. K344.6.3 for acceptable value limits.
- (7) For groove welds, height is the lesser of the measurements made from the surfaces of the adjacent components. For fillet welds, height is measured from the theoretical throat; internal protrusion does not apply. Required thickness t_m shall not include reinforcement or internal protrusion.

Examination shall be as follows:

- (a) When the defective item or work is repaired, the repaired portion of the item or work shall be examined. The examination shall use the same methods and acceptance criteria employed for the original examination. See also para. K341.3.1(a).
- (b) When the defective item or work is replaced, the new item or work used to replace the defective item or work shall be examined. The examination shall use any method and applicable acceptance criteria that meet the requirements for the original examination. See also para. K341.3.1(a).

K341.4 Extent of Required Examination

Piping shall be examined to the extent specified herein or to any greater extent specified in the engineering design.

K341.4.1 Visual Examination

- (a) The requirements of para. 341.4.1(a) apply with the following exceptions in regard to extent of examination:
 - (1) Materials and Components. 100%.
 - (2) Fabrication. 100%.
 - (3) Threaded, Bolted, and Other Joints. 100%.
- (4) Piping Erection. All piping erection shall be examined to verify dimensions and alignment. Supports, guides, and points of cold spring shall be checked to ensure that movement of the piping under all conditions of startup, operation, and shutdown will be accommodated without undue binding or unanticipated constraint.
- (b) Pressure-Containing Threads. 100% examination for finish and fit is required. Items with visible imperfections in thread finish and/or the following defects shall be rejected:
- (1) Tapered Threads. Failure to meet gaging requirements in API Spec 5B or ASME B1.20.1, as applicable.
- (2) Straight Threads. Excessively loose or tight fit when gaged for light interference fit.

K341.4.2 Radiographic and Ultrasonic Examination

(a) All girth, longitudinal, and branch connection welds shall be 100% radiographically examined, except as permitted in (b) below.

- (b) When specified in the engineering design and with the owner's approval, ultrasonic examination of welds may be substituted for radiographic examination where $\overline{T}_w \ge 13$ mm ($\frac{1}{2}$ in.).
- (c) In-process examination (see para. 344.7) shall not be substituted for radiographic or ultrasonic examination of welds.

K341.4.3 Certifications and Records. Paragraph 341.4.1(c) applies.

K341.5 Supplementary Examination

Any of the examination methods described in para. K344 may be specified by the engineering design to supplement the examination required by para. K341.4. The extent of supplementary examination to be performed and any acceptance criteria that differ from those specified in para. K341.3.2 shall be specified in the engineering design.

K341.5.1 Hardness Tests. Paragraph 341.5.2 applies.

K341.5.2 Examinations to Resolve Uncertainty. Paragraph 341.5.3 applies.

K342 EXAMINATION PERSONNEL (16)

Paragraph 342 applies in its entirety.

K343 EXAMINATION PROCEDURES (16)

Paragraph 343 applies, except that the examination methods shall comply with para. K344.

K344 TYPES OF EXAMINATION

K344.1 General

Paragraphs 344.1.1 and 344.1.2 apply. In para. 344.1.3, terms other than "100% examination" apply only to supplementary examinations.

K344.2 Visual Examination

Paragraph 344.2 applies in its entirety.

K344.3 Magnetic Particle Examination

The method for magnetic particle examination shall be as specified in

- (a) paragraph K302.3.3(b) for castings
- (b) BPV Code, Section V, Article 7 for welds and other components

K344.4 Liquid Penetrant Examination

The method for liquid penetrant examination shall be as specified in

- (a) paragraph K302.3.3(b) for castings
- (b) BPV Code, Section V, Article 6 for welds and other components

K344.5 Radiographic Examination

The method for radiographic examination shall be as specified in

- (a) paragraph K302.3.3(c) for castings
- (b) BPV Code, Section V, Article 2 for welds and other components

K344.6 Ultrasonic Examination

K344.6.1 Castings. The method for ultrasonic examination of castings shall be as specified in para. K302.3.3(c).

K344.6.2 Pipe and Tubing

- (a) Method. Pipe and tubing, required or selected in accordance with Table K305.1.2 to undergo ultrasonic examination, shall pass a 100% examination for longitudinal defects in accordance with ASTM E213, Ultrasonic Testing of Metal Pipe and Tubing. Longitudinal (axial) reference notches shall be introduced on the outer and inner surfaces of the calibration (reference) standard in accordance with Fig. 3(c) of ASTM E213 to a depth not greater than the larger of 0.1 mm (0.004 in.) or 4% of specimen thickness and a length not more than 10 times the notch depth.
- (b) Acceptance Criteria. Any indication greater than that produced by the calibration notch represents a defect; defective pipe and tubing shall be rejected.
- (c) Records. For pipe and tubing that passes this examination, a report shall be prepared that contains at least the information specified in 15.2.1 through 15.2.6 of ASTM E213.

(16) K344.6.3 Welds

- (a) Method. The method for ultrasonic examination of welds shall be as specified in the ASME BPV Code, Section V, Article 4 for nominal thickness, T_w , greater than or equal to 13 mm ($\frac{1}{2}$ in.) but less than 25 mm (1 in.), and Section VIII, Division 3, KE-301 and KE-302 for nominal wall thickness, T_w , greater than or equal to 25 mm (1 in.).
- (b) Acceptance Criteria. Cracks, lack of fusion, incomplete penetration, or undercutting are unacceptable

regardless of size or length (see Table K341.3.2). In addition, for an internal slag inclusion, tungsten inclusion, or elongated indication

- (1) for nominal wall thickness, \overline{T}_w , greater than or equal to 13 mm ($\frac{1}{2}$ in.) but less than 25 mm (1 in.), the acceptance criterion for the thickness to be examined specified in para. 344.6.2 applies.
- (2) for nominal wall thickness, \overline{T}_w , greater than or equal to 25 mm (1 in.), the acceptance criteria specified in ASME BPV Code, Section VIII, Division 3, KE-333 for the thickness to be examined apply.

K344.7 In-Process Examination

Paragraph 344.7 applies in its entirety.

K344.8 Eddy Current Examination

- **K344.8.1 Method.** The method for eddy current examination of pipe and tubing shall follow the general guidelines of the ASME BPV Code, Section V, Article 8, subject to the following specific requirements:
- (a) Cold drawn austenitic stainless steel pipe and tubing, selected in accordance with Table K305.1.2 for eddy current examination, shall pass a 100% examination for longitudinal defects.
- (b) A calibration (reference) standard shall be prepared from a representative sample. A longitudinal (axial) reference notch shall be introduced on the inner surface of the standard to a depth not greater than the larger of 0.1 mm (0.004 in.) or 5% of specimen thickness and a length not more than 6.4 mm (0.25 in.).
- **K344.8.2 Acceptance Criteria.** Any indication greater than that produced by the calibration notch represents a defect; defective pipe or tubing shall be rejected.
- **K344.8.3 Records.** For pipe and tubing that passes this examination, a report shall be prepared that includes at least the following information:
 - (a) material identification by type, size, lot, heat, etc.
 - (b) listing of examination equipment and accessories
- (c) details of examination technique (including examination speed and frequency) and end effects, if any
- (*d*) description of the calibration standard, including dimensions of the notch, as measured
 - (e) examination results

K345 LEAK TESTING

K345.1 Required Leak Test

Prior to initial operation, each piping system shall be leak tested.

(a) Each weld and each piping component, except bolting and individual gaskets to be used during final system assembly and pressure-relieving devices to be used during operation, shall be hydrostatically or pneumatically leak tested in accordance with para. K345.4 or K345.5, respectively. The organization conducting the test shall ensure that during the required leak testing of components and welds, adequate protection is provided to prevent injury to people and damage to property from missile fragments, shock waves, or other consequences of any failure that might occur in the pressurized system.

- (b) In addition to the requirements of (a) above, a leak test of the installed piping system, excluding pressure-relieving devices to be used during operation, shall be conducted at a pressure not less than 110% of the design pressure to ensure tightness, except as provided in (c) or (d) below.
- (c) If the leak test required in (a) above is conducted on the installed piping system, the additional test in (b) above is not required.
- (d) With the owner's approval, pressure-relieving devices to be used during operation may be included in the leak test required in (b) above. The leak test pressure may be reduced to prevent the operation of, or damage to, the pressure-relieving devices, but shall not be less than 90% of the lowest set pressure of the pressure-relieving devices in the system.
- (e) For closure welds, examination in accordance with para. K345.2.3(c) may be substituted for the leak test required in (a) above.
- (f) None of the following leak tests may be used in lieu of the leak tests required in para. K345.1:
 - (1) initial service leak test (para. 345.7)
 - (2) sensitive leak test (para. 345.8)
 - (3) alternative leak test (para. 345.9)

K345.2 General Requirements for Leak Tests

Paragraphs 345.2.4 through 345.2.7 apply. See below for paras. K345.2.1, K345.2.2, and K345.2.3.

K345.2.1 Limitations on Pressure

- (a) Through-Thickness Yielding. If the test pressure would produce stress (exclusive of stress intensification) in excess of S_{yt} at the outside surface of a component 10 at test temperature, as determined by calculation or by testing in accordance with para. K304.7.2(b), the test pressure may be reduced to the maximum pressure that will result in a stress (exclusive of stress intensification) at the outside surface that will not exceed S_{yt} .
 - (b) The provisions of paras. 345.2.1(b) and (c) apply.

K345.2.2 Other Test Requirements. Paragraph 345.2.2 applies. In addition, the minimum metal temperature during testing shall be not less than the impact test temperature (see para. K323.3.4).

K345.2.3 Special Provisions for Leak Testing. Paragraphs K345.2.3(a), (b), and (c) below apply only to the leak test specified in para. K345.1(a). They are not applicable to the installed piping system leak test specified in para. K345.1(b).

- (a) Piping Components and Subassemblies. Piping components and subassemblies may be leak tested either separately or as assembled piping.
- (b) Flanged Joints. Flanged joints used to connect piping components that have previously been leak tested, and flanged joints at which a blank or blind flange is used to isolate equipment or other piping during the leak test, need not be leak tested.
- (c) Closure Welds. Leak testing of the final weld connecting piping systems or components that have been successfully leak tested is not required, provided the weld is examined in-process in accordance with para. 344.7 and passes the required 100% radiographic examination in accordance with para. K341.4.2.

K345.3 Preparation for Leak Test

Paragraph 345.3 applies in its entirety.

K345.4 Hydrostatic Leak Test

Paragraph 345.4.1 applies. See paras. K345.4.2 and K345.4.3 below.

K345.4.2 Test Pressure for Components and Welds.

Except as provided in para. K345.4.3, the hydrostatic test pressure at every point in a metallic piping system shall be as follows:

- (a) not less than 1.25 times the design pressure.
- (*b*) when the design temperature is greater than the test temperature, the minimum test pressure, at the point under consideration, shall be calculated by eq. (38)

$$P_T = 1.25 P S_T / S (38)$$

where

P = internal design gage pressure

 P_T = minimum test gage pressure

- S = allowable stress at component design temperature for the prevalent pipe material; see
 Appendix K, Table K-1
- S_T = allowable stress at test temperature for the prevalent pipe material; see Table K-1
- (c) in those cases where the piping system may not include pipe itself, any other component in the piping system, other than pipe-supporting elements and bolting, may be used to determine the S_T/S ratio based on the applicable allowable stresses obtained from Table K-1. In those cases where the piping system may be made up of equivalent lengths of more than one material, the S_T/S ratio shall be based on the minimum calculated ratio of the included materials.

K345.4.3 Hydrostatic Test of Piping With Vessels as a System. Paragraph 345.4.3(a) applies.

K345.5 Pneumatic Leak Test

Paragraph 345.5 applies, except para. 345.5.4. See para. K345.5.4 below.

¹⁰ See para. K304.1.2, footnote 4.

K345.5.4 Test Pressure. The pneumatic test pressure for components and welds shall be identical to that required for the hydrostatic test in accordance with para. K345.4.2.

K345.6 Hydrostatic-Pneumatic Leak Test for Components and Welds

If a combination hydrostatic-pneumatic leak test is used, the requirements of para. K345.5 shall be met, and the pressure in the liquid-filled part of the piping shall not exceed the limits stated in para. K345.4.2.

K346 RECORDS

K346.1 Responsibility

It is the responsibility of the piping designer, the manufacturer, the fabricator, and the erector, as applicable, to prepare the records required by this Chapter and by the engineering design.

K346.2 Required Records

At least the following records, as applicable, shall be provided to the owner or the Inspector by the person responsible for their preparation:

- (a) the engineering design
- (b) material certifications
- (c) procedures used for fabrication, welding, heat treatment, examination, and testing
- (*d*) repair records of materials and piping components listed in Table K326.1 or unlisted components in accordance with para. K302.2.3(a), including the welding procedure used for each, and location of repairs
- (e) performance qualifications for welders and welding operators
 - (f) qualifications of examination personnel
- (*g*) records of examination of pipe and tubing for longitudinal defects as specified in paras. K344.6.2(c) and K344.8.3, as applicable

K346.3 Retention of Records

The owner shall retain one set of the required records for at least 5 years after they are received.

Chapter X High Purity Piping

U300 GENERAL STATEMENTS

- (a) Chapter X pertains to piping designated by the owner as being in High Purity Fluid Service. See also Appendix M.
- (b) The organization, content, and paragraph designations of this Chapter correspond to those of the base Code (Chapters I through VI), Chapter VII, and Chapter VIII. The prefix U is used to designate Chapter X requirements.
- (c) Provisions and requirements of the base Code, Chapter VII, and Chapter VIII apply only as stated in this Chapter.
- (d) For piping not in High Purity Fluid Service, Code requirements are found in Chapters I through IX.
- (e) High Purity Piping. Chapter X provides alternative rules for design and construction of piping designated by the owner as being High Purity Fluid Service.
- (1) These rules apply only when specified by the owner, and only as a whole, not in part.
- (2) Chapter X rules do not provide for High Pressure Fluid Service.
- (3) Chapter VII applies to nonmetallic piping and piping lined with nonmetals in High Purity Fluid Service.
 - (f) Chapter I applies.

PART 1 CONDITIONS AND CRITERIA

Chapter II, Part 1 applies. See para. U301.3.2(b)(5).

U301 DESIGN CONDITIONS

U301.3 Design Temperature

U301.3.2 Uninsulated Components

(*b*)(5) compression, face seal, and hygienic clamped fittings and joints — 100% of the fluid temperature

PART 2 PRESSURE DESIGN OF PIPING COMPONENTS

Chapter II, Part 2 applies. See Fig. U304.5.3 for representative configuration for metal face seal blanks.

PART 3 FLUID SERVICE REQUIREMENTS FOR PIPING COMPONENTS

Chapter II, Part 3 applies. See paras. U306.6, U307.3, and U308.

U306 FITTINGS, BENDS, MITERS, LAPS, AND BRANCH CONNECTIONS

U306.6 Tube Fittings

- (a) Tube fittings not listed in Table 326.1 or Appendix A shall meet the pressure design requirements described in para. 302.2.3 and the mechanical strength requirements described in para. 303.
- (*b*) Compression-type tube fittings may be used in accordance with para. U315.2 provided that the type of fitting selected complies with the following:
- (1) The gripping action of the fitting shall provide vibration resistance as demonstrated by exhibiting a stress intensity factor equal to or less than 1.5.
- (2) Intermixing of components from different manufacturers is permitted only when specified in the engineering design.
- (c) Face seal or hygienic clamped-type fittings in which the tightness of the joint is provided by a seating surface other than the threads (e.g., a metal face-seal fitting comprising internal and external threaded components, glands, and gasket or other constructions shown typically in Fig. U335.7.1) may be used.

U307 VALVES AND SPECIALTY COMPONENTS


U307.3 High Purity Fluid Service Valves

Valves such as ball, bellows, and diaphragm valves designed for High Purity Fluid Service that are not listed in Table 326.1 shall meet the pressure design requirements described in para. 302.2.2 and the mechanical strength requirements described in para. 303.


U308 FLANGES, BLANKS, FLANGE FACINGS, AND GASKETS

Flanges should be avoided whenever possible. When flanges are utilized, para. 308 applies, except expanded joint flanges described in para. 308.2.2 are not permitted.

Fig. U304.5.3 Blanks







(b) Metal Face Seal

PART 4 FLUID SERVICE REQUIREMENTS FOR PIPING JOINTS

Chapter II, Part 4 applies, except expanded joints, flared tube fittings, and caulked joints, described in paras. 313, 315, and 316, respectively, are not permitted. See paras. U311, U311.1(c), U314, and U315.

U311 WELDED JOINTS

Paragraph 311 applies, except for para. 311.1(c). See para. U311.1(c).

U311.1 General

(c) Examination shall be in accordance with para. U341.4.1.

U314 THREADED JOINTS

Threaded joints should be avoided whenever possible. When threaded joints are utilized, para. 314 applies.

U315 TUBING JOINTS

Paragraph 315 applies. See paras. U315.1, U315.2(c), and U315.3.

U315.1 General

In selecting and applying compression, face seal, and hygienic clamp-type tube fittings, the designer shall consider the possible adverse effects on the joints of such factors as assembly and disassembly, cyclic loading, vibration, shock, and thermal expansion and contraction. See para. FU315.

U315.2 Joints Conforming to Listed Standards

(c) Joints using compression, face seal, hygienic clamp, and automatic welding tube fittings covered by listed standards may be used.

U315.3 Joints Not Conforming to Listed Standards

- (a) Compression-type tube fitting joints shall be fully gaugeable on initial installation to ensure sufficient tightening.
- (*b*) Safeguarding is required for face seal or hygienic clamped-type joints used under severe cyclic conditions.

PART 5 FLEXIBILITY AND SUPPORT

Chapter II, Part 5 applies. See para. U319.3.6.

U319 PIPING FLEXIBILITY

U319.3 Properties for Flexibility Analysis

U319.3.6 Flexibility and Stress Intensification Factors. Paragraph 319.3.6 applies; however, piping components used in high-purity applications, e.g., multiport block valves, hygienic unions, crosses, and point-of-use and adaptor fittings, often do not have geometries similar to those in Table D300.

PART 6 SYSTEMS

Chapter II, Part 6 applies.

PART 7 METALLIC MATERIALS

The provisions and requirements in Chapter III for materials apply. Materials commonly used in high purity process piping systems include austenitic, ferritic, and duplex stainless steels, and nickel and nickel alloys.

PART 8 STANDARDS FOR PIPING COMPONENTS

Chapter IV applies.

PART 9 FABRICATION, ASSEMBLY, AND ERECTION U327 GENERAL

Metallic piping materials and components are prepared for assembly and erection by one or more of the fabrication processes covered in paras. U328, U330, U331, and U332. When any of these processes is used in assembly or erection, requirements are the same as for fabrication.

U328 WELDING

Paragraph 328 applies, except for paras. 328.3.2, 328.5.4, and 328.5.5. See paras. U328.2.1(g) and (h), U328.4, U328.4.4, and U328.5.1(g) for additional requirements.

U328.2 Welding and Brazing Qualification

U328.2.1 Qualification Requirements

- (*g*) A change in the type or nominal composition of the backing (purge) gas shall require requalification.
- (h) The welding process shall be orbital GTAW, except for tack welds. Tack welds made prior to orbital welding may be manual GTAW.

(16) U328.4 Preparation for Welding

Paragraph 328.4.1 applies. Additionally, when weld coupon examination is specified in the engineering design, primary weld coupons shall be made in accordance with para. U328.4.4(b)(1) and examined in accordance with para. U344.8 prior to the start of production welding. This will demonstrate that the orbital welding equipment is set up properly and the weld program is sufficient to make repeatable production welds in accordance with the qualified welding procedure specification (WPS).

U328.4.4 Preparation of Weld Coupons

- (a) Weld coupons shall be made by qualified welding operators using the same qualified WPS and the same variables used for production welds.
 - (b) Methods
- (1) Primary weld coupons shall be made from two short sections of tubing selected from the same diameter, wall thickness, and alloy as the material used for production. Sections shall be of sufficient length for fit up in the weld head allowing for attachment of inside diameter

purge apparatus outside of the weld head. The sections shall be welded together in a square groove weld on a butt joint.

(2) Production weld coupons may be made in accordance with para. U328.4.4(b)(1) or, at the owner's discretion, may be cut from actual production welds. The weld coupons shall be selected to ensure that the work product of each welding operator doing the production welding is represented.

U328.5 Welding Requirements

U328.5.1 General

(g) Tack welds shall be fully consumed after completion of the weld. Tack welds shall be made by a qualified welder or welding operator.

U330 PREHEATING

Paragraph 330 applies.

U331 HEAT TREATMENT

Paragraph 331 applies.

U332 BENDING AND FORMING

Paragraph 332 applies in its entirety.

U333 BRAZING AND SOLDERING

Brazing and soldering are not permitted.

U335 ASSEMBLY AND ERECTION

Paragraph 335 applies, except for paras. 335.4.1, 335.5, and 335.6. See paras. U335.7 and U335.8.

U335.7 Face Seal Joints

U335.7.1 Metal Face Seal. Metal face seal joints shall be installed and assembled in accordance with manufacturer's instructions. See Fig. U335.7.1, illustration (a).

U335.7.2 Nonmetallic Face Seal. Nonmetallic face seal joints shall be installed and assembled in accordance with manufacturer's instructions. Care shall be taken to avoid distorting the seal when incorporating such joints into piping assemblies by welding. See Fig. U335.7.1, illustration (b).

U335.8 Hygienic Clamp Joint Assembly

Hygienic clamp joint assembly components, e.g., those shown in Figs. U335.8A, U335.8B, and U335.8C, shall be installed and assembled in accordance with the manufacturer's instructions. Care shall be taken to avoid distorting the seal when incorporating such joints into piping assemblies by welding.

Fig. U335.7.1 Face Seal Joints




Fig. U335.8A Hygienic Clamp Joint Assembly




Fig. U335.8B Hygienic Clamp Types





Fig. U335.8C Hygienic Ferrules



PART 10 INSPECTION, EXAMINATION, AND TESTING

U340 INSPECTION

Paragraph 340 applies in its entirety.

U341 EXAMINATION

Paragraph 341 applies. See paras. U341.3.2 and U341.4.1.

U341.3 Examination Requirements

(16) **U341.3.2 Acceptance Criteria.** Where weld coupon examination is specified in the engineering design, acceptance criteria for all welds shall be as stated in the referencing code or standard (e.g., ASME BPE or SEMI) and shall at least meet the applicable requirements in para. 341.3.2.

U341.4 Extent of Required Examination

U341.4.1 Examination. A weld coupon examination in accordance with para. U344.8 may be used in lieu of the 5% random radiography/ultrasonic examination required in para. 341.4.1(b)(1) when the following are employed in fabrication:

- (a) autogenous automatic orbital welding
- (b) automatic orbital welding with the use of consumable insert rings

U341.4.5 Weld Coupon Examination. Weld coupons shall be made and examined in accordance with para. U344.8 when any of the following conditions exist:

- (a) beginning of shift
- (b) change of purge source
- (c) change of power supply

- (*d*) change of equipment, e.g., weld head, weld-head extensions, tungsten
 - (e) anytime there is a weld defect

U342 EXAMINATION PERSONNEL

Paragraph 342 applies in its entirety. See para. U342.2(a).

U342.2 Specific Requirement

- (a) For weld coupon examination
- (1) the examinations shall be performed by personnel other than those performing the production work or
- (2) with the owner's approval, the personnel performing the production work shall be permitted to perform the examination, provided the personnel meet the personnel qualification and certification requirements in para. 342.1

U343 EXAMINATION PROCEDURES

Paragraph 343 applies.

U344 TYPES OF EXAMINATION

Paragraph 344 applies. See paras. U344.2 and U344.8.

U344.2 Visual Examination

Paragraph 344.2 applies, except in addition to the method described in para. 344.2.2, borescopic examination shall be acceptable.

U344.8 Weld Coupon Examination

- **U344.8.1 Requirements.** Weld coupon examination comprises examination of weld coupons for the following, as applicable:
- (a) prior to welding of coupons made in accordance with para. U328.4.4(b)(1)
 - (1) joint preparation and cleanliness
- (2) fit-up, collet or clamp grip, and alignment in the weld head
- (3) variables in the orbital welding machine specified in the WPS
- (b) after welding of coupons made in accordance with para. U328.4.4(b)(1), and for weld coupons made in accordance with para. U328.4.4(b)(2), for compliance with para. U341.3.2
 - (1) alignment
 - (2) weld penetration
 - (3) weld bead width variation
 - (4) weld bead meander
 - (5) discoloration
- (6) weld defects, e.g., cracks, porosity, or sulfur stringers

To allow direct visual examination of the inside surfaces, the weld coupon may be cut or a suitable indirect visual examination method (e.g., borescopic examination) may be used.

U344.8.2 Method. A weld coupon shall be made to allow visual examination in accordance with para. U344.2, unless otherwise specified in the engineering design.

U345 TESTING (16)

(16)

Paragraph 345 applies except for paras. 345.1, 345.8, and 345.9. See paras. U345.1, U345.8, and U345.9.

U345.1 Required Leak Test

Paragraph 345.1 applies, except that, at the owner's option, a helium mass spectrometer test in accordance with para. U345.8.1 may be substituted for the hydrostatic leak test.

U345.8 Sensitive Leak Test

Paragraph 345.8 applies, except the helium mass spectrometer test described in para. U345.8.1 is also an acceptable method.

- **U345.8.1 Helium Mass Spectrometer Test.** The test shall be one of the following methods and performed in accordance with the following:
- (a) For pressurized systems, the test shall be in accordance with BPV Code Section V, Article 10, Appendix IV (Helium Mass Spectrometer Detector Probe Technique).
- (1) The test pressure shall be the lesser of 105 kPa (15 psig) gage, or 25% of the design pressure.
- (2) Prior to testing, the test pressure shall be held a minimum of 30 min.
- (3) Unless otherwise specified in the engineering design, the system tested is acceptable when no leakage is detected that exceeds the allowable leakage rate of 1×10^{-4} std cc/s.
- (b) For evacuated systems, the test shall be in accordance with BPV Code Section V, Article 10, Appendix V (Helium Mass Spectrometer Test Tracer Probe Technique).
- (1) The piping system shall be evacuated to an absolute pressure sufficient for connection of the helium mass spectrometer to the system.
- (2) Unless otherwise specified in the engineering design, the system tested is acceptable when no leakage is detected that exceeds the allowable leakage rate of 1×10^{-5} std cc/s.

U345.9 Alternative Leak Test

Paragraph 345.9 applies, except welds may be examined by weld coupon examination method in accordance with para. U341.4.5 and the test method may be helium mass spectrometer test in accordance with para. U345.8.1.

U346 RECORDS

U346.2 Responsibility

It is the responsibility of the piping designer, the manufacturer, the fabricator, and the erector, as applicable, to prepare the records required by this Code, ASME BPE, SEMI, or other industry standard as specified in the engineering design.

U346.3 Retention of Records

Paragraph 346.3 applies.

PART 11 HIGH PURITY PIPING IN CATEGORY M FLUID SERVICE

UM300 GENERAL STATEMENTS

- (a) Chapter X, Part 11 pertains to piping designated by the owner as being high purity piping in Category M Fluid Service. See also Appendix M.
- (b) The organization, content, and paragraph designations of these Parts correspond to those of Chapter VIII. The prefix UM is used.
 - (c) Paragraphs M300(d), (e), and (f) apply.
- (d) Provisions and requirements of Chapter VIII apply with the additional requirements in paras. UM307, UM307.2, UM322, UM322.3, UM328, UM335, UM335.3.3, UM341, UM341.4(b)(1) and (2), and UM345(b).

(16) UM307 METALLIC VALVES AND SPECIALTY COMPONENTS

Paragraph M307 applies in its entirety. See also para. UM307.2(a).

UM307.2 Specific Requirements

(a) For bellows or diaphragm sealed type valves, the bonnet or cover plate closure shall be secured by a straight thread sufficient for mechanical strength, have a metal-to-metal seat, and include a secondary stem seal.

UM322 SPECIFIC PIPING SYSTEMS

Paragraph M322 applies, except for para. M322.3(c). See para. UM322.3(c).

UM322.3 Instrument Piping

(c) joining methods shall conform to the requirements of para. U315

UM328 WELDING OF MATERIALS

Welding shall be in accordance with paras. M311.1 and U328, except examination shall be in accordance with UM341.

UM335 ASSEMBLY AND ERECTION OF METALLIC PIPING

Paragraph M335 applies, except for para. M335.3.3. See para. UM335.3.3.

UM335.3.3 Straight-Threaded Joints. The requirements of para. M335.3.3 are subject to the limitations in para. UM322.

UM341 EXAMINATION

Paragraph M341 applies. See paras. UM341.4(b)(1) and (2).

UM341.4 Extent of Required Examination

(16)

- (b) Other Examination
- (1) The 100% radiography/ultrasonic examination required in para. M341.4(b) applies.
- (2) The in-process examination alternative permitted in para. 341.4.1(b)(1) applies, except a weld coupon examination in accordance with para. U344.8 is also an acceptable substitute when specified in the engineering design or by the Inspector.

UM345 TESTING

Paragraph M345(a) applies. See para. UM345(b).

(*b*) A sensitive leak test in accordance with para. U345.8 shall be included in the required leak test (para. U345.1).

APPENDIX A ALLOWABLE STRESSES AND QUALITY FACTORS FOR METALLIC PIPING AND BOLTING MATERIALS

Begins on the next page.

Specification Index for Appendix A

Spec. No.	Title	Spec. No.	Title
ASTM		ASTM (C	ont'd)
A36	Carbon Structural Steel	A312	Seamless, Welded, and Heavily Cold Worked
A47	Ferritic Malleable Iron Castings		Austenitic Stainless Steel Pipe
A48	Gray Iron Castings	A320	Alloy-Steel and Stainless Steel Bolting Materials for
A53	Pipe, Steel, Black and Hot-Dipped, Zinc Coated, Welded and Seamless	A325	Low-Temperature Service Structural Bolts, Steel, Heat Treated, 120/105 ksi
A10E	Carbon Stool Forgings for Dining Applications	A222	Minimum Tensile Strength
A105 A106	Carbon Steel Forgings, for Piping Applications Seamless Carbon Steel Pipe for High-Temperature	A333	Seamless and Welded Steel Pipe for Low- Temperature Service
71100	Service	A334	Seamless and Welded Carbon and Alloy-Steel Tubes
A126	Gray Iron Castings for Valves, Flanges, and Pipe		for Low-Temperature Service
	Fittings	A335	Seamless Ferritic Alloy Steel Pipe for High-
A134	Pipe, Steel, Electric-Fusion (Arc)-Welded (Sizes		Temperature Service
	NPS 16 and Over)	A350	Carbon and Low-Alloy Steel Forgings, Requiring Notch
A135	Electric-Resistance-Welded Steel Pipe	1254	Toughness Testing for Piping Components
A139	Electric-Fusion (Arc)-Welded Steel Pipe (NPS 4 and	A351	Castings, Austenitic, for Pressure-Containing Parts
A179	Over) Seamless Cold-Drawn Low-Carbon Steel Heat-	A352	Steel Castings, Ferritic and Martensitic, for Pressure- Containing Parts Suitable for Low-Temperature
A179	Exchanger and Condenser Tubes		Service
A181	Carbon Steel Forgings for General Purpose Piping	A353	Pressure Vessel Plates, Alloy Steel, 9 Percent Nickel,
A182	Forged or Rolled Alloy and Stainless Steel Pipe		Double Normalized and Tempered
	Flanges, Forged Fittings, and Valves and Parts for High Temperature Service	A354	Quenched and Tempered Alloy Steel Bolts, Studs, and Other Externally Threaded Fasteners
A193/A193M	Alloy-Steel and Stainless Steel Bolting Materials for	A358	Electric-Fusion-Welded Austenitic Chromium-Nickel
	High Temperature or High Pressure Service and		Alloy Stainless Steel Pipe for High-Temperature
	Other Special Purpose Applications		Service and General Applications
A194/A194M	Carbon and Alloy Steel Nuts for Bolts for High	A369	Carbon and Ferritic Alloy Steel Forged and Bored
	Pressure or High Temperature Service, or Both		Pipe for High-Temperature Service
A197	Cupola Malleable Iron	A376	Seamless Austenitic Steel Pipe for High-Temperature Central-Station Service
A203	Pressure Vessel Plates, Alloy Steel, Nickel	A381	Metal-Arc-Welded Steel Pipe for Use with High-
A204	Pressure Vessel Plates, Alloy Steel, Molybdenum		Pressure Transmission Systems
A213	Seamless Ferritic and Austenitic Alloy-Steel Boiler, Superheater, and Heat-Exchanger Tubes	A387	Pressure Vessel Plates, Alloy Steel, Chromium- Molybdenum
A216	Steel Castings, Carbon, Suitable for Fusion Welding for High-Temperature Service	A395	Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures
A217	Steel Castings, Martensitic Stainless and Alloy, for Pressure-Containing Parts Suitable for High-	A403	Wrought Austenitic Stainless Steel Piping Fittings
	Temperature Service	A403 A409	Welded Large Diameter Austenitic Steel Pipe for
A234	Piping Fittings of Wrought Carbon Steel and Alloy	71407	Corrosive or High-Temperature Service
	Steel for Moderate and High Temperatures	A420	Piping Fittings of Wrought Carbon Steel and Alloy
A240	Chromium and Chromium-Nickel Stainless Steel		Steel for Low-Temperature Service
	Plate, Sheet, and Strip for Pressure Vessels	A426	Centrifugally Cast Ferritic Alloy Steel Pipe for High-
A268	Seamless and Welded Ferritic and Martensitic		Temperature Service
	Stainless Steel Tubing for General Service	A437	Alloy-Steel Turbine-Type Bolting Material Specifically
A269	Seamless and Welded Austenitic Stainless Steel	1.54	Heat Treated for High-Temperature Service
A270	Tubing for General Service	A451	Centrifugally Cast Austenitic Steel Pipe for High-
A278	Gray Iron Castings for Pressure-Containing Parts for Temperatures Up to 650°F (350°C)	A453	Temperature Service High Temperature Bolting with Expansion Coefficients
A283	Low and Intermediate Tensile Strength Carbon Steel	M433	Comparable to Austenitic Stainless Steels
71203	Plates	A479	Stainless Steel Bars and Shapes for Use in Boilers
A285	Pressure Vessel Plates, Carbon Steel, Low- and	-	and Other Pressure Vessels
	Intermediate-Tensile Strength	A487	Steel Castings Suitable for Pressure Service
A299	Pressure Vessel Plates, Carbon Steel, Manganese- Silicon	A494	Castings, Nickel and Nickel Alloy
A202	Proceure Vescal Plates Alley Steel Manganese	A515	Pressure Vessel Plates, Carbon Steel, for
A302	Pressure Vessel Plates, Alloy Steel, Manganese- Molybdenum and Manganese-Molybdenum-Nickel		Intermediate- and Higher-Temperature Service
A307	Carbon Steel Bolts and Studs, 60,000 PSI Tensile	A516	Pressure Vessel Plates, Carbon Steel, for Moderate-
	Strength		and Lower-Temperature Service

Specification Index for Appendix A (Cont'd)

Spec. No.	Title	Spec. No.	Title
ASTM (Co	nt'd)	ASTM (C	ont'd)
A524	Seamless Carbon Steel Pipe for Atmospheric and Lower Temperatures	B96	Copper-Silicon Alloy Plate, Sheet, Strip, and Rolled Bar for General Purposes and Pressure Vessels
A536	Ductile Iron Castings	B98	Copper-Silicon Alloy Rod, Bar and Shapes
A537	Pressure Vessel Plates, Heat-Treated, Carbon-	270	copper smeon rmoy hou, but and shapes
,	Manganese-Silicon Steel	D1 27	Nickel Conner Alley (UNS NO 4400) Plate Sheet and
A553	Pressure Vessel Plates, Alloy Steel, Quenched and Tempered 8 and 9 Percent Nickel	B127	Nickel-Copper Alloy (UNS N04400) Plate, Sheet, and Strip
A563	Carbon and Alloy Steel Nuts	B133	Copper Rod, Bar and Shapes
A570	Steel Sheet and Strip, Carbon Hot-Rolled	B148	Aluminum-Bronze Sand Castings
A571	Austenitic Ductile Iron Castings for Pressure-	B150	Aluminum-Bronze Rod, Bar and Shapes
, -	Containing Parts Suitable for Low-Temperature	B152	Copper Sheet, Strip, Plate and Rolled Bar
	Service	B160	Nickel Rod and Bar
A587	Electric-Resistance-Welded Low-Carbon Steel Pipe for	B161	Nickel Plate, Shoot and Strip
	the Chemical Industry	B162	Nickel Plate, Sheet and Strip
	···· ·································	B164	Nickel Copper Alloy (UNS NO ((00) Scapless Bine
A645	Pressure Vessel Plates, Five Percent Nickel Alloy Steel, Specially Heat Treated	B165	Nickel-Copper Alloy (UNS N04400) Seamless Pipe and Tube
A671	Electric-Fusion-Welded Steel Pipe for Atmospheric and Lower Temperatures	B166	Nickel-Chromium-Iron Alloys (UNS N06600, N06601, N06603, N06690, N06693, N06025, and N06045) and Nickel-Chromium-Cobalt-Molybdenum Alloy
A672	Electric-Fusion-Welded Steel Pipe for High-Pressure Service at Moderate Temperatures	B167	(UNS N06617) Rod, Bar, and Wire Nickel-Chromium-Iron Alloys (UNS N06600, N06601,
A675	Steel Bars, Carbon, Hot-Wrought, Special Quality, Mechanical Properties	210,	N06603, N06690, N06693, N06025, and N06045) and Nickel-Chromium-Cobalt-Molybdenum Alloy
A691	Carbon and Alloy Steel Pipe, Electric Fusion-Welded for High-Pressure Service at High Temperatures	B168	(UNS N06617) Seamless Pipe and Tube Nickel-Chromium-Iron Alloys (UNS N06600, N06601,
A696	Steel Bars, Carbon, Hot-Wrought or Cold-Finished, Special Quality, for Pressure Piping Components	B100	N06603, N06690, N06693, N06025, and N06045) and Nickel-Chromium-Cobalt-Molybdenum Alloy (UNS N06617) Plate, Sheet, and Strip
A789	Seamless and Welded Ferritic/Austenitic Stainless	B169	Aluminum-Bronze Sheet, Strip, and Rolled Bar
	Steel Tubing for General Service	B171	Copper-Alloy Plate and Sheet for Pressure Vessels,
A790	Seamless and Welded Ferritic/Austenitic Stainless Steel Pipe	B187	Condensers, and Heat Exchangers Copper, Bus Bar, Rod, and Shapes and General
A813	Single- or Double-Welded Austenitic Stainless Steel		Purpose Rod, Bar, and Shapes
	Pipe	B209	Aluminum and Aluminum-Alloy Sheet and Plate
A814 A815	Cold-Worked Welded Austenitic Stainless Steel Pipe Wrought Ferritic, Ferritic/Austenitic, and Martensitic	B210	Aluminum and Aluminum-Alloy Drawn Seamless Tubes
	Stainless Steel Piping Fittings	B211	Aluminum and Aluminum-Alloy Bars, Rods, and Wire
1000	F ''' /A ' ''' (D) C' ' C' D'	B221	Aluminum and Aluminum-Alloy Extruded Bars, Rods,
A928	Ferritic/Austenitic (Duplex) Stainless Steel Pipe		Wire, Profiles, and Tubes
A992	Electric Fusion Welded with Addition of Filler Metal Structural Steel Shapes	B241	Aluminum and Aluminum-Alloy Seamless Pipe and
A995	Castings, Austenitic-Ferritic (Duplex) Stainless Steel,	D2 (7	Seamless Extruded Tube
	for Pressure-Containing Parts	B247	Aluminum and Aluminum-Alloy Die Forgings, Hand Forgings, and Rolled Ring Forgings
A1010	Higher Strength Martensitic Stainless Steel Plate,	B265	Titanium and Titanium Alloy Strip, Sheet, and Plate
AIOIO	Sheet, and Strip	B280	Seamless Copper Tube for Air Conditioning and
A1053	Welded Ferritic-Martensitic Stainless Steel Pipe	B283	Refrigeration Field Service Copper and Copper-Alloy Die Forgings (Hot-Pressed)
B21	Naval Brass Rod, Bar, and Shapes		,, , , , , , , , , , , , , , , , , , , ,
B26	Aluminum-Alloy Sand Castings	B333	Nickel-Molybdenum Alloy Plate, Sheet, and Strip
B42	Seamless Copper Pipe, Standard Sizes	B335	Nickel-Molybdenum Alloy Rod
B43	Seamless Red Brass Pipe, Standard Sizes	B338	Seamless and Welded Titanium and Titanium Alloy
B61	Steam or Valve Bronze Castings		Tubes for Condensers and Heat Exchangers
B62	Composition Bronze or Ounce Metal Castings	B345	Aluminum and Aluminum-Alloy Seamless Pipe and
B68	Seamless Copper Tube, Bright Annealed		Seamless Extruded Tube for Gas and Oil
B75 B88	Seamless Copper Tube		Transmission and Distribution Piping Systems
	Seamless Copper Water Tube		

Specification Index for Appendix A (Cont'd)

Spec. No.	Title	Spec. No.	Title
ASTM (Co	ont'd)	ASTM (C	ont'd)
B361	Factory-Made Wrought Aluminum and Aluminum- Alloy Welding Fittings	B523	Seamless and Welded Zirconium and Zirconium Alloy Tubes
B363	Seamless and Welded Unalloyed Titanium and Titanium Alloy Welding Fittings	B547	Aluminum and Aluminum-Alloy Formed and Arc- Welded Round Tube
B366	Factory-Made Wrought Nickel and Nickel Alloy Fittings	B550	Zirconium and Zirconium Alloy Bar and Wire
B371 B381	Copper-Zinc-Silicon Alloy Rod Titanium and Titanium Alloy Forgings	B551	Zirconium and Zirconium Alloy Strip, Sheet, and Plate
		B564	Nickel Alloy Forgings
B407	Nickel-Iron-Chromium Alloy Seamless Pipe and Tube	B574	Low-Carbon Nickel-Molybdenum-Chromium Alloy Rod
B409	Nickel-Iron-Chromium Alloy Plate, Sheet, and Strip	B575	Low-Carbon Nickel-Molybdenum-Chromium Alloy
B423	Nickel-Iron-Chromium-Molybdenum-Copper Alloy (UNS N08825 and N08221) Seamless Pipe and	B581	Plate, Sheet and Strip Nickel-Chromium-Iron-Molybdenum-Copper Alloy Rod
	Tube	B582	· · · · · · · · · · · · · · · · · · ·
B424	Nickel-Iron-Chromium-Molybdenum-Copper Alloy	D302	Nickel-Chromium-Iron-Molybdenum-Copper Alloy Plate, Sheet and Strip
B424	(UNS N08825 and N08221) Plate, Sheet and Strip Nickel-Iron-Chromium-Molybdenum-Copper Alloy	B584	Copper Alloy Sand Castings for General Applications
D423	(UNS N08825 and N08221) Rod and Bar	B619	Welded Nickel and Nickel-Cobalt Alloy Pipe
B435	UNS N06022, UNS N06230, and UNS R30556 Plate, Sheet, and Strip	B620	Nickel-Iron-Chromium-Molybdenum Alloy (UNS N08320) Plate, Sheet and Strip
B443	Nickel-Chromium-Molybdenum-Columbium Alloy (UNS N06625) and Nickel-Chromium-Molybdenum-	B621	Nickel-Iron-Chromium-Molybdenum Alloy (UNS N08320) Rod
B444	Silicon Alloy (UNS N06219) Plate, Sheet, and Strip Nickel-Chromium-Molybdenum-Columbium Alloys	B622	Seamless Nickel and Nickel-Cobalt Alloy Pipe and Tube
	(UNS N06625 and UNS N06852) and Nickel-	B625	Nickel Alloy Plate and Sheet
	Chromium-Molybdenum-Silicon Alloy	B626	Welded Nickel and Nickel-Cobalt Alloy Tube
B446	(UNS N06219) Pipe and Tube Nickel-Chromium-Molybdenum-Columbium Alloy (UNS N06625), Nickel-Chromium-Molybdenum-	B649	Ni-Fe-Cr-Mo-Cu Low Carbon Alloy (UNS N08904) and Ni-Fe-Cr-Mo-Cu-N Low Carbon Alloy UNS N08925, UNS N08031, and UNS N08926) Bar and Wire
	Silicon Alloy (UNS N06219), and Nickel-Chromium- Molybdenum-Tungsten Alloy (UNS N06650) Rod	B658	Seamless and Welded Zirconium and Zirconium Alloy Pipe
D / (2)	and Bar	B668	UNS N08028 Seamless Pipe and Tube
B462	Forged or Rolled UNS N06030, UNS N06022,	B675	UNS N08366 and UNS N08367 Welded Pipe
	UNS N06035, UNS N06200, UNS N06059, UNS N06686, UNS N08020, UNS N08024.	B688	Chromium-Nickel-Molybdenum-Iron (UNS N08366 and UNS N08367) Plate, Sheet, and Strip
	UNS N08026, UNS N08367, UNS N10276, UNS N10665, UNS N10675, UNS N10629, UNS N08031, UNS N06045, UNS N06025, and UNS R20033 Alloy Pipe Flanges, Forged Fittings,	B690	Iron-Nickel-Chromium-Molybdenum Alloys (UNS N08366 and UNS N08367) Seamless Pipe and Tube
	and Valves and Parts for Corrosive High- Temperature Service	B705	Nickel-Alloy (UNS N06625, N06219 and N08825) Welded Pipe
B463	UNS N08020, UNS N08026, and UNS N08024 Alloy Plate, Sheet, and Strip	B709	Iron-Nickel-Chromium-Molybdenum Alloy (UNS N08028) Plate, Sheet, and Strip
B464	Welded UNS N08020, N08024, and N08026 Alloy Pipe	B725	Welded Nickel (UNS N02200/UNS N02201) and Nickel-Copper Alloy (UNS N04400) Pipe
B466	Seamless Copper-Nickel Pipe and Tube	B729	Seamless UNS N08020, UNS N08026, UNS N08024
B467	Welded Copper-Nickel Pipe		Nickel-Alloy Pipe and Tube
B474	Electric Fusion Welded Nickel and Nickel Alloy Pipe		
B491	Aluminum and Aluminum Alloy Extruded Round Tubes for General-Purpose Applications	B804 B861	UNS N08367 Welded Pipe Titanium and Titanium Alloy Seamless Pipe
B493	Zirconium and Zirconium Alloy Forgings	B862	Titanium and Titanium Alloy Welded Pipe
B514 B517	Welded Nickel-Iron-Chromium Alloy Pipe Welded Nickel-Chromium-Iron Alloy (UNS N06600,	E112	Methods for Determining Average Grain Size
	UNS N06603, UNS N06025, and UNS N06045)	API	
	Pipe		Line Pipe
		5L	Line ripe

GENERAL NOTE: It is not practical to refer to a specific edition of each standard throughout the Code text. Instead, the approved edition references, along with the names and addresses of the sponsoring organizations, are shown in Appendix E.

NOTES FOR TABLES A-1, A-1M, A-1A, A-1B, A-2, AND A-2M

GENERAL NOTES:

- (a) The allowable stress values, P-Number assignments, weld joint and casting quality factors, and minimum temperatures in Tables A-1, A-1A, A-1B, and A-2, together with the referenced Notes in the stress tables, are requirements of this Code.
- (b) Notes (1) through (7) are referenced in column headings and in body headings for material type and product form; Notes (8) and following are referenced in the Notes column for specific materials. Notes marked with an asterisk (*) restate requirements found in the text of the Code.
- (c) The stress values given in ksi as shown in Tables A-1 and A-2, and given in MPa as shown in Tables A-1M and A-2M, may be used. The values stated in ksi are not exact equivalents to the values stated in MPa. Therefore, for any given material, the user of the Code should use only the ksi or the MPa values.
- (d) For copper and copper alloys, the following symbols are used in the Temper column: H = drawn; H01 = quarter hard; H02 = half hard; H06 = extra hard; H55 = light drawn; H58 = drawn, general purpose; H80 = hard drawn; HR50 = drawn, stress relieved; M20 = hot rolled; O25 = hot rolled, annealed; O50 = light annealed; O60 = soft annealed; O61 = annealed; W050 = welded, annealed; and W061 = welded, fully finished, annealed.
- (e) For nickel and nickel alloys, the following abbreviations are used in the Class column: ann., annealed; C.D., cold worked; forg., forged; H.F., hot finished; H.R., hot rolled; H.W., hot worked; plt., plate; R., rolled; rel., relieved; sol., solution; str., stress; and tr., treated.
- (f) In Table A-1M, the following abbreviations are used in the Product Form column: forg., forgings; ftg., fittings; pl., plate; shps., shapes; sht., sheet; smls., seamless; and wld., welded.

NOTES:

- (1) *The stress values in Tables A-1 and A-1M, and the design stress values in Tables A-2 and A-2M, are basic allowable stresses in tension in accordance with para. 302.3.1(a). For pressure design, the stress values from Tables A-1 and A-1M are multiplied by the appropriate quality factor E (E_c from Table A-1A or E_j from Table A-1B). Stress values in shear and bearing are stated in para. 302.3.1(b); those in compression in para. 302.3.1(c).
- (2) *The quality factors for castings E_c in Table A-1A are basic factors in accordance with para. 302.3.3(b). The quality factors for longitudinal weld joints E_i in Table A-1B are basic factors in accordance with para. 302.3.4(a). See paras. 302.3.3(c) and 302.3.4(b) for enhancement of quality factors. See also para. 302.3.1(a), footnote 1.
- (3) The stress values for austenitic stainless steels in these Tables may not be applicable if the material has been given a final heat treatment other than that required by the material specification or by reference to Note (30) or (31).
- (4a) *In Table A-1, stress values printed in *italics* exceed two-thirds of the expected yield strength at temperature. Stress values in **boldface** are equal to 90% of expected yield strength at temperature. See paras. 302.3.2(d)(3) and (e).

- (4b) *In Table A-1M, stress values printed in *italics* are tensilecontrolled values. Yield-controlled stress values are in normal font and time-dependent stress values are in **boldface**.
- (5) *See the BPV Code, Section IX, QW-200.3 for a description of P-Number groupings. P-Numbers are indicated by number or by a number followed by a letter (e.g., 8, 5B, or 11A).
- (6) *The minimum temperature shown is that design minimum temperature for which the material is normally suitable without impact testing other than that required by the material specification. However, the use of a material at a design minimum temperature below -29°C (-20°F) is established by rules elsewhere in this Code, including para. 323.2.2(a) and other impact test requirements. For carbon steels with a letter designation in the Min. Temp. column, see para. 323.2.2(b) and the applicable curve and Notes in Fig. 323.2.2A.
- (7) The letter "a" indicates alloys that are not recommended for welding and that, if welded, must be individually qualified. The letter "b" indicates copper base alloys that must be individually qualified.
- (8) *There are restrictions on the use of this material in the text of the Code as follows:
 - (a) See para. 305.2.1; temperature limits are -29° C to 186°C (-20° F to 366°F).
 - (b) See para. 305.2.2; pipe shall be safeguarded when used outside the temperature limits in Note (8a).
 - (c) See Table 323.2.2, Section B-2.
 - (d) See para. 323.4.2(a).
 - (e) See para. 323.4.2(b).
 - (f) See para. 309.2.1.
 - (g) See para. 309.2.2.
- (9) *For pressure-temperature ratings of components made in accordance with standards listed in Table 326.1, see para. 326.2.1. Stress values in Tables A-1 and A-1M may be used to calculate ratings for unlisted components, and special ratings for listed components, as permitted by para. 303.
- (9a) Component standards listed in Table 326.1 impose the following restrictions on this material when used as a forging: composition, properties, heat treatment, and grain size shall conform to this specification: manufacturing procedures, tolerances, tests, certification, and markings shall be in accordance with ASTM B564.
- (10) *This casting quality factor is applicable only when proper supplementary examination has been performed (see para. 302.3.3).
- (11) *For use under this Code, radiography shall be performed after heat treatment.
- (12) *Certain forms of this material, as stated in Table 323.2.2, must be impact tested to qualify for service below -29°C (-20°F). Alternatively, if provisions for impact testing are included in the material specification as supplementary requirements and are invoked, the material may be used down to the temperature at which the test was conducted in accordance with the specification.
- (13) Properties of this material vary with thickness or size. Stress values are based on minimum properties for the thickness listed.

- (14) For use in Code piping at the stated stress values, the required minimum tensile and yield properties must be verified by tensile test. If such tests are not required by the material specification, they shall be specified in the purchase order.
- (15) These stress values are established from a consideration of strength only and will be satisfactory for average service. For bolted joints where freedom from leakage over a long period of time without retightening is required, lower stress values may be necessary as determined from the flexibility of the flange and bolts and corresponding relaxation properties.
- (16) DELETED.
- (17) DELETED.
- (18) DELETED.
- (19) *This specification includes requirements for random radiographic inspection for mill quality control. If the 0.90 joint factor is to be used, the welds shall meet the requirements of Table 341.3.2 for longitudinal butt welds with spot radiography in accordance with Table 302.3.4. This shall be a matter of special agreement between purchaser and manufacturer.
- (20) For pipe sizes ≥DN 200 (NPS 8) with wall thicknesses ≥Sch 140, the specified minimum tensile strength is 483 MPa (70 ksi).
- (21) For material thickness >127 mm (5 in.), the specified minimum tensile strength is 483 MPa (70 ksi).
- (21a) For material thickness >127 mm (5 in.), the specified minimum tensile strength is 448 MPa (65 ksi).
- (22) The minimum tensile strength for weld (qualification) and stress values shown shall be multiplied by 0.90 for pipe having an outside diameter less than 51 mm (2 in.) and a *D/t* value less than 15. This requirement may be waived if it can be shown that the welding procedure to be used will consistently produce welds that meet the listed minimum tensile strength of 165 MPa (24 ksi).
- (23) DELETED.
- (24) Yield strength is not stated in the material specification. The value shown is based on yield strengths of materials with similar characteristics.
- (25) This steel may develop embrittlement after service at approximately 316°C (600°F) and higher temperature.
- (26) This unstabilized grade of stainless steel increasingly tends to precipitate intergranular carbides as the carbon content increases above 0.03%. See also para. F323.4(c)(2).
- (27) For temperatures above 427°C (800 °F), these stress values apply only when the carbon content is 0.04% or higher.
- (28) For temperatures above 538°C (1,000°F), these stress values apply only when the carbon content is 0.04% or higher.
- (29) The stress values above 538°C (1,000°F) listed here shall be used only when the steel's austenitic micrograin size, as defined in ASTM E112, is No. 6 or less (coarser grain). Otherwise, the lower stress values listed for the same material, specification, and grade shall be used.
- (30) For temperatures above 538°C (1,000°F), these stress values may be used only if the material has been heat treated at a temperature of 1 093°C (2,000°F) minimum.
- (31) For temperatures above 538°C (1,000°F), these stress values may be used only if the material has been heat treated by heating to a minimum temperature of 1 038°C (1,900°F) and quenching in water or rapidly cooling by other means.
- (32) Stress values shown are for the lowest strength base material permitted by the specification to be used in the manufacture of this grade of fitting. If a higher strength base material

- is used, the higher stress values for that material may be used in design.
- (33) For welded construction with work hardened grades, use the stress values for annealed material; for welded construction with precipitation hardened grades, use the special stress values for welded construction given in the Tables.
- (34) If material is welded, brazed, or soldered, the allowable stress values for the annealed condition shall be used.
- (35) This steel is intended for use at high temperatures; it may have low ductility and/or low impact properties at room temperature after being used above the temperature indicated by para. F323.4(c)(4).
- (36) The specification permits this material to be furnished without solution heat treatment or with other than a solution heat treatment. When the material has not been solution heat treated, the minimum temperature shall be −29°C (−20°F) unless the material is impact tested in accordance with para. 323.3.
- (37) Impact requirements for seamless fittings shall be governed by those listed in this Table for the particular base material specification in the grades permitted (A312, A240, and A182). When A276 materials are used in the manufacture of these fittings, the Notes, minimum temperatures, and allowable stresses for comparable grades of A240 materials shall apply.
- (38) DELETED.
- (39) This material when used below -29°C (-20°F) shall be impact tested if the carbon content is above 0.10%.
- (40) *This casting quality factor can be enhanced by supplementary examination in accordance with para. 302.3.3(c) and Table 302.3.3C. The higher factor from Table 302.3.3C may be substituted for this factor in pressure design equations.
- (41) Design stresses for the cold drawn temper are based on hot rolled properties until required data on cold drawn are submitted.
- (42) This is a product specification. No design stresses are necessary. Limitations on metal temperature for materials covered by this specification are as follows:

	Metal Temperature,
Grade(s)	°C (°F)
1	-29 to 482 (-20 to 900)
2, 2H, and 2HM	-48 to 593 (-55 to 1,100)
3	-29 to 593 (-20 to 1,100)
4	-48 to 593 (-55 to 1,100)
4L	-101 to 593 (-150 to 1,100)
6	-29 to 427 (-20 to 800)
7	-48 to 593 (-55 to 1,100)
7L	-101 to 593 (-150 to 1,100)
7M	-48 to 593 (-55 to 1,100)
7ML	-73 to 593 (-100 to 1,100)
8FA [see Note (39)]	-29 to 427 (-20 to 800)
8MA and 8TA	-198 to 816 (-325 to 1,500)
8, 8A, and 8CA	-254 to 816 (-425 to 1,500)

(42a) DELETED.

(42b) This is a product specification. No design stresses are necessary. For limitations on usage, see paras. 309.2.1 and 309.2.2.

- (44) This material shall not be welded.
- (45) Stress values shown are applicable for "die" forgings only.
- (46) Lines of allowable stresses in Tables A-1 and A-1M for all materials in A312 include heavily cold worked (HCW) material as defined in A312 para. 6.1.4.
- (47) If no welding is employed in fabrication of piping from these materials, the stress values may be increased to 230 MPa (33.3 ksi).
- (48) The stress value to be used for this gray iron material at its upper temperature limit of 232°C (450°F) is the same as that shown in the 204°C (400°F) column.
- (49) If the chemical composition of this Grade is such as to render it hardenable, qualification under P-No. 6 is required.
- (50) This material is grouped in P-No. 7 because its hardenability is low.
- (51) This material may require special consideration for welding qualification. See the BPV Code, Section IX, QW/QB-422. For use in this Code, a qualified WPS is required for each strength level of material.
- (52) Copper-silicon alloys are not always suitable when exposed to certain media and high temperature, particularly above 100°C (212°F). The user should satisfy himself that the alloy selected is satisfactory for the service for which it is to be used.
- (53) Stress relief heat treatment is required for service above 232°C (450°F).
- (54) The maximum operating temperature is arbitrarily set at 260°C (500°F) because hard temper adversely affects design stress in the creep rupture temperature ranges.
- (55) Pipe produced to this specification is not intended for high temperature service. The stress values apply to either nonexpanded or cold expanded material in the as-rolled, normalized, or normalized and tempered condition.
- (56) Because of thermal instability, this material is not recommended for service above 427°C (800°F).
- (57) Conversion of carbides to graphite may occur after prolonged exposure to temperatures over 427°C (800°F). See para. F323.4(b)(2).
- (58) Conversion of carbides to graphite may occur after prolonged exposure to temperatures over 468°C (875°F). See para. F323.4(b)(3).
- (59) For temperatures above 482°C (900°F), consider the advantages of killed steel. See para. F323.4(b)(4).
- (60) For all design temperatures, the maximum hardness shall be Rockwell C35 immediately under the thread roots. The hardness shall be taken on a flat area at least 3 mm (1/8 in.) across, prepared by removing threads. No more material than necessary shall be removed to prepare the area. Hardness determination shall be made at the same frequency as tensile tests.
- (61) Annealed at approximately 982°C (1,800°F).
- (62) Annealed at approximately 1 121°C (2,050°F).
- (63) For stress relieved tempers (T351, T3510, T3511, T451, T4510, T4511, T651, T6510, T6511), stress values for material in the listed temper shall be used.

- (64) The minimum tensile strength of the reduced section tensile specimen in accordance with the BPV Code, Section IX, QW-462.1, shall not be less than 758 MPa (110.0 ksi).
- (65) The minimum temperature shown is for the heaviest wall permissible by the specification. The minimum temperature for lighter walls shall be as shown in the following tabulation:

Impact Test Temperature (°C) for Plate Thicknesses Shown

	THICKIESSES SHOWI	
Spec. No.	51 mm	Over 51 mm to
Grade	Max.	
A203 A	-68	-59
A203 B	-68	-59
A203 D	-101	-87
A203 E	-101	-87

Impact Test Temperature (°F) for Plate Thicknesses Shown

Spec. No.		
and	2 in.	Over 2 in.
Grade	Max.	to 3 in.
A203 A	-90	-75
A203 B	-90	-75
A203 D	-150	-125
A203 E	-150	-125

- (66) Stress values shown are 90% of those for the corresponding core material.
- (67) For use under this Code, the heat treatment requirements for pipe manufactured to A671, A672, and A691 shall be as required by para. 331 for the particular material being used.
- (68) The tension test specimen from plate 12.7 mm ($\frac{1}{2}$ in.) and thicker is machined from the core and does not include the cladding alloy; therefore, the stress values listed are those for materials less than 12.7 mm.
- (69) This material may be used only in nonpressure applications.
- (70) Alloy 625 (UNS N06625) in the annealed condition is subject to severe loss of impact strength at room temperature after exposure in the range of 538°C to 760°C (1,000°F to 1,400°F).
- (71) These materials are normally microalloyed with Cb, V, and/or Ti. Supplemental specifications agreed to by manufacturer and purchaser commonly establish chemistry more restrictive than the base specification, as well as plate rolling specifications and requirements for weldability (i.e., C-equivalent) and toughness.
- (72) For service temperature >454°C (850°F), weld metal shall have a carbon content >0.05%.
- (73) Heat treatment is required after welding for all products of zirconium Grade R60705. See Table 331.1.1.
- (74) Mechanical properties of fittings made from forging stock shall meet the minimum tensile requirements of one of the bar, forging, or rod specifications listed in Table 2 of B366 for which tensile testing is required.

(75) Stress values shown are for materials in the normalized and tempered condition, or when the heat treatment is unknown. If material is annealed, use the following values above 510°C (950°F):

Temp., °C	538	566	593	621	649
S, MPa	55.1	39.3	26.2	16.5	9.6
Temp., °F	1,000	1,050	1,100	1,150	1,200
S, ksi	8.0	5.7	3.8	2.4	1.4

- (76) DELETED.
- (77) The pipe grades listed below, produced in accordance with CSA (Canadian Standards Association) Z245.1, shall be

considered as equivalents to API 5L and treated as listed materials.

Grade Equivalents

	1
API 5L	CSA Z245.1
В	241
X42	290
X46	317
X52	359
X56	386
X60	414
X65	448
X70	483
X80	550

(78) Not permitted for the P4 and P5 materials in Table 302.3.5 for Elevated Temperature Fluid Service.

Table A-1 Basic Allowable Stresses in Tension for Metals

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

									Basic Allowable Stress, <i>S</i> , ksi, at Metal Temperature, °F [Note (1)]							
		Type/	UNS	Class/ Condition/		Min. Temp.,	Specifie Strengt		Min. Temp.							
Material	Spec. No.		No.	Temper	Notes	°F (6)	Tensile	Yield	•	200	300	400	500	600	650	
Iron																
Castings (2)																
Gray	A48	20	F11401		(8e)(48)	-20	20		2.0	2.0	2.0	2.0				
Gray	A278	20	F11401		(8e)(48)	-20	20		2.0	2.0	2.0	2.0				
Gray	A126	Α	F11501	• • •	(8e)(9)(48)	-20	21	• • •	2.0	2.0	2.0	2.0	• • •		• • •	
Gray	A48	25	F11701		(8e)(48)	-20	25		2.5	2.5	2.5	2.5				
Gray	A278	25	F11701		(8e)(48)	-20	25	• • •	2.5	2.5	2.5	2.5	• • •			
Gray	A48	30	F12101		(8e)(48)	-20	30		3.0	3.0	3.0	3.0				
Gray	A278	30	F12101		(8e)(48)	-20	30		3.0	3.0	3.0	3.0				
Gray	A126	В	F12102		(8e)(9)(48)	-20	31	• • •	3.0	3.0	3.0	3.0		• • •		
Gray	A48	35	F12401		(8e)(48)	-20	35		3.5	3.5	3.5	3.5				
Gray	A278	35	F12401		(8e)(48)	-20	35		3.5	3.5	3.5	3.5				
Gray	A48	40	F12801		(8e)(9)(48)	-20	40		4.0	4.0	4.0	4.0				
Gray	A126	C	F12802		(8e)(9)(48)	-20	41		4.0	4.0	4.0	4.0				
Gray	A278	40	F12803	• • •	(8e)(9)(53)	-20	40		4.0	4.0	4.0	4.0	4.0	4.0	4.0	
Gray	A48	45	F13101		(8e)(48)	-20	45		4.5	4.5	4.5	4.5				
Gray	A48	50	F13501		(8e)(48)	-20	50		5.0	5.0	5.0	5.0				
Gray	A278	50	F13502	• • •	(8e)(53)	-20	50		5.0	5.0	5.0	5.0	5.0	5.0	5.0	
Gray	A48	55	F13801		(8e)(48)	-20	55		5.5	5.5	5.5	5.5				
Gray	A48	60	F14101		(8e)(48)	-20	60		6.0	6.0	6.0	6.0				
Gray	A278	60	F14102	• • •	(8e)(53)	-20	60		6.0	6.0	6.0	6.0	6.0	6.0	6.0	
Cupola malleable	A197	•••	F22000		(8e)(9)	-20	40	30	8.0	8.0	8.0	8.0	8.0	8.0	8.0	
Malleable	A47	32510	F22200		(8e)(9)	-20	50	32.5	10.0	10.0	10.0	10.0	10.0	10.0	10.0	
Ferritic ductile	A395	60-40-18	F32800		(8d)(9)	-20	60	40	20.0	19.0	17.9	16.9	15.9	14.9	14.1	
Austenitic ductile	A571	D-2M	F43010	1	(8d)	-20	65	30	20.0							
Ductile	A536	65-45-12	F33100		(8d)(9)	-20	65	45	21.7	21.7	21.7	21.7	21.6			

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

			UNS No.	Class/ Condition/ Temper				Min.	Specified Min. Strength, ksi		Min.		
Material	Spec. No.	Type/ Grade			Size, in.	P-No. (5)	Notes	Temp., °F (6)	Tensile		Temp. to 100	200	300
Carbon Steel Pipes and Tube	es (2)												
A285 Gr. A	A134					1	(8b)(57)	В	45	24	15.0	14.7	14.2
A285 Gr. A	A672	A45	K01700			1	(57)(59)(67)	В	45	24	15.0	14.7	
Butt weld	API 5L	A25				1	(8a)(77)	-20	45	25	15.0	15.0	14.7
Smls & ERW	API 5L	A25	• • •		• • •	1	(57)(59)(77)	В	45	25	15.0	15.0	14.7
• • •	A179		K01200			1	(57)(59)	-20	47	26	15.7	15.7	15.3
Type F	A53	Α	K02504			1	(8a)	20	48	30	16.0	16.0	16.0
	A139	Α				1	(8b)	Α	48	30	16.0	16.0	16.0
• • •	A587	• • •	K11500		• • •	1	(57)(59)	-20	48	30	16.0	16.0	16.0
	A53	Α	K02504			1	(57)(59)	В	48	30	16.0	16.0	16.0
	A106	Α	K02501			1	(57)	В	48	30	16.0	16.0	16.0
	A135	Α				1	(57)(59)	В	48	30	16.0	16.0	16.0
	A369	FPA	K02501			1	(57)	В	48	30	16.0	16.0	16.0
• • •	API 5L	Α	• • •	• • •	• • •	1	(57)(59)	В	48	30	16.0	16.0	16.0
A285 Gr. B	A134					1	(8b)(57)	В	50	27	16.7	16.5	15.9
A285 Gr. B	A672	A50	K02200	• • •	• • •	1	(57)(59)(67)	В	50	27	16.7	16.5	15.9
A285 Gr. C	A134					1	(8b)(57)	Α	55	30	18.3	18.3	17.7
	A524	II	K02104			1	(57)	-20	55	30	18.3	18.3	17.7
	A333	1	K03008			1	(57)(59)	-50	55	30	18.3	18.3	17.7
	A334	1	K03008			1	(57)(59)	-50	55	30	18.3	18.3	17.7
A285 Gr. C	A671	CA55	K02801			1	(59)(67)	Α	55	30	18.3	18.3	17.7
A285 Gr. C	A672	A55	K02801			1	(57)(59)(67)	Α	55	30	18.3	18.3	17.7
A516 Gr. 55	A672	C55	K01800	• • •	• • •	1	(57)(67)	С	55	30	18.3	18.3	17.7
A516 Gr. 60	A671	CC60	K02100			1	(57)(67)	С	60	32	20.0	19.5	18.9
A515 Gr. 60	A671	CB60	K02401			1	(57)(67)	В	60	32	20.0	19.5	18.9
A515 Gr. 60	A672	B60	K02401			1	(57)(67)	В	60	32	20.0	19.5	18.9
A516 Gr. 60	A672	C60	K02100	• • •	• • •	1	(57)(67)	С	60	32	20.0	19.5	18.9
• • •	A139	В	K03003			1	(8b)	Α	60	35	20.0	20.0	20.0
	A135	В	K03018			1	(57)(59)	В	60	35	20.0	20.0	20.0
• • •	A524	1	K02104	• • •	• • •	1	(57)	-20	60	35	20.0	20.0	20.0
	A53	В	K03005			1	(57)(59)	В	60	35	20.0	20.0	20.0
	A106	В	K03006			1	(57)	В	60	35	20.0	20.0	20.0
	A333	6	K03006			1	(57)	-50	60	35	20.0	20.0	20.0
	A334	6	K03006			1	(57)	-50	60	35	20.0	20.0	20.0
	A369	FPB	K03006			1	(57)	-20	60	35	20.0	20.0	20.0
	A381	Y35				1		Α	60	35	20.0	20.0	20.0
	API 5L	В				1	(57)(59)(77)	В	60	35	20.0	20.0	20.0

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

		able Stress, S, ksi, at Metal Temperature, °F [Note (1)]									Basic Allowabl							
Spec. 1	Type/ Grade	1,100	1,050	1,000	950	900	850	800	750	700	650	600	500	400				
Carbon St Tubes (2	Pipes and																	
A134						5.9	7.9	9.2	10.7	11.5	11.9	12.3	13.0	13.7				
A672	A45	1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	11.5	11.9	12.3	13.0	13.7				
API 5	A25													14.2				
API 5	A25		• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	14.2				
A179		1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	12.4	12.8	13.3	14.1	14.8				
A53	Α													16.0				
A139	Α																	
A587	• • •			• • •	• • •	• • •	7.9	9.2	10.7	12.5	14.6	15.3	16.0	16.0				
A53	Α	1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	12.5	14.6	15.3	16.0	16.0				
A106	Α	1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	12.5	14.6	15.3	16.0	16.0				
A135	Α	1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	12.5	14.6	15.3	16.0	16.0				
A369	FPA	1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	12.5	14.6	15.3	16.0	16.0				
API 5	Α	1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	12.5	14.6	15.3	16.0	16.0				
A134						5.9	7.9	9.2	10.7	12.5	13.3	13.8	14.7	15.4				
A672	A50	1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	12.5	13.3	13.8	14.7	15.4				
A134						5.9	8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1				
A524	II			2.5	4.0	5.9	8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1				
A333	1	1.0	1.6	2.5	4.0	5.9	8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1				
A334	1	1.0	1.6	2.5	4.0	5.9	8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1				
A671	CA55	1.0	1.6	2.5	4.0	5.9	8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1				
A672	A55	1.0	1.6	2.5	4.0	5.9	8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1				
A672	C55	1.0	1.6	2.5	4.0	5.9	8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1				
A671	CC60			2.5	4.0	5.9	8.7	11.4	13.9	15.3	15.8	16.4	17.4	18.2				
A671	CB60	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	15.3	15.8	16.4	17.4	18.2				
A672	B60	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	15.3	15.8	16.4	17.4	18.2				
A672	C60	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	15.3	15.8	16.4	17.4	18.2				
A139	В																	
A135	В			2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				
A524	1	• • •	• • •	2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				
A53	В	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				
A106	В	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				
A333	6	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				
A334	6	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				
A369	FPB	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				
A381	Y35	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				
API 5	В	1.0	1.6	2.5	4.0	5.9	8.7	11.4	13.9	16.7	17.3	17.9	19.0	19.9				

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

				Class/				Min.	Specified Min. Strength, ksi		Min.		
Material	Spec. No.	Type/ . Grade	UNS No.	Condition/ Temper	Size, in.	P-No. (5)	Notes	Temp., °F (6)	Tensile Yield		Temp. to 100	200	300
Carbon Steel (Cor Pipes and Tube	•	d)											
	A139	С	K03004			1	(8b)	Α	60	42	20.0	20.0	20.0
	A139	D	K03010			1	(8b)	Α	60	46	20.0	20.0	20.0
	API 5L	X42				1	(55)(77)	Α	60	42	20.0	20.0	20.0
• • •	A381	Y42	• • •		• • •	1	• • •	Α	60	42	20.0	20.0	20.0
	A381	Y48				1		Α	62	48	20.7	20.7	20.7
	API 5L	X46				1	(55)(77)	Α	63	46	21.0	21.0	21.0
	A381	Y46				1		Α	63	46	21.0		21.0
	A381	Y50				1		Α	64	50	21.3	21.3	21.3
A516 Gr. 65	A671	CC65	K02403			1	(57)(67)	В	65	35	21.7	21.4	20.6
A515 Gr. 65	A671	CB65	K02403	• • •	• • •	1	(57)(67)	A	65	35	21.7	21.4	20.6
A515 Gr. 65	A671	B65	K02800			1	(57)(67)	A	65	35	21.7	21.4	20.6
A516 Gr. 65	A672	C65	K02403			1	(57)(67)	В	65	35	21.7	21.4	
	A139	E	K03012			1	(8b)	Α	66	52	22.0	22.0	22.0
	API 5L	X52				1	(55)(77)	Α	66	52	22.0	22.0	22.0
• • •	A381	Y52	• • •			1		Α	66	52	22.0	22.0	22.0
A516 Gr. 70	A671	CC70	K02700			1	(57)(67)	В	70	38	23.3	23.2	22.4
A515 Gr. 70	A671	CB70	K03101			1	(57)(67)	Α	70	38	23.3	23.2	22.4
A515 Gr. 70	A672	B70	K03101			1	(57)(67)	Α	70	38	23.3	23.2	22.4
A516 Gr. 70	A672	C70	K02700			1	(57)(67)	В	70	38	23.3	23.2	22.4
	A106	C	K03501			1	(57)	В	70	40	23.3	23.3	23.3
A537 Cl. 1	A671	CD70	K12437		$\leq 2^{1}/_{2}$ thk.	1	(67)	D	70	50	23.3	23.3	22.8
A537 Cl. 1	A672	D70	K12437		$\leq 2^{1}/_{2}$ thk.	1	(67)	D	70	50	23.3	23.3	22.8
A537 Cl. 1	A691	CMSH-70) K12437	• • •	$\leq 2^{1}/_{2}$ thk.	1	(67)	D	70	50	23.3	23.3	22.8
	API 5L	X56				1	(51)(55)(71)(77)	A	71	56	23.7	23.7	23.7
	A381	Y56				1	(51)(55)(71)	Α	71	56	23.7	23.7	23.7
A299 Gr. A	A671	CK75	K02803		>1 thk.	1	(57)(67)	Α	75	40	25.0	24.4	23.6
A299 Gr. A	A672	N75	K02803		>1 thk.	1	(57)(67)	Α	75	40	25.0	24.4	23.6
A299 Gr. A	A691	CMS-75	K02803		>1 thk.	1	(57)(67)	Α	75	40	25.0	24.4	23.6
A299 Gr. A	A671	CK75	K02803		≤1 thk.	1	(57)(67)	Α	75	42	25.0	25.0	24.8
A299 Gr. A	A672	N75	K02803		≤1 thk.	1	(57)(67)	Α	75	42	25.0	25.0	24.8
A299 Gr. A	A691	CMS-75	K02803		≤1 thk.	1	(57)(67)	Α	75	42	25.0	25.0	24.8

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ 400 500 600 650 700 750 800 850 900 950 1,000 1,050 1,100 Grade Spec. No. Carbon Steel (Cont'd) Pipes and Tubes (2) (Cont'd) C D A139 X42 API 5L 20.0 20.0 Y42 A381 . . . 20.7 20.7 20.7 18.7 Y48 A381 API 5L 21.0 X46 21.0 Y46 A381 21.3 21.3 21.3 18.7 Y50 A381 19.9 19.0 17.9 17.3 16.7 13.9 11.4 9.0 6.3 4.0 2.5 CC65 A671 19.9 19.0 **CB65** 17.9 17.3 16.7 13.9 11.4 9.0 6.3 4.0 2.5 1.6 1.0 A671 19.9 19.0 17.9 17.3 16.7 13.9 11.4 9.0 6.3 4.0 2.5 1.0 B65 A672 1.6 9.0 19.9 19.0 17.9 17.3 16.7 13.9 11.4 6.3 4.0 2.5 1.6 1.0 C65 A672 Ε A139 22.0 X52 API 5L 22.0 Y52 A381 21.6 20.6 19.4 18.8 18.1 14.8 12.0 9.3 6.7 4.0 2.5 CC70 A671 20.6 19.4 18.8 9.3 2.5 21.6 18.1 14.8 12.0 6.7 4.0 1.6 1.0 **CB70** A671 21.6 20.6 19.4 18.8 18.1 14.8 12.0 9.3 6.7 4.0 2.5 1.6 1.0 B70 A672 21.6 20.6 19.4 18.8 18.1 14.8 12.0 9.3 6.7 4.0 2.5 1.6 1.0 C70 A672 21.7 19.8 22.8 20.4 14.8 A106 18.3 12.0 C 22.7 22.7 22.4 21.9 18.3 CD70 A671 22.7 22.7 22.4 21.9 18.3 D70 A672 22.7 22.7 22.4 21.9 18.3 CMSH-70 A691 23.7 X56 API 5L 23.7 Y56 A381 22.8 19.8 CK75 21.7 20.4 19.1 15.7 12.6 9.3 6.7 4.0 2.5 1.6 1.0 A671 22.8 20.4 19.8 19.1 9.3 N75 A672 21.7 15.7 12.6 6.7 4.0 2.5 1.6 1.0 22.8 21.7 20.4 19.8 19.1 15.7 12.6 9.3 6.7 4.0 2.5 1.0 CMS-75 A691 1.6 23.9 20.8 CK75 22.8 21.5 19.6 A671 23.9 22.8 21.5 20.8 19.6 N75 A672 23.9 22.8 21.5 20.8 19.6 CMS-75 A691

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

		Type/	UNS	Class/ Condition/				Min.	Speci Mir Strengt	n.	Min.		
Material	Spec. No	Type/ . Grade	No.	Temper	Size, in.	P-No. (5)	Notes	Temp., °F (6)	Tensile		•	200	300
Carbon Steel (Co Pipes and Tub		d)											
• • •	API 5L	X60				1	(51)(55)(71)(77)	Α	75	60	25.0	25.0	25.0
	API 5L	X65				1	(51)(55)(71)(77)	Α	77	65	25.7	25.7	25.7
	API 5L	X70				1	(51)(55)(71)(77)	Α	82	70	27.3	27.3	27.3
	API 5L	X80				1	(51)(55)(71)(77)	Α	90	80	30.0		30.0
	A381	Y60				1	(51)(71)	Α	75	60	25.0	25.0	25.0
Pipes (Structu)											
A283 Gr. A	A134					1	(8a)(8c)	-20	45	24	15.0	14.7	14.2
A1011 Gr. 30	A134					1	(8a)(8c)	-20	49	30	16.3	16.3	16.3
A283 Gr. B	A134					1	(8a)(8c)	-20	50	27	16.7	16.5	15.9
A1011 Gr. 33	A134					1	(8a)(8c)	-20	52	33	17.3	17.3	17.3
A1011 Gr. 36	A134					1	(8a)(8c)	-20	53	36	17.7	17.7	17.7
A1011 Gr. 40	A134					1	(8a)(8c)	-20	55	40	18.3	18.3	18.3
A36	A134					1	(8a)(8c)	-20	58	36	19.3	19.3	19.3
A283 Gr. D A1011 Gr. 45	A134 A134	• • •			• • •	1 1	(8a)(8c) (8a)(8c)	-20 -20	60 60	33 45	20.0 20.0		19.5 20.0
A1011 Gr. 50	A134					1	(8a)(8c)	-20	65	50	21.7	21.7	21.7
Plates, Bars, S	hapes, and	Sheets											
	A285	Α	K01700	• • •	• • •	1	(57)(59)	В	45	24	15.0	14.7	14.2
	A285	В	K02200		• • •	1	(57)(59)	В	50	27	16.7	16.5	15.9
	A516	55	K01800		• • •	1	(57)	С	55	30	18.3	18.3	17.7
	A285	С	K02801		• • •	1	(57)(59)	Α	55	30	18.3	18.3	17.7
	A516	60	K02100			1	(57)	С	60	32	20.0	19.5	18.9
	A515	60	K02401			1	(57)	В	60	32		19.5	
• • •	A696	В	K03200			1	(57)	A	60	35	20.0	20.0	
	A = 4.4	. F	1/00/07			٠	(5.7)	-		2-	24 -	24 ·	26.5
• • •	A516	65	K02403	• • •	• • •	1	(57)	В	65 65	35	21.7		
• • •	A515	65	K02800	• • •	• • •	1	(57)	Α	65	35	21.7	21.4	20.6
	A516	70	K02700			1	(57)	В	70	38	23.3	23.2	22.4
	A515	70	K02700			1	(57)	A	70	38		23.2	
• • •	A696	C	K03101			1	(57)	A	70	40		23.3	
	A537		K03200	1	$\leq 2^{1}/_{2}$ thk.			D	70	50		23.3	
• • •	A299	A	K02803	• • •	>1 thk.	1	(57)	A	75 75	40		24.4	
	A299	Α	K02803		≤1 thk.	1	(57)	Α	75	42	25.0	25.0	24.8

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

				(1)]	F [Note	erature,	al Tempe	i, at Met	ss, <i>S</i> , ks	ble Stres	c Allowa	Basi		
Spec. No	Type/ Grade	1,100	1,050	1,000	950	900	850	800	750	700	650	600	500	400
iteel (Cont'd) 2) (Cont'd)	Carbon S and Tubes (Pipes												
API 5L	X60													25.0
API 5L	X65													25.7
API 5L	X70													27.3
API 5L	X80	• • •			• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	30.0
A381	Y60													25.0
Grade) (2)	es (Structural	Pipe												
A134														13.7
A134														16.3
A134														
A134														17.3
A134														17.7
	• • •	• • •	•••	• • •	• • •	• • • •	•••	• • • •	• • •	• • •	• • •			
A134	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • • •		• • • •	18.3
A134	• • •	• • •	• • •	• • • •	• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •	19.3
A134 A134	• • •	• • •	• • •	• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	20.0
	•••	•••	•••	•••	•••	•••	• • •	•••	•••	•••	•••	•••	• • •	
A134			•••	•••									• • • •	21.7
	rs, Shapes, a	lates, Ba	P 1.6	2.5	4.0	5.9	7.0	0.2	10.7	11.5	11.9	122	12.0	13.7
A285	Α			2.5			7.9	9.2				12.3	13.0	
A285	В	1.0	1.6	2.5	4.0	5.9	7.9	9.2	10.7	12.5	13.3	13.8	14.7	15.4
A516	55	• • •	• • •	• • •			8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1
A285	С	1.0	1.6	2.5	4.0	5.9	8.7	10.8	13.0	14.3	14.8	15.3	16.3	17.1
A516	60						8.7	11.4	13.9	15.3	15.8	16.4	17.4	18.2
A515	60			2.5	4.0	5.9	8.7	11.4	13.9	15.3	15.8	16.4	17.4	18.2
A696	В	• • •	• • •	• • •	• • •		• • •			15.6	17.3	17.9	19.0	19.9
A516	65						9.0	11.4	13.9	16.7	17.3	17.9	19.0	19.9
A515	65	• • •	• • •	2.5	4.0	6.3	9.0	11.4	13.9	16.7	17.3	17.9	19.0	19.9
A516	70						9.3	12.0	14.8	18.1	18.8	19.4	20.6	21.6
A515	70			2.5	4.0	6.7	9.3	12.0	14.8	18.1	18.8	19.4	20.6	21.6
A696	C									18.3	19.7	20.5	21.7	22.8
A537	Cl. 1	• • •	• • •	• • • •						18.3	21.9	22.4	22.7	22.7
4200	Α	1.0	1.6	2.5	4.0	6.7	9.3	12.6	15.7	19.1	19.8	20.4	21.7	22.8
A299						6.7	9.3	12.6	15.7	19.6	20.8	21.5	22.8	23.9

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

									Specified Min.				
		Type/	UNS	Class/ Condition/				Min. Temp.,	Strangt		Min. Temp.		
Material	Spec. No.		No.	Temper	Size, in.	P-No. (5)) Notes		Tensile	Yield	•	200	300
Carbon Steel (Co	nt'd)												
Plates, Bars, S		Sheets (S	tructural)										
	A283	Α	K01400	• • •	• • •	1	(8c)(57)	Α	45	24	15.0	14.7	14.2
	A1011	30	K02502			1	(8c)(57)	Α	49	30	16.3	16.3	16.3
	A283	В	K01702			1	(8c)(57)	Α	50	27	16.7	16.5	15.9
	A1011	33	K02502			1	(8c)(57)	Α	52	33	17.3	17.3	17.3
	11011	27	V02502			4	(0-)(57)		F.2	26	477	477	477
• • •	A1011	36	K02502	• • •	• • •	1	(8c)(57)	Α	53	36	17.7	17.7	17.7
	A283	C	K02401			1	(8c)(57)	Α	55	30	18.3	18.3	17.7
• • •	A1011	40	K02502	• • •	• • •	1	(8c)(57)	Α	55	40	18.3	18.3	18.3
	A36		K02600			1	(8c)	Α	58	36	19.3	19.3	19.3
	A283	D	K02702			1	(8c)(57)	А	60	33	20.0	20.0	19.5
	A1011	45	K02702			1	(8c)(57)	A	60	45	20.0		20.0
	712022	.,,	1102307			-	(00)(31)	,,		.,	20.0	2010	2010
	A1011	50	K02507			1	(8c)(57)	Α	65	50	21.7	21.7	21.7
• • •	A992	• • •	• • •	• • •	• • •	1	(8c)(57)	Α	65	50	19.9	19.9	19.9
Forgings and F	ittings												
	A350	LF1	K03009			1	(9)(57)(59)	-20	60	30	20.0	18.3	17.7
	A181		K03502	60		1	(9)(57)(59)	Α	60	30	20.0	18.3	17.7
	A420	WPL6	K03006			1	(57)	-50	60	35	20.0	20.0	20.0
	A234	WPB	K03006			1	(57)(59)	В	60	35	20.0	20.0	20.0
• • •	71234	WIB	ROJOOO	• • •	•••	-	(31)(32)	5	00	,,,	20.0	20.0	20.0
	A350	LF2	K03011	1		1	(9)(57)	-50	70	36	23.3	22.0	21.2
• • •	A350	LF2	K03011	2	• • •	1	(9)(57)	0	70	36	23.3	22.0	21.2
	A105		K03504			1	(9)(57)(59)	-20	70	36	23.3	22.0	21.2
	A181		K03502	70		1	(9)(57)(59)	A	70	36	23.3		21.2
	4227	WDC	1/02504				(57)(50)		7.0		22.2	22.2	22.2
• • •	A234	WPC	K03501	• • •	• • •	1	(57)(59)	В	70	40	23.3	23.3	23.3
Castings (2)													
• • •	A216	WCA	J02502		• • •	1	(57)	-20	60	30	20.0	18.3	17.7
	A352	LCB	J03003			1	(9)(57)	-50	65	35	21.7	21.4	20.6
	A352	LCC	J02505			1	(9)	-50	70	40	23.3		23.3
	A216	WCB	J03002			1	(9)(57)	-20	70	36	23.3	22 0	21.2
• • •	A216	WCC	J02503			1	(9)(57)	-20 -20	70	40	23.3		
•			,,-,			-	· / (- · /		. •	. •		,_	

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ 400 500 600 650 700 750 800 850 900 950 1,000 1,050 1,100 Grade Spec. No. Carbon Steel (Cont'd) Plates, Bars, Shapes, and Sheets (Structural) 13.7 13.0 12.3 11.9 11.5 10.7 Α . . . A1011 16.3 16.3 15.3 14.6 12.5 10.7 30 13.3 15.4 14.7 13.8 12.5 10.7 В A283 . . . A1011 17.3 17.3 16.9 14.6 12.5 10.7 33 17.7 17.7 17.7 14.6 12.5 10.7 36 A1011 A283 17.1 16.3 15.3 14.8 14.3 13.0 C . . . 18.3 18.3 18.3 18.3 15.6 13.0 40 A1011 A36 19.3 19.3 18.4 17.8 15.6 17.9 16.9 16.3 15.8 D A283 18.8 13.9 20.0 20.0 20.0 20.0 16.9 13.9 A1011 45 21.7 A1011 21.7 21.7 20.5 16.9 13.9 50 19.9 19.9 19.9 18.9 15.5 12.8 A992 10.5 . . . Forgings and Fittings LF1 14.3 8.7 A350 17.1 16.3 15.3 14.8 13.8 11.4 5.9 4.0 2.5 17.1 16.3 15.3 14.8 14.3 13.8 11.4 8.7 5.9 4.0 2.5 1.6 1.0 Cl. 60 A181 19.9 19.0 WPL6 17.9 17.3 16.7 13.9 11.4 8.7 5.9 4.0 2.5 . . . A420 . . . 19.9 19.0 17.9 17.3 16.7 13.9 11.4 8.7 5.9 4.0 2.5 1.0 **WPB** A234 1.6 20.5 19.6 18.4 17.8 17.2 14.8 12.0 9.3 6.7 4.0 2.5 LF2 Cl. 1 A350 . . . 20.5 LF2 Cl. 2 19.6 18.4 17.8 17.2 14.8 12.0 9.3 6.7 4.0 2.5 . . . A350 20.5 19.6 18.4 17.8 17.2 14.8 12.0 9.3 6.7 4.0 2.5 1.6 1.0 A105 20.5 19.6 18.4 17.8 17.2 14.8 12.0 9.3 6.7 4.0 2.5 1.6 1.0 Cl. 70 A181 22.8 21.7 20.4 19.8 18.3 14.8 12.0 WPC A234 Castings (2) 17.1 WCA A216 16.3 15.3 14.8 14.3 13.8 11.4 8.7 5.9 4.0 2.5 1.6 1.0 19.9 19.0 17.9 17.3 16.7 13.9 11.4 9.0 6.3 4.0 2.5 1.6 1.0 LCB A352 21.7 19.8 22.8 20.4 19.2 LCC A352 **WCB** 20.5 19.6 18.4 17.8 17.2 14.8 12.0 9.3 6.7 4.0 2.5 A216 1.6 1.0 WCC 22.8 21.7 20.4 19.8 18.3 14.8 A216 12.0 9.3 6.7 4.0 2.5

Nominal		Type/	UNS	Class/ Condition/	Size,			Min. Temp.,	Specifie Strengt		Min. Temp.	
Composition	Spec. No.		No.	Temper	in.	P-No. (5)	Notes	°F (6)	Tensile	Yield	to 100	200
Low and Intermediat Pipes (2)	te Alloy Stee	el										
$^{1}/_{2}Cr-^{1}/_{2}Mo$	A335	P2	K11547			3		-20	55	30	18.3	18.3
$^{1}/_{2}$ Cr $^{-1}/_{2}$ Mo A387 Gr. 2 Cl. 1	A691	¹ / ₂ CR	K12143	•••	• • •	3	(11)(67)	-20	55	33	18.3	18.3
$C-\frac{1}{2}Mo$	A335	P1	K11522			3	(58)	-20	55	30	18.3	18.3
$C-\frac{1}{2}Mo$	A369	FP1	K11522			3	(58)	-20	55	30	18.3	18.3
$^{1}/_{2}Cr-^{1}/_{2}Mo$	A369	FP2	K11547			3		-20	55	30	18.3	18.3
1Cr-½Mo A387 Gr. 12 Cl. 1	A691	1CR	K11757	• • •	•••	4	(11)(67)	-20	55	33	18.3	18.3
¹ / ₂ Cr- ¹ / ₂ Mo	A426	CP2	J11547			3	(10)	-20	60	30	20.0	18.8
$1^{1}/_{2}Si^{-1}/_{2}Mo$	A335	P15	K11578			3		-20	60	30	20.0	18.8
$C-\frac{1}{2}Mo-Si$	A426	CP15	J11522		• • •	3	(10)	-20	60	30	20.0	18.8
$1Cr-\frac{1}{2}Mo$	A426	CP12	J11562			4	(10)	-20	60	30	20.0	18.1
5Cr-1 ¹ / ₂ Si- ¹ / ₂ Mo	A426	CP5b	J51545			5B	(10)	-20	60	30	20.0	18.1
3Cr–Mo	A426	CP21	J31545			5A	(10)	-20	60	30	20.0	18.7
³ / ₄ Cr- ³ / ₄ Ni-Cu-Al	A333	4	K11267			4		-150	60	35	20.0	19.1
$2Cr-\frac{1}{2}Mo$	A369	FP3b	K21509			4		-20	60	30	20.0	18.7
1Cr−¹/₂Mo	A335	P12	K11562			4		-20	60	32	20.0	19.3
$1Cr-\frac{1}{2}Mo$	A369	FP12	K11562			4		-20	60	32	20.0	19.3
1 ¹ / ₄ Cr- ¹ / ₂ Mo-Si	A335	P11	K11597			4		-20	60	30	20.0	18.5
$1\frac{1}{4}\text{Cr}-\frac{1}{2}\text{Mo-Si}$	A369	FP11	K11597			4		-20	60	30	20.0	18.5
1 ¹ / ₄ Cr- ¹ / ₂ Mo-Si	A691	1 ¹ / ₄ CR	K11789			4	(11)(67)	-20	60	35	20.0	20.0
A387 Gr. 11 Cl. 1 5Cr-½Mo A387 Gr. 5 Cl. 1	A691	5CR	K41545		•••	5B	(11)(67)	-20	60	30	20.0	18.1
5Cr- ¹ / ₂ Mo	A335	P5	K41545			5B		-20	60	30	20.0	18.1
$5Cr-\frac{1}{2}Mo-Si$	A335	P5b	K51545			5B		-20	60	30	20.0	18.1
$5Cr-\frac{1}{2}Mo-Ti$	A335	P5c	K41245			5B		-20	60	30	20.0	18.1
$5Cr-\frac{1}{2}Mo$	A369	FP5	K41545			5B		-20	60	30	20.0	
9Cr-1Mo	A335	P9	K90941			5B		-20	60	30	20.0	18.1
9Cr-1Mo	A369	FP9	K90941			5B		-20	60	30	20.0	18.1
9Cr-1Mo A387 Gr. 9 Cl. 1	A691	9CR	K90941	• • •	• • •	5B	(11)(67)	-20	60	30	20.0	18.1
3Cr-1Mo	A335	P21	K31545			5A		-20	60	30	20.0	18.7
3Cr-1Mo	A369	FP21	K31545	• • •	• • •	5A	• • •	-20	60	30	20.0	18.7
3Cr-1Mo A387 Gr. 21 Cl. 1	A691	3CR	K31545		•••	5A	(11)(67)	-20	60	30	20.0	18.5

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ 500 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 Grade Spec. No. Low and Intermediate Alloy Steel Pipes (2) 18.0 17.4 16.9 16.4 16.1 15.7 15.4 14.9 14.5 13.9 9.2 5.9 P2 A335 . . . $\frac{1}{2}$ CR 18.3 18.3 18.3 18.0 17.7 17.3 16.9 16.4 15.9 5.9 A691 18.0 17.4 16.9 16.4 16.1 15.7 15.4 14.9 14.5 13.7 8.2 4.8 4.0 2.4 P1 A335 18.0 17.4 16.9 16.4 16.1 15.7 15.4 14.9 14.5 8.2 4.8 2.4 FP1 A369 13.7 4.0 18.0 17.4 16.9 16.4 16.1 15.7 15.4 14.9 14.5 13.9 9.2 5.9 4.1 2.5 FP2 A369 17.6 17.6 17.2 16.8 16.5 16.3 16.0 15.7 15.4 15.0 11.3 7.2 4.5 2.8 1.8 A691 1.1 1CR 18.0 17.4 16.9 16.4 16.1 15.7 15.4 14.9 14.5 13.9 9.2 5.9 4.0 2.4 CP2 A426 . . . 18.2 17.7 17.3 16.8 16.6 16.3 15.9 15.4 13.8 10.0 4.0 P15 A335 12.5 6.3 2.4 18.2 17.7 17.3 16.8 16.6 16.3 15.9 15.4 13.8 12.5 10.0 6.3 4.0 2.4 CP15 A426 17.0 16.2 15.7 15.2 15.0 14.8 14.6 14.3 14.0 13.6 7.2 2.8 1.8 1.1 CP12 A426 4.5 CP5b 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.3 10.9 8.0 5.8 4.2 2.9 1.8 A426 1.0 18.2 18.0 17.9 17.9 17.9 17.9 17.7 16.0 12.0 CP21 A426 9.0 7.0 5.5 4.0 2.7 1.5 18.2 17.3 16.4 15.5 15.0 4 A333 18.2 18.0 17.9 17.9 17.9 17.9 17.7 17.5 12.5 10.0 FP3b 1.0 A369 6.2 4.2 2.6 1.4 18.1 17.3 16.7 16.3 16.0 15.8 15.5 15.3 14.9 14.5 11.3 A335 7.2 4.5 2.8 1.8 1.1 P12 18.1 17.3 16.7 16.3 16.0 15.8 15.5 15.3 14.9 14.5 11.3 7.2 4.5 2.8 1.8 1.1 FP12 A369 17.6 16.8 16.2 15.7 15.4 15.1 14.8 14.4 14.0 13.6 9.3 6.3 4.2 2.8 1.9 1.2 P11 A335 17.6 16.8 16.2 15.7 15.4 15.1 14.8 14.4 14.0 13.6 9.3 6.3 2.8 1.9 1.2 FP11 A369 4.2 20.0 19.6 18.9 18.3 18.0 17.6 17.2 16.8 16.4 13.7 9.3 6.3 4.2 2.8 1.9 1.2 1¹/₄CR A691 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.3 10.9 8.0 2.9 1.0 5CR A691 5.8 4.2 1.8 17.4 17.2 17.1 16.8 16.6 16.3 15.9 2.9 P5 A335 15.4 14.3 10.9 8.0 5.8 4.2 1.8 1.0 17.4 17.2 17.1 16.8 16.6 16.3 15.4 P5b A335 15.9 14.3 10.9 8.0 5.8 4.2 2.9 1.8 1.0 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.3 10.9 8.0 5.8 2.9 1.8 1.0 P5c A335 4.2 17.4 17.2 17.1 16.8 16.6 16.3 15.9 FP5 15.4 5.8 2.9 1.8 1.0 A369 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.8 14.1 10.6 7.4 5.0 3.3 2.2 1.5 P9 A335 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.8 14.1 10.6 7.4 5.0 3.3 2.2 1.5 FP9 A369 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.8 10.6 7.4 5.0 3.3 2.2 1.5 9CR A691 18.2 18.0 17.9 17.9 17.9 17.9 17.7 16.0 12.0 9.0 7.0 4.0 P21 A335 5.5 2.7 1.5 18.2 18.0 17.9 17.9 17.9 17.9 17.9 17.7 16.0 12.0 9.0 7.0 5.5 4.0 2.7 1.5 FP21 A369

9.0

7.0

5.5

4.0

2.7

1.5

3CR

18.2 18.0 17.9 17.9 17.9 17.9 17.7 16.0 12.0

(16)

A691

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd) Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Nominal		Type/	UNS	Class/ Condition/	Size,			Min. Temp.,	Specifie Strengt		Min. Temp.	
Composition	Spec. No.		No.	Temper	in.	P-No. (5)	Notes	°F (6)	Tensile	Yield	to 100	200
Low and Intermediat Pipes (2) (Cont'd)	e Alloy Stee	el (Cont'o	i)									
2 ¹ / ₄ Cr-1Mo A387 Gr. 22 Cl. 1	A691	2 ¹ / ₄ CR	K21590	• • •	• • •	5A	(11)(67)(72)(75)	-20	60	30	20.0	18.7
$2^{1}/_{4}$ Cr-1Mo	A369	FP22	K21590			5A	(72)(75)	-20	60	30	20.0	18.7
2 ¹ / ₄ Cr–1Mo	A335	P22	K21590	• • •	• • •	5A	(72)(75)	-20	60	30	20.0	18.7
2Ni-1Cu	A333	9	K22035			9A		-100	63	46	21.0	
2Ni-1Cu	A334	9	K22035		• • •	9A	• • •	-100	63	46	21.0	• • •
2 ¹ / ₄ Ni	A333	7	K21903			9A		-100	65	35	21.7	21.4
2 ¹ / ₄ Ni	A334	7	K21903		• • •	9A	• • •	-100	65	35	21.7	21.4
3½Ni	A333	3	K31918			9B		-150	65	35	21.7	21.4
3 ¹ / ₂ Ni	A334	3	K31918			9B	• • •	-150	65	35	21.7	21.4
$C - \frac{1}{2}Mo$	A426	CP1	J12521			3	(10)(58)	-20	65	35	21.7	21.7
C-1/2Mo A204 Gr. A	A672	L65	K11820			3	(11)(58)(67)	-20	65	37	21.7	21.7
$C - \frac{1}{2}Mo$ A204 Gr. A	A691	CM-65	K11820		• • •	3	(11)(58)(67)	-20	65	37	21.7	21.7
2 ¹ / ₄ Ni A203 Gr. B	A671	CF70	K22103			9A	(11)(65)(67)	-20	70	40	23.3	
$3\frac{1}{2}$ Ni A203 Gr. E	A671	CF71	K32018		• • •	9B	(11)(65)(67)	-20	70	40	23.3	
C-1/2Mo A204 Gr. B	A672	L70	K12020			3	(11)(58)(67)	-20	70	40	23.3	23.3
$C-\frac{1}{2}Mo A204 Gr. B$	A691	CM-70	K12020			3	(11)(58)(67)	-20	70	40	23.3	23.3
$1\frac{1}{4}Cr - \frac{1}{2}Mo$	A426	CP11	J12072			4	(10)	-20	70	40	23.3	23.3
2 ¹ / ₄ Cr–1Mo	A426	CP22	J21890		• • •	5A	(10)(72)	-20	70	40	23.3	23.3
C- ¹ / ₂ Mo A204 Gr. C	A672	L75	K12320			3	(11)(58)(67)	-20	75	43	25.0	25.0
$C - \frac{1}{2} Mo A204 Gr. C$	A691	CM-75	K12320		• • •	3	(11)(58)(67)	-20	75	43	25.0	25.0
9Cr-1Mo-V	A335	P91	K90901		≤3 thk.	15E	• • •	-20	85	60	28.3	28.3
9Cr-1Mo-V	A691	91	K90901		≤3 thk.	15E	(11)(67)	-20	85	60	28.3	28.3
5Cr- ¹ / ₂ Mo	A426	CP5	J42045			5B	(10)	-20	90	60	30.0	29.9
9Cr-1Mo	A426	CP9	J82090		• • •	5B	(10)	-20	90	60	30.0	29.9
9Ni	A333	8	K81340			11A	(47)	-320	100	75	33.3	33.3
9Ni	A334	8	K81340	• • •	• • •	11A	•••	-320	100	75	33.3	33.3
Plates												
$^{1}/_{2}Cr-^{1}/_{2}Mo$	A387	2	K12143	1		3		-20	55	33	18.3	18.3
$1Cr - \frac{1}{2}Mo$	A387	12	K11757	1		4		-20	55	33	18.3	18.0
9Cr-1Mo	A387	9	K90941	1	• • •	5	• • •	-20	60	30	20.0	18.1

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ 650 700 750 500 800 850 900 950 1,000 1,050 1,100 1,150 1,200 Grade Spec. No. Low and Intermediate Alloy Steel (Cont'd) Pipes (2) (Cont'd) 18.2 18.0 17.9 17.9 17.9 17.9 17.7 17.1 13.6 10.8 8.0 5.7 3.8 2.4 1.4 2¹/₄CR A691 FP22 18.2 18.0 17.9 17.9 17.9 17.9 17.7 17.1 13.6 10.8 8.0 5.7 3.8 2.4 1.4 A369 18.2 18.0 17.9 17.9 17.9 17.9 17.9 17.1 13.6 10.8 3.8 2.4 1.4 P22 A335 17.7 8.0 5.7 A333 9 A334 . . . 20.6 19.9 18.9 17.5 16.7 15.7 13.9 11.4 9.0 6.5 4.5 2.5 1.0 A333 1.6 20.6 19.9 18.9 17.5 16.7 15.7 13.9 11.4 6.5 4.5 2.5 1.6 1.0 A334 20.6 19.9 18.9 17.5 16.7 15.7 13.9 9.0 4.5 2.5 3 A333 11.4 6.5 1.6 1.0 20.6 19.9 18.9 17.5 16.7 15.7 13.9 11.4 9.0 6.5 4.5 2.5 1.6 1.0 3 A334 . . . 21.0 20.3 19.7 19.1 18.7 18.4 17.9 17.4 8.2 4.8 4.0 CP1 A426 2.4 21.7 21.5 20.8 20.2 19.8 19.4 19.0 18.4 17.9 8.2 4.8 4.0 165 A672 13.7 2.4 21.7 21.5 20.8 20.2 19.8 19.4 19.0 18.4 17.9 CM-65 A691 13.7 8.2 4.8 4.0 2.4 . . . CF70 A671 CF71 A671 23.3 23.2 22.5 21.8 21.4 21.0 20.5 19.9 19.3 13.7 L70 8.2 4.8 4.0 2.4 A672 . . . 23.3 23.2 22.5 21.8 21.4 21.0 20.5 19.9 19.3 13.7 8.2 4.8 4.0 2.4 CM-70 A691 23.3 22.5 21.7 20.9 20.5 20.1 19.7 19.2 18.7 13.7 CP11 9.3 4.2 2.8 1.9 1.2 A426 6.3 22.6 22.6 22.6 22.6 22.6 22.6 22.6 21.9 15.8 11.4 7.8 5.1 3.2 2.0 1.2 CP22 A426 25.0 25.0 24.2 23.4 23.0 22.6 22.0 21.4 20.7 13.7 8.2 4.8 4.0 2.4 L75 A672 25.0 25.0 24.2 23.4 23.0 22.6 22.0 21.4 20.7 13.7 8.2 4.8 4.0 2.4 CM-75 A691 . . . 27.3 25.9 P91 28.2 28.1 27.7 26.7 24.9 23.7 22.3 20.7 18.0 14.0 10.3 7.0 4.3 A335 28.3 28.2 28.1 27.7 27.3 26.7 25.9 24.9 23.7 22.3 20.7 18.0 14.0 10.3 7.0 4.3 91 A691 29.1 28.7 28.3 27.9 27.3 26.5 25.5 24.2 16.4 7.4 5.0 3.3 2.2 1.5 CP5 28.8 11.0 A426 29.1 28.8 28.7 28.3 27.9 27.3 26.5 25.5 24.2 16.4 7.4 5.0 3.8 2.2 1.5 CP9 A426 11.0 8 A333 8 A334 **Plates** 18.3 18.3 18.3 18.0 17.7 17.3 16.9 16.4 15.9 14.3 9.2 5.9 2 Cl. 1 A387 17.6 17.6 17.2 16.8 16.5 16.3 16.0 15.7 15.4 15.0 11.3 7.2 4.5 2.8 12 Cl. 1 A387 1.8 1.1 17.4 17.2 17.1 16.8 16.6 16.3 15.9 7.4 5.0 3.3 2.2 9 Cl. 1 A387 15.4 14.8 14.1 10.6 1.5

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Nominal		Type/	UNS	Class/ Condition/	Size,			Min. Temp.,	Specifie Strengt		Min. Temp.	
Composition	Spec. No.		No.	Temper	in.	P-No. (5)	Notes	°F (6)	Tensile	Yield	to 100	200
Low and Intermedia Plates (Cont'd)	ate Alloy Stee	el (Cont'o	i)									
1 ¹ / ₄ Cr- ¹ / ₂ Mo-Si	A387	11	K11789	1		4		-20	60	35	20.0	20.0
$5Cr-\frac{1}{2}Mo$	A387	5	K41545	1		5B		-20	60	30	20.0	18.1
3Cr-1Mo	A387	21	K31545	1		5A		-20	60	30	20.0	18.3
$2\frac{1}{4}$ Cr -1 Mo	A387	22	K21590	1	• • •	5A	(72)	-20	60	30	20.0	18.7
2 ¹ / ₄ Ni	A203	Α	K21703			9A	(12)(65)	-20	65	37	21.7	21.7
$3\frac{1}{2}$ Ni	A203	D	K31718	• • •	• • •	9B	(12)(65)	-20	65	37	21.7	21.7
$C-\frac{1}{2}Mo$	A204	Α	K11820			3	(58)	-20	65	37	21.7	21.7
$1Cr-\frac{1}{2}Mo$	A387	12	K11757	2	• • •	4	• • •	-20	65	40	21.7	21.3
2 ¹ / ₄ Ni	A203	В	K22103			9A	(12)(65)	-20	70	40	23.3	23.3
3½Ni	A203	E	K32018		• • •	9B	(12)(65)	-20	70	40	23.3	23.3
$^{1}/_{2}Cr-^{1}/_{2}Mo$	A387	2	K12143	2		3		-20	70	45	23.3	23.3
$C-\frac{1}{2}Mo$	A204	В	K12020		• • •	3	(58)	-20	70	40	23.3	23.3
$Mn-\frac{1}{2}Mo$	A302	Α	K12021			3		-20	75	45	25.0	25.0
$C-\frac{1}{2}Mo$	A204	C	K12320		• • •	3	(58)	-20	75	43	25.0	25.0
$1\frac{1}{4}Cr-\frac{1}{2}Mo-Si$	A387	11	K11789	2		4		-20	75	45	25.0	25.0
$5Cr-\frac{1}{2}Mo$	A387	5	K41545	2		5B		-20	75	45	25.0	24.9
3Cr-1Mo	A387	21	K31545	2		5A		-20	75	45	25.0	25.0
$2\frac{1}{4}$ Cr -1 Mo	A387	22	K21590	2	• • •	5A	(72)	-20	75	45	25.0	25.0
$Mn-\frac{1}{2}Mo$	A302	В	K12022			3		-20	80	50	26.7	26.7
$Mn-\frac{1}{2}Mo-\frac{1}{2}Ni$	A302	C	K12039			3		-20	80	50	26.7	26.7
$Mn - \frac{1}{2}Mo - \frac{3}{4}Ni$	A302	D	K12054		• • •	3	• • •	-20	80	50	26.7	26.7
9Cr-1Mo-V	A387	91	K90901	2	≤3 thk.	15E		-20	85	60	28.3	28.3
8Ni	A553	II	K71340			11A	(47)	-275	100	85	33.3	
5Ni-1/4Mo	A645	Α	K41583		• • •	11A		-275	95	65	31.7	31.7
9Ni	A553	ı	K81340			11A	(47)	-320	100	85	33.3	33.3
9Ni	A353		K81340			11A	(47)	-320	100	75	33.3	33.3
Forgings and Fitt	ings											
$C - \frac{1}{2}Mo$	A234	WP1	K12821			3	(58)	-20	55	30	18.3	18.3
1Cr- ¹ / ₂ Mo	A182	F12	K11562	1		4	(9)	-20	60	32	20.0	19.3
$1Cr-\frac{1}{2}Mo$	A234	WP12	K12062	1		4		-20	60	32	20.0	19.3
1 ¹ / ₄ Cr- ¹ / ₂ Mo-Si	A182	F11	K11597	1		4	(9)	-20	60	30	20.0	18.5
$1\frac{1}{4}Cr - \frac{1}{2}Mo - Si$	A234	WP11	K11597	1		4		-20	60	30	20.0	18.5

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ 650 700 750 500 800 850 900 950 1,000 1,050 1,100 1,150 1,200 Grade Spec. No. Low and Intermediate Alloy Steel (Cont'd) Plates (Cont'd) 20.0 19.6 18.9 18.3 18.0 17.6 17.2 16.8 16.4 13.7 9.3 6.3 4.2 2.8 1.9 1.2 11 Cl. 1 A387 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.3 10.9 8.0 5.8 4.2 2.9 1.8 1.0 5 Cl. 1 A387 17.5 17.0 16.6 16.2 14.9 21 Cl. 1 16.0 15.8 15.5 15.2 12.0 9.0 7.0 5.5 4.0 2.7 1.5 A387 18.2 18.0 17.9 17.9 17.9 17.9 17.9 17.7 17.1 13.6 10.8 8.0 5.7 3.8 1.4 22 Cl. 1 A387 2.4 11.4 20.0 18.5 17.6 16.6 13.9 9.0 4.5 A203 21.1 6.5 2.5 21.7 21.1 20.0 18.5 17.6 16.6 13.9 11.4 9.0 6.5 4.5 2.5 D A203 21.7 21.5 20.8 20.2 19.8 19.4 19.0 18.4 17.9 4.8 4.0 2.4 A204 20.8 20.8 20.8 20.3 20.0 19.7 19.4 19.1 18.6 7.2 4.5 2.8 1.8 1.1 12 Cl. 2 A387 A203 23.3 22.8 21.6 20.0 19.0 16.9 13.9 9.0 4.5 2.5 R 11.4 6.5 23.3 22.8 21.6 20.0 19.0 18.0 14.8 12.0 9.3 6.5 4.5 2.5 F A203 . . . 23.3 23.3 23.3 23.3 23.3 23.3 23.1 22.4 21.7 20.9 9.2 5.9 2 Cl. 2 A387 23.3 23.2 22.5 21.8 21.4 21.0 20.5 19.9 19.3 13.7 8.2 4.8 4.0 2.4 В A204 25.0 25.0 25.0 25.0 24.9 24.4 23.9 23.2 20.0 13.7 8.2 4.8 A302 Α 24.2 23.4 23.0 22.6 22.0 8.2 4.8 4.0 2.4 A204 11 Cl. 2 A387 25.0 25.0 24.4 23.5 23.1 22.6 22.2 21.6 20.2 13.7 9.3 6.3 4.2 2.8 1.9 1.2 24.2 24.0 24.0 23.6 23.2 22.7 16.5 16.0 15.1 10.9 8.0 2.9 1.0 5 Cl. 2 A387 5.8 4.2 1.8 24.2 24.2 9.5 21 Cl. 2 A387 24.2 24.2 24.2 24.2 24.2 18.1 13.1 6.8 4.9 3.2 2.4 1.3 24.3 24.1 24.0 23.8 23.6 23.4 23.0 22.5 21.9 15.8 11.4 7.8 3.2 2.0 1.2 22 Cl. 2 A387 5.1 26.7 A302 26.7 26.7 26.7 26.7 26.7 26.5 25.7 20.0 8.2 4.8 В 13.7 26.7 26.7 26.7 26.7 26.7 26.5 25.7 20.0 13.7 8.2 4.8 C A302 26.7 26.7 26.7 26.7 26.7 26.5 25.7 20.0 13.7 8.2 D A302 4.8 7.0 91 Cl. 2 A387 28.3 28.2 28.1 27.7 27.3 26.7 25.9 24.9 23.7 22.3 20.7 18.0 14.0 10.3 4.3 Ш A553 A645 A553 - 1 A353 . . . Forgings and Fittings 18.0 17.4 16.9 16.4 16.1 15.7 15.4 14.9 14.5 13.7 4.8 4.0 WP1 A234 8.2 2.4 . . . 18.1 17.3 16.7 16.3 16.0 15.8 15.5 15.3 14.9 14.5 11.3 7.2 2.8 1.8 1.1 F12 Cl. 1 A182 4.5 18.1 17.3 16.7 16.3 16.0 15.8 15.5 15.3 14.9 14.5 11.3 7.2 4.5 2.8 1.8 1.1 WP12 Cl. 1 A234 17.6 16.8 16.2 15.7 15.4 15.1 14.8 14.4 14.0 13.6 9.3 6.3 4.2 2.8 1.9 1.2 F11 Cl. 1 A182 17.6 16.8 16.2 15.7 15.4 15.1 14.8 14.4 6.3 4.2 2.8 1.9 1.2 WP11 Cl. 1 A234

Nominal		Type/	UNS	Class/ Condition/	Size,			Min. Temp.,	Specifie Strengt		Min. Temp.	
Composition	Spec. No.	• • •	No.	Temper	in.	P-No. (5)	Notes	°F (6)		Yield	to 100	200
Low and Intermedia Forgings and Fitti	•	el (Cont'd)										
$2\frac{1}{4}$ Cr-1Mo $2\frac{1}{4}$ Cr-1Mo	A182 A234	F22 WP22	K21590 K21590	1 1		5A 5A	(9)(72)(75) (72)	-20 -20	60 60	30 30	20.0 20.0	18.7 18.7
$5Cr-\frac{1}{2}Mo$	A234	WP5	K41545			5B	•••	-20	60	30	20.0	18.1
9Cr-1Mo	A234	WP9	K90941			5B		-20	60	30	20.0	18.1
3 ¹ / ₂ Ni	A420	WPL3	K31918			9B		-150	65	35	21.7	21.4
3 ¹ / ₂ Ni	A350	LF3	K32025			9B	(9)	-150	70	37.5	23.3	22.9
¹ / ₂ Cr- ¹ / ₂ Mo	A182	F2	K12122			3	(9)	-20	70	40	23.3	23.3
$C-\frac{1}{2}Mo$	A182	F1	K12822	• • •	• • •	3	(9)(58)	-20	70	40	23.3	23.3
$1Cr - \frac{1}{2}Mo$	A182	F12	K11564	2		4	(9)	-20	70	40	23.3	22.9
$1 \text{Cr} - \frac{1}{2} \text{Mo}$	A234	WP12	K12062	2	• • •	4	• • •	-20	70	40	23.3	22.9
$1\frac{1}{4}Cr - \frac{1}{2}Mo - Si$	A182	F11	K11572	2		4	(9)	-20	70	40	23.3	23.3
$1\frac{1}{4}$ Cr $-\frac{1}{2}$ Mo $-$ Si	A234	WP11	K11572	2	• • •	4	• • •	-20	70	40	23.3	23.3
$5Cr-\frac{1}{2}Mo$	A182	F5	K41545			5B	(9)	-20	70	40	23.3	23.3
3Cr-1Mo	A182	F21	K31545			5A	(9)	-20	75	45	25.0	25.0
2 ¹ / ₄ Cr–1Mo	A182	F22	K21590	3		5A	(9)(72)	-20	75	45	25.0	25.0
2 ¹ / ₄ Cr–1Mo	A234	WP22	K21590	3	• • •	5A	(72)	-20	75	45	25.0	25.0
9Cr-1Mo	A182	F9	K90941			5B	(9)	-20	85	55	28.3	28.3
9Cr-1Mo-V	A182	F91	K90901		≤3 thk.	15E		-20	85	60	28.3	28.3
9Cr-1Mo-V	A234	WP91	K90901		≤3 thk.	15E	• • •	-20	85	60	28.3	28.3
$5Cr-\frac{1}{2}Mo$	A182	F5a	K42544		• • •	5B	(9)	-20	90	65	30.0	29.9
9Ni	A420	WPL8	K81340	• • •	• • •	11A	(47)	-320	100	75	33.3	33.3
Castings (2)												
$C-\frac{1}{2}Mo$	A352	LC1	J12522			3	(9)(58)	-75	65	35	21.7	21.7
$C-\frac{1}{2}Mo$	A217	WC1	J12524	• • •	• • •	3	(9)(58)	-20	65	35	21.7	21.7
2 ¹ / ₂ Ni	A352	LC2	J22500			9A	(9)	-100	70	40	23.3	23.3
3½Ni	A352	LC3	J31550		• • •	9B	(9)	-150	70	40	23.3	23.3
$1 \text{Ni} - \frac{1}{2} \text{Cr} - \frac{1}{2} \text{Mo}$	A217	WC4	J12082			4	(9)	-20	70	40	23.3	23.3
³ / ₄ Ni−1Mo− ³ / ₄ Cr	A217	WC5	J22000			4	(9)	-20	70	40	23.3	23.3
$1\frac{1}{4}$ Cr $-\frac{1}{2}$ Mo	A217	WC6	J12072			4	(9)	-20	70	40	23.3	23.3
$2\frac{1}{4}$ Cr -1 Mo	A217	WC9	J21890	• • •	• • •	5A	(9)	-20	70	40	23.3	23.3
$5Cr-\frac{1}{2}Mo$	A217	C5	J42045			5B	(9)	-20	90	60	30.0	29.9
9Cr-1Mo	A217	C12	J82090	• • •	• • •	5B	(9)	-20	90	60	30.0	29.9

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ 500 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 Grade Spec. No. Low and Intermediate Alloy Steel (Cont'd) Forgings and Fittings (Cont'd) 18.2 18.0 17.9 17.9 17.9 17.9 17.7 17.1 13.6 10.8 8.0 5.7 3.8 2.4 F22 Cl. 1 A182 18.2 18.0 17.9 17.9 17.9 17.9 17.9 17.7 17.1 13.6 10.8 8.0 5.7 3.8 2.4 1.4 WP22 Cl. 1 A234 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.3 10.9 8.0 5.8 4.2 2.9 1.8 1.0 WP5 A234 WP9 17.4 17.2 17.1 16.8 16.6 16.3 15.9 15.4 14.8 14.1 11.0 7.4 5.0 3.3 2.2 1.5 A234 20.6 19.9 18.9 17.5 16.7 WPL3 A420 . . . 22.1 21.4 20.3 18.8 17.9 LF3 A350 23.3 23.2 22.5 21.8 21.4 21.0 20.5 19.9 19.3 18.6 9.2 5.9 F2 A182 23.3 23.2 22.5 21.8 21.4 21.0 20.5 19.9 19.3 8.2 4.8 4.0 2.4 A182 F12 Cl. 2 A182 22.4 21.7 20.9 20.3 20.0 19.7 19.4 19.1 18.6 18.0 11.3 7.2 4.5 2.8 1.8 1.1 22.4 21.7 20.9 20.0 19.7 19.4 19.1 18.6 WP12 Cl. 2 20.3 18.0 11.3 7.2 2.8 A234 4.5 1.8 1.1 23.3 22.5 21.7 20.9 20.5 20.1 19.7 19.2 18.7 13.7 F11 Cl. 2 A182 9.3 6.3 4.2 2.8 1.9 23.3 22.5 21.7 20.9 20.5 20.1 19.7 19.2 18.7 13.7 9.3 6.3 4.2 2.8 1.9 1.2 WP11 Cl. 2 A234 22.6 22.4 22.4 22.0 21.7 21.2 20.6 19.8 14.3 10.9 8.0 2.9 1.0 F5 A182 5.8 4.2 1.8 24.3 24.1 24.0 23.8 23.6 23.4 23.0 22.5 18.1 13.1 9.5 6.8 4.9 3.2 2.4 1.3 F21 A182 24.2 24.2 24.2 24.2 24.2 24.2 24.2 F22 Cl. 3 24.2 21.9 15.8 11.4 7.8 5.1 3.2 2.0 A182 1.2 24.2 24.2 24.2 24.2 24.2 24.2 24.2 24.2 21.9 11.4 7.8 5.1 3.2 2.0 1.2 WP22 Cl. 3 A234 27.4 27.2 27.1 26.8 26.3 F9 A182 25.8 25.0 24.0 22.9 15.2 10.6 7.4 5.0 3.3 2.2 1.5 28.3 28.2 28 1 27.7 273 26.7 25.9 249 23.7 223 20.7 18.0 14.0 10.3 7.0 4.3 F91 A182 28.2 28.1 27.3 26.7 25.9 24.9 23.7 22.3 20.7 18.0 10.3 7.0 4.3 WP91 A234 28.3 27.7 14.0 A182 29.1 28.8 28.7 28.3 27.9 27.3 26.5 25.5 14.3 10.9 8.0 5.8 4.2 2.9 1.8 1.0 F5a WPL8 A420 Castings (2) 21.0 20.3 19.7 19.1 18.7 18.4 LC1 A352 21.0 20.3 19.7 19.1 18.7 18.4 17.9 17.4 16.9 13.7 8.2 4.8 4.0 2.4 WC1 A217 . . . 23.3 22.8 21.6 20.0 19.0 LC2 A352 23.3 22.8 21.6 20.0 19.0 LC3 A352 23.3 23.3 23.0 22.4 22.1 9.2 21.7 21.2 20.6 19.8 14.3 5.9 WC4 A217 23.3 23.0 22.4 22.1 21.7 21.2 20.6 19.8 14.3 9.2 5.9 4.0 2.4 WC5 A217 23.3 22.5 21.7 20.9 20.5 20.1 19.7 19.2 18.7 13.7 9.3 2.8 1.9 1.2 WC6 A217 6.3 4.2 22.6 22.6 22.6 22.6 22.6 22.6 22.6 21.9 15.8 11.4 7.8 5.1 3.2 2.0 1.2 WC9 A217 C5 29.1 28.8 28.7 28.3 27.9 27.3 26.5 25.5 14.3 10.9 8.0 2.9 1.0 A217 5.8 4.2 1.8 29.1 28.8 28.7 28.3 27.9 27.3 26.5 25.5 24.2 15.2 10.6 7.4 5.0 3.3 2.2 C12 A217 1.5

Nominal	Product	Spec.	Type/	UNS	Class/ Condition/		P-No.		Min. Temp.,	Specified Strength		Min. Temp.			
Composition	Form	No.	Grade	No.	Temper	Size, in.	(5)	Notes	°F (6)	Tensile	Yield	to 100	200	300	400
Stainless Steel (3) Pipes and Tubes															
18Cr-10Ni-Ti	Smls. pipe	A312	TP321	S32100		$> \frac{3}{8}$ thk.	8	(30)(36)	-425	70	25	16.7	16.7	16.7	16.7
18Cr-10Ni-Ti	Pipe	A376	TP321	S32100		$>\frac{3}{8}$ thk.	8	(30)(36)	-425	70	25	16.7	16.7	16.7	16.7
18Cr-8Ni	Tube	A213	TP304L	S30403			8	(14)(36)	-425	70	25	16.7	16.7	16.7	15.8
18Cr-8Ni	Tube	A269	TP304L	S30403			8	(14)(36)	-425	70	25	16.7		16.7	
18Cr-8Ni	Pipe	A312	TP304L	S30403			8	•••	-425	70	25	16.7	16.7	16.7	15.8
18Cr-8Ni	Pipe	A358	304L	S30403			8	(36)	-425	70	25	16.7	16.7	16.7	15.8
16Cr-12Ni-2Mo	Tube	A213	TP316L	S31603			8	(14)(36)	-425	70	25	16.7	16.7	16.7	15.7
16Cr-12Ni-2Mo	Tube	A269	TP316L	S31603			8	(14)(36)	-425	70	25	16.7	16.7	16.7	15.7
16Cr-12Ni-2Mo	Pipe	A312	TP316L	S31603			8	•••	-425	70	25	16.7	16.7	16.7	15.7
16Cr-12Ni-2Mo	Pipe	A358	316L	S31603			8	(36)	-425	70	25	16.7	16.7	16.7	15.7
16Cr-12Ni-2Mo-Ti	Tube	A213	TP316Ti	S31635			8	(30)	-325	75	30	20.0	20.0	20.0	19.3
18Cr-10Ni-Ti	Smls. pipe	A312	TP321	S32100		$> \frac{3}{8}$ thk.	8	(28)(30)(36)	-425	70	25	16.7	16.7	16.7	16.7
18Cr-10Ni-Ti	Pipe	A376	TP321	S32100		$> \frac{3}{8}$ thk.	8	(28)(30)(36)	-425	70	25	16.7	16.7	16.7	16.7
18Cr-10Ni-Ti	Smls. pipe	A312	TP321H	S32109		$> \frac{3}{8}$ thk.	8	(30)(36)	-325	70	25	16.7	16.7	16.7	16.7
18Cr-10Ni-Ti	Pipe	A376	TP321H	S32109		$> \frac{3}{8}$ thk.	8		-325	70	25	16.7	16.7	16.7	16.7
25Cr-12Ni		A451	CPH8	J93400			8	(26)(28)(35)	-325	65	28	18.7	18.7	18.5	18.0
25Cr-20Ni		A451	CPK20	J94202			8	(12)(28)(35)(39)	-325	65	28	18.7	18.7	18.5	18.0
11Cr-Ti	Tube	A268	TP409	S40900			7	(35)	-20	60	30	20.0			
18Cr-Ti	Tube	A268	TP430Ti	S43036			7	(35)(49)	-20	60	40	20.0			
16Cr-14Ni-2Mo		A451	CPF10MC	J92971			8	(28)	-325	70	30	20.0			
16Cr-8Ni-2Mo	Pipe	A376	16-8-2H	S16800		• • •	8	(26)(31)(35)	-325	75	30	20.0		• • •	
12Cr-Al	Tube	A268	TP405	S40500			7	(35)	-20	60	30	20.0	20.0	19.6	19.3
13Cr	Tube	A268	TP410	S41000			6	(35)	-20	60	30	20.0	20.0	19.6	19.3
17Cr	Tube	A268	TP430	S43000		• • •	7	(35)(49)	-20	60	35	20.0	20.0	19.6	19.3
18Cr-13Ni-3Mo	Pipe	A312	TP317L	S31703			8		-325	75	30	20.0	20.0	20.0	18.9
25Cr-20Ni	Pipe	A312	TP310	S31009			8	(35)(39)	-325	75	30	20.0	20.0	20.0	20.0
25Cr-20Ni		A358	310S	S31008			8	(28)(35)(36)	-325	75	30	20.0	20.0	20.0	20.0
25Cr-20Ni	Pipe	A409	TP310S	S31008			8	(28)(31)(35)(36)	-325	75	30	20.0	20.0	20.0	20.0
18Cr-10Ni-Ti	Smls. & wld. pipe	A312	TP321	S32100		$\leq \frac{3}{8}$ thk.	8	(30)	-425	75	30	20.0	20.0	20.0	20.0
18Cr-10Ni-Ti	Pipe	A358	321	S32100			8	(30)(36)	-425	75	30	20.0	20.0	20.0	20.0
18Cr-10Ni-Ti	Pipe	A376	TP321	S32100		$\leq \frac{3}{8}$ thk.	8	(30)(36)	-425	75 75	30	20.0		20.0	
18Cr-10Ni-Ti	Pipe	A409	TP321	S32100		-/8 time	8	(30)(36)	-425	75	30	20.0		20.0	
23Cr-12Ni	Pipe	A312	TP309				8	(28)(35)(39)	-325	75	30	20.0	20.0	20.0	20.0
23Cr-12Ni		A358	3095	S30908			8	(28)(31)(35)(36)	-325	75	30	20.0		20.0	
18Cr-8Ni		A451	CPF8	J92600			8	(26)(28)	-425	70	30	20.0	20.0	20.0	18.6

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Spec. Type/ 500 600 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 Grade No. Stainless Steel (3)(4a) Pipes and Tubes (2) **16.1** 15.2 14.9 14.6 14.3 14.1 13.9 13.8 13.6 9.6 6.9 5.0 3.6 2.6 1.7 1.1 0.8 0.5 0.3 TP321 A312 **16.1** 15.2 14.9 14.6 14.3 14.1 13.9 13.8 13.6 6.9 5.0 3.6 2.6 0.5 0.3 TP321 A376 0.8 14.7 14.0 13.7 13.5 13.3 13.0 12.8 12.6 12.3 12.0 6.3 5.1 4.0 3.2 2.6 2.1 1.7 1.1 1.0 0.9 TP304L A213 14.7 14.0 13.7 13.5 13.3 13.0 12.8 12.6 12.3 12.0 6.3 5.1 4.0 3.2 2.6 2.1 1.7 1.1 1.0 0.9 TP304L A269 14.7 14.0 13.7 13.5 13.3 13.0 12.8 12.6 12.3 12.0 0.9 TP304L A312 6.3 5.1 4.0 3.2 2.6 1.7 1.0 2.1 1.1 14.7 14.0 13.7 13.5 13.3 13.0 12.8 12.6 12.3 12.0 6.3 5.1 4.0 3.2 2.6 2.1 1.7 1.1 1.0 0.9 304L A358 14.8 14.0 13.7 13.5 13.2 12.9 12.7 12.4 12.1 11.8 11.6 11.4 8.8 6.4 4.7 3.5 2.5 1.8 1.3 1.0 TP316L A213 13.2 12.9 14.0 13.7 13.5 12.7 12.4 12.1 11.8 11.6 11.4 8.8 6.4 4.7 3.5 2.5 1.8 1.3 1.0 TP316L A269 14.8 14.0 13.7 13.5 13.2 12.9 12.7 12.4 12.1 11.8 11.6 11.4 8.8 6.4 4.7 3.5 2.5 1.8 1.3 1.0 TP316L A312 14.8 14.0 13.7 13.5 13.2 12.9 12.7 12.4 12.1 11.8 11.6 11.4 8.8 6.4 4.7 3.5 2.5 1.8 1.3 1.0 316L A358 17.8 16.8 16.5 16.2 16.1 15.9 15.8 15.7 15.5 TP316Ti 15.3 15.1 12.3 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 A213 16.1 15.2 14.9 14.6 14.3 14.1 13.9 13.8 13.6 13.5 9.1 6.9 3.2 2.5 1.9 1.5 TP321 A312 12.3 5.4 4.1 1.1 16.1 15.2 14.9 14.6 14.3 14.1 13.9 13.8 13.6 13.5 12.3 9.1 6.9 5.4 2.5 1.9 1.5 TP321 A376 4.1 3.2 1.1 16.1 15.2 14.9 14.6 14.3 14.1 13.9 13.8 13.6 9.1 6.9 5.4 3.2 2.5 1.5 TP321H A312 13.5 12.3 4.1 1.9 1.1 16.1 15.2 14.9 14.6 14.3 14.1 13.9 13.8 13.6 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 TP321H A376 CPH8 17.7 **17.1 16.7 16.3 15.9 15.4** 14.9 14.4 13.9 11.1 8.5 6.5 5.0 3.8 2.9 2.3 1.8 1.3 0.9 0.8 A451 17.7 17.1 16.7 16.3 15.9 15.4 14.9 14.4 13.9 11.3 8.5 CPK20 9.8 7.3 6.0 4.8 3.5 2.4 1.6 1.1 0.8 A451 TP409 A268 TP430Ti A268 CPF10MC A451 A376 16-8-2H 18.5 18.1 17.7 17.1 16.4 15.6 14.3 8.4 4.0 TP405 A268 18.5 18.1 17.7 17.1 16.4 15.6 12.3 8.8 6.4 4.4 2.9 1.8 1.0 TP410 A268 18.5 18.1 17.7 17.1 16.4 15.6 12.0 19.0 9.2 6.5 4.5 3.2 2.4 1.8 TP430 A268 17.7 16.9 16.5 16.2 15.8 15.5 15.2 TP317L A312 9.9 TP310 19.3 18.5 18.2 17.9 17.7 17.4 17.2 16.9 15.9 7.1 5.0 3.6 2.5 0.8 0.5 0.3 0.2 A312 1.5 0.4 18.5 18.2 17.9 17.7 17.4 17.2 16.9 15.9 9.9 310S 7.1 5.0 3.6 2.5 1.5 0.8 0.5 0.4 0.3 0.2 A358 19.3 18.5 18.2 17.9 17.7 17.4 17.2 16.9 15.9 9.9 7.1 5.0 3.6 2.5 1.5 0.8 0.5 0.4 0.3 0.2 **TP310S** A409 TP321 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 9.6 6.9 5.0 3.6 2.6 1.7 1.1 0.8 0.5 0.3 A312 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 9.6 6.9 5.0 3.6 2.6 1.7 1.1 0.8 0.5 0.3 321 A358 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 TP321 16.2 9.6 6.9 5.0 3.6 2.6 1.7 1.1 0.8 0.5 0.3 A376 18.3 17.9 17.5 17.2 16.9 16.7 16.5 6.9 TP321 A409 16.4 16.2 9.6 5.0 3.6 2.6 0.8 0.5 0.3 1.7 1.1 19.4 18.8 18.5 18.2 18.0 17.7 17.5 17.2 16.9 13.8 10.3 7.6 5.5 4.0 3.0 2.2 1.7 1.3 1.0 0.8 TP309 A312 **18.8 18.5 18.2 18.0 17.7** *17.5 17.2 16.9* 13.8 10.3 7.6 5.5 4.0 3.0 2.2 1.7 1.3 1.0 0.8 309S A358 **17.5 16.6 16.2 15.8 15.5 15.2** *14.9 14.6 14.3 12.2* 7.5 CPF8 A451 9.5 6.0 4.8 3.9 3.3 2.7 2.3 2.0 1.7

Nominal	Product	Spec.	Type/	UNS	Class/ Condition/		P-No.		Min. Temp.,	Specified Strength		Min. Temp.			
Composition	Form	No.	Grade	No.	Temper	Size, in.	(5)	Notes	°F (6)	Tensile	Yield	•	200	300	400
Stainless Steel (3 Pipes and Tube		•													
18Cr-10Ni-Cb 18Cr-10Ni-Cb 18Cr-10Ni-Cb 18Cr-10Ni-Cb 18Cr-10Ni-Cb 18Cr-10Ni-Cb 18Cr-10Ni-Cb 18Cr-10Ni-Cb 25Cr-12Ni 25Cr-12Ni	Pipe Pipe Pipe Pipe Pipe Pipe Pipe Pipe	A312 A358 A376 A409 A312 A358 A376 A409 A451	TP347 347 TP347 TP347 TP348 348 TP348 TP348 CPH10 CPH20	\$34700 \$34700 \$34700 \$34700 \$34800 \$34800 \$34800 \$34800 \$34800 \$34800			8 8 8 8 8 8 8	(30)(36) (30)(36) (30)(36) (30)(36) (30)(36) (30)(36) (30)(36) (12)(14)(28)(35)(39) (12)(14)(28)(35)(39)	-425 -425 -425 -425 -325 -325 -325 -325 -325 -325	75 75 75 75 75 75 75 75 70	30 30 30 30 30 30 30 30 30 30	20.0 20.0 20.0 20.0 20.0 20.0 20.0 20.0	20.0 20.0 20.0 20.0 20.0 20.0 20.0 20.0	20.0 20.0 20.0 20.0 20.0 20.0 20.0 19.9	20.0 20.0 20.0 20.0 20.0 20.0 20.0 20.0
25Cr–20Ni 25Cr–20Ni 18Cr–10Ni–Cb 18Cr–10Ni–Ti	Pipe Pipe Smls. & wld. pipe	A312 A358 A451 A312	TP310H 310S CPF8C TP321	S31009 S31008 J92710 S32100		 ≤³/ ₈ thk.	8 8 8	(29)(35)(39) (28)(29)(35)(36) (28) (28)(30)	-325 -325 -325 -425	75 75 70 75	30 30 30 30	20.0 20.0 20.0 20.0	20.0 20.0	20.0 20.0	20.0 20.0 18.6 20.0
18Cr-10Ni-Ti 18Cr-10Ni-Ti 18Cr-10Ni-Ti 18Cr-10Ni-Ti 18Cr-10Ni-Ti	Pipe Pipe Pipe Pipe Pipe Smls. & wld. pipe	A358 A376 A409 A376 A312	321 TP321 TP321 TP321H TP321H	\$32100 \$32100 \$32100 \$32109 \$32109		\leq ³ / ₈ thk. \leq ³ / ₈ thk. \leq ³ / ₈ thk.	8 8 8 8	(28)(30)(36) (28)(30)(36) (28)(30)(36) (30)(36) 	-425 -425 -425 -325 -325	75 75 75 75 75	30 30 30 30 30	20.0 20.0 20.0 20.0 20.0	20.0 20.0 20.0	20.0 20.0	20.0 20.0 20.0 20.0 20.0
16Cr-12Ni-2Mo 16Cr-12Ni-2Mo	Tube Tube	A213 A269	TP316 TP316	S31600 S31600			8	(14)(26)(28)(31)(36) (14)(26)(28)(31)(36)	-425 -425	75 75	30 30	20.0 20.0		20.0 20.0	
16Cr-12Ni-2Mo 16Cr-12Ni-2Mo 16Cr-12Ni-2Mo 16Cr-12Ni-2Mo 16Cr-13Ni-3Mo 18Cr-13Ni-3Mo 16Cr-12Ni-2Mo	Pipe Pipe Pipe Pipe Pipe Pipe Pipe Pipe	A312 A358 A376 A409 A312 A409 A376	TP316 316 TP316 TP316 TP317 TP317 TP316H	\$31600 \$31600 \$31600 \$31600 \$31700 \$31700 \$31609			8 8 8 8 8	(26)(28) (26)(28)(31)(36) (26)(28)(31)(36) (26)(28)(31)(36) (26)(28) (26)(28)(31)(36) (26)(31)(36)	-425 -425 -425 -425 -325 -325 -325	75 75 75 75 75 75 75	30 30 30 30 30 30 30	20.0 20.0 20.0 20.0 20.0 20.0 20.0	20.0 20.0 20.0 20.0 20.0 20.0	20.0 20.0 20.0	19.3 19.3 19.3 19.3 19.3 19.3
16Cr-12Ni-2Mo 18Cr-10Ni-Cb 18Cr-10Ni-Cb	Pipe Pipe Pipe Pipe Pipe Pipe Pipe Pipe	A312 A376 A312 A358 A376 A409 A312 A358 A376 A409	TP316H TP347H TP347 347 TP347 TP347 TP348 348 TP348 TP348	\$31609 \$34709 \$34700 \$34700 \$34700 \$34800 \$34800 \$34800 \$34800			8 8 8 8 8 8 8	(26) (30)(36) (28) (28)(30)(36) (28)(30)(36) (28)(30)(36) (28)(30)(36) (28)(30)(36) (28)(30)(36) (28)(30)(36)	-325 -325 -425 -425 -425 -425 -325 -325 -325 -325	75 75 75 75 75 75 75 75 75	30 30 30 30 30 30 30 30 30 30	20.0 20.0 20.0 20.0 20.0 20.0 20.0 20.0	20.0 20.0 20.0 20.0 20.0 20.0 20.0 20.0	20.0 20.0 20.0 20.0 20.0 20.0 20.0	20.0 20.0 20.0 20.0 20.0 20.0 20.0 20.0
18Cr–10Ni–Cb 18Cr–10Ni–Cb	Pipe Pipe	A312 A312	TP347H TP348H	S34709 S34809			8		-325 -325	75 75	30 30	20.0 20.0	20.0 20.0		20.0 20.0

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Spec. Type/ 500 600 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 No. Stainless Steel (3)(4a) (Cont'd) Pipes and Tubes (2) (Cont'd) 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 TP347 A312 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 347 A358 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 TP347 A376 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 9.1 4.4 3.3 0.9 0.8 TP347 12.1 6.1 2.2 1.5 1.2 A409 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 TP348 A312 19.0 18.3 18.1 16.0 3.3 2.2 20.0 19.3 18.7 18.5 18.2 18.1 12.1 9.1 6.1 4.4 1.5 1.2 0.9 0.8 348 A358 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 TP348 A376 TP348 A409 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 1.8 CPH10 A451 18.9 **18.3** 17.9 17.5 17.0 16.5 16.0 15.4 14.9 11.1 8.5 6.5 5.0 3.8 2.9 2.3 1.3 0.9 0.8 18.3 17.9 17.5 17.0 16.5 16.0 CPH20 15.4 14.9 11.1 8.5 6.5 5.0 3.8 2.9 2.3 1.8 1.3 0.9 0.8 A451 18.5 18.2 17.9 17.7 17.4 17.2 16.9 16.7 13.8 10.3 7.6 5.5 4.0 3.0 2.2 1.7 1.3 1.0 0.8 TP310H A312 18.5 18.2 17.9 17.7 17.4 17.2 16.9 19.3 16.7 13.8 10.3 7.6 5.5 4.0 3.0 2.2 1.7 1.3 1.0 0.8 310S A358 **16.6 16.2 15.8 15.5 15.2** *14.9 14.6 14.3* 14.0 12.1 9.1 2.2 1.5 0.9 CPF8C A451 6.1 4.4 3.3 1.2 0.8 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 TP321 A312 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 321 A358 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 TP321 A376 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 TP321 A409 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 TP321H A376 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 TP321H A312 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 4.1 3.1 2.3 1.7 1.3 TP316 A213 5.5 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 TP316 A269 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 TP316 A312 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 316 A358 TP316 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 98 7.4 5.5 4.1 3.1 2.3 1.7 13 A376 18.0 17.0 16.6 16.1 15.9 15.7 15.4 15.3 7.4 1.3 TP316 16.3 15.6 15.1 12.4 9.8 5.5 4.1 3.1 2.3 1.7 A409 TP317 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 A312 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 TP317 A409 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 TP316H A376 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 TP316H A312 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 TP347H A376 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 1.8 TP347 A312 20.0 19.3 19.0 2.5 1.3 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 347 A358 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 3.2 2.5 1.8 1.3 TP347 A376 4.4 19.3 19.0 18.7 18.5 18.3 18.2 7.9 5.9 3.2 TP347 A409 20.0 18.1 18.1 18.1 17.4 14.1 10.5 4.4 2.5 1.8 1.3 TP348 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 A312 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 348 A358 3.2 TP348 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 2.5 1.8 1.3 A376 19.3 19.0 18.7 18.5 18.3 18.1 18.1 TP348 20.0 18.2 18.1 17.4 14.1 10.5 7.9 5.9 3.2 1.8 A409 4.4 2.5 1.3 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 TP347H A312 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 TP348H 17.4 14.1 10.5 7.9 5.9 3.2 2.5 1.8 A312 4.4 1.3

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Nominal	Product	Spec.	Type/	UNS	Class/ Condition/		P-No.		Min. Temp.,	Specified Strength		Min. Temp.			
Composition	Form	No.	Grade	No.	Temper	Size, in.	(5)	Notes	°F (6)	Tensile	Yield	to 100	200	300	400
Stainless Steel (3)(4a) (Pipes and Tubes (2) (
18Cr-8Ni	Tube	A213	TP304	S30400			8	(14)(26)(28)(31)(36)	-425	75	30	20.0	20.0		
18Cr–8Ni	Tube	A269	TP304	S30400		• • •	8	(14)(26)(28)(31)(36)	-425	75	30	20.0	20.0		
18Cr-8Ni	Pipe	A312	TP304	S30400		• • •	8	(26)(28)	-425	75	30	20.0	20.0		
18Cr–8Ni	Pipe	A358	304	S30400		• • •	8	(26)(28)(31)(36)	-425	75	30	20.0	20.0		
18Cr-8Ni	Pipe	A376	TP304	S30400		• • •	8	(20)(26)(28)(31)(36)	-425	75 75	30	20.0	20.0		
18Cr–8Ni 18Cr–8Ni	Pipe Pipe	A376 A409	TP304H TP304	S30409 S30400		• • •	8 8	(26)(31)(36) (26)(28)(31)(36)	-325 -425	75 75	30 30	20.0 20.0	<i>20.0 20.0</i>		
18Cr–8Ni	Pipe Pipe	A312	TP304H	S30400		• • •	8	(26)	-425 -325	75 75	30	20.0	20.0		
18Cr-12Ni-2Mo	Pipe	A451	CPF8M	J92900			8	(26)(28)	-325 -425	70	30	20.0	20.0		
						• • • •		(20)(20)							
44Fe-25Ni-21Cr-Mo	Tube	A249	• • •	N08904		• • •	45		-325	71	31	20.7	20.7		
44Fe-25Ni-21Cr-Mo	Pipe	A312	• • •	N08904	• • • •	• • •	45	• • •	-325	71	31	20.7	20.7	20.4	18.7
20Cr-Cu	Tube	A268	TP443	S44300			a	(7)(35)	-20	70	40	23.3	23.3	23.3	23.3
27Cr	Tube	A268	TP446-1	S44600			101	(35)	-20	70	40	23.3	23.3	22.5	21.9
12Cr	Wld. pipe	A1053	50	S41003			7	• • •	-20	70	50	23.3	23.3	23.3	22 R
25Cr–8Ni–N		A451	CPE20N	J92802			8	(35)(39)	-325	80	40	26.7	26.7		
	•••					•••									
23Cr-4Ni-Mo-Cu-N	• • •	A789	• • •	S32304		• • •	10H	(25)	-60	87	58	29.0	27.9		
23Cr-4Ni-Mo-Cu-N		A790		S32304		• • •	10H	(25)	-60	87	58	29.0	27.9		
23Cr-4Ni-Mo-Cu-N	Wld. pipe	A928	2304	S32304	• • •	• • •	10H	(25)	-60	87	58	29.0	27.9	26.1	24.7
20Cr-18Ni-6Mo	Pipe	A813		S31254			8	(8)	-325	94	44	29.3	29.3	28.9	26.7
20Cr-18Ni-6Mo	Pipe	A814		S31254			8	(8)	-325	94	44	29.3	29.3	28.9	26.7
13Cr		A426	CPCA15	J91150			6	(10)(35)	-20	90	65	30.0			
20Cr-18Ni-6Mo	Wld pipe	A358		S31254		>3/16	8		-325	95	45	30.0	30.0	30 O	27 A
20Cr-18Ni-6Mo	Wld pipe	A358		S31254		$\leq \frac{3}{16}$	8		-325	100	45	30.0	30.0		
22Cr-5Ni-3Mo-N	• • •	A789	• • •	S31803		• • •	10H	(25)	-60	90	65	30.0	30.0		
22Cr-5Ni-3Mo-N	 Wld nine	A790	• • •	S31803		• • •	10H	(25)	-60	90	65 65	30.0	30.0		
22Cr-5Ni-3Mo-N	Wld pipe	A928	• • •	S31803	• • •	•••	10H		-60	90	65	30.0	30.0	28.9	27.8
20Cr-18Ni-6Mo	Tube	A249	• • •	S31254		$>^{3}/_{16}$ thk.	8	(8)	-325	95	45	30.0	30.0	29.5	27.3
20Cr-18Ni-6Mo	Tube	A249	• • •	S31254		$\leq \frac{3}{16}$ thk.	8	(8)	-325	98	45	30.0	30.0	29.5	27.3
20Cr-18Ni-6Mo	Pipe	A312	• • •	S31254		$>_{16}^{3}$ thk.	8	(8)	-325	95	45	30.0	30.0		
20Cr-18Ni-6Mo	Pipe	A312	• • •	S31254	• • •	$\leq \frac{3}{16}$ thk.	8	(8)	-325	98	45	30.0	30.0	29.5	27.3
26Cr-4Ni-Mo		A789		S32900			10H	(25)	-20	90	70	30.0			
26Cr-4Ni-Mo		A790		S32900			10H	(25)	-20	90	70	30.0			
46Eo 24Ni 21Cr 6Mo Cu N	Cmlc 0	N212		N00247		\ 3/			225	O.E.	/ ₁ E	20.0	20.0	20.0	20 6
46Fe-24Ni-21Cr-6Mo-Cu-N		A312	• • •	N08367	• • •	>3/16	45	(26)	-325	95	45	30.0	30.0	29.9	20.0
46Fe-24Ni-21Cr-6Mo-Cu-N	wld. pipe	: A358		N08367		>3/16	45	(26)	-325	95	45	30.0	30.0	20 0	28 6
46Fe-24Ni-21Cr-6Mo-Cu-N		A813		N08367		$\frac{3}{16}$	45	(26)	-325 -325	95	45	30.0	30.0		
46Fe-24Ni-21Cr-6Mo-Cu-N		A814		N08367		$\frac{3}{16}$	45	(26)	-325 -325	95	45	30.0	30.0		
46Fe-24Ni-21Cr-6Mo-Cu-N		A312		N08367		$\frac{2}{16}$	45	(26)	-325	100	45		30.0		
401 C-24111-21 CI-01110-Cu-11	wld. pipe		•••	וטכטטוו	• • • •	≥/16	4)	(20)	-525	100	4)	50.0	50.0	50.0	29.0
46Fe-24Ni-21Cr-6Mo-Cu-N		: A358		N08367		≤ ³ / ₁₆	45	(26)	-325	100	45	30.0	30.0	30 N	29 6
46Fe-24Ni-21Cr-6Mo-Cu-N				N08367		≤ ³ / ₁₆	45	(26)	-325 -325	100	45	30.0	30.0		
46Fe-24Ni-21Cr-6Mo-Cu-N		A814		N08367		$\leq \frac{16}{16}$	45	(26)	-325 -325	100			30.0		
21Cr-5Mn-1½Ni-Cu-N	Tube		• • •	S32101		>3/16	10H		-20	94	65		31.3		
21Cr-5Mn-1 ¹ / ₂ Ni-Cu-N	Pipe			S32101		>3/16	10H	• •	-20	94	65		31.3		
22Cr-5Ni-3Mo-N	Tube	A789		S32205		• • •	10H		-60	95	70		31.7		
22Cr-5Ni-3Mo-N	Pipe	A790		S32205			10H		-60	95	70	31.7	31.7		
21Cr-5Mn-1½Ni-Cu-N	Tube	A789	• • •	S32101		$\leq \frac{3}{16}$	10H		-20	101	77		33.7		
21Cr-5Mn-1 ¹ / ₂ Ni-Cu-N	Pipe	A790	• • •	S32101		$\leq \frac{3}{16}$	10H	(25)	-20	101	77	33.7	33.7	32.1	31.0

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ Spec. 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 No. Stainless Steel (3)(4a) (Cont'd) Pipes and Tubes (2) (Cont'd) 17.5 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 7.7 6.1 4.7 3.7 2.9 2.3 1.8 1.4 TP304 A213 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 7.7 6.1 4.7 3.7 2.9 2.3 1.8 1.4 TP304 A269 A312 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 7.7 6.1 4.7 3.7 2.9 2.3 1.8 1.4 TP304 16.6 16.2 15.8 14.9 14.0 9.8 7.7 6.1 4.7 3.7 2.9 304 15.5 15.2 14.6 14.3 12.4 2.3 1.8 1.4 A358 17.5 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 7.7 6.1 4.7 3.7 2.9 2.3 1.8 1.4 TP304 A376 15.8 15.2 14.9 14.3 14.0 12.4 9.8 7.7 2.9 TP304H 16.6 16.2 15.5 14.6 6.1 4.7 3.7 2.3 1.8 1.4 A376 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 7.7 6.1 4.7 3.7 2.9 2.3 1.8 1.4 TP304 A409 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 9.8 7.7 4.7 3.7 29 TP304H A312 12.4 6.1 2.3 1.8 1.4 15.0 14.7 14.4 14.2 14.1 13.9 13.7 13.4 13.1 CPF8M 15.8 11.5 8.9 6.9 5.4 4.3 3.4 2.8 2.3 1.9 1.6 A451 17.1 A249 17.1 A312 23.3 23.3 14.6 12.5 10.7 9.2 7.9 5.9 4.0 TP443 A268 2.5 20.9 20.6 20.2 19.7 19.1 18.4 17.5 16.4 TP446-1 15.1 A268 22.1 21.2 50 A1053 26.7 26.7 26.7 26.7 26.7 26.7 CPE20N 26.7 A451 22.9 19.2 A789 22.9 19.2 A790 22.9 19.2 2304 A928 25.2 24.1 23.8 23.6 23.4 23.2 23.0 A813 25.2 24.1 23.8 23.6 23.4 23.2 23.0 A814 CPCA15 A426 24.7 24.3 24.1 23.9 23.7 22.8 A358 24.7 24.3 24.1 23.9 23.7 22.8 A358 A789 27.2 26.9 A790 27.2 26.9 A928 25.8 24.7 24.3 24.1 23.9 23.7 23.6 A249 25.8 24.7 24.3 24.1 23.9 23.7 23.6 A249 25.8 24.7 24.3 24.1 23.9 23.7 23.6 A312 25.8 24.7 24.3 24.1 23.9 23.7 23.6 A312 . . . A789 A790 . . . 27.7 26.2 25.7 25.1 24.7 24.3 A312 26.2 25.7 25.1 24.7 24.3 A358 26.2 25.7 25.1 24.7 24.3 A813 26.2 25.7 25.1 24.7 24.3 A814 26.2 25.7 25.1 24.7 24.3 A312 27.7 26.2 25.7 25.1 24.7 24.3 A358 26.2 25.7 25.1 24.7 24.3 A813 27.7 26.2 25.7 25.1 24.7 24.3 A814 28.5 28.5 A789 28.5 28.5 A790 28.7 28.4 . . . 2205 A789 2205 A790 . . . 30.9 30.9 A789 30.9 A790

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Nominal	Product	Spec.	Type/	UNS	Class/ Condition/		P-No.		Min. Temp.,	Specified Strength		Min. Temp.			
Composition	Form	No.	Grade	No.	Temper	Size, in.	(5)	Notes	°F (6)	Tensile	Yield	•	200	300	400
Stainless Steel (3)(4a) Pipes and Tubes (2)															
21Cr-3 ¹ / ₂ Ni-1 ³ / ₄ Mo-N 21Cr-3 ¹ / ₂ Ni-1 ³ / ₄ Mo-N 22Cr-5Ni-3Mo-N 21Cr-3 ¹ / ₂ Ni-1 ³ / ₄ Mo-N 21Cr-3 ¹ / ₂ Ni-1 ³ / ₄ Mo-N 25Cr-8Ni-3Mo- W-Cu-N 25Cr-8Ni-3Mo- W-Cu-N 29Cr-6.5Ni-2Mo-N 29Cr-6.5Ni-2Mo-N 24Cr-17Ni-6Mn- 4 ¹ / ₂ Mo-N 25Cr-7Ni-4Mo-N	Wld pipe Wld pipe Wld. pipe Tube Pipe Smls. & wld. tube Smls. &	A928 A789 A928 A789 A790 A789 A790 A358	2205	\$32003 \$32003 \$32205 \$32003 \$32760 \$32760 \$32906 \$32906 \$34565 \$32750		 > ³ / ₁₆ ≤ ³ / ₁₆ ≤ ³ / ₁₆ ≥0.40 thk. ≥0.40 thk.	10H 10H 10H 10H 10H	(25) (25) (25) (25) (25) (25) (25) (26) (27) (28) (29) (29)	-60 -60 -60 -60 -60 -60 -60 -325 -60	95 95 95 100 100 109 109 109 115 116	65 65 70 70 80 80 80 60	31.7 31.7 31.7 33.3 33.3 36.3 36.3 36.3 38.3 38.7	31.7 32.3 32.3 35.9 35.9 36.3 36.3 38.1	28.9 30.6 30.4 30.4 34.4 34.0 35.8 36.4	28.6 29.4 30.1 30.1 34.0 34.0 33.5 33.5 34.5
25Cr-7Ni-4Mo-N 29Cr-6.5Ni-2Mo-N 29Cr-6.5Ni-2Mo-N	wld. pipe Wld. pipe Tube Pipe	A928 A789 A790		\$32750 \$32906 \$32906		<0.40 thk. <0.40 thk.	10H 10H	(25) (25)	-60 -60 -60	116 116 116	80 94	38.7 38.7 38.7	38.5 38.6	36.4 36.8	
Plates and Sheet	S														
18Cr-11Ni		A240	305	S30500			8	(26)(36)(39)	-325	70	25	16.7			
12Cr-Al		A240	405	S40500			7	(35)	-20	60	25	16.7	15.3	14.8	14.5
18Cr-8Ni 16Cr-12Ni-2Mo		A240 A240	304L 316L	S30403 S31603			8	(36) (36)	-425 -425	70 70	_	16.7 16.7	16.7 16.7		15.8 15.7
18Cr-Ti		A240	439	S43035				(35)	-20	60	30	20.0			
18Cr-8Ni	• • •	A240	302	S30200		• • •	8	(26)(36)	-325	75	30	20.0			18.6
12Cr-1Ni 12Cr-1Ni		A1010 A1010		S41003 S41003			7 7		-20 -20	66 70		22.0 23.3	22.0 23.3		
13Cr 13Cr 15Cr 17Cr		A240 A240 A240 A240	429	S41008 S41000 S42900 S43000			7 6 6 7	(35)(50) (35) (35) (35)	-20 -20 -20 -20	60 65 65	30 30	20.0 20.0 20.0 20.0	18.4	17.8 17.8	17.4 17.4
18Cr-13Ni-3Mo		A240	317L	S31703			8	(36)	-325	75	30	20.0	20.0	20.0	18.9
25Cr-20Ni		A240	3105	S31008			8	(28)(31)(35)(36)	-325	75	30	20.0	20.0	20.0	20.0
18Cr-10Ni-Ti		A240	321	S32100			8	(30)(36)	-325	75	30	20.0	20.0	20.0	20.0
23Cr-12Ni		A240	3095	S30908			8	(28)(35)(36)	-325	75	30	20.0	20.0	20.0	20.0
18Cr-10Ni-Cb 18Cr-10Ni-Cb		A240 A240		S34700 S34800			8 8	(36) (36)	-425 -325	75 75					20.0
25Cr-20Ni		A240	310S	S31008			8	(28)(29)(35)(36)	-325	75	30	20.0	20.0	20.0	20.0
18Cr-10Ni-Ti 18Cr-10Ni-Ti		A240 A240		S32100 S32109			8 8	(28)(30)(36) (36)	-325 -325	75 75		20.0 20.0	20.0 20.0		
16Cr-12Ni-2Mo 18Cr-13Ni-3Mo		A240 A240		S31600 S31700			8 8	(26)(28)(36) (26)(28)(36)	-425 -325	75 75		20.0 20.0			19.3 19.3

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ Spec. 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 Grade No. Stainless Steel (3)(4a) (Cont'd) Pipes and Tubes (2) (Cont'd) 28.6 28.6 28.6 28.6 28.6 28.6 A928 . . . 28.7 28.4 28.3 2205 A928 30.1 30.1 30.1 A789 30.1 30.1 30.1 A928 . . . 34.0 34.0 A789 34.0 34.0 A790 33.0 33.0 A789 33.0 33.0 A790 33.8 33.2 33.1 32.7 32.4 32.0 A358 A789 34.5 34.3 2507 A790 34.5 34.3 2507 A928 A789 A790 Plates and Sheets 305 A240 14.3 14.0 13.8 13.5 13.1 12.6 12.0 11.3 8.4 4.0 405 A240 14.0 13.7 13.5 13.3 13.0 12.8 12.6 12.3 12.0 6.3 5.1 4.0 3.2 2.6 2.1 1.7 1.0 0.9 304L A240 1.1 14.0 13.7 13.5 13.2 12.9 12.7 12.4 12.1 11.8 10.8 10.2 8.8 6.4 4.7 3.5 2.5 1.8 1.3 1.0 316L A240 439 A240 17.5 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 302 A240 14.0 20.0 40 A1010 22.1 21.2 A1010 50 16.8 16.6 16.2 15.7 15.1 14.4 12.3 8.8 6.4 4.4 2.9 1.8 1.0 410S A240 . . . 16.8 16.6 16.2 15.7 15.1 14.4 12.3 8.8 6.4 4.4 2.9 1.8 1.0 410 A240 17.2 16.8 16.6 16.2 15.7 15.1 14.4 12.0 9.2 6.5 4.5 3.2 A240 2.4 1.8 429 16.6 16.2 15.7 15.1 14.4 9.2 3.2 430 A240 17.2 16.8 12.0 6.5 4.5 2.4 1.8 16.5 16.2 15.8 15.5 A240 16.9 15.2 317L 18.2 17.9 17.7 17.4 17.2 16.9 15.9 9.9 7.1 2.5 0.3 310S A240 5.0 3.6 1.5 0.8 0.4 0.2 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 9.6 6.9 5.0 3.6 2.6 1.7 1.1 0.8 0.5 0.3 321 A240 18.8 18.5 18.2 18.0 **17.7** *17.5* 17.2 16.9 13.8 10.3 7.6 5.5 4.0 3.0 2.2 1.7 1.3 1.0 0.8 3095 A240 A240 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 347 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 4.4 3.3 0.9 348 A240 6.1 2.2 1.5 1.2 0.8 18.5 18.2 17.9 17.7 17.4 16.9 13.8 10.3 7.6 4.0 3.0 2.2 310S A240 19.3 17.2 16.7 5.5 1.7 1.3 1.0 0.8 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 3.2 2.5 1.9 321 A240 4.1 1.5 1.1 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 2.5 1.9 1.5 321H A240 3.2 1.1 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 4.1 3.1 2.3 1.7 1.3 316 A240 5.5 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 317 A240

Specified Min. Min Min. Class/ Strength, ksi Nominal Product Spec. UNS Condition/ P-No. Temp., Temp. Type/ °F (6) Composition Form No. Grade Temper Size, in. (5) Notes Tensile Yield to 100 200 300 400 Stainless Steel (3)(4a) (Cont'd) Plates and Sheets (Cont'd) 18Cr-10Ni-Cb A240 347 S34700 8 (28)(36)-425 75 30 20.0 20.0 20.0 20.0 . . . 18Cr-10Ni-Cb A240 348 S34800 8 (28)(36)-325 75 30 20.0 20.0 20.0 20.0 18Cr-8Ni A240 304 S30400 8 (26)(28)(36) -425 75 30 20.0 20.0 20.0 18.6 904L N08904 71 20.7 20.7 20.4 18.7 44Fe-25Ni-21Cr-Mo A240 . . . 45 -32531 (25)23Cr-4Ni-Mo-Cu-N 2304 10H 87 58 27.9 26.1 24.7 A240 S32304 -6029.0 22Cr-5Ni-3Mo-N A240 S31803 10H (25)-60 90 65 30.0 30.0 28.9 27.8 16Cr-4Ni-6Mn 201LN -325 95 45 30.0 27.6 24.7 23.4 A240 S20153 $>^{3}/_{16}$ thk. 20Cr-18Ni-6Mo A240 S31254 8 (8) -325 95 45 30.0 30.0 29.5 27.3 $\leq \frac{3}{16}$ thk. 20Cr-18Ni-6Mo A240 . . . S31254 8 (8) -325 98 45 30.0 30.0 29.5 27.3 46Fe-24Ni-21Cr-6Mo- Plate >3/16 30.0 30.0 29.9 28.6 N08367 45 (26)-32595 45 A240 . . . Cu-N46Fe-24Ni-21Cr-6Mo- Sheet & A240 N08367 $\leq \frac{3}{16}$ 45 (26)-325 100 45 30.0 30.0 30.0 **29.6** strip Cu-N 21Cr-5Mn-1¹/₂Ni-Cu-N ... $>^3/_{16}$ thk. 10H A240 S32101 (25)-2094 65 31.3 31.3 29.8 28.5 21Cr-5Mn-1¹/₂Ni-Cu-N ... S32101 $\leq^3/_{16}$ thk. 10H 101 77 33.7 33.7 32.1 31.0 A240 (25)-20. . . 22Cr-5Ni-3Mo-N A240 2205 S32205 10H (25)-60 95 65 31.7 31.7 30.6 29.4 . . . $>^3/_{16}$ 21Cr-3¹/₂Ni-1³/₄Mo-N 10H (25)95 65 31.7 30.7 28.9 28.6 A240 S32003 -60. $21Cr-3\frac{1}{2}Ni-1\frac{3}{4}Mo-N$ A240 S32003 $\leq^3/_{16}$ 10H (25)-60 100 70 33.3 32.3 30.4 30.1 . . . 29Cr-6.5Ni-2Mo-N A240 S32906 ≥0.40 10H (25)-60 109 80 36.3 36.3 34.5 33.5 thk. 29Cr-6.5Ni-2Mo-N A240 S32906 < 0.40 10H (25)-60 116 94 38.7 38.6 36.8 35.6 thk. 25Cr-8Ni-3Mo-W-Cu-N... A240 S32760 10H (25)-60 109 80 36.3 36.3 34.8 34.0 . . . 25Cr-7Ni-4Mo-N A240 2507 S32750 10H (25)-60 116 80 38.7 38.5 36.4 35.1 Forgings and Fittings 18Cr-13Ni-3Mo A182 F317L S31703 ≤5 thk. 8 (9)(21a) -325 70 25 16.7 16.7 16.7 15.7 18Cr-8Ni A182 F304L S30403 8 (9)(21a) -425 70 25 16.7 16.7 15.8 18Cr-8Ni A403 WP304L S30403 8 (32)(37)-425 70 25 16.7 16.7 16.7 15.8 F316L S31603 8 70 25 16Cr-12Ni-2Mo A182 (9)(21a) -42516.7 16.7 16.7 **15.7** . . . 16Cr-12Ni-2Mo WP316L 70 25 16.7 16.7 15.7 A403 S31603 8 (32)(37)-42516.7 20Ni-8Cr F10 80 20.0 A182 S33100 8 (26)(28)(39) -32530 18Cr-13Ni-3Mo A403 WP317L S31703 8 -325 75 30 20.0 20.0 20.0 18.9 (32)(37). . . F310H 25Cr-20Ni A182 S31009 8 (9)(35)(39) -325 75 30 20.0 20.0 20.0 20.0 25Cr-20Ni A403 WP310 S31008 8 (28)(32)(35)(37)(39) -325 75 30 20.0 20.0 20.0 20.0 18Cr-10Ni-Ti F321 S32100 8 (9)(21)-325 75 30 20.0 20.0 20.0 20.0 A182 18Cr-10Ni-Ti A403 WP321 S32100 8 (32)(37)-32575 30 20.0 20.0 20.0 **20.0** A403 WP309 S30900 8 75 20.0 20.0 20.0 20.0 23Cr-12Ni (28)(32)(35)(37)(39) -32530 25Cr-20Ni A182 F310H S31009 8 (9)(21)(29)(35)(39) -325 75 30 20.0 20.0 20.0 20.0 WP310 (28)(29)(32)(35) 75 30 20.0 20.0 20.0 20.0 25Cr-20Ni A403 S31008 -3258 (37)(39)18Cr-10Ni-Cb A182 F347 8 (9)(21)75 30 20.0 20.0 20.0 20.0 S34700 -425. 75 18Cr-10Ni-Cb A403 WP347 S34700 8 (32)(37)-425 30 20.0 20.0 20.0 20.0 18Cr-10Ni-Cb F348 S34800 (9)(21)-325 75 30 20.0 20.0 20.0 20.0 A182 8 18Cr-10Ni-Cb WP348 30 20.0 20.0 20.0 A403 S34800 8 (32)(37)-32575 20.0

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ Spec. 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 Grade No. Stainless Steel (3)(4a) (Cont'd) Plates and Sheets (Cont'd) 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 4.4 3.2 2.5 1.8 1.3 347 A240 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 10.5 7.9 5.9 4.4 3.2 2.5 1.3 348 A240 17.5 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 6.1 4.7 3.7 2.9 2.3 1.8 1.4 304 A240 17.1 904L A240 22.9 2304 19.2 A240 27.2 26.9 A240 22.8 22.6 22.3 21.8 21.5 A240 201LN 24.7 24.3 24.1 23.9 23.7 23.6 A240 . . . 24.7 24.3 24.1 23.9 23.7 23.6 A240 26.2 25.7 25.1 24.7 A240 24.3 27.7 26.2 25.7 25.1 24.7 24.3 A240 28.5 28.5 A240 30.9 A240 28.4 2205 A240 28.6 28.6 A240 30.1 30.1 A240 . . . 33.0 33.0 A240 A240 35.2 35.2 33.9 A240 34.5 34.3 2507 A240 Forgings and Fittings 14.8 14.0 13.7 13.5 13.2 12.9 12.7 F317L A182 14.0 13.7 13.5 13.3 13.0 12.8 F304L 12.6 12.3 12.0 6.3 5.1 4.0 3.2 2.6 2.1 1.7 1.1 1.0 0.9 A182 14.0 13.7 13.5 13.3 13.0 12.8 12.6 12.3 12.0 6.3 5.1 4.0 3.2 2.6 2.1 1.7 1.1 1.0 0.9 WP304L A403 14.8 14.0 13.7 13.5 13.2 12.9 12.7 12.4 12.1 2.5 11.8 10.8 10.2 8.8 6.4 4.7 3.5 1.8 1.3 1.0 F316L A182 14.0 13.7 13.5 13.2 12.9 12.7 12.4 12.1 WP316L 11.8 10.8 10.2 8.8 6.4 4.7 3.5 2.5 1.8 1.3 1.0 A403 F10 A182 WP317L 17.7 16.9 16.5 16.2 15.8 15.5 15.2 A403 18.2 17.9 17.7 17.4 17.2 16.9 15.9 9.9 7.1 5.0 3.6 2.5 1.5 0.8 0.5 0.4 0.3 0.2 F310H A182 18.5 18.2 17.9 17.7 17.4 17.2 16.9 9.9 7.1 5.0 3.6 2.5 1.5 0.8 0.5 0.4 0.3 0.2 WP310 A403 18.3 17.9 17.5 17.2 16.9 16.7 16.2 9.6 6.9 5.0 3.6 2.6 1.1 0.8 0.5 F321 16.5 16.4 1.7 0.3 A182 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 9.6 6.9 5.0 3.6 2.6 1.7 1.1 0.8 0.5 0.3 WP321 A403 **18.8 18.5 18.2 18.0 17.7** *17.5 17.2 16.9* 13.8 WP309 10.3 7.6 5.5 4.0 3.0 2.2 1.7 1.3 1.0 0.8 A403 19.3 18.5 18.2 17.9 17.7 17.4 17.2 16.9 16.7 13.8 10.3 7.6 5.5 4.0 3.0 2.2 1.7 1.3 1.0 0.8 F310H A182 WP310 18.5 18.2 17.9 17.7 17.4 17.2 16.9 13.8 10.3 7.6 5.5 4.0 3.0 1.3 1.0 A403 16.7 2.2 1.7 0.8 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 2.2 A182 12.1 9.1 6.1 3.3 1.5 1.2 0.9 0.8 F347 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 WP347 A403 9.1 3.3 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 6.1 4.4 2.2 1.5 1.2 0.9 0.8 F348 A182 WP348 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 0.9 0.8 A403

Specified Min. Min Min. Class/ Strength, ksi Nominal Product Spec. Type/ UNS Condition/ P-No. Temp.. Temp. Composition Form No. Grade Temper Size, in. (5) Notes °F (6) Tensile Yield to 100 200 300 400 Stainless Steel (3)(4a) (Cont'd) Forgings and Fittings (Cont'd) 18Cr-10Ni-Ti A182 F321 S32100 (9)(21)(28)(30) -325 75 30 20.0 20.0 20.0 20.0 . . . 18Cr-10Ni-Ti A182 F321H S32109 8 (9)(21)-32575 30 20.0 20.0 20.0 20.0 18Cr-10Ni-Ti A403 WP321 S32100 8 (28)(30)(32)(37) -32575 30 20.0 20.0 20.0 20.0 18Cr-10Ni-Ti A403 WP321H S32109 8 75 30 20.0 20.0 20.0 20.0 (32)(37)-325WP316H S31609 8 20.0 16Cr-12Ni-2Mo A403 (26)(32)(37)-32575 30 20.0 20.0 19.3 . . . 16Cr-12Ni-2Mo F316H 20.0 20.0 20.0 19.3 A182 S31609 8 (9)(21)(26) -32575 30 18Cr-10Ni-Cb WP347H A403 S34709 8 (32)(37)-32575 30 20.0 20.0 20.0 20.0 18Cr-10Ni-Ch 30 20.0 20.0 20.0 20.0 A182 F347 \$34700 8 (9)(21)(28) -425 75 18Cr-10Ni-Cb A403 WP347 S34700 8 -425 75 30 20.0 20.0 20.0 20.0 (28)(32)(37). 18Cr-10Ni-Cb A182 F348 S34800 8 (9)(21)(28) -32575 30 20.0 20.0 20.0 20.0 18Cr-10Ni-Cb A403 WP348 S34800 8 (28)(32)(37)-32575 30 20.0 20.0 20.0 20.0 75 20.0 20.0 20.0 20.0 18Cr-10Ni-Cb A182 F347H S34709 (9)(21)-32530 . . . 18Cr-10Ni-Cb F348H (9)(21)75 30 20.0 20.0 20.0 20.0 A182 S34809 -325. 16Cr-12Ni-2Mo A182 F316 S31600 8 (9)(21)(26)(28) -325 75 30 20.0 20.0 20.0 19.3 16Cr-12Ni-2Mo A403 WP316 S31600 8 (26)(28)(32)(37) -425 75 30 20.0 20.0 20.0 19.3 18Cr-13Ni-3Mo A403 WP317 S31700 8 (26)(28)(32)-32575 30 20.0 20.0 20.0 **19.3** . . . 18Cr-8Ni A182 F304 S30400 (9)(21)(26)(28) -425 75 30 20.0 20.0 20.0 18.6 18Cr-8Ni A403 WP304 S30400 8 (26)(28)(32)(37) -425 75 30 20.0 20.0 20.0 18.6 WP304H 8 75 30 20.0 18Cr-8Ni A403 S30409 (26)(32)(37)-325 20.0 20.0 18.6 18Cr-8Ni A182 F304H S30409 8 (9)(21)(26) -325 75 30 20.0 20.0 20.0 18.6 44Fe-25Ni-21Cr-Mo A182 F904L N08904 45 -325 71 31 20.7 20.7 20.4 18.7 13Cr S41000 A182 F6a 6 (35)-20 70 40 23.3 23.3 22.9 22.5 1 . . . 13Cr A182 F6a S41000 2 6 (35)-2085 55 28.3 28.3 27.8 27.3 . . . 20Cr-18Ni-6Mo F44 S31254 8 (8) 29.3 A182 -32594 44 29.3 28.9 26.7 20Cr-18Ni-6Mo A403 WPS31254 S31254 (8) -325 94 44 29.3 29.3 28.9 26.7 8 . . . 20Cr-18Ni-6Mo A403 CRS31254 S31254 8 (8) -32594 44 29.3 29.3 28.9 26.7 23Cr-4Ni-Mo-Cu-N A182 F68 S32304 (25)-60 87 58 29.0 27.9 26.1 24.7 10H 22Cr-5Ni-3Mo-N A182 F51 S31803 10H (25)-60 90 65 30.0 30.0 28.9 27.8 22Cr-5Ni-3Mo-N A815 WPS31803 S31803 10H (25)-60 90 65 30.0 30.0 28.9 27.8 22Cr-5Ni-3Mo-N A815 CRS31803 S31803 10H (25)-60 90 65 30.0 30.0 28.9 27.8 46Fe-24Ni-21Cr-6Mo- Forgings A182 F62 N08367 (26)-325 95 45 30.0 30.0 29.9 28.6 45 Cu-N WP6XN 46Fe-24Ni-21Cr-6Mo- Fittings A403 N08367 30.0 30.0 29.9 28.6 45 (26)-32595 45 Cu-N 46Fe-24Ni-21Cr-6Mo- Fittings A403 CR6XN N08367 (26)30.0 30.0 29.9 28.6 45 -32595 45 Cu-N $21Cr-5Mn-1\frac{1}{2}Ni-Cu-N \dots$ (25)31.3 29.8 28.5 A815 S32101 10H -2094 65 31.3 22Cr-5Ni-3Mo-N A182 F60 S32205 10H (25)-6095 65 31.7 31.7 30.6 29.4 22Cr-5Ni-3Mo-N A815 2205 S32205 10H (25)-60 95 65 31.7 31.7 30.6 29.4 80 25Cr-8Ni-3Mo-W-Cu-N... A182 S32760 10H (25)-60109 36.3 36.3 34.8 34.0 25Cr-8Ni-3Mo-W-Cu-N... A815 S32760 10H (25)-60 109 80 36.3 36.3 34.8 34.0 S41000 -20 110 85 13Cr A182 F6a 3 6 (35)36.7 13Cr-¹/₂Mo A182 F6b S41026 (35)110-135 90 36.7 6 . . . 25Cr-7Ni-4Mo-N F53 S32750 (25)-60 80 38.7 38.5 36.4 35.1 **Forgings** A182 10H 116 . . . 25Cr-7Ni-4Mo-N **Fittings** A815 WPS32750 S32750 10H (25)-60 116 80 38.7 38.5 36.4 35.1 25Cr-7Ni-4Mo-N **Fittings** CRS32750 80 A815 S32750 10H (25)-60116 38.7 38.5 36.4 35.1 . . . 13Cr A182 F6a S41000 4 6 (35)-20130 110 43.3

...

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ Spec. 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 No. Stainless Steel (3)(4a) (Cont'd) Forgings and Fittings (Cont'd) 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 F321 A182 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 F321H A182 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 WP321 A403 18.3 6.9 1.5 WP321H 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 5.4 4.1 3.2 2.5 1.9 1.1 A403 WP316H 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 A403 16.1 15.9 18.0 17.0 16.6 16.3 15.7 15.6 15.4 15.3 15.1 12.4 7.4 5.5 3.1 1.7 F316H A182 9.8 4.1 2.3 1.3 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 WP347H A403 18.3 18.2 18.1 18.1 18.1 5.9 3.2 20.0 19.3 19.0 18.7 18.5 17.4 14.1 10.5 7.9 4.4 2.5 1.8 1.3 F347 A182 19.3 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 5.9 WP347 A403 20.0 19.0 14.1 10.5 7.9 4.4 3.2 2.5 1.8 1.3 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 F348 A182 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 WP348 A403 19.3 **19.0 18.7 18.5** 18.3 18.2 18.1 18.1 18.1 17.4 7.9 5.9 4.4 3.2 2.5 1.8 1.3 F347H A182 19.3 **19.0 18.7** 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.3 F348H A182 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 F316 A182 16.3 15.9 15.7 15.3 15.1 7.4 WP316 A403 17.0 16.6 16.1 15.6 15.4 12.4 9.8 5.5 4.1 3.1 2.3 1.7 1.3 18.0 17.0 16.6 16.3 16.1 15.9 15.7 15.6 15.4 15.3 15.1 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 WP317 A403 **16.6** 16.2 15.8 15.5 15.2 14.9 12.4 9.8 7.7 6.1 4.7 3.7 2.9 2.3 1.4 F304 A182 **16.6** 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 6.1 3.7 2.9 1.8 WP304 A403 7.7 4.7 2.3 1.4 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 7.7 6.1 4.7 3.7 2.9 2.3 1.8 1.4 WP304H A403 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 7.7 4.7 3.7 2.9 2.3 1.8 1.4 F304H A182 F904L A182 17.1 22.1 21.6 21.2 20.6 20.0 19.2 17.2 12.3 F6a Cl. 1 A182 8.8 6.4 26.9 26.2 25.7 25.1 24.3 23.3 17.2 12.3 8.8 4.4 2.9 1.8 1.0 F6a Cl. 2 A182 6.4 24.1 23.8 23.6 23.4 23.2 23.0 F44 A182 24.1 23.8 23.6 23.4 23.2 23.0 WPS31254 A403 24.1 23.8 23.6 23.4 23.2 23.0 CRS31254 A403 22.9 A182 19.2 F68 27.2 26.9 F51 A182 27.2 26.9 WPS31803 A815 27.2 26.9 CRS31803 A815 26.2 25.7 25.1 24.7 24.3 A182 . . . 26.2 25.7 25.1 24.7 24.3 WP6XN 27.7 A403 CR6XN 26.2 25.7 25.1 24.7 24.3 A403 28.5 28.5 A815 28.7 28.4 A182 F60 28.7 28.4 A815 2205 A182 33.9 33.9 33.9 33.9 A815 . . . F6a Cl. 3 A182 . . . F6b A182 34.3 F53 A182 . . . 34.5 34.3 WPS32750 A815 34.3 CRS32750 A815 F6a Cl. 4 A182

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Nominal	Product	Spec.	Type/	UNS	Class/ Condition/		P-No.		Min. Temp.,	Specified Strength		Min. Temp.			
Composition	Form	No.	Grade	No.	Temper	Size, in.	(5)	Notes	°F (6)	Tensile	Yield	•	200	300	400
Stainless Steel (3)(4a) (Bar	(Cont'd)														
18Cr-8Ni		A479	304	S30400			8	(26)(28)(31)	-425	75	30	20.0	20.0	20.0	18.6
18Cr-8Ni		A479	304H	S30409			8	(26)(31)	-325	75	30	20.0			18.7
18Cr-8Ni		A479	304L	S30403			8	(31)	-425	70	25	16.7			15.8
16Cr-12Ni-2Mo		A479	316	S31600			8	(26)(28)(31)	-325	75	30	20.0			19.3
16Cr-12Ni-2Mo		A479	316H	S31609			8	(26)(31)	-325	75	30	20.0			19.3
16Cr-12Ni-2Mo		A479	316L	S31603			8	(31)	-425	70	25	16.7			15.5
18Cr-10Ni-Ti			221	S32100			0	•	225	75	20	20.0	20.0	20.0	20.0
18Cr-10Ni-Ti	• • •	A479 A479	321 321	S32100		• • •	8	(28)(30)	-325	75 75	30 30	20.0 20.0			20.0
18Cr-10Ni-Ti	• • •		321 321H	S32100		• • •	8		−325 −325	75 75	30	20.0			20.0
18Cr-10Ni-Cb	• • •	A479 A479	347	S34700		• • •	8	• • •	-325 -425	75 75	30	20.0			20.0
18Cr-10Ni-Cb	• • •	A479	347	S34700		• • •	8	(28)(30)	-425 -425	75 75	30	20.0			20.0
18Cr-10Ni-Cb	• • •	A479	347 347H	S34700		• • •	8		-325	75 75	30	20.0			20.0
	• • •					• • •		•••							
44Fe-25Ni-21Cr-Mo	• • •	A479	904L	N08904		• • •	45	•••	-325	71	31	20.7			18.7
22Cr-5Ni-3Mo-N		A479		S31803		• • •	10H	(25)	-60	90	65	30.0			27.8
20Cr-18Ni-6Mo		A479		S31254		• • •	8	(8)	-325	95	45	30.0			27.3
46Fe-24Ni-21Cr-6Mo-Cu-N		A479		N08367		• • •	45	(26)	-325	95	45	30.0			28.6
21Cr-5Mn-1.5Ni-Cu-N	• • •	A479	• • •	S32101		• • •	10H	(25)	-20	94	65	31.3			28.5
22Cr-5Ni-3Mo-N	• • •	A479	2205	S32205	• • •	• • •	10H	(25)	-60	95	65	31.7	31.7	30.6	29.4
22Cr-13Ni-5Mn		A479	XM-19	S20910			8		-20	100	55	33.3	33.1	31.4	30.4
29Cr-6.5Ni-2Mo-N		A479		S32906			10H	(25)	-60	109	80	36.3	36.3	34.5	33.5
25Cr-7Ni-4Mo-N	• • •	A479	• • •	S32750	• • • •	≤2 thk.	10H	(25)	-60	116	80	38.7	38.5	36.4	35.1
Castings (2)															
29Ni-20Cr-3Cu-2Mo		A351	CN7M	N08007			45	(9)(30)	-325	62	25	16.7			
35Ni-15Cr- ¹ / ₂ Mo		A351	HT30	N08603			45	(36)(39)	-325	65	28	18.7			
25Cr-12Ni		A351	CH8	J93400			8	(9)(31)	-325	65	28	18.7			18.0
25Cr-20Ni		A351	CK20	J94202			8	(9)(27)(31)(35)(39)	-325	65	28	18.7			18.0
					• • • • • • • • • • • • • • • • • • • •									10.5	20.0
16Cr-14Ni-2Mo	• • •	A351	CF10MC		• • • •	• • •	8	(30)	-325	70		20.0			
18Cr-8Ni	• • •	A351	CF3	J92500	• • •	• • •	8	(9)	-425	70	30	20.0			18.6
18Cr-12Ni-2Mo	• • •	A351	CF3M	J92800	• • • •	• • •	8	(9)	-425	70	30	20.0	20.0	20.0	19.2
18Cr-8Ni	• • •	A351	CF8	J92600			8	(9)(26)(27)(31)	-425	70	30	20.0	20.0	20.0	18.6
25Cr-12Ni		A351	CH10	J93401			8	(27)(31)(35)	-325	70	30	20.0	20.0	20.0	20.0
25Cr-12Ni				J93402			8	(9)(27)(31)(35)(39)	-325	70	30	20.0			20.0
10C* 10N; Ch							0		225	70	20	20.0			
18Cr-10Ni-Cb	• • •	A351		J92710	• • • •	• • •	8	(9)(27)(30) (0)(27)(20)	-325	70		20.0			20.0
18Cr-12Ni-2Mo	• • •	A351	CF8IVI	J92900	• • • •	• • •	8	(9)(26)(27)(30)	-425	70	30	20.0	20.0	20.0	18.6
$25Cr-20Ni-\frac{1}{2}Mo$		A351	HK40	J94204			8	(35)(36)(39)	-325	62	35	20.7	• • •	• • •	• • •
25Cr-20Ni-1/2Mo		A351	HK30	J94203			8	(35)(39)	-325	65	35	21.7	• • •		
18Cr-8Ni		A351	CF3A	J92500			8	(9)(56)	-425	77	35	23.3	23.3	22.7	21.7
18Cr-8Ni		A351	CF8A	J92600			8	(9)(26)(56)	-425	77	35	23.3	23.3	22.7	21.7
25Cr-8Ni-N		A351	CE20N	J92802			8	(35)(39)	-325	80	40	26.7			26.7
12Cr		A217	CA15	J91150			6	(35)	-20	90	65	30.0	30 N	29 <i>l</i> ı	28.9
24Cr-10Ni-4Mo-N			2A	J93345			10H	(9)	-60	95		31.7			28.2
25Cr-8Ni-3Mo-W-Cu-N		A995		J93380			10H	(9)(25)	-60	100		33.3	33.2		
13Cr-4Ni	• • •	A487	CA6NM	J91540	Α	• • •	6	(9)(35)	-20	110	80	36.7	36.7	35.9	35.3

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] Type/ Spec. 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 Grade No. Stainless Steel (3)(4a) (Cont'd) 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 14.0 12.4 9.8 7.7 6.1 4.7 3.7 2.9 2.3 1.8 1.4 304 A479 16.4 16.2 16.0 15.6 15.2 14.9 14.6 14.4 13.8 12.2 9.7 7.7 6.0 4.7 3.7 2.9 2.3 1.8 1.4 304H A479 3.2 14.0 13.7 13.5 13.3 13.0 12.8 11.9 9.9 7.8 6.3 5.1 4.0 2.6 2.1 1.7 1.1 1.0 0.9 3041 A479 17.9 15.3 17.0 16.7 16.3 16.1 15.9 15.7 15.5 15.4 14.5 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 316 A479 17.9 17.0 16.7 16.3 16.1 15.9 15.7 15.5 15.4 15.3 14.5 12.4 9.8 7.4 5.5 4.1 3.1 2.3 1.7 1.3 316H A479 12.9 12.4 12.1 11.8 10.8 14.4 13.5 13.2 12.6 11.5 11.2 10.2 8.8 6.4 4.7 3.5 2.5 1.8 1.3 1.0 316L A479 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 9.6 6.9 5.0 3.6 2.6 1.7 1.1 0.8 0.5 0.3 321 A479 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 321 A479 19.3 18.3 17.9 17.5 17.2 16.9 16.7 16.5 16.4 16.2 12.3 9.1 6.9 5.4 4.1 3.2 2.5 1.9 1.5 1.1 321H A479 3.3 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 16.0 12.1 9.1 6.1 4.4 2.2 1.5 1.2 0.9 0.8 347 A479 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 7.9 5.9 17.4 10.5 4.4 3.2 2.5 1.8 1.3 347 A479 14.1 20.0 19.3 19.0 18.7 18.5 18.3 18.2 18.1 18.1 18.1 17.4 14.1 10.5 7.9 5.9 4.4 3.2 2.5 1.8 1.3 347H A479 17.1 A479 9041 27.2 26.9 A479 24.7 24.3 24.1 23.9 23.7 23.6 A479 . . . 27.7 26.2 25.7 25.1 24.7 24.3 A479 28.5 28.5 A479 28.7 28.4 A479 2205 . . . 29.7 29.0 XM-19 A479 29.2 28.8 28.6 28.3 27.9 27.5 27.0 26.3 25.5 20.4 13.0 8.3 33.0 33.0 A479 34.5 34.3 A479 Castings (2) CN7M A351 HT30 A351 17.7 17.1 16.7 16.3 15.9 15.4 14.9 13.9 0.8 CH8 A351 14.4 8.5 5.0 3.8 2.9 2.3 0.9 11.1 6.5 1.8 1.3 17.7 17.1 16.7 16.3 15.9 15.4 14.9 14.4 13.9 CK20 A351 11.3 9.8 8.5 7.3 6.0 4.8 3.5 2.4 1.6 1.1 0.8 CF10MC A351 17.5 16.6 16.2 15.8 15.5 15.2 CF3 A351 17.0 16.6 16.3 16.0 15.8 15.7 CF3M A351 16.6 16.2 15.8 15.5 15.2 14.9 14.6 14.3 12.2 9.5 7.5 6.0 4.8 3.9 3.3 2.7 2.3 2.0 1.7 CF8 A351 20.0 20.0 20.0 20.0 20.0 CH10 A351 20.0 20.0 20.0 20.0 11.1 8.5 6.5 5.0 3.8 2.9 2.3 1.8 0.9 0.8 1.3 20.0 20.0 20.0 20.0 20.0 20.0 20.0 20.0 20.0 11.1 8.5 6.5 5.0 3.8 2.9 2.3 1.8 1.3 0.9 0.8 CH₂0 A351 A351 20.0 20.0 CF8C 17.5 16.6 16.2 15.8 15.5 15.2 14.9 0.9 0.8 CF8M A351 14.6 14.3 14.0 12.1 9.1 6.1 4.4 3.3 2.2 1.5 1.2 HK40 A351 HK30 A351 19.3 18.9 18.5 CF3A A351 CF8A A351 26.7 26.7 26.7 26.7 26.7 26.7 26.7 CE20N A351 28.4 27.7 27.2 26.5 17.5 16.8 14.9 11.0 7.6 5.0 2.3 CA15 A217 3.3 1.5 1.0 28.2 28.2 2A A995 29.8 29.6 . . . 6A A995 33.9 33.3 32.4 CA6NM A487 Cl. A

	Product		UNS	Class/ Condition/				Min. Temp.,	Speci Mir Strengt	n.
Nominal Composition	Form	Spec. No.	No.	Temper	Size Range, in.	P-No. (5)(7)	Notes	°F (6)	Tensile	Yield
Copper and Copper Alloy Pipes and Tubes (2)	,									
99.95Cu-P	Pipe	B42	C10200	061		31		-452	30	9
99.9Cu-P	Pipe	B42	C12000	061		31		-452	30	9
99.9Cu-P	Pipe	B42	C12200	061		31		-452	30	9
99.95Cu-P	Tube	B75	C10200	050		31		-452	30	9
99.95Cu-P	Tube	B75	C10200	060	• • •	31		-452	30	9
99.9Cu-P	Tube	B75	C12000	050		31		-452	30	9
99.9Cu-P	Tube	B75	C12000	060	• • •	31		-452	30	9
99.9Cu-P	Tube	B75	C12200	050		31		-452	30	9
99.9Cu-P	Tube	B75	C12200	060	• • •	31	• • •	-452	30	9
99.9Cu-P	Tube	B68	C12200	050	• • •	31	(24)	-452	30	9
99.9Cu-P	Tube	B68	C12200	060	• • •	31	(24)	-452	30	9
99.9Cu-P	Tube	B88	C12200	050	• • •	31	(24)	-452	30	9
99.9Cu-P	Tube	B88	C12200	060		31	(24)	-452	30	9
99.9Cu-P	Tube	B280	C12200	060	•••	31	(24)	-452	30	9
85Cu-15Zn	Pipe	B43	C23000	061	• • •	32	• • •	-452	40	12
90Cu-10Ni		B467	C70600	W050	>4.5 O.D.	34	(14)	-452	38	13
90Cu-10Ni		B467	C70600	W061	>4.5 O.D.	34	(14)	-452	38	13
90Cu-10Ni		B466	C70600	Annealed		34	(14)	-452	38	13
90Cu-10Ni		B467	C70600	W050	≤4.5 O.D.	34	(14)	-452	40	15
90Cu-10Ni		B467	C70600	W061	≤4.5 O.D.	34	(14)	-452	40	15
70Cu-30Ni		B467	C71500	W050	>4.5 O.D.	34	(14)	-452	45	15
70Cu-30Ni		B467	C71500	W061	>4.5 O.D.	34	(14)	-452	45	15
80Cu-20Ni		B466	C71000	Annealed	≤4.5 O.D.	34	(14)	-452	45	16
99.95Cu–P	Pipe	B42	C10200	H55	NPS 2 ¹ / ₂ thru 12	31	(14)(34)	-452	36	30
99.9Cu-P	Pipe	B42	C10200	H55	NPS $2\frac{1}{2}$ thru 12	31	(14)(34)	-452	36	30
99.9Cu-P	Pipe	B42	C12000	H55	NPS $2\frac{1}{2}$ thru 12	31	(14)(34)	-452	36	30
99.95Cu-P	Tube	B75	C12200	H58		31	(14)(34)	-452 -452	36	30
99.9Cu-P	Tube	B75	C10200	H58	• • •	31	(14)(34)	-452	36	30
99.9Cu-P	Tube	B75	C12000	H58	•••	31	(14)(34)	-452 -452	36	30
99.9Cu-P	Tube	B88	C12200	H58	•••	31	(14)(24)(34)	-452 -452	36	30
70Cu-30Ni		B466	C71500	060		34	(14)	-452	52	18
70Cu-30Ni	• • •	B467	C71500	WO50	 ≤4.5 O.D.	34	(14)	-452 -452	50	20
70Cu-30Ni		B467	C71500	W061	≤4.5 O.D. ≤4.5 O.D.	34	(14)	-452 -452	50	20
99.95Cu–P	Dine	B42	(10200	H80	NPS ½ thru 2	21	(14)(34)	% E2	<i>\</i> . r	40
99.95Cu=P 99.9Cu=P	Pipe Pipe	B42 B42	C10200 C12000	H80 H80	NPS $\frac{1}{8}$ thru 2	31 31	(14)(34) (14)(34)	-452 -452	45 45	40 40
99.9Cu=P 99.9Cu=P	Pipe Pipe	B42 B42	C12000	H80	NPS 1/8 thru 2	31	(14)(34)	-452 -452	45 45	
								-452 -452		40 40
99.95Cu-P	Tube	B75	C10200 C12000	H80	• • •	31	(14)(34)		45 45	40
99.9Cu-P	Tube	B75		H80	•••	31	(14)(34)	-452	45	40
99.9Cu–P	Tube	B75	C12200	H80	•••	31	(14)(34)	-452	45	40
Plates and Sheets		_								
99.95Cu-P	• • •	B152	C10200	025	• • •	31	(14)(24)	-452	30	10
99.95Cu-Ag	• • •	B152	C10400	025	• • •	31	(14)(24)	-452	30	10
99.95Cu-Ag	• • •	B152	C10500	025	• • •	31	(14)(24)	-452	30	10
99.95Cu-Ag	• • •	B152	C10700	025	• • •	31	(14)(24)	-452	30	10
99.9Cu-P	• • •	B152	C12200	025	• • •	31	(14)(24)	-452	30	10
99.9Cu-P	• • •	B152	C12300	025	• • •	31	(14)(24)	-452	30	10

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

		Bas	sic Allowa	able Stre	ss, <i>S</i> , ksi	, at Meta	l Temper	ature, °F	[Note (1)]				
Min. Temp.													UNS	
o 100	150	200	250	300	350	400	450	500	550	600	650	700	No.	Spec. No.
													Copper and O	
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C10200	B42
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12000	B42
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12200	B42
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C10200	B75
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C10200	B75
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12000	B75
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12000	B75
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12200	B75
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12200	B75
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12200	B68
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12200	B68
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12200	B88
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12200	B88
6.0	5.1	4.9	4.8	4.7	4.0	3.0	2.3	1.7					C12200	B280
8.0	7.9	7.9	7.9	7.9	7.0	5.0	2.0	• • •	• • •	• • •	• • • •	• • •	C23000	B43
8.7	8.4	8.2	8.0	7.8	7.7	7.5	7.4	7.3	7.0	6.0			C70600	B467
8.7	8.4	8.2	8.0	7.8	7.7	7.5	7.4	7.3	7.0	6.0			C70600	B467
8.7	8.4	8.2	8.0	7.8	7.7	7.5	7.4	7.3	7.0	6.0			C70600	B466
10.0	9.7	9.5	9.3	9.1	8.9	8.7	8.5	8.0	7.0	6.0			C70600	B467
10.0	9.7	9.5	9.3	9.1	8.9	8.7	8.5	8.0	7.0	6.0			C70600	B467
10.0	9.6	9.4	9.2	9.0	8.8	8.6	8.4	8.2	8.1	8.0	7.9	7.8	C71500	B467
10.0	9.6	9.4	9.2	9.0	8.8	8.6	8.4	8.2	8.1	8.0	7.9	7.8	C71500	B467
10.7	10.6	10.5	10.4	10.2	10.1	9.9	9.6	9.3	8.9	8.4	7.7	7.0	C71000	B466
12.0	11.6	10.9	10.4	10.0	9.8	9.5							C10200	B42
12.0	11.6	10.9	10.4	10.0	9.8	9.5		• • •		• • •	• • • •		C12000	B42
12.0	11.6	10.9	10.4	10.0	9.8	9.5		• • •		• • •	• • • •		C12200	B42
12.0	11.6	10.9	10.4	10.0	9.8	9.5		• • •		• • • •	• • • •	• • • •	C10200	B75
12.0	11.6	10.9	10.4	10.0	9.8	9.5			• • • •	• • •	• • • •	• • • •	C12000	B75
12.0	11.6	10.9	10.4	10.0	9.8	9.5	• • •	• • • •		• • •	• • • •		C12200	B75
12.0	11.6	10.9	10.4	10.0	9.8	9.5							C12200	B88
12.0	11.6	11.3	11.0	10.8	10.6	10.3	10.1	9.9	9.8	9.6	9.5	9.4	C71500	B466
13.3	12.9	12.6	12.3	12.0	11.7	11.5	11.2	11.0	10.8	10.7	10.5	10.4	C71500	B467
13.3	12.9	12.6	12.3	12.0	11.7	11.5	11.2	11.0	10.8	10.7	10.5	10.4	C71500	B467
15.0	14.5	13.6	13.0	12.6	12.2	4.3							C10200	B42
15.0	14.5	13.6	13.0	12.6	12.2	4.3							C12000	B42
15.0	14.5	13.6	13.0	12.6	12.2	4.3							C12200	B42
15.0	14.5	13.6	13.0	12.6	12.2	4.3							C10200	B75
15.0	14.5	13.6	13.0	12.6	12.2	4.3							C12000	B75
15.0	14.5	13.6	13.0	12.6	12.2	4.3	• • •	• • •	• • •	• • •	•••		C12200	B75
													Plates a	nd Sheets
6.7	5.7	5.4	5.3	5.0	4.0	3.0	2.3	1.7					C10200	B152
6.7	5.7	5.4	5.3	5.0	4.0	3.0	2.3	1.7					C10400	B152
6.7	5.7	5.4	5.3	5.0	4.0	3.0	2.3	1.7					C10500	B152
6.7	5.7	5.4	5.3	5.0	4.0	3.0	2.3	1.7					C10700	B152
6.7	5.7	5.4	5.3	5.0	4.0	3.0	2.3	1.7					C12200	B152
6.7	5.7	5.4	5.3	5.0	4.0	3.0	2.3	1.7					C12300	B152

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd) Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

	Product		UNS	Class/ Condition/				Min. Temp.,	Spec Mi Streng	n.
Nominal Composition	Form	Spec. No.	No.	Temper	Size Range, in.	P-No. (5)(7)	Notes	°F (6)	Tensile	Yield
Copper and Copper Alloy (Plates and Sheets (Cont	•									
90Cu-10Ni		B171	C70600		≤2.5 thk.	34	(14)	-452	40	15
97Cu-3Si		B96	C65500	061		33	• • •	-452	50	18
70Cu-30Ni	• • •	B171	C71500	• • •	≤2.5 thk.	34	(14)	-452	50	20
90Cu-7Al-3Fe		B169	C61400	025	≤2.0 thk.	35	(13)	-452	70	30
90Cu-7Al-3Fe	• • •	B169	C61400	060	≤2.0 thk.	35	(13)	-452	70	30
Forgings										
99.9Cu		B283	C11000			31	(14)	-452	33	11
97Cu-3Si		B283	C65500			33	(14)	-452	52	18
60Cu-38Zn-2Pb	• • •	B283	C37700	• • •	• • •	a	(14)	-325	58	23
60Cu-37Zn-2Pb-Sn		B283	C48500			a	(14)	-325	62	24
60Cu-39Zn-Sn		B283	C46400			32	(14)	-425	64	26
59Cu-39Zn-Fe-Sn		B283	C67500		•••	32	(14)	-325	72	34
Castings (2)										
5		D.(0	500/00				(a)			
85Cu-5Sn-5Zn-5Pb		B62	C83600	• • •	• • •	a	(9)	-325	30	14
57Cu-20Zn-12Ni- 9Pb-2Sn	• • •	B584	C97300	• • •	• • •	a	• • •	-325	30	15
64Cu-20Ni-8Zn- 4Sn-4Pb		B584	C97600			a		-325	40	17
87Cu-8Sn-4Zn-1Pb		B584	C92300		• • •	a		-325	36	16
88Cu-Sn-Zn-Pb		B584	C92200			a		-325	34	16
88Cu-Sn-Zn-Pb		B61	C92200			a	(9)	-325	34	16
88Cu-8Sn-4Zn		B584	C90300			b		-325	40	18
88Cu-10Sn-2Zn		B584	C90500			b		-325	40	18
							(1)			
58Cu-38Zn-1Sn-1Pb-1Fe		B584	C86400	• • •	• • •	a	(9)	-325	60	20
66Cu-25Ni-5Sn-2Pb-2Zn	• • •	B584	C97800	• • •	• • •	a	• • •	-325	50	22
58Cu-39Zn-1Fe-1Al-1Mn	• • •	B584	C86500	• • •	• • •	b	• • •	-325	65	25
88Cu-9Al-3Fe		B148	C95200			35	(9)	-425	65	25
89Cu-10Al-1Fe		B148	C95300			35	(9)	-425	65	25
90Cu-7Al-3Si		B148	C95600			35		-325	60	28
85Cu-11Al-4Fe		B148	C95400			35		-325	75	30
58Cu-34Zn-2Fe-2Al-2Mn		B584	C86700			2		-325	80	32
82Cu-11Al-4Fe-3Mn		B148	C95500		• • •	a 35	• • •	-323 -452	90	40
63Cu-27Zn-4Al-3Fe-3Mn		B584	C86200		• • •	b		-325	90	45
61Cu-27Zn-6Al-3Fe-3Mn		B584	C86300			b		-325	110	60
Rod										
75Cu-21.5Zn-3Si		B371	C69300	H02	≤ ¹ / ₂	2		_37E	Q.5	45
75Cu-21.5Zn-3Si 75Cu-21.5Zn-3Si	• • •	B371 B371	C69300	H02 H02	$\leq /2$ > $\frac{1}{2}$, ≤ 1	a a	• • •	−325 −325	85 75	45 35
75Cu-21.5Zn-3Si		B371	C69300	H02	> ₁ , ≤ ₂ >1, ≤ ₂	a	• • •	-325 -325	70	30
, , cu 21., Juli Juli	• • •	ב וכם	20/300	1102	· 1, ==	u	• • •	223	70	20

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Min.				able Stre	55, 5, 115	, 41	ро.		[, <u>,</u>				
Temp.													UNS	
to 100	150	200	250	300	350	400	450	500	550	600	650	700	No.	Spec. No
												Connor	nd Copper A	May (Cant's
													es and Shee	
10.0	9.7	9.5	9.3	9.1	8.9	8.7	8.5	8.0	7.0	6.0			C70600	B171
12.0	12.0	11.9	11.9	11.9	10.7	6.8							C65500	B96
13.3	12.9	12.6	12.3	12.0	11.7	11.5	11.2	11.0	10.8	10.7	10.5	10.4	C71500	B171
20.0	19.9	19.8	19.7	19.5	19.4	19.2	19.0	18.8					C61400	B169
20.0	19.9	19.8	19.7	19.5	19.4	19.2	19.0	18.8					C61400	B169
														Forgings
7.3	6.2	6.0	5.8	5.0	4.0	3.0	2.3	1.7					C11000	B283
12.0	12.0	11.9	11.9	11.9	10.7	6.8							C65500	B283
15.3	14.5	13.9	13.3	10.5	7.5	2.0			• • •	• • •	• • •	• • •	C37700	B283
15.5	14.5	13.9	1).)	10.5	7.5	2.0	• • •	• • •		• • •	• • •	• • • •	C37700	6263
16.0	16.0	16.0	16.0	16.0	16.0	16.0							C48500	B283
17.3	17.3	17.3	17.3	17.1	6.3	2.5							C46400	B283
22.7	22.7	22.7	22.7	22.7	22.7	22.7							C67500	B283
													Ca	astings (2)
9.3	9.3	9.2	8.6	8.1	7.7	7.4	7.3						C83600	B62
10.0													C97300	B584
11.3	10.1	9.5	9.1	8.7									C97600	B584
10.7	10.7	10.7	10.7	10.7	10.7	10.7							C92300	B584
10.7	9.6	9.5	9.4	9.2	8.9	8.6							C92200	B584
10.7	9.6	9.5	9.4	9.2	8.9	8.6	8.4	8.3	8.3				C92200	B61
12.0	12.0	12.0	12.0	12.0	12.0	12.0							C90300	B584
12.0	12.0	12.0	12.0	12.0	12.0	12.0							C90500	B584
13.3	13.3	13.3	13.3	13.3	13.3								C86400	B584
14.7	14.7	14.7	14.7	14.7	14.7								C97800	B584
16.7	16.7	16.7	16.7	16.7	16.7								C86500	B584
16.7	15.7	15.2	14.8	14.5	14.3	14.2	14.1	14.1	11.7	7.4			C95200	B148
16.7	16.7	16.7	16.7	16.7	16.7	16.7	16.7	16.7	16.7	16.7			C95300	B148
18.7													C95600	B148
20.0	19.0	18.7	18.5	18.5	18.5	18.5	16.0	13.9					C95400	B148
21.3	21.3	21.3	21.3	21.3	21.3								C86700	B584
26.7	26.7	26.7	26.7	26.7	26.7	26.7	26.7	26.7	• • •		• • •		C95500	B148
30.0									• • •		• • •	• • •	C86200	
36.7	30.0 36.7	30.0 36.7	30.0 36.7	30.0 36.7	30.0 36.7								C86300	B584 B584
														Rod
28.3	25.9	25.4	25.4	25.4									C69300	B371
23.3	20.2	19.8	19.8	19.8									C69300	B371
20.0	17.3	17.0	17.0	17.0			• • •	• • •			• • • •		C69300	B371
20.0	17.5	17.0	17.0	17.0	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	C07300	1/60

	Spec.	UNS	Class/Condition/	Size Range,	P-No.		Min. Temp.,	Specifie Strengt		Min. Temp. to						
Nominal Composition	No.	No.	Temper	in.	(5)	Notes	°F (6)	Tensile	Yield	100	200	300	400	500	600	650
Nickel and Nickel All Pipes and Tubes (1														
99.0Ni-Low C	B161	N02201	Annealed	>5 O.D.	41		-325	50	10	6.7	6.4	6.3	6.3	6.3	6.3	6.2
99.0Ni-Low C	B725	N02201	Annealed	>5 O.D.	41		-325	50	10	6.7	6.4	6.3	6.3	6.3	6.3	6.2
99.0Ni	B161	N02200	Annealed	>5 O.D.	41		-325	55	12	8.0	8.0	8.0	8.0	8.0	8.0	
99.0Ni	B725	N02200	Annealed	>5 O.D.	41		-325	55	12	8.0	8.0	8.0	8.0	8.0	8.0	
99.0Ni-Low C	B161	N02201	Annealed	≤5 O.D.	41	• • •	-325	50	12	8.0	7.7	7.5	7.5	7.5	7.5	7.5
99.0Ni–Low C	B725	N02201	Annealed	≤5 O.D.	41	• • •	-325	50	12	8.0	7.7	7.5	7.5	7.5	7.5	7.5
99.0Ni	B161	N02200	Annealed	≤5 O.D.	41	• • •	-325	55	15	10.0	10.0	10.0	10.0	10.0	10.0	• • •
99.0Ni	B725	N02200	Annealed	≤5 O.D.	41	•••	-325	55	15	10.0	10.0	10.0	10.0	10.0	10.0	• • • •
67Ni-30Cu	B165	N04400	Annealed	>5 O.D.	42		-325	70	25	16.7	14.6	13.6	13.2	13.1	13.1	13.1
67Ni-30Cu	B725	N04400	Annealed	>5 O.D.	42	• • •	-325	70	25	16.7	14.6	13.6	13.2	13.1	13.1	13.1
33Ni-42Fe-21Cr	B407	N08800	H.F. or H.F. ann.		45	• • •	-325	65 75	25	16.7	16.7	16.7	16.7	16.7	16.7	16.7
72Ni-15Cr-8Fe	B167	N06600	H.F. or H.F. ann.	>5 O.D.	43	((2)	-325	75 65	25 25	16.7	16.7	16.7	16.7	16.7	16.7	16.7
33Ni-42Fe-21Cr	B407	N08810	C.D. sol. ann. or H.F. ann.	•••	45	(62)	-325	65	25	16.7	16.7	16.7	16.7	16.7	16.5	16.1
33Ni-42Fe-21Cr	B514	N08810	Annealed		45	(62)	-325	65	25	16.7	16.7	16.7	16.7	16.7	16.5	16.1
33Ni-42Fe-21Cr-Al-Ti	B407	N08811	C.D. sol. ann. or		45	(62)	-325	65	25	16.7	16.7	16.7	16.7	16.7	16.5	16.1
			H.F. ann.													
67Ni-30Cu	B165	N04400	Annealed	≤5 O.D.	42		-325	70	28	18.7	16.4	15.2	14.7	14.7	14.7	14.7
67Ni-30Cu	B725	N04400	Annealed	≤5 O.D.	42	• • •	-325	70	28	18.7	16.4	15.2	14.7	14.7	14.7	14.7
26Ni-22Cr-5Mo-Ti	B619	N08320	Sol. ann.	• • • •	45	• • •	-325	75	28	18.7	18.7	18.7	18.7	18.7	18.6	18.2
26Ni-22Cr-5Mo-Ti	B622	N08320	Sol. ann.	• • •	45	• • •	-325	75	28	18.7	18.7	18.7	18.7	18.7	18.6	18.2
99.0Ni-Low C	B161	N02201	Str. rel.	• • •	41	• • •	-325	60	30	20.0	20.0	19.8	19.8	19.7	19.0	• • •
99.0Ni-Low C 33Ni-42Fe-21Cr	B725	N02201 N08800	Str. rel. Annealed	• • •	41	• • •	-325	60 75	30	20.0	20.0 20.0	19.8 20.0	19.8 20.0	19.7 20.0	19.0 20.0	 20.0
72Ni-15Cr-8Fe	B514 B167	N06600	H.F. or H.F. ann.	 ≤5 O.D.	45 43	• • •	-325 -325	75 80	30 30	20.0 20.0	20.0	20.0	20.0	20.0	20.0	20.0
72Ni-15Cr-8Fe	B167	N06600	C.D. ann.	≥5 O.D. >5 O.D.	43		-325 -325	80	30	20.0	20.0	20.0	20.0	20.0	20.0	20.0
72W 19C 01C	D107	1100000	C.D. dilli.	/J 0.D.	40	•••	223	00	50	20.0	20.0	20.0	20.0	20.0	20.0	20.0
33Ni-42Fe-21Cr	B407	N08800	C.D. ann.		45	(61)	-325	75	30	20.0	20.0	20.0	20.0	20.0	20.0	20.0
31Ni-31Fe-29Cr-Mo	B668	N08028	Sol. ann.		45	• • •	-325	73	31	20.7	20.7	20.7	20.7	20.7	19.5	18.9
99.0Ni	B161	N02200	Str. rel.	• • • •	41	• • •	-325	65	40	21.7	21.7	21.6	21.6	21.4	20.6	• • •
99.0Ni	B725	N02200	Str. rel.	• • •	41	• • •	-325	65	40	21.7	21.7	21.6	21.6	21.4	20.6	
35Ni-35Fe-20Cr-Cb	B464	N08020	Annealed	• • • •	45	• • •	-325	80	35	23.3	23.3	23.3	23.3	23.3	23.3	23.3
35Ni-35Fe-20Cr-Cb	B474	N08020	Annealed	• • •	45	• • •	-325	80	35	23.3	23.3	23.3	23.3	23.3	23.3	23.3
35Ni-35Fe-20Cr-Cb	B729	N08020	Annealed	•••	45	• • •	-325	80	35	23.3	23.3	23.3	23.3	23.3	23.3	23.3
42Ni-21.5Cr-3Mo-2.3Cu		N08825	C.D. ann.		45		-325	85	35	23.3	23.3	23.3		23.3	23.3	23.3
42Ni-21.5Cr-3Mo-2.3Cu		N08825	 Cal ann	• • •	45	• • •	-325	85	35	23.3	23.3	23.3	23.3	23.3	23.3	23.3
47Ni-22Cr-19Fe-6Mo 47Ni-22Cr-19Fe-6Mo	B619 B622	N06007	Sol. ann.	• • •	45 45	• • •	-325	90	35 25	23.3		23.3		23.3	22.7 22.7	22.4 22.4
40Ni-29Cr-15Fe-5Mo	B619	N06007 N06030	Sol. ann. Sol. ann.	• • •	45 45	• • • •	-325 -325	90 85	35 35	23.3 23.3	23.3 23.3	23.3 23.3	23.3	23.3 22.1	21.3	20.9
40Ni-29Cr-15Fe-5Mo	B622	N06030	Sol. ann.	• • •	45 45	• • •	-325 -325	85	35	23.3		23.3		22.1	21.3	20.9
40Ni-29Cr-15Fe-5Mo	B626	N06030	Sol. ann.		45		-325 -325	85	35	23.3	23.3	23.3	23.2		21.3	20.9
72Ni-15Cr-8Fe	B167	N06600	C.D. ann.	 ≤5 O.D.	43		-325	80	35	23.3	23.3	23.3	23.3	23.3	23.3	23.3
72Ni-15Cr-8Fe	B517	N06600	C.D. ann.	 	43		-325	80	35	23.3	23.3	23.3		23.3	23.3	
61Ni-16Mo-16Cr	B619	N06455	Sol. ann.		43		-325	100	40	26.7			26.7			26.7
			•				-		-							

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)]

UNS Spec. 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 1,550 1,600 1,650 Nickel and Nickel Alloy (4a) Pipes and Tubes (2) 6.2 6.0 5.8 4.5 3.7 3.0 2.4 2.0 1.5 1.2 N02201 B161 6.0 5.8 4.5 3.7 3.0 2.4 2.0 1.5 1.2 N02201 B725 N02200 B161 N02200 B725 N02201 B161 7.3 7.2 5.8 4.5 3.7 3.0 2.4 2.0 1.5 1.2 7.3 7.2 5.8 4.5 3.7 3.0 2.4 2.0 1.5 1.2 N02201 B725 N02200 B161 N02200 B725 13.0 12.9 12.7 11.0 8.0 ... N04400 B165 8.0 ... N04400 B725 13.0 12.9 12.7 11.0 16.7 16.7 16.7 16.7 16.7 16.7 16.6 16.3 13.0 9.8 6.6 4.2 2.0 1.0 0.8 N08800 B407 1.6 1.1 N06600 B167 16.7 16.7 16.7 16.0 10.6 7.0 4.5 3.0 2.2 2.0 15.7 15.3 15.0 14.7 14.5 14.2 9.3 7.4 N08810 B407 14.0 13.8 11.6 4.7 2.4 1.9 1.4 1.1 0.86 15.7 15.3 15.0 14.7 14.5 14.2 7.4 N08810 B514 14.0 13.8 11.6 9.3 5.9 4.7 3.8 3.0 2.4 1.9 1.1 0.86 1.4 15.7 15.3 15.0 14.7 14.5 14.2 0.91 N08811 B407 14.0 13.8 12.9 10.4 8.3 6.7 4.3 2.7 2.2 1.2 5.4 3.4 1.6 8.0 ... N04400 B165 14.6 14.5 14.3 11.0 14.6 14.5 14.3 11.0 N04400 B725 8.0 17.8 17.5 17.2 ... N08320 B619 17.8 17.5 17.2 ... N08320 B622 N02201 B161 N02201 B725 20.0 20.0 20.0 20.0 20.0 20.0 19.9 N08800 B514 17.0 13.0 9.8 4.2 2.0 1.0 0.8 6.6 1.6 1.1 . . . N06600 B167 20.0 20.0 20.0 20.0 16.0 10.6 3.0 20.0 20.0 20.0 20.0 16.0 10.6 3.0 2.2 2.0 N06600 B167 20.0 20.0 20.0 20.0 20.0 20.0 N08800 B407 19.9 17.0 13.0 9.8 6.6 4.2 2.0 1.6 1.1 1.0 0.8 . . . 18.3 17.7 17.2 16.7 N08028 B668 N02200 B161 N02200 B725 23.3 23.2 22.7 ... N08020 B464 23.3 23.2 22.7 ... N08020 B474 23.3 23.2 22.7 ... N08020 B729 23.3 23.2 23.0 22.9 22.8 22.6 22.3 N08825 B423 23.3 23.2 23.0 22.9 22.8 22.6 22.3 N08825 B705 22.2 22.0 **21.8** 21.7 20.0 19.5 18.9 N06007 B619 22.2 22.0 21.8 N06007 B622 20.5 20.1 19.7 N06030 B619 20.5 20.1 19.7 N06030 B622 . . . 20.5 20.1 19.7 N06030 B626 . . . 23.3 23.3 23.3 16.0 10.6 4.5 3.0 2.2 N06600 B167 . . . 23.3 23.3 23.3 16.0 10.6 7.0 4.5 3.0 2.2 2.0 N06600 B517 . . . 26.5 26.2 25.8 N06455 B619

Numbers in Parenthese

0.6Cu-N

Specified Min. Class/ Min. Min. Strength, ksi Condition/ Size Range, P-No. Product Spec. Type/ Temp.. Temp. **Nominal Composition** Form No. Grade UNS No. Temper in. (5) Notes °F (6) Tensile Yield to 100 200 300 400 500 Nickel and Nickel Alloy (4a) (Cont'd) Pipes and Tubes (2) (Cont'd) 47Ni-22Cr-9Mo-18Fe B619 ... N06002 Sol. ann. 43 ... -325 100 40 26.7 26.7 26.7 26.7 25.5 47Ni-22Cr-9Mo-18Fe N06002 Sol. ann. 100 40 26.7 26.7 26.7 26.7 25.5 B622 ... 43 ... -32531Ni-33Fe-27Cr-6.5Mo-Cu-N... B619 ... N08031 Annealed 45 ... -32594 40 26.7 26.7 26.7 24.7 23.3 31Ni-33Fe-27Cr-6.5Mo-Cu-N... B622 ... N08031 Annealed 45 ... -32594 40 26.7 26.7 26.7 24.7 23.3 43 ... -325 100 40 61Ni-16Mo-16Cr B622 ... N06455 Sol. ann. 26.7 26.7 26.7 26.7 26.7 . . . 54Ni-16Mo-15Cr B619 ... N10276 Sol. ann. 43 ... -325 100 41 27.3 27.3 27.3 27.3 26.9 54Ni-16Mo-15Cr B622 ... N10276 Sol. ann. 43 ... -325 100 41 27.3 27.3 27.3 27.3 26.9 54Ni-16Mo-15Cr N10276 Sol. ann. 100 27.3 27.3 27.3 **26.9** B626 ... 43 -32541 27.3 67Ni-30Cu N04400 Str. rel. 42 (54)-325 85 28.3 28.3 28.3 28.3 28.3 B165 ... 55 . . . 67Ni-30Cu B725 ... N04400 Str. rel. 42 (54)-32585 55 28.3 28.3 28.3 28.3 28.3 >3/16 46Fe-24Ni-21Cr-6Mo-Cu-N ... N08367 Annealed 45 -32595 45 30.0 30.0 29.9 28.6 27.7 B675 >3/16 46Fe-24Ni-21Cr-6Mo-Cu-N ... N08367 Annealed 95 30.0 30.0 29.9 28.6 27.7 B690 ... 45 -32545 . . . B804 ... >3/16 45 ... 46Fe-24Ni-21Cr-6Mo-Cu-N ... N08367 Annealed -32595 45 30.0 30.0 29.9 28.6 27.7 46Fe-24Ni-21Cr-6Mo-Cu-N ... B675 ... N08367 Annealed ≤3/16 45 ... -325 100 45 30.0 30.0 30.0 29.6 27.7 46Fe-24Ni-21Cr-6Mo-Cu-N ... 30.0 30.0 30.0 29.6 27.7 B690 ... N08367 Annealed ≤3/16 45 ... -325100 45 N08367 Annealed $\leq \frac{3}{16}$ 45 ... 30.0 30.0 29.9 **28.6 27.7** 46Fe-24Ni-21Cr-6Mo-Cu-N ... B804 ... -325100 45 43 ... 55Ni-21Cr-13.5Mo B619 ... N06022 Sol. ann. -325 100 45 30.0 30.0 30.0 30.0 29.0 30.0 30.0 30.0 29.0 55Ni-21Cr-13.5Mo B622 ... N06022 Sol. ann. 43 -325100 45 30.0 B619 ... 58Ni-33Cr-8Mo N06035 Sol. ann. 43 -32585 35 23.3 23.3 23.3 22.2 20.6 . . . 58Ni-33Cr-8Mo B622 ... N06035 Sol. ann. 43 . . . -325 85 35 23.3 23.3 23.3 22.2 20.6 Sol. ann. 58Ni-33Cr-8Mo N06035 -32523.3 23.3 23.3 22.2 20.6 B626 ... 43 . . . 85 35 . . . 59Ni-23Cr-16Mo B619 ... N06059 Sol. ann. 43 -325100 45 30.0 30.0 30.0 30.0 29.7 B622 ... 59Ni-23Cr-16Mo N06059 Sol. ann. 43 . . . -325100 45 30.0 30.0 30.0 30.0 29.7 . . . B626 ... 59Ni-23Cr-16Mo N06059 Sol. ann. All 43 ... -325100 45 30.0 30.0 30.0 30.0 29.7 59Ni-23Cr-16Mo-1.6Cu B619 ... N06200 Sol. ann. All 43 ... 100 45 30.0 30.0 30.0 30.0 28.6 -325. . . 59Ni-23Cr-16Mo-1.6Cu B622 ... N06200 Sol. ann. All 43 -325 100 45 30.0 30.0 30.0 30.0 28.6 59Ni-23Cr-16Mo-1.6Cu N06200 Sol. ann. All -325 30.0 30.0 30.0 28.6 B626 ... 43 100 45 30.0 . . . 62Ni-22Mo-15Cr B619 ... N10362 Sol. ann. All 43 . . . -325105 45 30.0 30.0 30.0 30.0 **28.9** N10362 Sol. ann. 30.0 30.0 30.0 28.9 62Ni-22Mo-15Cr B622 ... All 43 . . . -325105 45 30.0 62Ni-22Mo-15Cr N10362 Sol. ann. ΑII 43 -325 105 30.0 30.0 30.0 30.0 **28.9** B626 ... 45 62Ni-28Mo-5Fe B619 ... N10001 Sol. ann. 44 ... -325100 45 30.0 30.0 30.0 30.0 30.0 44 ... 62Ni-28Mo-5Fe . . . B622 ... N10001 Sol. ann. -325100 45 30.0 30.0 30.0 30.0 30.0 N10665 Sol. ann. 34.0 34.0 34.0 34.0 34.0 65Ni-28Mo-2Fe B619 ... 44 . . . -325110 51 65Ni-28Mo-2Fe B622 ... N10665 Sol. ann. 44 -325110 34.0 34.0 34.0 34.0 34.0 51 34.0 34.0 34.0 34.0 65Ni-29.5Mo-2Fe-2Cr B619 ... N10675 Sol. ann. 44 -325 110 51 34.0 65Ni-29.5Mo-2Fe-2Cr N10675 Sol. ann. 44 -325 110 51 34.0 34.0 34.0 34.0 34.0 B622 34.0 34.0 34.0 34.0 65Ni-29.5Mo-2Fe-2Cr B626 ... N10675 Sol. ann. 44 -325110 51 34.0 (64)(70) - 32540.0 40.0 39.6 39.2 38.6 60Ni-22Cr-9Mo-3.5Cb B444 1 N06625 Annealed 43 120 60 60Ni-22Cr-9Mo-3.5Cb B705 1 N06625 Annealed 43 (64)(70) - 325120 40.0 40.0 39.6 39.2 38.6 60 . . . 57Ni-22Cr-14W-2Mo-La B619 ... N06230 Sol. ann. 43 -325110 45 30.0 30.0 30.0 30.0 30.0 B622 ... 57Ni-22Cr-14W-2Mo-La N06230 Sol. ann. 43 -325 110 45 30.0 30.0 30.0 30.0 30.0 . . . 30.0 30.0 30.0 30.0 30.0 57Ni-22Cr-14W-2Mo-La B626 ... N06230 Sol. ann. 43 ... -325110 45 R20033 Sol. ann. 33Cr-31Ni-32Fe-1.5Mo-B619 ... All 45 ... -325109 55 36.3 30.9 28.1 26.1 24.7 0.6Cu-N 33Cr-31Ni-32Fe-1.5Mo-B622 ... R20033 Sol. ann. 45 ... -325 109 55 36.3 30.9 28.1 26.1 24.7 . . . 0.6Cu-N 33Cr-31Ni-32Fe-1.5Mo-B626 ... R20033 Sol. ann. All 45 ... -325109 55 36.3 30.9 28.1 26.1 24.7

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)]

UNS No. Spec.

600 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 1,550 1,600 1,650 or Grade No.

	or Grade	1,000	1,000	1,550	1,500	1,700	1,400	1,550	1,500	1,230	1,200	1,130	1,100	1,000	1,000	750	700	0,0	000	7 50	, , ,	0,00	
	loy (4a) (C es (2) (Coı				Nic																		
B6:	N06002				3.0	3.8	4.8	6.1	7.7	9.3	11.3	14.1	17.5	19.3	19.3	19.5	19.6	22.5	22.7	22.9	23.3	23.7	24.2
B62	N06002				3.0	3.8	4.8	6.1	7.7	9.3	11.3	14.1	17.5	19.3	19.3	19.5	19.6	22.5	22.7	22.9	23.3	23.7	24.2
B6:	N08031																			8.9			
B62	N08031																		7.2	8.9			
B62	N06455																			26.1			
B6:	N10276									7.8	9.8	12.2	15.0	18.5	22.3		22.6						
ъ.	1110270	• • •	•••	•••	•••	•••	• • •	• • •	• • •	,.0	7.0	12.2	13.0	10.5	22.5	22.7	22.0	22.0	23.1	23.5	24.0	24.0	
B62	N10276									7.8	9.8	12.2	15.0	18.5	22.3	22.4	22.6	22.8	23.1	23.5	24.0	24.6	25.2
B62	N10276						• • •		• • •	7.8	9.8	12.2	15.0	18.5	22.3	22.4	22.6	22.8	23.1	23.5	24.0	24.6	5.2
B16	N04400																						
B72	N04400																						
B67	N08367																23.6	23.9	24.3	24.7	25.1	25.6	6.2
B69	N08367																23.6	23.9	24.3	24.7	25.1	25.6	6.2
B80	N08367																23.6	23.9	24.3	24.7	25.1	25.6	6.2
B67	N08367																23.6	23.9	24.3	24.7	25.1	25.6	6.2
B69	N08367																	23.9					
B80	N08367																			24.7			
B6:	N06022																			26.1			
B62	N06022																			26.1			
B6:	N06035															• • •	• • •			19.0			
B62	N06035						• • •	• • •			• • • •				•••	• • •	• • •			19.0			
B62	N06035	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •				19.0			
B6:	N06055	• • •				• • •	• • •			• • •			• • •	• • •	• • •	• • •	• • •			26.1			
		• • •	• • •	• • •	• • • •	• • •	• • •		• • •	• • •			• • •	• • •	• • •	• • •	• • •			26.1			
B62	N06059	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			26.1			
B62	N06059	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •					
B6:	N06200		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			25.4			
B62	N06200	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			25.4			
B62	N06200	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			25.4			
B6:	N10362	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			26.7			
B62	N10362	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		26.7			
B62	N10362	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		26.7			
B6:	N10001	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			30.0			
B62	N10001	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			30.0			
B6:	N10665	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			34.0			
B62	N10665	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •			• • •					34.0			
B6:	N10675				• • •						• • •	• • •								33.9			
B62	N10675				• • •						• • •	• • •	• • •						33.5	33.9	34.0	34.0	4.0
B62	N10675																		33.5	33.9	34.0	34.0	4.0
B44	N06625										13.2	21.0	23.1	31.2	31.2	35.4	35.8	36.1	36.3	36.6	37.0	37.4	7.8
B70	N06625										13.2	21.0	23.1	31.2	31.2	35.4	35.8	36.1	36.3	36.6	37.0	37.4	7.8
B6:	N06230	1.5	2.1	2.9	4.1	5.3	6.7	8.5	10.6	12.9	15.6	19.0	23.2	28.2	28.2	28.2	28.2	28.2	28.2	28.4	28.7	29.1	9.6
B62	N06230	1.5	2.1	2.9	4.1	5.3	6.7	8.5	10.6	12.9	15.6	19.0	23.2	28.2	28.2	28.2	28.2	28.2	28.2	28.4	28.7	29.1	9.6
B62	N06230	1.5	2.1	2.9	4.1	5.3	6.7	8.5	10.6	12.9	15.6	19.0	23.2	28.2	28.2	28.2	28.2	28.2	28.2	28.4	28.7	29.1	9.6
B63	R20033					• • •													22.6	22.9	23.1	23.5	3.8
B62	R20033							• • •											22.6	22.9	23.1	23.5	3.8
B62	R20033																		22.6	22.9	23.1	23.5	3.8

Specified Min. Min. Class/ Min. Strength, ksi Condition/ Product Spec. Type/ Size Range, P-No. Temp.. Temp. **Nominal Composition** Form No. Grade UNS No. Temper (5) Notes °F (6) Tensile Yield to 100 200 300 400 500 Nickel and Nickel Alloy (4a) (Cont'd) Plates and Sheets 99.0Ni-Low C Plate B162 ... N02201 H.R. ann. 41 ... -325 50 12 8.0 7.7 7.5 7.5 7.5 99.0Ni-Low C N02201 H.R. as R. 50 12 8.0 7.7 7.5 7.5 Plate B162 ... 41 . . . -3257.5 . . . 99.0Ni Plate B162 ... N02200 H.R. ann. 41 ... -32555 15 10.0 10.0 10.0 10.0 10.0 99.0Ni Plate B162 ... N02200 H.R. as R. 41 ... -32555 20 13.3 13.3 13.3 13.3 13.3 33Ni-42Fe-21Cr N08810 Annealed 45 25 B409 ... All -32565 16.7 16.7 16.7 16.7 16.7 33Ni-42Fe-21Cr-Al-Ti B409 ... N08811 Annealed All 45 -325 65 25 16.7 16.7 16.7 16.7 16.7 26Ni-22Cr-5Mo-Ti B620 ... N08320 Sol. ann. All 45 -325 75 28 18.7 18.7 18.7 18.7 . . . N04400 H.R. ann. 42 -325 70 28 18.7 16.4 15.2 14.7 14.7 67Ni-30Cu Plate B127 47Ni-22Cr-19Fe-6Mo B582 ... N06007 Sol. ann. $>^{3}/_{4}$ 45 -32585 30 20.0 20.0 20.0 20.0 20.0 . . . N08800 Annealed 20.0 20.0 20.0 20.0 20.0 33Ni-42Fe-21Cr . . . B409 ... All 45 . . . -32575 30 N08028 Sol. ann. -325 73 20.7 20.7 20.7 20.7 20.7 31Ni-31Fe-29Cr-Mo B709 ... 45 31 42Ni-21.5Cr-3Mo-2.3Cu . . . B424 ... N08825 Annealed 45 -32585 35 23.3 23.3 23.3 23.3 23.3 . . . 35Ni-35Fe-20Cr-Cb B463 ... N08020 Annealed All 45 -32580 35 23.3 23.3 23.3 23.3 23.3 . . . 40Ni-29Cr-15Fe-5Mo N06030 Sol. ann. ΑII 45 ... 85 35 23.3 23.3 23.3 23.2 22.1 B582 ... -32547Ni-22Cr-19Fe-6Mo B582 ... N06007 Sol. ann. ≤3/4 45 -32590 35 23.3 23.3 23.3 23.3 23.3 N06002 H.R. sol. ann. 23.3 23.3 23.3 22.3 47Ni-22Cr-9Mo-18Fe B435 ... All 43 -325 95 35 23.3 72Ni-15Cr-8Fe Plate B168 ... N06600 H.R. ann. 43 -325 80 35 23.3 23.3 23.3 23.3 23.3 N06600 H.R. as R. 43 -325 85 23.3 23.3 23.3 23.3 72Ni-15Cr-8Fe Plate B168 ... 35 23.3 B127 ... 25.0 24.7 23.9 23.4 67Ni-30Cu Plate N04400 H.R. as R. 42 -32575 40 25.0 . . . 26.7 26.7 24.7 23.3 31Ni-33Fe-27Cr-B625 ... N08031 Annealed All 45 . . . -32594 40 26.7 6.5Mo-Cu-N 43 ... 26.7 26.7 26.7 26.7 26.7 61Ni-16Mo-16Cr B575 ... N06455 Sol. ann. -325100 54Ni-16Mo-15Cr B575 ... N10276 Sol. ann. All 43 ... -325100 41 27.3 27.3 27.3 27.3 **26.9** . . . 60Ni-22Cr-9Mo-3.5Cb Plate B443 1 N06625 Annealed All 43 (64)(70) -325 110 55 36.7 36.7 36.3 35.9 35.4 57Ni-22Cr-14W-B435 ... N06230 Sol. ann. All 43 . . . -325110 45 30.0 30.0 30.0 30.0 30.0 2Mo-La 55Ni-21Cr-13.5Mo Sheet B575 ... N06022 Sol. ann. $<^{3}/_{16}$ 43 -325 100 45 30.0 30.0 30.0 30.0 **29.0** . . . 58Ni-33Cr-8Mo N06035 Sol. ann. 43 85 23.3 23.3 23.3 22.2 20.6 B575 All -32535 . . . 46Fe-24Ni-21Cr-B688 ... N08367 Annealed $>^{3}/_{16}$ 45 ... -325 95 30.0 30.0 29.9 28.6 **27.7** 6Mo-Cu-N 46Fe-24Ni-21Cr-B688 ... N08367 Annealed ≤3/16 30.0 30.0 30.0 29.6 27.7 45 ... -325100 45 6Mo-Cu-N N06059 Sol. ann. 43 ... 30.0 30.0 30.0 30.0 29.6 59Ni-23Cr-16Mo B575 ... All -325100 45 43 ... 59Ni-23Cr-16Mo-1.6Cu ... B575 ... N06200 Sol. ann. All -325 100 45 30.0 30.0 30.0 30.0 28.6 62Ni-22Mo-15Cr B575 ... N10362 Sol. ann. ΑII 43 ... -325105 45 30.0 30.0 30.0 30.0 **28.9** N10001 Sol. ann. $\geq \frac{3}{16}$, $\leq 2\frac{1}{2}$ 62Ni-28Mo-5Fe B333 ... 100 45 30.0 30.0 30.0 30.0 30.0 Plate 44 ... -32562Ni-28Mo-5Fe Sheet B333 ... N10001 Sol. ann. $<^{3}/_{16}$ 44 -325 115 50 33.3 33.3 33.3 33.3 33.3 . . . 65Ni-28Mo-2Fe B333 ... N10665 Sol. ann. All 44 . . . -325 110 51 34.0 34.0 34.0 34.0 34.0 . . . 65Ni-29.5Mo-2Fe-2Cr B333 ... N10675 Sol. ann. All 44 -325110 51 34.0 34.0 34.0 34.0 34.0 . . . 45 ... 33Cr-31Ni-32Fe-B625 ... R20033 Sol. ann. All -325109 55 36.3 30.9 28.1 26.1 24.7 1.5Mo-0.6Cu-N Forgings and Fittings 99.0Ni-Low C B160 ... N02201 Annealed All 41 (9)(9a) -32550 10 6.7 6.4 6.3 6.3 6.3 (32)(74) -325 99.0Ni-Low C 10 6.3 B366 ... N02201 Annealed ΑII 41 50 6.7 6.4 6.3 6.3 . . . N02200 Annealed 99.0Ni B366 ... 41 (32)(74) - 32555 12 8.0 8.0 8.0 8.0 8.0 99.0Ni B564 ... N02200 ... 41 (32)-325 55 12 8.0 8.0 8.0 8.0 8.0

B366

B564

N02200

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)]

UNS No. Spec. 600 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 1,550 1,600 1,650 or Grade No. Nickel and Nickel Alloy (4a) (Cont'd) Plates and Sheets 7.5 7.5 7.4 7.4 7.2 5.8 4.5 3.7 3.0 2.4 2.0 1.5 1.2 N02201 B162 7.5 7.5 7.4 7.4 7.2 5.8 4.5 3.7 3.0 2.4 2.0 1.5 1.2 N02201 B162 N02200 B162 . . . N02200 B162 16.6 16.2 15.8 15.5 15.1 14.9 14.6 14.3 14.0 13.8 11.6 9.3 7.4 5.9 N08810 4.7 3.8 3.0 2.4 1.9 1.4 1.1 0.86 B409 16.5 16.1 15.7 15.3 15.0 14.7 14.5 14.2 14.0 13.7 12.9 10.4 8.3 6.7 5.4 4.3 3.4 2.7 1.6 0.91 N08811 B409 18.6 18.2 17.8 **17.5 17.2** N08320 B620 . . . 14.7 14.7 14.6 14.5 14.3 11.0 8.0 N04400 B127 **19.5 19.2 19.0 18.8 18.7** *18.6 18.5 18.4 18.3* ... N06007 B582 . . . 9.8 6.6 4.2 2.0 1.6 1.1 1.0 0.8 N08800 B409 19.5 18.9 18.3 17.7 17.2 16.7 N08028 B709 23.3 23.3 23.3 23.2 23.0 22.9 22.8 22.6 22.3 ... N08825 23.3 23.3 23.3 23.2 22.7 N08020 B463 21.3 20.9 20.5 20.1 19.7 N06030 B582 22.7 22.4 22.2 22.0 21.8 21.7 20.0 19.5 18.9 ... N06007 B582 21.2 20.7 20.3 20.1 19.9 N06002 B435 . . . 23.3 23.3 23.3 23.3 23.3 16.0 10.6 7.0 4.5 3.0 2.2 2.0 N06600 B168 . . . 23.3 23.3 23.3 23.3 23.3 16.0 10.6 7.0 4.5 3.0 2.2 2.0 N06600 B168 23.1 22.9 22.7 20.0 14.5 8.5 4.0 N04400 B127 22.2 21.7 21.3 20.9 20.5 N08031 B625 . . . 26.7 26.7 **26.5 26.1 25.8** **25.2 24.6 24.0 23.5 23.1 22.8 22.6 22.4 22.3** 18.5 15.0 12.2 9.8 7.8 34.7 34.3 33.9 33.6 33.3 33.1 32.8 32.5 31.2 31.2 23.1 21.0 13.2 N06625 **B443** 5.3 4.1 2.9 2.1 1.5 N06230 B435 27.6 27.0 26.5 26.1 25.7 N06022 B575 19.7 19.4 19.2 19.0 18.8 N06035 B575 . . . 26.2 25.6 25.1 24.7 24.3 23.9 23.6 26.2 25.6 25.1 24.7 24.3 23.9 23.6 N08367 **B688** 28.1 27.5 **26.7 26.1 25.6** 26.9 26.2 25.7 25.4 25.2 N06200 B575 27.7 27.3 27.0 26.7 26.4 N10362 B575 30.0 30.0 30.0 30.0 **29.8** N10001 B333 *33.3 33.3 33.3 33.3* **33.2** N10001 B333 34.0 34.0 34.0 34.0 N10665 B333 *34.0 34.0 34.0* **33.9 33.5** N10675 B333 . . . 23.8 23.5 23.1 22.9 22.6 R20033 B625 Forgings and Fittings 6.3 6.2 6.2 6.1 6.0 5.8 4.5 3.7 3.0 2.4 2.0 1.5 1.2 N02201 B160 6.3 6.2 6.2 6.1 6.0 5.8 4.5 3.7 3.0 B366 2.4 2.0 1.5 1.2 N02201

...

. . .

.

. . .

8.0

Specified Min. Min. Class/ Min. Strength, ksi Condition/ Size Range, P-No. Product Spec. Temp.. Temp. Type/ **Nominal Composition** Form No. Grade UNS No. Temper (5) Notes °F (6) Tensile Yield to 100 200 300 400 500 Nickel and Nickel Alloy (4a) (Cont'd) Forgings and Fittings (Cont'd) 99.0Ni B564 ... N02200 Annealed All 41 (9) -325 55 15 10.0 10.0 10.0 10.0 10.0 33Ni-42Fe-21Cr B564 ... N08810 Annealed 45 (9) -32565 25 16.7 16.7 16.7 16.7 16.7 . . . 33Ni-42Fe-21Cr-Al-Ti B564 ... N08811 Annealed 45 (9) -325 65 25 16.7 16.7 16.7 16.7 16.7 33Ni-42Fe-21Cr B366 ... N08810 Annealed All 45 (9)(74)-325 65 25 16.7 16.7 16.7 16.7 16.7 . . . 33Ni-42Fe-21Cr-Al-Ti B366 ... N08811 Annealed (9)(74)-325 25 16.7 16.7 16.7 16.7 ΑII 45 65 16.7 . . . 67Ni-30Cu B564 ... N04400 Annealed 42 (9)-325 70 25 16.7 14.6 13.6 13.2 13.1 . . . (32)(74) - 32567Ni-30Cu N04400 Annealed 25 16.7 14.6 13.6 13.2 13.1 B366 ... All 42 70 N06600 Annealed 72Ni-15Cr-8Fe B366 ... All 43 (32)(74) - 32575 25 16.7 16.7 16.7 16.7 16.7 N06030 Sol. ann. 45 85 35 23.3 23.3 23.2 22.1 40Ni-29Cr-15Fe-5Mo B366 ... All (74)-32523.3 . . . 40Ni-29Cr-15Fe-5Mo B462 ... N06030 Sol. ann. ΑII 45 -325 85 35 23.3 23.3 23.3 23.2 22.1 33Ni-42Fe-21Cr В366 ... N08800 C.D. ann. All 45 (74)-325 75 30 20.0 20.0 20.0 20.0 20.0 . . . 33Ni-42Fe-21Cr B564 ... N08800 Annealed 45 (9) -325 75 30 20.0 20.0 20.0 20.0 20.0 В366 ... N08020 Annealed (74)35Ni-35Fe-20Cr-Ch ΑII 45 -325 80 35 23.3 23.3 23.3 23.3 23.3 . . . 35Ni-35Fe-20Cr-Cb B462 ... N08020 Annealed 45 (9) -325 80 35 23.3 23.3 23.3 23.3 23.3 . . . 72Ni-15Cr-8Fe B564 ... N06600 Annealed 43 (9) -325 80 35 23.3 23.3 23.3 23.3 All 42Ni-21.5Cr-3Mo-2.3Cu... N08825 C.D. ann. (74)23.3 23.3 23.3 23.3 23.3 B366 ... ΑII 45 -32585 35 42Ni-21.5Cr-3Mo-2.3Cu . . . N08825 Annealed -325 35 23.3 23.3 23.3 23.3 23.3 B564 ... 45 85 47Ni-22Cr-9Mo-18Fe B366 ... N06002 Sol. ann. 43 (32) 40 26.7 26.7 26.7 26.7 25.5 All -325100 31Ni-33Fe-27Cr-B366 ... N08031 Sol. ann. All 45 (74)-32594 40 26.7 26.7 26.7 24.7 23.3 6.5Mo-Cu-N 31Ni-33Fe-27Cr-B564 ... N08031 Annealed H.W. All 45 -325 94 40 26.7 26.7 26.7 24.7 23.3 6.5Mo-Cu-N 54Ni-16Mo-15Cr B366 ... N10276 Sol. ann. 43 (74) -325 100 41 27.3 27.3 27.3 27.3 **26.9** All . . . 54Ni-16Mo-15Cr B462 ... N10276 Sol. ann. All 43 (9) -325 100 41 27.3 27.3 27.3 27.3 **26.9** 54Ni-16Mo-15Cr B564 ... N10276 Sol. ann. 43 (9) 100 41 27.3 27.3 27.3 27.3 26.9 All -325. . . 62Ni-28Mo-5Fe B366 ... N10001 Sol. ann. All 44 (32)-325 100 45 30.0 30.0 30.0 30.0 30.0 . . . (32)(74) - 32555Ni-21Cr-13.5Mo B366 ... N06022 Sol. ann. All 43 100 45 30.0 30.0 30.0 30.0 29.0 . . . B462 ... 55Ni-21Cr-13.5Mo N06022 Sol. ann. All 43 (9) -325100 45 30.0 30.0 30.0 30.0 30.0 . . . 55Ni-21Cr-13.5Mo N06022 Sol. ann. 43 (9) 30.0 30.0 30.0 30.0 **29.0** B564 ... ΑII -325 100 45 . . . 58Ni-33Cr-8Mo B366 ... N06035 Sol. ann. All 43 (32)(74) - 32585 35 23.3 23.3 23.3 22.2 20.6 . . . 58Ni-33Cr-8Mo B462 ... N06035 Sol. ann. All 43 (9)-32585 35 23.3 23.3 23.3 22.2 20.6 . . . B564 ... N06035 58Ni-33Cr-8Mo Sol. ann. All 43 (9)-325 85 35 23.3 23.3 23.3 22.2 20.6 . . . 59Ni-23Cr-16Mo B366 ... N06059 Sol. ann. ΑII 43 (74)-325100 45 30.0 30.0 30.0 30.0 29.7 59Ni-23Cr-16Mo B564 ... N06059 H.W. sol. ann. All 43 -325 100 45 30.0 30.0 30.0 30.0 29.7 . . . 59Ni-23Cr-16Mo-1.6Cu ... B366 ... N06200 Sol. ann. ΑII 43 (74)-325100 45 30.0 30.0 30.0 30.0 28.6 59Ni-23Cr-16Mo-1.6Cu ... B462 ... N06200 Sol. ann. 43 100 45 30.0 30.0 30.0 30.0 28.6 ΑII -325. . . N06200 43 30.0 30.0 30.0 28.6 59Ni-23Cr-16Mo-1.6Cu . . . B564 ... Sol. ann. All -325100 45 30.0 (9) N10362 Sol. ann. 30.0 30.0 30.0 28.9 62Ni-22Mo-15Cr . . . B366 ... All 43 -325105 45 30.0 62Ni-22Mo-15Cr B462 ... N10362 Sol. ann. All 43 (9) -325 105 45 30.0 30.0 30.0 30.0 28.9 . . . 62Ni-22Mo-15Cr B564 ... N10362 Sol. ann. ΑII 43 (9) -325105 45 30.0 30.0 30.0 30.0 28.9 40.0 40.0 39.6 39.2 38.6 60Ni-22Cr-9Mo-3.5Cb ... N06625 Annealed 43 (9)(64)-325120 60 B564 ... ≤4 В366 ... 65Ni-28Mo-2Fe N10665 Sol. ann. All 44 (74)-325 110 51 34.0 34.0 34.0 34.0 34.0 . . . В366 ... Sol. ann. 65Ni-29.5Mo-2Fe-2Cr . . . N10675 All 44 (74)-325110 51 34.0 34.0 34.0 34.0 34.0 65Ni-29.5Mo-2Fe-2Cr B462 ... N10675 Sol. ann. All 44 -325110 51 34.0 34.0 34.0 34.0 34.0 65Ni-29.5Mo-2Fe-2Cr B564 ... N10675 Sol. ann. All 44 -325110 51 34.0 34.0 34.0 34.0 34.0 57Ni-22Cr-14W-N06230 Sol. ann. 30.0 30.0 30.0 30.0 30.0 B564 ... All 43 -325110 45 . . . 2Mo-La 57Ni-22Cr-14W-B366 ... N06230 Sol. ann. All 43 (74) -325110 45 30.0 30.0 30.0 30.0 30.0 2Mo-La

(16)

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)]

UNS No. Spec.

600 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 1,550 1,600 1,650 or Grade No.

100																					ttings (Co	-
		45.2	45.0					42.0			· · ·										N02200	B564
16.5 16.1 16.5 16.1								13.8	11.6	9.3 10.4	7.4 8.3	5.9	4.7	3.8	3.0	2.4	1.9	1.4	1.1		N08810 N08811	B564 B564
16.5 16.1 16.5 16.1								13.8 13.8	12.9 11.6	9.3	7.4	6.7 5.9	5.4 4.7	4.3 3.8	3.4 3.0	2.7 2.4	2.2 1.9	1.6 1.4	1.2 1.1		N08811 N08810	B366
16.5 16.1								13.8	12.9	10.4	8.3	6.7	5.4	4.3	3.4	2.7	2.2	1.6	1.2		N08810	B366
13.1 13.1																					N04400	B564
13.1 13.1 13.1 13.1																					N04400	B366
16.7 16.7							7.0	4.5	3.0	2.2	2.0	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		N06600	B366
21.3 20.9							• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	N06030	B366
21.3 20.9								47.0										• • •	• • •	• • •	N06030	B462
20.0 20.0								17.0	13.0	9.8	6.6	4.2	2.0	1.6	1.1	1.0	0.8	• • •	• • •	• • •	N08800	B366
20.0 20.0	20.0	20.0	20.0	20.0	20.0	20.0	19.9	17.0	13.0	9.8	6.6	4.2	2.0	1.6	1.1	1.0	0.8	• • •	• • • •	• • • •	N08800	B564
23.3 23.3	3 23.3	23.2	22.7																		N08020	B366
23.3 23.3	3 23.3	23.2	22.7																		N08020	B462
23.3 23.3	3 23.3	23.3	23.3	23.3	16.0	10.6	7.0	4.5	3.0	2.2	2.0										N06600	B564
23.3 23.3	3 23 3	22.2	23 U	22.0	22.8	22.6	22.3														N08825	B366
23.3 23.3 23.3											• • •	• • •	• • • •								N08825	B564
20.0 20.0	, 25.5	23.2	25.0	22.7	22.0	22.0	22.5	• • •	•••	•••	•••	•••	•••	• • •	•••	• • •	• • •	• • •	• • • •	• • • •	1100023	D 7 0 4
24.2 23.7	7 23.3	22.9	22.7	22.5	19.6	19.5	19.3	19.3	17.5	14.1	11.3	9.3	7.7	6.1	4.8	3.8	3.0				N06002	B366
22.2 21.7	7 21.3	20.9	20.5	• • •		• • •	• • •	• • •	• • •	• • •	• • •		• • •	• • •		• • •	• • •	• • •	• • •	• • •	N08031	B366
22.2 21.7	7 21.3	20.9	20.5																		N08031	B564
25.2 24.6	6 24.0	23.5	23.1	22.8	22.6	22.4	22.3	18.5	15.0	12.2	9.8	7.8									N10276	B366
25.2 24.6								18.5	15.0	12.2	9.8	7.8									N10276	B462
25.2 24.6								18.5	15.0	12.2	9.8	7.8									N10276	B564
30.0	0 30.0	30.0	29.9																		N10001	B366
27.6 27.0	0 26.5	26.1	25.7																		N06022	B366
27.6 27.0																					N06022	B462
27.6 27.0																					N06022	B564
19.7 19.4																					N06035	B366
19.7 19.4	4 19.2	19.0	18.8																		N06035	B462
19.7 19.4	4 19.2	19.0	18.8																		N06035	B564
28.2 27.5	5 26.8	26.1	25.5																		N06059	B366
28.2 27.5	5 26.8	26.1	25.5																		N06059	B564
26.9 26.2	2 25.7	25.4	25.2																		N06200	B366
26.9 26.2																					N06200	B462
26.9 26.2					• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		N06200	B564
27.7 27.3					• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	N10362	B366
27.7 27.3					• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	N10362	B462
27.7 27.3											122	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	N10362	B564
37.8 37.4	4 3/.0	36.6	36.3	36.1	35.8	35.4	31.2	31.2	23.1	21.0	13.2	• • • •	• • • •	• • •			• • •	• • •	• • • •	• • • •	N06625	B564
34.0 34.0	0 34.0	34.0	34.0																		N10665	B366
34.0 34.0	0 34.0	33.9	33.5																		N10675	B366
34.0 34.0																					N10675	B462
34.0 34.0								• • •			• • •										N10675	B564
29.6 29.1	1 28.7	28.4	28.2	28.2	28.2	28.2	28.2	28.2	23.2	19.0	15.6	12.9	10.6	8.5	6.7	5.3	4.1	2.9	2.1	1.5	N06230	B564
29.6 29.1	1 20 7	20 /	20.2	20 2	20 2	20 2	20 2	20.2	າລາ	100	15 4	120	10 4	ОГ	6.7	5.3	4.1	2.9	2.1	1.5	N06230	B366

										Speci	ified					
					Class/				Min.	Mir Strengt		Min.				
Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Condition/ Temper	Size Range, in.	P-No. (5)	Notes	Temp., °F (6)			Temp. to 100	200	300	400	500
NICL LANCE LANC	(1.) (6															
Nickel and Nickel Allo Forgings and Fittin																
33Cr-31Ni-32Fe- 1.5Mo-0.6Cu-N		B366		R20033	Sol. ann.	All	45		-325	109	55	36.3	30.9	28.1	26.1	24.7
33Cr-31Ni-32Fe- 1.5Mo-0.6Cu-N	• • •	B462	• • •	R20033	Sol. ann.	All	45	• • •	-325	109	55	36.3	30.9	28.1	26.1	24.7
33Cr-31Ni-32Fe- 1.5Mo-0.6Cu-N	•••	B564		R20033	Sol. ann.	All	45		-325	109	55	36.3	30.9	28.1	26.1	24.7
Rod and Bar																
99.0Ni		B160		N02200	H.W.	All	41	(9)	-325	60	15	10.0	10.0	10.0	10.0	10.0
99.0Ni	•••	B160		N02200	Annealed	All	41	(9)	-325	55	15			10.0		
67Ni-30Cu	• • •	B164	• • •	N04400	Ann. forg.	All	42	(13)	-325	70	25	16.7	14.6	13.6	13.2	13.1
33Ni-42Fe-21Cr	Bar	B408		N08810	Sol. tr. or ann.		45		-325	65	25	16.7	16.7	16.7	16.7	16.7
33Ni-42Fe-21Cr-Al-Ti	Bar	B408		N08811	Sol. tr. or ann.		45		-325	65	25	16.7	16.7	16.7	16.7	16.7
33Ni-42Fe-21Cr	Bar	B408	• • •	N08800	H.F.	• • •	45	• • •	-325	75	30	20.0	20.0	20.0	20.0	20.0
26Ni-22Cr-5Mo-Ti	• • •	B621	• • •	N08320	Sol. ann.	All	45		-325	75	28	18.7	18.7	18.7	18.7	18.7
47Ni-22Cr-19Fe-6Mo		B581			Sol. ann.	>3/4	45		-325	85	30	20.0		20.0		
42Ni-21.5Cr-3Mo-2.3Cu		B425		N08825	Annealed		45	• • •	-325	85	35	23.3		23.3		
47Ni-22Cr-19Fe-6Mo 40Ni-29Cr-15Fe-5Mo		B581 B581		N06007 N06030	Sol. ann. Sol. ann.	≤³/ ₄ All	45 45		-325 -325	90 85	35 35	23.3 23.3		23.3 23.3		
31Ni-33Fe-27Cr-6.5Mo-		B649			Annealed	All	45		-325	94	40	26.7		26.7		
Cu-N 67Ni-30Cu		B164		N04400	H.W.	All except hex. >21/8	42		-325	80	40	26.7	25.8	24.8	23.9	23.4
58Ni-33Cr-8Mo		B574		N06035	Sol. ann.	All	43	(9)	-325	85	35	23.3	23.3	23.3	22.2	20 6
61Ni-16Mo-16Cr		B574		N06455		All	43	(9)	-325	100	40	26.7		26.7		
54Ni-16Mo-15Cr		B574		N10276	Sol. ann.	All	43		-325	100	41	27.3		27.3		
62Ni-22Mo-15Cr		B574		N10362	Sol. ann.	All	43	(9)	-325	105	45	30.0		30.0		
60Ni-22Cr-9Mo-3.5Cb	• • •	B446	1	N06625	Annealed	>4 to 10	43	(9)(64) (70)	-325	110	50	33.3	33.3	33.3	33.3	33.3
60Ni-22Cr-9Mo-3.5Cb	• • •	B446	1	N06625	Annealed	≤4	43	(9)(64) (70)	-325	120	60	40.0	40.0	40.0	40.0	38.3
57Ni-22Cr-14W-2Mo-La	а	B572		N06230	Sol. ann.	All	43		-325	110	45	30.0	30.0	30.0	30.0	30.0
59Ni-23Cr-16Mo		B574		N06059	Sol. ann.	All	43		-325	100	45	30.0	30.0	30.0	30.0	29.7
59Ni-23Cr-16Mo-1.6Cu		B574		N06200	Sol. ann.	All	43		-325	100	45	30.0	30.0	30.0	30.0	28.6
65Ni-29.5Mo-2Fe-2Cr	• • •	B335	• • •	N10675	Sol. ann.	All	44		-325	110	51	34.0	34.0	34.0	34.0	34.0
33Cr-31Ni-32Fe- 1.5Mo-0.6Cu-N		B649		R20033	Sol. ann.	All	45	•••	-325	109	55	36.3	30.9	28.1	26.1	24.7
Castings (2)																
53Ni-17Mo-16Cr- 6Fe-5W	• • • •	A494	CW12MW	N30002		• • • •		(9)(44)	-325	72	40	24.0	24.0	24.0	24.0	24.0
56Ni-19Mo-18Cr-2Fe		A494	CW6M	N30107				(9)	-325	72	40	24.0	24.0	24.0	24.0	24.0
59Ni-22Cr-14Mo- 4Fe-3W	•••	A494	CX2MW	N26022	Sol. ann.		43	(9)	-325	80	45	26.7	26.7	26.7	26.7	26.7

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] UNS No. Spec. 600 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 1,350 1,400 1,450 1,500 1,550 1,600 1,650 or Grade No. Nickel and Nickel Alloy (4a) (Cont'd) Forgings and Fittings (Cont'd) R20033 B366 23.8 23.5 23.1 22.9 22.6 23.8 23.5 23.1 22.9 22.6 R20033 B564 Rod and Bar N02200 . . . B160 N02200 B160 13.1 13.1 13.0 12.9 12.7 11.0 8.0 N04400 B164 16.5 16.1 15.7 15.3 15.0 14.7 14.5 14.2 14.0 13.8 11.6 9.3 7.4 5.9 4.7 3.8 3.0 24 1.9 1.4 1.1 0.86 N08810 R408 16.5 16.1 15.7 15.3 15.0 14.7 14.5 14.2 14.0 13.7 12.9 10.4 8.3 6.7 5.4 4.3 3.4 2.7 2.2 1.6 1.2 0.91 N08811 B408 13.0 9.8 6.6 4.2 2.0 1.6 1.1 1.0 0.8 N08800 B408 18.6 18.2 17.8 17.5 17.2 N08320 B621 **19.5 19.2 19.0** 18.8 **18.7** 18.6 18.5 18.4 18.3 ... B581 N06007 23.3 23.3 23.3 23.2 23.0 22.9 22.8 22.6 22.3 ... N08825 B425 **22.7 22.4** 22.2 22.0 21.8 21.7 20.0 19.5 18.9 ... N06007 B581 21.3 20.9 20.5 20.1 19.7 N06030 B581 22.2 21.7 21.3 20.9 20.5 N08031 B649 23.1 22.9 22.7 20.0 14.5 8.5 4.0 1.9 N04400 B164 19.7 19.4 19.2 19.0 18.8 N06035 **B574** 26.7 26.7 26.5 26.1 25.8 N06455 B574 **25.2 24.6 24.0 23.5 23.1 22.8 22.6 22.4 22.3** 18.5 15.0 12.2 9.8 7.8 N10276 **B574** 27.7 27.3 27.0 26.7 26.4 B574 N10362 33.3 33.3 33.3 33.3 33.1 32.8 32.5 31.2 31.2 23.1 21.0 13.2 B446 N06625 B446 5.3 2.9 2.1 6.7 4.1 1.5 N06230 B572 28.2 27.5 26.8 26.1 25.5 B574 N06059 26.9 26.2 25.7 25.4 25.2 N06200 B574 *34.0 34.0 34.0* **33.9 33.5** N10675 B335 23.8 23.5 23.1 22.9 22.6 R20033 B649 Castings (2) A494

...

						Min.	Specifie	d Min.		ble Stress, emperature ote (1)]	
Nominal		Type/	UNS	P-No.		Temp.,	Strengt		Min. Temp.		
Composition	Spec. No.	Grade	No.	(5)	Notes	°F (6)	Tensile	Yield	to 100	150	200
Titanium and Tit Pipes and Tub											
Ti	B861	1	R50250	51		-75	35	20	11.7	10.7	9.3
Ti	B862	1	R50250	51		-75	35	20	11.7	10.7	9.3
Ti	B861	2	R50400	51		-75	50	40	16.7	16.0	14.5
Ti	B862	2	R50400	51		-75	50	40	16.7	16.0	14.5
Ti-Pd	B861	7	R52400	51		-75	50	40	16.7	16.0	14.5
Ti-Pd	B862	7	R52400	51		-75	50	40	16.7	16.0	14.5
Ti	B861	3	R50550	52		-75	65	55	21.7	20.4	18.4
Ti	B862	3	R50550	52		-75	65	55	21.7	20.4	18.4
Plates and Sh	eets										
Ti	B265	1	R50250	51		-75	35	25	11.7	10.9	9.6
Ti	B265	2	R50400	51		-75	50	40	16.7	16.0	14.5
Ti	B265	3	R50550	52		-75	65	55	21.7	20.4	18.4
Forgings											
Ti	B381	F1	R50250	51		-75	35	25	11.7	10.9	9.6
Ti	B381	F2	R50400	51		-75	50	40	16.7	16.0	14.5
Ti	B381	F3	R50550	52		-75	65	55	21.7	20.4	18.4
Zirconium and Z Pipes and Tub		/									
99.2Zr	B523		R60702	61		-75	55	30	18.3	17.2	15.4
99.2Zr	B658		R60702	61		-75	55	30	18.3	17.2	15.4
95.5Zr + 2.5Cb	B523		R60705	62	(73)	-75	80	55	26.7	24.4	22.1
95.5Zr + 2.5Cb	B658		R60705	62	(73)	-75	80	55	26.7	24.4	22.1
Plates and Sh	eets										
99.2Zr	B551		R60702	61		-75	55	30	18.3	17.2	15.4
95.5Zr + 2.5Cb	B551		R60705	62	(73)	-75	80	55	26.7	24.4	22.1
Forgings and I	Bar										
99.2Zr	B493		R60702	61		-75	55	30	18.3	17.2	15.4
99.2Zr	B550		R60702	61		-75	55	30	18.3	17.2	15.4
95.5Zr + 2.5Cb	B493		R60705	62	(73)	-75	70	55	26.7	24.4	22.1
95.5Zr + 2.5Cb	B550		R60705	62	(73)	-75	80	55	26.7	24.4	22.1

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, ksi, at Metal Temperature, °F [Note (1)] UNS 350 400 450 250 300 500 550 600 650 700 No. Spec. No. Titanium and Titanium Alloy Pipes and Tubes (2) 7.2 5.5 4.8 4.2 3.8 R50250 B861 8.2 6.3 3.5 B862 8.2 3.8 R50250 7.2 6.3 5.5 4.8 4.2 3.5 . . . 13.2 12.1 10.3 9.6 8.9 8.2 7.6 R50400 B861 11.1 13.2 12.1 11.1 10.3 9.6 8.9 8.2 7.6 R50400 B862 8.9 10.3 9.6 8.2 13.2 12.1 11.1 7.6 R52400 B861 12.1 10.3 B862 13.2 11.1 9.6 8.9 8.2 7.6 R52400 16.6 14.9 13.4 12.1 10.9 9.9 9.2 8.6 R50550 B861 . . . 10.9 9.2 R50550 B862 16.6 14.9 13.4 12.1 9.9 8.6 Plates and Sheets 8.6 7.7 7.0 6.4 5.9 5.2 4.7 4.2 R50250 B265 13.2 12.1 10.3 9.6 8.9 8.2 7.6 R50400 B265 11.1 16.6 14.9 13.4 12.1 10.9 9.9 9.2 8.6 R50550 B265 . . . **Forgings** 8.6 7.7 7.0 6.4 5.9 5.2 4.7 4.2 R50250 B381 B381 13.2 12.1 11.1 10.3 9.6 8.9 8.2 7.6 R50400 16.6 14.9 13.4 12.1 10.9 9.9 9.2 8.6 R50550 B381 . . . Zirconium and Zirconium Alloy Pipes and Tubes (2) 13.6 12.0 10.6 9.3 8.3 7.4 6.6 6.0 5.6 5.2 R60702 B523 13.6 12.0 10.6 9.3 8.3 7.4 6.6 6.0 5.6 5.2 R60702 B658 17.7 20.4 18.9 16.7 15.8 15.0 14.4 13.9 13.5 R60705 B523 13.2 20.4 18.9 17.7 16.7 15.8 15.0 14.4 13.9 13.5 13.2 R60705 B658 Plates and Sheets 13.6 12.0 10.6 9.3 8.3 7.4 6.6 6.0 5.6 5.2 R60702 B551 20.4 18.9 17.7 16.7 15.8 15.0 14.4 13.9 13.5 13.2 R60705 B551 Forgings and Bar 13.6 12.0 10.6 9.3 8.3 7.4 6.6 6.0 5.6 5.2 R60702 B493 13.6 12.0 10.6 9.3 8.3 7.4 6.6 6.0 5.6 5.2 R60702 B550 20.4 18.9 16.7 R60705 B493 17.7 15.8 15.0 14.4 13.9 13.5 13.2 15.8 R60705 B550 20.4 18.9 17.7 16.7 15.0 14.4 13.9 13.5 13.2

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

													ic Allo tal Ten				- 1	
Nominal			UNS	Class/ Condition/	Size or Thickness	P-No.			Min. Temp.,	Spec Mi Streng	n.	Min. Temp. to						
Composition	Spec. No.	Type/Grade	No.	Temper	Range, in.	(5)		Notes		Tensile	Yield	100	150	200	250	300	350	400
Aluminum Al Seamless	•	l Tubes																
99.60Al	B210	1060	A91060	0		21	(14)(33)		-452	8.5	2.5	1.7	1.7	1.6	1.4	1.2	1.1	0.8
99.60Al	B210	1060	A91060		• • •	21	(14)(33)		-452	8.5	2.5	1.7	1.7	1.6	1.4		1.1	
99.60Al	B210	1060	A91060		• • •	21	(14)(33)		-452	8.5	2.5	1.7	1.7	1.6		1.2		
99.60Al	B241	1060	A91060		• • •	21	(14)(33)		-452	8.5	2.5	1.7	1.7			1.2		
99.60Al	B241	1060	A91060		• • •	21	(14)(33)		-452	8.5	2.5	1.7	1.7	1.6	1.4		1.1	
99.60Al	B241	1060	A91060		• • •	21	(14)(33)		-452	8.5	2.5	1.7	1.7	1.6	1.4			
99.60Al	B345	1060	A91060		• • •	21	(14)(33)		-452	8.5	2.5	1.7	1.7			1.2		
99.60Al	B345	1060	A91060		• • •	21	(14)(33)		-452	8.5	2.5	1.7	1.7	1.6	1.4			
99.60Al	B345	1060	A91060		• • •	21	(14)(33)		-452	8.5	2.5	1.7	1.7	1.6		1.2		
99.60Al	B210	1060	A91060	H14	• • •	21	(14)(33)		-452	12	10	4.0	4.0	4.0	4.0	2.7	1.8	1.1
99.0Al-Cu	B241	1100	A91100	0		21	(14)(33)		-452	11	3	2.0	2.0	2.0	1.9			
99.0Al-Cu	B241	1100	A91100	H112	• • •	21	(14)(33)		-452	11	3	2.0	2.0	2.0	1.9	1.7	1.3	1.0
99.0Al-Cu	B210	1100	A91100	H113		21	(14)(33)		-452	11	3.5	2.3	2.3	2.3	2.3	1.7	1.3	1.0
99.0Al-Cu	B210	1100	A91100	H14	• • •	21	(14)(33)		-452	16	14	5.3	5.3	5.3	4.9	2.8	1.9	1.1
Al-Mn-Cu	B210	3003	A93003	0		21	(14)(33)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B210	3003	A93003			21	(14)(33)		-452	14	5	3.3	3.2			2.7		
Al-Mn-Cu	B241	3003	A93003	0		21	(14)(33)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B241	3003	A93003	H112		21	(14)(33)		-452	14	5	3.3	3.2	3.1	3.0		1.9	1.5
Al-Mn-Cu	B345	3003	A93003	0		21	(14)(33)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B345	3003	A93003	H112		21	(14)(33)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B491	3003	A93003	0		21	(14)(33)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B491	3003	A93003	H112	• • •	21	(14)(33)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B210	3003	A93003	H14		21	(14)(33)		-452	20	17	6.7	6.7	6.5	4.8	4.3	3.0	2.3
Al-Mn-Cu	B210	3003	A93003			21	(14)(33)		-452	27	24	9.0	9.0	8.7	8.0		3.5	
Al-Mn-Cu	B241	3003	A93003			21	(14)(33)		-452	27	24	9.0	9.0	8.7	8.0		3.5	
Al-Mn-Cu	B345	3003	A93003			21	(14)(33)		-452	27	24	9.0	9.0	8.7	8.0			2.5
Al-Mn-Cu	B210	Alclad 3003	A83003	0		21	(14)(33)		-452	13	4.5	3.0	2.9	2.8	2.7	2.5	1.9	1.5
Al-Mn-Cu	B210	Alclad 3003	A83003			21	(14)(33)		-452	13	4.5	3.0						1.5
Al-Mn-Cu	B241	Alclad 3003	A83003			21	(14)(33)		-452	13	4.5	3.0				2.5		
Al-Mn-Cu	B241	Alclad 3003	A83003				(14)(33)		-452	13	4.5	3.0				2.5		
Al-Mn-Cu	B345	Alclad 3003	A83003			21	(14)(33)		-452	13	4.5	3.0	2.9					1.5
Al-Mn-Cu	B345	Alclad 3003	A83003				(14)(33)		-452	13	4.5	3.0	2.9			2.5		
Al-Mn-Cu	B210	Alclad 3003	A83003				(14)(33)		-452	19	16	6.3				4.3		
Al-Mn-Cu	B210	Alclad 3003	A83003				(14)(33)		-452	26	23	8.7				4.3		
Al-2.5Mg	B210	5052	A95052	0		22	(14)		-452	25	10	6.7	6.7	6.7	6.6	6.1	4.1	2.4
Al-2.5Mg	B241	5052	A95052			22	(14)		-452	25	10	6.7				6.1		
Al-2.5Mg	B210	5052	A95052				(14)(33)		-452	31	23		10.3					
Al-2.5Mg	B210	5052	A95052				(14)(33)		-452	34	26		11.3					
Al-4.4Mg-Mn	B241	5083	A95083	0		25	(33)		-452	39	16	10 7	10.7					
	B241	5083	A95083			25	(33)		-452 -452	39	16		10.7					
Al-4.4Mg-Mn						25	(33)		-452	39	16		10.7					
•	B210	ういかう	AYTUAT															
Al-4.4Mg-Mn	B210 B210	5083 5083	A95083															
Al-4.4Mg-Mn Al-4.4Mg-Mn Al-4.4Mg-Mn Al-4.4Mg-Mn	B210 B210 B345	5083 5083	A95083 A95083	H112		25 25	(33) (33)		-452 -452	39 39	16 16	10.7	10.7 10.7					

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

							<u> </u>				Basic	Allowable Tempera					Metal
Nominal			UNS	Class/ Condition/		P-No.		Min. Temp.,		n. th, ksi	Min. Temp.	· ·					
Composition	Spec. No.	Type/Grade	No.	Temper	Range, in.	(5)	Notes	°F (6)	Tensile	Yield	100	150 20	00 2	250	300	350	400
Aluminum A Seamless		nt'd) Ind Tubes (Co	ont'd)														
Al-4.0Mg-Mn	B241	5086	A95086	0		25	(33)	-452	35	14	9.3	9.3					
Al-4.0Mg-Mn	B241	5086	A95086	H112		25	(33)	-452	35	14	9.3	9.3					
Al-4.0Mg-Mn		5086	A95086	0		25	(33)	-452	35	14	9.3	9.3					
Al-4.0Mg-Mn	B210	5086	A95086	H112		25	(33)	-452	35	14	9.3	9.3					
Al-4.0Mg-Mn		5086	A95086	0		25	(33)	-452	35	14	9.3	9.3					
Al-4.0Mg-Mn		5086	A95086	H112		25	(33)	-452	35	14	9.3	9.3					
Al-4.0Mg-Mn		5086	A95086	H32		25	(33)	-452	40	28	13.3	13.3					
Al-4.0Mg-Mn		5086	A95086	H34		25	(33)	-452	44	34	14.7						
Al-3.5Mg	B210	5154	A95154	0		22		-452	30	11	7.3	7.3					
Al-3.5Mg	B210	5154	A95154			22	(33)	-452	39	29	13.3	13.0					
A1 2 7M M	D2/4	F./F./	105/5/	0		22	(22)	450	24	4.0		0.0		- ,		, ,	2.0
Al-2.7Mg-Mn		5454	A95454		• • •	22	(33)	-452	31	12	8.0			7.4		4.1	
Al-2.7Mg-Mn	B241	5454	A95454	H112	• • • •	22	(33)	-452	31	12	8.0	8.0 8	5.0	7.4	5.5	4.1	3.0
Al-5.1Mg-Mn	B210	5456	A95456	0		25	(33)	-452	41	19	12.7	12.7					
Al-5.1Mg-Mn	B210	5456	A95456	H112		25	(33)	-452	41	19	12.7	12.7					
Al-5.1Mg-Mn	B241	5456	A95456	0		25	(33)	-452	41	19	12.7	12.7					
Al-5.1Mg-Mn	B241	5456	A95456	H112		25	(33)	-452	41	19	12.7	12.7					
Al-Mg-Si-Cu	B210	6061	A96061	T4		23	(33)	-452	30	16	10.0	10.0 10	0.0	9.9	9.5	8.4	5.2
Al-Mg-Si-Cu	B241	6061	A96061	T4		23	(33)(63)	-452	26	16	8.7	8.7	3.7	8.7	8.3	7.4	5.2
Al-Mg-Si-Cu	B345	6061	A96061	T4	• • •	23	(33)(63)	-452	26	16	8.7	8.7	3.7	8.7	8.3	7.4	5.2
Al-Mg-Si-Cu	B210	6061	A96061	T6		23	(33)	-452	42	35	14.0	14.0 14	.0 1	13.6	11.7	8.9	5.2
Al-Mg-Si-Cu	B241	6061	A96061	T6		23	(33)(63)	-452	38	35	12.7	12.7 12	7.7 1	12.3	10.5	8.1	5.2
Al-Mg-Si-Cu	B345	6061	A96061			23	(33)(63)	-452	38	35		12.7 12					
Al Ma Ci Cu	D210	6061	106061	T/ wld		22	(22)((2)	452	2.6		ο Λ	0.0	. ^	0 0	77	6.0	E 1
Al-Mg-Si-Cu	B210	6061	A96061		• • •	23	(22)(63)	-452	24	• • •	8.0				7.7		
Al-Mg-Si-Cu	B210	6061	A96061		• • •	23	(22)(63)	-452	24	• • •	8.0			8.0	7.7		
Al-Mg-Si-Cu	B241	6061	A96061		• • •	23	(22)(63)	-452	24	• • •	8.0				7.7		
Al-Mg-Si-Cu	B241	6061	A96061		• • •	23	(22)(63)	-452	24	• • •	8.0				7.7 7.7		
Al-Mg-Si-Cu	B345	6061	A96061		• • •	23	(22)(63)	-452	24	• • •	8.0						
Al-Mg-Si-Cu	B345	6061	A96061	T6 wld.	• • •	23	(22)(63)	-452	24	• • •	8.0	8.0 8	5.0	8.0	7.7	6.9	5.1
Al-Mg-Si	B210	6063	A96063	T4		23	(33)	-452	22	10	6.7	6.5					
Al-Mg-Si	B241	6063	A96063		≤0.500	23	(33)	-452	19	10	6.3			6.3		3.9	
Al-Mg-Si	B345	6063	A96063	T4	≤0.500	23	(33)	-452	19	10	6.3	6.3	5.3	6.3	5.8	3.9	1.5
Al-Mg-Si	B241	6063	A96063		≤0.500		(33)	-452	22	16	7.3	7.3 7					
Al-Mg-Si	B345	6063	A96063	T5	≤0.500	23	(33)	-452	22	16	7.3	7.3 7	'.3	7.3	7.1	3.8	2.0
Al-Mg-Si	B210	6063	A96063	T6		23	(33)	-452	33	28	11.0	11.0 11	.0	9.6	7.3	3.8	2.0
Al-Mg-Si	B241	6063	A96063			23	(33)	-452	30	25		10.0 10					
Al-Mg-Si	B345	6063	A96063				(33)	-452	30	25		10.0 10					
₀ 51			, 500)	. •			()	772	50		- 3.0	20.0 10		,	,	۶۰-۲	_

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

												Basic				<i>S</i> , ksi [Note		Metal
Nominal			UNS	Class/ Condition/	Size or Thickness	P-No.			Min. Temp.,	Spec Mi Streng	in.	Min. Temp. to						
Composition	Spec. No.	Type/Grade	No.	Temper	Range, in.	(5)		Notes	°F (6)	Tensile	Yield	100	150	200	250	300	350	400
Aluminum A		nt'd) ind Tubes (Co	ont'd)															
Al-Mg-Si	B210	6063	A96063	T4 wld.		23			-452	17		5.7	5.7	5.6	5.3	4.8	3.8	2.0
Al-Mg-Si	B210	6063	A96063	T5 wld.		23			-452	17		5.7	5.7	5.6	5.3	4.8	3.8	2.0
Al-Mg-Si	B210	6063	A96063			23			-452	17		5.7	5.7	5.6	5.3	4.8	3.8	
Al-Mg-Si	B241	6063	A96063						-452	17		5.7	5.7	5.6	5.3	4.8	3.8	
Al-Mg-Si	B241	6063	A96063			23			-452	17		5.7	5.7	5.6	5.3	4.8	3.8	
Al-Mg-Si	B241	6063	A96063						-452	17		5.7	5.7	5.6	5.3	4.8	3.8	
Al-Mg-Si	B345	6063	A96063			23			-452	17		5.7	5.7	5.6	5.3	4.8	3.8	
Al-Mg-Si	B345	6063	A96063			23			-452	17		5.7	5.7	5.6	5.3	4.8	3.8	
∖l−Mg−Si	B345	6063	A96063						-452	17		5.7	5.7	5.6		4.8		2.0
Welded F	Pipes and	d Tubes																
Al-4.4Mg-Mn	B547	5083	A95083	0		25			-452	40	18	12.0	12.0					
Structura	ıl Tubes																	
99.0Al	B221	1060	A91060	0		21	(33)(69)		-452	8.5	2.5	1.7	1.7	1.6	1.4	1.2	1.1	0.8
9.0Al	B221	1060	A91060			21	(33)(69)		-452	8.5	2.5	1.7	1.7	1.6	1.4	1.2	1.1	
9.0Al-Cu	B221	1100	A91100			21	(33)(69)		-452	11	3	2.0	2.0	2.0	1.9	1.7	1.3	
99.0Al–Cu	B221	1100	A91100			21	(33)(69)		-452	11	3	2.0	2.0			1.7		
Al-Mn-Cu	B221	3003	A93003	0		21	(33)(69)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B221	3003	A93003	H112		21	(33)(69)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B221	Alclad 3003	A83003	0		21	(33)(69)		-452	13	4.5	3.0	2.9	2.8	2.7	2.5	1.9	1.5
Al-Mn-Cu	B221	Alclad 3003	A83003			21	(33)(69)		-452	13	4.5	3.0	2.9	2.8		2.5	1.9	1.5
Al-2.5Mg	B221	5052	A95052	0		22	(69)		-452	25	10	6.7	6.7	6.7	6.6	6.1	4.1	2.3
Al-4.4Mg-Mn	B221	5083	A95083	0		25	(69)		-452	39	16	10.7	10.7					
Al-4.0Mg-Mn		5086	A95086			25	(69)		-452	35	14	9.3	9.3					
Al-3.5Mg	B221	5154	A95154	0		22	(69)		-452	30	11	7.3	7.3					
Al-2.7Mg-Mn	B221	5454	A95454	0		22	(69)		-452	31	12	8.0	8.0	8.0	7.4	5.5	4.1	3.0
Al-5.1Mg-Mn		5456	A95456	0		25	(69)		-452	41	19	12.7	12.7					
Al-Mg-Si-Cu	B221	6061	A96061	T4		23	(33)(63)(69)	-452	26	16	8.7	8.7	8.7	8.7	8.3	7.4	5.2
Al-Mg-Si-Cu		6061	A96061			23	(33)(63)(-452	38	35		12.7					
« Mg−Si−Cu Al−Mg−Si−Cu		6061	A96061			23	(22)(63)(-452	24		8.0				7.7		5.1
Al-Mg-Si-Cu		6061	A96061			23	(22)(63)(-452	24		8.0				7.7		
Al-Mg-Si	B221	6063	A96063	T4	≤0.500	23	(13)(33)(69)	-452	19	10	6.3	6.3	6.3	6.3	5.8	3.9	1.5
Al-Mg-Si	B221	6063	A96063		≤0.500		(13)(33)(-452	22	16	7.3		7.3				2.0
ıl-Mg-Si	B221	6063	A96063			23	(33)(69)	,	-452	30	25	10.0		10.0		7.2		2.0
ıl-Mg-Si	B221	6063	A96063			23	(69)		-452	17		5.7				4.8		2.0
ıl-Mg-Si	B221	6063	A96063			23	(69)		-452	17		5.7				4.8		2.0
N Mg Si NI-Mg-Si	B221	6063		T6 wld.		23	(69)		-452	17		5.7				4.8		
ii mg Ji	DZZI	000)	A20003	io wiu.	• • •	۷)	(0))		-432	1/	• • •	٦./	ر.ر	ا.ر	ر.ر	4.0	٥.ر	۷.

												Basic	Allowa Temp			<i>S</i> , ksi [Note		1etal
Nominal			UNS	Class/ Condition/	Size or Thickness	P-No.			Min. Temp.,	Specifie Streng		Min. Temp.						
Composition	Spec. No.	Type/Grade	No.	Temper	Range, in.	(5)		Notes	°F (6)	Tensile	Yield	100	150	200	250	300	350	400
Aluminum Plates a	Alloy (Co																	
99.60Al	B209	1060	A91060	0		21			-452	8	2.5	1.7	1.6	1.6	1.4	1.2	1.1	0.8
99.60Al	B209	1060	A91060	H112	0.500-1.000	21	(13)(33)		-452	10	5	3.3	3.2	2.9	2.5	2.0	1.5	0.9
99.60Al	B209	1060	A91060	H12		21	(33)		-452	11	9	3.7	3.7	3.4	3.1	2.7	1.8	1.1
99.60Al	B209	1060	A91060	H14	• • • •	21	(33)		-452	12	10	4.0	4.0	4.0	4.0	2.7	1.8	1.1
99.0Al-Cu	B209	1100	A91100	0		21			-452	11	3.5	2.3	2.3	2.3	2.3	1.7	1.3	1.0
99.0Al-Cu	B209	1100	A91100		0.500-2.000	21	(13)(33)		-452	12	5	3.3	3.3	3.3	3.2		1.7	1.0
99.0Al-Cu	B209	1100	A91100	H12		21	(33)		-452	14	11	4.7	4.7	4.6	3.8	2.8	1.9	1.1
99.0Al-Cu	B209	1100	A91100	H14		21	(33)		-452	16	14	5.3	5.3	5.3	4.9	2.8	1.9	1.1
Al-Mn-Cu	B209	3003	A93003	0		21			-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B209	3003	A93003	H112	0.500-2.000	21	(13)(33)		-452	15	6	4.0	3.9	3.7	3.6	2.7	1.9	1.5
Al-Mn-Cu	B209	3003	A93003	H12		21	(33)		-452	17	12	5.7	5.7	5.6	5.2	4.3	3.0	2.3
Al-Mn-Cu	B209	3003	A93003	H14	• • •	21	(33)		-452	20	17	6.7	6.7	6.7	6.5	4.3	3.0	2.3
Al-Mn-Cu	B209	Alclad 3003	A83003	0	0.006-0.499	21	(66)		-452	13	4.5	3.0	2.9	2.8	2.7	2.5	1.9	1.5
Al-Mn-Cu	B209	Alclad 3003	A83003	0	0.500-3.000	21	(68)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B209	Alclad 3003	A83003	H112	0.500-2.000	21	(33)(66)		-452	15	6	4.0	3.9	3.7	3.6	2.7	1.9	1.5
Al-Mn-Cu	B209	Alclad 3003	A83003	H12	0.017-0.499	21	(33)(66)		-452	16	11	5.3	5.3	5.2	4.9	4.3	3.0	2.3
Al-Mn-Cu	B209	Alclad 3003	A83003	H12	0.500-2.000	21	(33)(68)		-452	17	12	5.7	5.7	5.7	5.7	4.3	3.0	2.3
Al-Mn-Cu	B209	Alclad 3003	A83003		0.009-0.499		(33)(66)		-452	19	16	6.3	6.3	6.3	6.1	4.3	3.0	2.3
Al-Mn-Cu	B209	Alclad 3003	A83003	H14	0.500-1.000	21	(33)(68)		-452	20	17	6.7	6.7	6.7	6.5	4.3	3.0	2.3
Al-Mn-Mg	B209	3004	A93004	0		22			-452	22	8.5	5.7	5.7	5.7	5.7	5.7	3.8	2.3
Al-Mn-Mg	B209	3004	A93004		• • •	22	(33)		-452	23	9	6.0	6.0	6.0	6.0	5.8	3.8	2.3
Al-Mn-Mg	B209	3004	A93004		• • •	22	(33)		-452	28	21	9.3		9.3		5.7	3.8	2.3
Al-Mn-Mg	B209	3004	A93004	H34	• • •	22	(33)		-452	32	25	10.7	10.7	10.7	10.7	5.7	3.8	2.3
Al-Mn-Mg	B209	Alclad 3004	A83004	0	0.006-0.499	22	(66)		-452	21	8	5.3	5.3	5.3	5.3	5.3	3.8	2.3
Al-Mn-Mg	B209	Alclad 3004	A83004	0	0.500-3.000	22	(68)		-452	22	8.5	5.7	5.6	5.6	5.6	5.6	3.8	2.3
Al-Mn-Mg	B209	Alclad 3004	A83004	H112	0.250-0.499	22	(33)(66)		-452	22	8.5	5.7	5.6	5.6	5.6	5.6	3.8	2.3
Al-Mn-Mg	B209	Alclad 3004	A83004		0.500-3.000		(33)(68)		-452	23	9	6.0	6.0		6.0		3.8	2.3
Al-Mn-Mg	B209	Alclad 3004	A83004		0.017-0.499		(33)(66)		-452	27	20	9.0	9.0				3.8	
Al-Mn-Mg	B209	Alclad 3004	A83004		0.500-2.000				-452	28	21	9.3				5.7		
Al-Mn-Mg Al-Mn-Mg	B209 B209	Alclad 3004 Alclad 3004	A83004 A83004		0.009-0.499 0.500-1.000				-452 -452	31 32	24 25		10.3 10.7					
Al-1.5Mg	B209	5050	A95050		•••		(22)		-452 452	18	6	4.0				4.0		
Al-1.5Mg Al-1.5Mg	B209	5050 5050	A95050		•••	21	(33) (33)		-452 -452	20 22	8 16	5.3 7.3				5.2 5.3		
Al-1.5Mg	B209 B209	5050	A95050 A95050		• • •		(33)		-452 -452	25	20	8.3				5.3		
אוכיד "י	5207	5050	11,70,70	T-1-1-1	•••	21	(33)		432	23	20	0.7	ر.ں	0.)	, .0	ر.ر	2.0	1.4
Al-2.5Mg	B209	5052	A95052	0		22			-452	25	9.5	6.3	6.3	6.3	6.2	6.1	4.1	2.3
Al-2.5Mg	B209	5652	A95652						-452	25	9.5	6.3				6.1		
Al-2.5Mg	B209	5052	A95052		0.500-3.000		(13)(33)		-452	25	9.5	6.3				6.1		
Al-2.5Mg	B209	5652	A95652		0.500-3.000				-452	25	9.5	6.3				6.1		
Al-2.5Mg	B209	5052	A95052		• • •		(33)		-452	31	23		10.3					
Al-2.5Mg	B209	5652	A95652		• • •		(33)		-452	31	23		10.3					
Al-2.5Mg	B209	5052	A95052		• • •	22			-452	34	26 26		11.3					
Al-2.5Mg	B209	5652	A95652	H34	• • •	22	(33)		-452	34	26	11.3	11.3	11.3	11.3	6.1	4.1	2.3

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

												Basic				S, ks [Note	1 .	Metal
Nominal			UNS	Class/ Condition/	Size or Thickness	P-No.			Min. Temp.,	Spec Mi Streng	n.	Min. Temp. to						
Composition	Spec. No.	Type/Grade	No.	Temper	Range, in.	(5)		Notes		Tensile	Yield	100	150	200	250	300	350	400
Aluminum <i>I</i> Plates an		nt'd) s (Cont'd)																
Al-4.4Mg-Mn	B209	5083	A95083	0	0.051-1.500	25	(13)		-452	40	18	12.0	12.0					
Al-4.4Mg-Mn	B209	5083	A95083		0.188-1.500		(13)(33)		-452	44	31		14.7					
Al-4.0Mg-Mn	B209	5086	A95086		•••	25			-452	35	14	9.3			• • •	• • •	• • •	• • •
Al-4.0Mg-Mn	B209	5086	A95086		0.500-1.000	25	(13)(33)		-452	35	16	9.3			• • •		• • •	• • •
Al-4.0Mg-Mn	B209	5086	A95086		• • •	25	(33)		-452	40	28		13.3				• • •	• • •
Al-4.0Mg-Mn	B209	5086	A95086	H34	•••	25	(33)		-452	44	34	14.7	14.7	• • •	• • •	• • •	• • •	• • •
Al-3.5Mg	B209	5154	A95154	0		22			-452	30	11	7.3	7.3					
Al-3.5Mg	B209	5254	A95254	0		22			-452	30	11	7.3	7.3					
Al-3.5Mg	B209	5154	A95154	H112	0.500-3.000	22	(13)(33)		-452	30	11	7.3	7.3					
Al-3.5Mg	B209	5254	A95254	H112	0.500-3.000	22	(13)(33)		-452	30	11	7.3	7.3					
Al-3.5Mg	B209	5154	A95154	H32		22	(33)		-452	36	26	12.0	12.0					
Al-3.5Mg	B209	5254	A95254	H32		22	(33)		-452	36	26	12.0	12.0					
Al-3.5Mg	B209	5154	A95154	H34		22	(33)		-452	39	29	13.0	13.0					
Al-3.5Mg	B209	5254	A95254	H34	• • •	22	(33)		-452	39	29	13.0	13.0	• • •	• • •	• • •	• • •	• • •
Al-2.7Mg-Mn	B209	5454	A95454	0		22			-452	31	12	8.0	8.0	8.0	7.4	5.5	4.1	3.0
Al-2.7Mg-Mn	B209	5454	A95454		0.500-3.000	22	(13)(33)		-452	31	12	8.0	8.0				4.1	
Al-2.7Mg-Mn	B209	5454	A95454			22	(33)		-452	36	26	12.0	12.0				4.1	
Al-2.7Mg-Mn	B209	5454	A95454			22	(33)		-452	39	29		13.0					3.0
Al-5.1Mg-Mn	B209	5456	A95456	0	0.051-1.500	25	(13)		-452	42	19	127	12.7					
Al-5.1Mg-Mn	B209	5456	A95456		0.188-0.499	25	(13)(33)		-452 -452	46	33		15.3					
_																		
Al-Mg-Si-Cu	B209	6061	A96061			23	(33)(63)		-452	30	16		10.0				8.4	
Al-Mg-Si-Cu	B209	6061	A96061		•••	23	(33)		-452	42	35	14.0	14.0				8.9	
Al-Mg-Si-Cu	B209	6061	A96061		0.250-4.000	23	(13)(33)		-452	42	35	14.0			13.6		8.9	
Al-Mg-Si-Cu	B209	6061	A96061		• • •	23	(22)(63)		-452	24	• • •	8.0	8.0		8.0		6.9	
Al-Mg-Si-Cu	B209	6061	A96061	16 wld.	• • •	23	(22)(63)		-452	24	• • •	8.0	8.0	8.0	8.0	7.7	6.9	5.1
Al-Mg-Si-Cu	B209	Alclad 6061	A86061	T4		23	(33)(66)		-452	27	14	9.0	9.0	9.0	8.9	8.6	7.6	5.2
Al-Mg-Si-Cu	B209	Alclad 6061	A86061		0.250-0.499	23	(33)(66)		-452	27	14	9.0	9.0	9.0			7.6	
Al-Mg-Si-Cu	B209	Alclad 6061	A86061		0.500-3.000		(33)(68)		-452	30	16	9.0	9.0			8.5		
Al Ma Ci Cu	P200	Alclad 6061	A86061	Т/		22	(22)(66)		452	20	22	12.7	127	127	122	10.6	0 1	r 2
Al-Mg-Si-Cu	B209				0.350.0400	23	(33)(66)		-452	38	32		12.7					
Al-Mg-Si-Cu	B209	Alclad 6061	A86061		0.250-0.499	23	(33)(66)		-452	38	32		12.7					
Al-Mg-Si-Cu	B209	Alclad 6061	A86061		0.500-4.000		(33)(68)		-452	42	35	14.0						5.2
Al-Mg-Si-Cu	B209	Alclad 6061 Alclad 6061	A86061		• • •		(22)(63)		-452	24	• • •	8.0						5.1
Al-Mg-Si-Cu	B209	Alcidu 0001	A86061	ib wiu.	•••	23	(22)(63)		-452	24	•••	8.0	0.0	0.0	0.0	7.7	0.9	5.1
Forgings	and Fitti	ngs																
Al-Mn-Cu	B247	3003	A93003			21	(9)(45)		-452	14	5	3.3						1.5
Al-Mn-Cu	B247	3003	A93003	H112 wld.		21	(9)(45)		-452	14	5	3.3	3.2	3.1	3.0	2.7	1.9	1.5
Al-Mn-Cu	B247	5083	A95083	0		25	(9)(32)(3	3)	-452	39	16	10.7	10.7					
Al-Mn-Cu	B247	5083	A95083	H112		25	(9)(32)(3	3)	-452	39	16		10.7					
Al-Mn-Cu	B247	5083	A95083	H112 wld.	•••	25	(9)(32)(3	3)	-452	39	16	10.7	10.7					
Al-Mg-Si-Cu	B247	6061	A96061	T6		23	(9)(33)		-452	38	35	12.7	12.7	12.7	12.3	10.5	8.1	5.2
Al-Mg-Si-Cu	B247	6061	A96061	T6 wld.		23	(9)(22)		-452	24		8.0	8.0	8.0	8.0	7.7	6.9	5.1

Table A-1 Basic Allowable Stresses in Tension for Metals (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

											Basic	Allowa Tempe				1 .	Metal
Nominal			UNS	Class/ Condition/	Size or Thickness	P-No.		Min. Temp.,	Spec Mi Streng	n.	Min. Temp. to						
Composition	Spec. No.	Type/Grade	No.	Temper	Range, in.	(5)	Notes	°F (6)	Tensile	Yield	100	150	200	250	300	350	400
Aluminum / Forgings		nt'd) ngs (Cont'd)															
99.60Al	B361	WP1060	A91060	0		21	(13)(14)(32)(33)	-452	8	2.5	1.7	1.6	1.6	1.4	1 2	1.1	0.8
99.60Al	B361	WP1060	A91060			21	(13)(14)(32)(33)	-452	8	2.5	1.7	1.6	1.6	1.4			0.8
99.0Al-Cu	B361	WP1100	A91100	0		21	(13)(14)(32)(33)	-452	11	3	2.0	2.0	2.0	1.9	1.7	1.3	1.0
99.0Al-Cu	B361	WP1100	A91100			21	(13)(14)(32)(33)	-452	11	3	2.0	2.0	2.0	1.9	1.7	1.3	1.0
Al-Mn-Cu	B361	WP3003	A93003			21	(13)(14)(32)(33)	-452	14	5	3.3	3.2	3.1	3.0		1.9	
Al-Mn-Cu	B361	WP3003	A93003		• • •	21	(13)(14)(32)(33)	-452	14	5	3.3	3.2	3.1	3.0		1.9	
Al-Mn-Cu	B361	WP Alclad 3003	A83003	0		21	(13)(14)(32)(33)(66)	-452	13	4.5	3.0	2.9	2.8	2.7	2.5	1.9	1.5
Al-Mn-Cu	B361	WP Alclad 3003	A83003	H112	• • •	21	(13)(14)(32)(33)(66)	-452	13	4.5	3.0	2.9	2.8	2.7	2.5	1.9	1.5
Al-4.4Mg-Mn	B361	WP5083	A95083	0		25	(13)(32)(33)	-452	39	16	10.7	10.7					
Al-4.4Mg-Mn	B361	WP5083	A95083	H112	• • •	25	(13)(32)(33)	-452	39	16	10.7	10.7		• • •		• • •	• • •
Al-3.5Mg	B361	WP5154	A95154	0		22	(32)(33)	-452	30	11	7.3	7.3					
Al-3.5Mg	B361	WP5154	A95154	H112	• • • •	22	(32)(33)	-452	30	11	7.3	7.3	• • •	• • •	• • •	• • •	• • •
Al-Mg-Si-Cu	B361	WP6061	A96061	T4	•••	23	(13)(32)(33)(63)	-452	26	16	8.7	8.7	8.7	8.7	8.3	7.4	5.2
Al-Mg-Si-Cu	B361	WP6061	A96061	T6		23	(13)(32)(33)(63)	-452	38	35	12.7	12.7	12.7	12.3	10.5	8.1	5.2
Al-Mg-Si-Cu	B361	WP6061	A96061	T4 wld.		23	(22)(32)(63)	-452	24		8.0	8.0	8.0	8.0	7.7	6.9	5.1
Al-Mg-Si-Cu	B361	WP6061	A96061	T6 wld.	• • •	23	(22)(32)(63)	-452	24	•••	8.0	8.0	8.0	8.0	7.7	6.9	5.1
Al-Mg-Si	B361	WP6063	A96063	T4	•••	23	(13)(32)(33)	-452	18	9	6.0	5.9	5.8	5.7	5.5	3.7	1.4
Al-Mg-Si	B361	WP6063	A96063	T6		23	(13)(32)(33)	-452	30	25	10.0	10.0	10.0	9.1	7.2	3.4	2.0
Al-Mg-Si	B361	WP6063	A96063	T4 wld.		23	(32)	-452	17		5.7	5.7	5.7	5.7	5.5	3.8	2.0
Al-Mg-Si	B361	WP6063	A96063	T6 wld.	• • •	23	(32)	-452	17	•••	5.7	5.7	5.7	5.7	5.5	3.8	2.0
Castings	(2)																
Al-Si	B26	443.0	A04430	F			(9)(43)	-452	17	7	4.7	4.7	4.7	4.7	4.7	4.7	3.5
Al-Si-Mg	B26	356.0	A03560				(9)(43)	-452	30	20	10.0	10.0		8.4			
Al-Si-Mg	B26	356.0	A03560	T74			(9)(43)	-452	25	18	8.3				7.3	5.5	2.4

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric)

(16)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Notes	Min. Temp., °C (6)	Min. Tensile Strgth., MPa	Min. Yield Strgth., MPa	Max. Use Temp., °C
1	Fe	Castings	A48	20	F11401		(2)(8e)(48)	-29	138		204
2	Fe	Castings	A278	20	F11401		(2)(8e)(48)	-29	138		204
3	Fe	Castings	A126	Α	F11501		(2)(8e)(9)(48)	-29	145	• • •	204
4	Fe	Castings	A48	25	F11701		(2)(8e)(48)	-29	172		204
5	Fe	Castings	A278	25	F11701	•••	(2)(8e)(48)	-29	172	• • •	204
	Fe	Castings	A48	30	F12101		(2)(8e)(48)	-29	207		204
7	Fe	Castings	A278	30	F12101	• • •	(2)(8e)(48)	-29	207	• • •	204
8	Fe	Castings	A126	В	F12102	•••	(2)(8e)(9)(48)	-29	214	• • •	204
9	Fe	Castings	A48	35	F12401		(2)(8e)(48)	-29	241		204
10	Fe	Castings	A278	35	F12401	• • •	(2)(8e)(48)	-29	241	• • • •	204
11	Fe	Castings	A48	40	F12801		(2)(8e)(9)(48)	-29	276		204
12	Fe	Castings	A126	C	F12802		(2)(8e)(9)(48)	-29	283		204
13	Fe	Castings	A278	40	F12803		(2)(8e)(9)(53)	-29	276	•••	343
14	Fe	Castings	A48	45	F13101		(2)(8e)(48)	-29	310		204
15	Fe	Castings	A48	50	F13501		(2)(8e)(48)	-29	345		204
16	Fe	Castings	A278	50	F13502	• • •	(2)(8e)(53)	-29	345		343
17	Fe	Castings	A48	55	F13801		(2)(8e)(48)	-29	379		204
18	Fe	Castings	A48	60	F14101		(2)(8e)(48)	-29	414		204
19	Fe	Castings	A278	60	F14102	• • •	(2)(8e)(53)	-29	414	•••	343
20	Fe	Castings	A197		F22000		(2)(8e)(9)	-29	276	207	343
21	Fe	Castings	A47	32510	F22200	• • •	(2)(8e)(9)	-29	345	224	343
22	Fe	Castings	A395	60-40-18	F32800		(2)(8d)(9)	-29	414	276	343
23	Fe	Castings	A571	D-2M	F43010	1	(2)(8d)	-29	448	207	40
24	Fe	Castings	A536	65-45-12	F33100		(2)(8d)(9)	-29	448	310	260

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Min. Line Temp. to 40 125 150 No. 65 100 175 200 225 250 275 300 325 350 13.8 13.8 13.8 13.8 13.8 13.8 13.8 13.8 2 13.8 13.8 13.8 13.8 13.8 13.8 13.8 13.8 3 13.8 13.8 13.8 13.8 13.8 13.8 13.8 13.8 17.2 17.2 17.2 17.2 17.2 17.2 17.2 17.2 5 17.2 17.2 17.2 17.2 17.2 17.2 17.2 17.2 6 20.7 20.7 20.7 20.7 20.7 20.7 20.7 20.7 7 20.7 20.7 20.7 20.7 20.7 20.7 20.7 20.7 8 20.7 20.7 20.7 20.7 20.7 20.7 20.7 20.7 . . . 9 24.1 24.1 24.1 24.1 24.1 24.1 24.1 24.1 10 24.1 24.1 24.1 24.1 24.1 24.1 24.1 24.1 11 27.6 27.6 27.6 27.6 27.6 27.6 27.6 27.6 12 27.6 27.6 27.6 27.6 27.6 27.6 27.6 27.6 13 27.6 27.6 27.6 27.6 27.6 27.6 27.6 27.6 27.6 27.6 27.6 27.6 27.6 14 31.0 31.0 31.0 31.0 31.0 31.0 31.0 31.0 15 34.5 34.5 34.5 34.5 34.5 34.5 34.5 34.5 34.5 34.5 16 34.5 34.5 34.5 34.5 34.5 34.5 34.5 34.5 34.5 34.5 34.5 17 37.9 37.9 37.9 37.9 37.9 37.9 37.9 37.9 18 41.4 41.4 41.4 41.4 41.4 41.4 41.4 41.4 19 41.4 41.4 41.4 41.4 41.4 41.4 41.4 41.4 41.4 41.4 41.4 41.4 41.4 20 *55.2* 55.2 55.2 55.2 55.2 55.2 55.2 55.2 55.2 55.2 55.2 *55.2* 55.2 21 68.9 68.9 68.9 68.9 68.9 68.9 68.9 68.9 68.9 68.9 68.9 68.9 68.9 22 128 125 122 119 116 109 106 98.0 93.5 137 133 112 103 23 138 24 149 149 148 148 149 149 149 149 148 147

(16)

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

(16)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Cond./ Temper	Size, mm	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
1	Carbon steel	Pipe & tube	A134					1	(2)(8b)(57)	В	310	165	482
2	Carbon steel	Pipe & tube	A672	A45	K01700			1	(2)(57)(59)(67)	В	310	165	593
3	Carbon steel	Pipe & tube	API 5L	A25				1	(2)(8a)(77)	-29	310	172	204
4	Carbon steel	Pipe & tube	API 5L	A25				1	(2)(57)(59)(77)	В	310	172	204
5	Carbon steel	Pipe & tube	A179		K01200			1	(2)(57)(59)	-29	324	179	593
6	Carbon steel	Pipe & tube	A53	Α	K02504			1	(2)(8a)	-7	331	207	204
	Carbon steel	Pipe & tube	A139	Α				1	(2)(8b)	A	331	207	149
8	Carbon steel	Pipe & tube	A587		K11500			1	(2)(57)(59)	-29	331	207	454
9	Carbon steel	Pipe & tube	A53	Α	K02504			1	(2)(57)(59)	В	331	207	593
10	Carbon steel	Pipe & tube	A106	Α	K02501			1	(2)(57)	В	331	207	593
11	Carbon steel	Pipe & tube	A135	Α				1	(2)(57)(59)	В	331	207	593
12	Carbon steel	Pipe & tube	A369	FPA	K02501			1	(2)(57)	В	331	207	593
13	Carbon steel	Pipe & tube	API 5L	Α				1	(2)(57)(59)	В	331	207	593
14	Carbon steel	Pipe & tube	A134					1	(2)(8b)(57)	В	345	186	482
15	Carbon steel	Pipe & tube	A672	A50	K02200			1	(2)(57)(59)(67)	В	345	186	593
	Carbon steel	Pipe & tube	A134	• • •				1	(2)(8b)(57)	Α	379	207	482
17	Carbon steel	Pipe & tube	A524	II	K02104	• • •	• • •	1	(2)(57)	-29	379	207	538
18	Carbon steel	Pipe & tube	A333	1	K03008	• • •		1	(2)(57)(59)	-46	379	207	593
19	Carbon steel	Pipe & tube	A334	1	K03008	• • •	• • •	1	(2)(57)(59)	-46	379	207	593
	Carbon steel	Pipe & tube	A671	CA55	K02801	• • •	• • •	1	(2)(59)(67)	Α	379	207	593
21	Carbon steel	Pipe & tube	A672	A55	K02801	• • •	• • •	1	(2)(57)(59)(67)	Α	379	207	593
22	Carbon steel	Pipe & tube	A672	C55	K01800		• • •	1	(2)(57)(67)	C	379	207	593
	Carbon steel	Pipe & tube	A671	CC60	K02100	• • •	• • •	1	(2)(57)(67)	С	414	221	538
	Carbon steel	Pipe & tube	A671	CB60	K02401	• • •	• • •	1	(2)(57)(67)	В	414	221	593
	Carbon steel	Pipe & tube	A672	B60	K02401	• • •	• • •	1	(2)(57)(67)	В	414	221	593
26	Carbon steel	Pipe & tube	A672	C60	K02100	• • •	•••	1	(2)(57)(67)	С	414	221	593
27	Carbon steel	Pipe & tube	A139	В	K03003			1	(2)(8b)	Α	414	241	149
	Carbon steel	Pipe & tube	A135	В	K03018	• • • •	• • •	1	(2)(57)(59)	В	414	241	538
29	Carbon steel	Pipe & tube	A524	1	K02104	• • • •	• • •	1	(2)(57)	-29	414	241	538

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Min. Temp. to 40 150 200 250 300 350 400 425 450 475 500 No. 65 100 325 525 575 103 103 101 97.5 94.6 90.8 86.1 83.6 81.1 78.6 73.3 64.0 55.8 43.9 40.7 . . . 103 103 101 97.5 94.6 90.8 86.1 83.6 81.1 78.6 73.3 64.0 55.8 43.9 31.7 21.4 14.2 9.40 6.89 98.5 103 103 103 102 103 103 103 102 98.5 108 108 108 106 102 98.3 93.3 90.6 64.0 43.9 31.7 21.4 6.89 87.8 84.3 73.3 110 110 110 110 110 110 110 110 110 110 110 110 110 110 110 108 105 97.0 84.3 73.3 64.0 55.8 54.5 110 108 105 84.3 73.3 64.0 43.9 31.7 6.89 110 110 110 110 110 97.0 55.8 21.4 9.40 110 110 21.4 6.89 10 110 110 110 110 108 105 97.0 84.3 73.3 64.0 55.8 43.9 31.7 14.2 9.40 11 110 110 105 97.0 84.3 73.3 64.0 55.8 43.9 31.7 21.4 14.2 9.40 6.89 110 110 110 110 108 12 110 110 110 110 110 110 108 105 97.0 84.3 73.3 64.0 55.8 43.9 31.7 21.4 14.2 9.40 6.89 13 110 110 110 110 110 110 108 105 97.0 84.3 73.3 64.0 55.8 43.9 31.7 21.4 14.2 9.40 6.89 14 115 115 113 110 106 102 96.9 94.1 91.2 84.3 73.3 64.0 55.8 43.9 40.7 . . . 15 115 115 113 110 106 102 96.9 94.1 91.2 84.3 73.3 64.0 55.8 43.9 31.7 21.4 14.2 9.40 6.89 16 126 126 126 122 118 113 108 105 101 98.3 89.0 75.3 62.1 45.0 40.7 17 126 126 126 122 118 113 108 105 101 98.3 89.0 75.3 62.1 45.0 31.7 21.4 17.2 126 122 118 105 98.3 89.0 75.3 62.1 45.0 31.7 21.4 14.2 9.40 6.89 18 126 126 113 108 101 19 126 126 118 108 105 101 98.3 89.0 75.3 62.1 45.0 31.7 21.4 14.2 9.40 6.89 126 122 113 20 126 126 126 122 118 113 108 105 101 98.3 89.0 75.3 62.1 45.0 31.7 21.4 9.40 6.89 75.3 31.7 21.4 14.2 9.40 6.89 21 126 126 126 122 118 113 108 105 101 98.3 89.0 62.1 45.0 22 105 101 98.3 89.0 75.3 62.1 45.0 31.7 21.4 14.2 9.40 6.89 126 126 126 122 118 113 108 95.1 79.5 31.7 21.4 17.2 23 138 138 134 130 126 121 115 111 108 105 62.6 45.0 95.1 79.5 62.6 45.0 31.7 21.4 14.2 9.40 6.89 24 138 138 134 130 126 121 111 108 105 115 45.0 31.7 21.4 9.40 6.89 25 138 138 134 130 126 121 115 111 108 105 79.5 62.6 26 138 138 134 130 126 121 115 111 108 105 95.1 79.5 62.6 45.0 31.7 21.4 14.2 9.40 6.89 27 138 138 138 138

219

45.0

45.0

31.7

31.7

21.4

21.4

17.2

62.6

62.6

138

138

138

138

138

138

132

132

126

126

122

122

118

118

95.1

95.1

79.5

79.5

113

113

138

138

28 *138*

29 138

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Cond./ Temper	Size, mm	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
30	Carbon steel	Pipe & tube	A53	В	K03005			1	(2)(57)(59)	В	414	241	593
31	Carbon steel	Pipe & tube	A106	В	K03006			1	(2)(57)	В	414	241	593
32	Carbon steel	Pipe & tube	A333	6	K03006			1	(2)(57)	-46	414	241	593
33	Carbon steel	Pipe & tube	A334	6	K03006			1	(2)(57)	-46	414	241	593
34	Carbon steel	Pipe & tube	A369	FPB	K03006			1	(2)(57)	-29	414	241	593
35	Carbon steel	Pipe & tube	A381	Y35				1	(2)	Α	414	241	593
36	Carbon steel	Pipe & tube	API 5L	В	• • • •	• • • •		1	(2)(57)(59)(77)	В	414	241	593
37	Carbon steel	Pipe & tube	A139	С	K03004			1	(2)(8b)	Α	414	290	149
38	Carbon steel	Pipe & tube	A139	D	K03010			1	(2)(8b)	Α	414	317	149
39	Carbon steel	Pipe & tube	API 5L	X42				1	(2)(55)(77)	Α	414	290	204
40	Carbon steel	Pipe & tube	A381	Y42		• • •		1	(2)	Α	414	290	204
41	Carbon steel	Pipe & tube	A381	Y48				1	(2)	Α	427	331	343
42	Carbon steel	Pipe & tube	API 5L	X46				1	(2)(55)(77)	Α	434	317	204
43	Carbon steel	Pipe & tube	A381	Y46		• • •		1	(2)	Α	434	317	204
44	Carbon steel	Pipe & tube	A381	Y50				1	(2)	Α	441	345	343
45	Carbon steel	Pipe & tube	A671	CC65	K02403			1	(2)(57)(67)	В	448	241	538
46	Carbon steel	Pipe & tube	A671	CB65	K02800			1	(2)(57)(67)	Α	448	241	593
47	Carbon steel	Pipe & tube	A672	B65	K02800			1	(2)(57)(67)	Α	448	241	593
48	Carbon steel	Pipe & tube	A672	C65	K02403	• • •	• • •	1	(2)(57)(67)	В	448	241	593
49	Carbon steel	Pipe & tube	A139	E	K03012			1	(2)(8b)	Α	455	359	149
50	Carbon steel	Pipe & tube	API 5L	X52				1	(2)(55)(77)	Α	455	359	204
51	Carbon steel	Pipe & tube	A381	Y52	• • •	• • •	• • •	1	(2)	Α	455	359	204
52	Carbon steel	Pipe & tube	A671	CC70	K02700			1	(2)(57)(67)	В	483	262	538
53	Carbon steel	Pipe & tube	A671	CB70	K03101			1	(2)(57)(67)	Α	483	262	593
54	Carbon steel	Pipe & tube	A672	B70	K03101			1	(2)(57)(67)	Α	483	262	593
55	Carbon steel	Pipe & tube	A672	C70	K02700			1	(2)(57)(67)	В	483	262	593
56	Carbon steel	Pipe & tube	A106	C	K03501			1	(2)(57)	В	483	276	427
57	Carbon steel	Pipe & tube	A671	CD70	K12437		≤64	1	(2)(67)	D	483	345	371
58	Carbon steel	Pipe & tube	A672	D70	K12437		≤64	1	(2)(67)	D	483	345	371
59	Carbon steel	Pipe & tube	A691	CMSH-70	K12437	• • •	≤64	1	(2)(67)	D	483	345	371

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Cond./ Temper		P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
60	Carbon steel	Pipe & tube	API 5L	X56				1	(2)(51)(55)(71)(77)	A	490	386	204
		·											
61	Carbon steel	Pipe & tube	A381	Y56				1	(2)(51)(55)(71)	Α	490	386	204
62	Carbon steel	Pipe & tube	A671	CK75	K02803		>25	1	(2)(57)(67)	Α	517	276	593
63	Carbon steel	Pipe & tube	A672	N75	K02803		>25	1	(2)(57)(67)	Α	517	276	593
64	Carbon steel	Pipe & tube	A691	CMS-75	K02803	• • •	>25	1	(2)(57)(67)	Α	517	276	593
					.,								
	Carbon steel	Pipe & tube	A671	CK75	K02803	•••	≤25	1	(2)(57)(67)	A	517	290	371
	Carbon steel	Pipe & tube	A672	N75	K02803	•••	≤25	1	(2)(57)(67)	A	517	290	371
67	Carbon steel	Pipe & tube	A691	CMS-75	K02803	• • •	≤25	1	(2)(57)(67)	Α	517	290	371
68	Carbon steel	Pipe & tube	API 5L	X60				1	(2)(51)(55)(71)(77)	Α	517	414	204
	Carbon steel	Pipe & tube	API 5L					1	(2)(51)(55)(71)(77)	Α	531	448	204
	Carbon steel	Pipe & tube	API 5L					1	(2)(51)(55)(71)(77)	Α	565	483	204
	Carbon steel	Pipe & tube	API 5L					1	(2)(51)(55)(71)(77)	Α	621	552	204
, 1	carbon steet	Tipe a tabe	711132	7,00	•••	•••	•••	•	(2)(31)(33)(11)(11)	,,	021	332	204
72	Carbon steel	Pipe & tube	A381	Y60				1	(2)(51)(71)	Α	517	414	204
		•											
73	Carbon steel	Pipe	A134					1	(2)(8a)(8c)	-29	311	165	204
74	Carbon steel	Pipe	A134					1	(2)(8a)(8c)	-29	338	207	204
75	Carbon steel	Pipe	A134	• • •	• • •	• • •	• • •	1	(2)(8a)(8c)	-29	345	186	149
76	Carbon steel	Pipe	A134	• • •	• • •	• • • •	• • •	1	(2)(8a)(8c)	-29	359	228	204
	Carlor at a d	D'	1127						(2)(2,)(2,)	20	275	2/0	201
//	Carbon steel	Pipe	A134	• • •	• • • •	•••	•••	1	(2)(8a)(8c)	-29	365	248	204
70	Carbon steel	Pipe	A134					1	(2)(8a)(8c)	-29	379	276	204
70	Carbon steet	ripe	A1)4	•••	•••	• • • •	•••	1	(2)(8a)(8c)	23	313	270	204
79	Carbon steel	Pipe	A134					1	(2)(8a)(8c)	-29	400	248	204
,,	carbon steet	Tipe	71154	•••	•••	•••	•••	•	(2)(04)(00)		400	240	204
80	Carbon steel	Pipe	A134					1	(2)(8a)(8c)	-29	414	228	149
	Carbon steel	Pipe	A134					1	(2)(8a)(8c)	-29	414	310	204
		·											
82	Carbon steel	Pipe	A134					1	(2)(8a)(8c)	-29	448	345	204
83	Carbon steel	Plate, bar, shps., sheet	A285	Α	K01700			1	(57)(59)	В	310	165	593
84	Carbon steel	Plate, bar, shps., sheet	A285	В	K02200	• • • •	• • •	1	(57)(59)	В	345	186	593
85	Carbon steel	Plate, bar, shps., sheet	A516	55	K01800	• • • •	• • •	1	(57)	С	379	207	454
	l												

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

No.	Min. Temp. to 40	65 163	100																
60	163		100	1 []	200	250	200	225	250	275	400	425	450	475	E00	E2F	EF0	. 7 .	600
		163	1/2	150	200	250	300	325	350	375	400	425	450	475	500	525	550	575	600
	163		163	163	163	• • •	• • • •	•••	• • • •	•••	•••	• • •	•••	•••	• • •	•••	• • •	•••	•••
61		163	163	163	163														
62	172	172	168	163	158	151	144	139	135	131	107	88.0	67.3	50.3	33.2	21.4	14.2	9.40	6.89
63	172	172	168	163	158	151	144	139	135	131	107	88.0	67.3	50.3	33.2	21.4	14.2	9.40	6.89
64	172	172	168	163	158	151	144	139	135	131	107	88.0	67.3	50.3	33.2	21.4	14.2	9.40	6.89
65	172	172	172	171	165	159	151	146	142	131									
66	172	172	172	171	165	159	151	146	142	131									
67	172	172	172	171	165	159	151	146	142	131	•••	•••	•••	•••	•••	•••	•••	•••	•••
68	172	172	172	172	172														
69	177	177	177	177	177			• • •	• • •		• • •	• • •	• • •	• • •			• • •	• • •	• • •
70	188	188	188	188	188	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
71	207	207	207	207	207	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••
72	172	172	172	172	172					•••		•••				•••	•••	•••	
73	103	103	101	97.5	94.6			•••		• • •		• • •	•••	•••	•••	• • •	• • •	•••	•••
74	113	113	113	113	113														
75	115	115	113	110		•••		•••				• • •	•••			• • •	• • •		•••
76	120	120	120	120	120														
77	122	122	122	122	122														
78	126	126	126	126	126														
79	133	133	133	133	133				•••										
80	138	138	138	13/															
81	138	138	138	138	 138	• • •	• • • •	• • • •	• • • •	•••	• • • •	•••	•••	• • • •	• • •	•••	•••	•••	•••
01	150	150	150	150	150	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••
82	149	149	149	149	149	•••		•••	• • •	• • •	• • •	• • •	•••	• • • •	• • •	• • •	• • •	•••	• • • •
83	103	103	101	97.5	94.6	90.8	86.1	83.6	81.1	78.6	73.3	64.0	55.8	43.9	31.7	21.4	14.2	9.40	6.89
84	115	115	113	110	106	102	96.9	94.1	91.2	84.3	73.3	64.0	55.8	43.9	31.7	21.4	14.2	9.40	6.89
85	126	126	126	122	118	113	108	105	101	98.3	89.0	75.3	62.1	60.0		•••	•••	•••	

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Cond./ Temper	Size, mm	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
86	Carbon steel	Plate, bar, shps., sheet	A285	С	K02801			1	(57)(59)	Α	379	207	593
0.7	Carlanatari	Distriction above about	A.E.4.6		1/02400			4	(5.7)	c		224	,,,
	Carbon steel	Plate, bar, shps., sheet	A516	60	K02100	• • •	• • •	1	(57)	С	414	221	454
	Carbon steel	Plate, bar, shps., sheet	A515	60	K02401	• • •	• • •	1	(57)	В .	414	221	538
89	Carbon steel	Plate, bar, shps., sheet	A696	В	K03200	•••	• • •	1	(57)	А	415	240	371
90	Carbon steel	Plate, bar, shps., sheet	A516	65	K02403			1	(57)	В	448	241	454
91	Carbon steel	Plate, bar, shps., sheet	A515	65	K02800		• • •	1	(57)	Α	448	241	538
92	Carbon steel	Plate, bar, shps., sheet	A516	70	K02700			1	(57)	В	483	262	454
93	Carbon steel	Plate, bar, shps., sheet	A515	70	K03101			1	(57)	Α	483	262	538
	Carbon steel	Plate, bar, shps., sheet	A696	С	K03200			1	(57)	Α	485	275	371
	Carbon steel	Plate, bar, shps., sheet	A537		K12437	1	≤64	1		D	483	345	371
		, , . , . ,											
96	Carbon steel	Plate, bar, shps., sheet	A299	Α	K02803		>25	1	(57)	Α	517	276	593
97	Carbon steel	Plate, bar, shps., sheet	A299	Α	K02803		≤25	1	(57)	Α	517	290	593
98	Carbon steel	Plate, bar, shps., sheet	A283	Α	K01400			1	(8c)(57)	Α	310	165	399
99	Carbon steel	Plate, bar, shps., sheet	A1011	30	K02502			1	(8c)(57)	Α	338	207	399
100	Carbon steel	Plate, bar, shps., sheet	A283	В	K01702			1	(8c)(57)	Α	345	186	399
101	Carbon steel	Plate, bar, shps., sheet	A1011	33	K02502			1	(8c)(57)	Α	359	228	399
102	Carbon steel	Plate, bar, shps., sheet	A1011	36	K02502	• • • •	• • •	1	(8c)(57)	Α	365	248	399
103	Carbon steel	Plate, bar, shps., sheet	A283	С	K02401			1	(8c)(57)	Α	379	207	399
		•				• • •	• • •						
104	Carbon steel	Plate, bar, shps., sheet	A1011	40	K02502	•••	• • •	1	(8c)(57)	А	379	276	399
105	Carbon steel	Plate, bar, shps., sheet	A36		K02600			1	(8c)	Α	400	248	371
103	curbon steet	rate, bar, stips., street	7150	•••	ROZOGO	•••	•••	-	(00)	,,	400	240	3, 1
106	Carbon steel	Plate, bar, shps., sheet	A283	D	K02702			1	(8c)(57)	Α	414	228	399
107	Carbon steel	Plate, bar, shps., sheet	A1011	45	K02507			1	(8c)(57)	Α	414	310	399
108	Carbon steel	Plate, bar, shps., sheet	A1011	50	K02507			1	(8c)(57)	Α	448	344	399
109	Carbon steel	Plate, bar, shps., sheet	A992					1	(8c)(57)	Α	448	344	427
	Carbon steel	Forgings & fittings	A350	LF1	K03009	• • •		1	(9)(57)(59)	-29	414	207	538
111	Carbon steel	Forgings & fittings	A181	• • •	K03502	60	• • •	1	(9)(57)(59)	Α	414	207	593
112	Carbon steel	Forgings & fittings	A420	WPL6	K03006			1	(E 7)	-46	414	241	£30
112	Carbon Steet	i vigiligs a illliligs	A420	VVFLO	KU3006	•••	• • •	1	(57)	-40	414	241	538
113	Carbon steel	Forgings & fittings	A234	WPB	K03006			1	(57)(59)	В	414	241	593

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Cond./ Temper	Size, mm	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
114	Carbon steel	Forgings & fittings	A350	LF2	K03011	1		1	(9)(57)	-46	483	248	538
115	Carbon steel	Forgings & fittings	A350	LF2	K03011	2		1	(9)(57)	-18	483	248	538
116	Carbon steel	Forgings & fittings	A105	• • •	K03504		• • •	1	(9)(57)(59)	-29	483	248	593
117	Carbon steel	Forgings & fittings	A181	• • •	K03502	70		1	(9)(57)(59)	Α	483	248	593
118	Carbon steel	Forgings & fittings	A234	WPC	K03501			1	(57)(59)	В	483	276	427
119	Carbon steel	Castings	A216	WCA	J02502			1	(2)(57)	-29	414	207	593
120	Carbon steel	Castings	A352	LCB	J03003			1	(2)(9)(57)	-46	448	241	593
121	Carbon steel	Castings	A352	LCC	J02505			1	(2)(9)	-46	483	276	371
122	Carbon steel	Castings	A216	WCB	J03002			1	(2)(9)(57)	-29	483	248	593
123	Carbon steel	Castings	A216	WCC	J02503			1	(2)(9)(57)	-29	483	276	538

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Min. Line Temp. No. to 40 83.8 66.8 33.2 21.4 17.2 50.3 83.8 66.8 50.3 33.2 21.4 17.2 . . . 83.8 66.8 50.3 33.2 21.4 14.2 9.40 6.89 83.8 66.8 50.3 33.2 21.4 9.40 6.89 14.2 83.8 82.7 98.3 95.1 79.5 62.6 45.0 31.7 21.4 14.2 9.40 6.89 6.89 95.1 79.5 64.4 47.7 32.5 21.4 14.2 9.40 . . . 6.89 83.8 66.8 50.3 33.2 21.4 14.2 9.40 83.8 66.8 50.3 33.2 21.4 17.2

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
1	¹/₂Cr−¹/₂Mo	Pipe	A335	P2	K11547			3	(2)	-29	379	207	538
2	½Cr–½Mo	Pipe	A691	1/2CR	K12143	•••	•••	3	(2)(11)(67)	-29	379	228	538
3	C-1/2Mo	Pipe	A335	P1	K11522			3	(2)(58)	-29	379	207	593
4	C-1/2Mo	Pipe	A369	FP1	K11522			3	(2)(58)	-29	379	207	593
5	¹/₂Cr−¹/₂Mo	Pipe	A369	FP2	K11547			3	(2)	-29	379	207	593
6	1Cr−¹⁄₂Mo	Pipe	A691	1CR	K11757			4	(2)(11)(67)	-29	379	228	649
7	¹/₂Cr−¹/₂Mo	Pipe	A426	CP2	J11547			3	(2)(10)	-29	414	207	593
8	1½Si-½Mo	Pipe	A335	P15	K11578			3	(2)	-29	414	207	593
9	C-½Mo-Si	Pipe	A426	CP15	J11522	• • • •		3	(2)(10)	-29	414	207	593
10	1Cr−½Mo	Pipe	A426	CP12	J11562			4	(2)(10)	-29	414	207	649
11	5Cr–1½Si–½Mo	Pipe	A426	CP5b	J51545			5B	(2)(10)	-29	414	207	649
12	3Cr-Mo	Pipe	A426	CP21	J31545			5A	(2)(10)	-29	414	207	649
13	³/4Cr–³/4Ni–Cu–Al	Pipe	A333	4	K11267			4	(2)	-101	414	241	40
14	2Cr−¹⁄₂Mo	Pipe	A369	FP3b	K21509	• • •	• • •	4	(2)	-29	414	207	649
15	1Cr−¹⁄₂Mo	Pipe	A335	P12	K11562			4	(2)	-29	414	221	649
16	1Cr−¹⁄₂Mo	Pipe	A369	FP12	K11562	• • •	• • •	4	(2)	-29	414	221	649
17	1½Cr-½Mo-Si	Pipe	A335	P11	K11597			4	(2)	-29	414	207	649
18	1½Cr-½Mo-Si	Pipe	A369	FP11	K11597	• • •		4	(2)	-29	414	207	649
19	1½Cr-½Mo-Si	Pipe	A691	11/4CR	K11789			4	(2)(11)(67)	-29	414	241	649
20	5Cr−¹⁄₂Mo	Pipe	A691	5CR	K41545			5B	(2)(11)(67)	-29	414	207	649
21	5Cr–¹∕₂Mo	Pipe	A335	P5	K41545			5B	(2)	-29	414	207	649
22	5Cr-1/2Mo-Si	Pipe	A335	P5b	K51545			5B	(2)	-29	414	207	649
23	5Cr−½Mo−Ti	Pipe	A335	P5c	K41245			5B	(2)	-29	414	207	649
24	5Cr−¹⁄₂Mo	Pipe	A369	FP5	K41545			5B	(2)	-29	414	207	649
25	9Cr-1Mo	Pipe	A335	P9	K90941			5B	(2)	-29	414	207	649
26	9Cr-1Mo	Pipe	A369	FP9	K90941			5B	(2)	-29	414	207	649
27	9Cr-1Mo	Pipe	A691	9CR	K90941			5B	(2)(11)(67)	-29	414	207	649
28	3Cr-1Mo	Pipe	A335	P21	K31545			5A	(2)	-29	414	207	649
29	3Cr-1Mo	Pipe	A369	FP21	K31545			5A	(2)	-29	414	207	649
30	3Cr-1Mo	Pipe	A691	3CR	K31545			5A	(2)(11)(67)	-29	414	207	649

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
31	21/4Cr-1Mo	Pipe	A691	21/4CR	K21590			5A	(2)(11)(67)(72)(75)	-29	414	207	649
32	21/4Cr-1Mo	Pipe	A369	FP22	K21590			5A	(2)(72)(75)	-29	414	207	649
33	2½Cr-1Mo	Pipe	A335	P22	K21590	•••		5A	(2)(72)(75)	-29	414	207	649
34	2Ni-1Cu	Pipe	A333	9	K22035			9A	(2)	-73	434	317	40
35	2Ni-1Cu	Pipe	A334	9	K22035			9A	(2)	-73	434	317	40
36	21/4Ni	Pipe	A333	7	K21903			9A	(2)	-73	448	241	593
37	21/4Ni	Pipe	A334	7	K21903		•••	9A	(2)	-73	448	241	593
38	3½Ni	Pipe	A333	3	K31918			9B	(2)	-101	448	241	593
39	31∕2Ni	Pipe	A334	3	K31918	• • •	• • •	9B	(2)	-101	448	241	593
40	C-1/2Mo	Pipe	A426	CP1	J12521			3	(2)(10)(58)	-29	448	241	593
41	C-1/2M0	Pipe	A672	L65	K11820			3	(2)(11)(58)(67)	-29	448	255	593
42	C−¹⁄₂Mo	Pipe	A691	CM-65	K11820	•••	• • •	3	(2)(11)(58)(67)	-29	448	255	593
43	21/4Ni	Pipe	A671	CF70	K22103			9A	(2)(11)(65)(67)	-29	483	276	40
44	31∕2Ni	Pipe	A671	CF71	K32018	• • •	• • •	9B	(2)(11)(65)(67)	-29	483	276	40
45	C-1/2Mo	Pipe	A672	L70	K12020			3	(2)(11)(58)(67)	-29	483	276	593
46	C-1/2M0	Pipe	A691	CM-70	K12020	•••	• • •	3	(2)(11)(58)(67)	-29	483	276	593
47	1½Cr-½Mo	Pipe	A426	CP11	J12072			4	(2)(10)	-29	483	276	649
48	21/4Cr-1Mo	Pipe	A426	CP22	J21890	•••	•••	5A	(2)(10)(72)	-29	483	276	649
49	C-1/2Mo	Pipe	A672	L75	K12320			3	(2)(11)(58)(67)	-29	517	296	593
50	C-½Mo	Pipe	A691	CM-75	K12320	•••	• • •	3	(2)(11)(58)(67)	-29	517	296	593
51	9Cr-1Mo-V	Pipe	A335	P91	K90901		≤75	15E	(2)	-29	586	414	649
52	9Cr-1Mo-V	Pipe	A691	91	K90901	•••	≤75	15E	(2)(11)(67)	-29	586	414	649
	5Cr−¹⁄₂Mo	Pipe	A426		J42045			5B	(2)(10)	-29	621	414	649
54	9Cr-1Mo	Pipe	A426	CP9	J82090	•••	• • •	5B	(2)(10)	-29	621	414	649
	9Ni	Pipe	A333		K81340				(2)(47)	-196	689	517	93
56	9Ni	Pipe	A334	8	K81340	•••	• • •	11A	(2)	-196	689	517	93
	½Cr-½M0	Plate	A387	2	K12143	1		3	•••	-29	379	228	538
	1Cr−¹⁄₂Mo	Plate		12	K11757	1	• • •	4	• • •	-29	379	228	649
59	9Cr-1Mo	Plate	A387	9	K90941	1	•••	5		-29	414	207	649

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Min. Line Temp. No. to 40 65 100 125 150 175 200 225 250 275 300 325 350 375 400 425 450 99.6 80.9 63.3 47.5 34.2 23.5 15.3 9.65 138 32 121 99.6 80.9 63.3 47.5 34.2 23.5 15.3 9.65 33 138 34 145 35 36 149 149 147 144 142 140 138 135 132 128 124 119 113 107 95.1 79.5 64.4 48.8 35.4 22.6 14.2 9.40 6.89 37 149 147 144 142 140 138 135 132 128 124 119 113 107 95.1 79.5 64.4 48.8 35.4 22.6 14.2 9.40 6.89 38 149 149 147 144 142 140 138 135 132 128 124 119 113 107 **95.1 79.5 64.4 48.8 35.4 22.6 14.2 9.48 7.06** ... 149 149 147 144 142 140 138 135 132 128 124 119 113 107 95.1 79.5 64.4 48.8 35.4 22.6 14.2 9.48 7.06 39 40 149 149 149 148 145 143 140 138 137 135 133 131 129 126 123 120 117 109 68.0 42.3 30.5 23.2 16.5 41 149 149 149 149 149 149 148 146 144 142 140 138 136 133 131 127 124 109 68.0 42.3 30.5 23.2 16.5 149 149 149 149 149 148 146 144 142 140 138 136 133 131 127 124 109 68.0 42.3 30.5 23.2 16.5 42 43 44 161 45 161 161 161 161 161 161 161 161 158 156 154 152 149 147 144 141 138 134 109 68.0 42.3 30.5 23.2 16.5 161 161 161 161 161 161 161 158 156 154 152 149 147 144 141 138 134 109 68.0 42.3 30.5 23.2 16.5 ... 46 161 161 161 161 161 158 155 153 150 148 146 143 141 138 136 133 130 104 73.7 52.0 36.3 25.2 17.6 12.3 8.27 48 49 172 172 172 172 172 170 168 165 163 161 158 155 152 148 144 109 68.0 42.3 30.5 23.2 16.5 172 172 172 172 172 172 172 170 168 165 163 161 158 155 152 148 144 109 68.0 42.3 30.5 23.2 16.5 ... 50 195 195 195 195 195 195 195 195 195 194 193 192 190 187 183 178 172 165 156 147 137 115 87.0 64.7 45.1 29.6 195 195 195 195 195 195 195 195 195 194 193 192 190 187 183 178 172 165 156 147 137 115 87.0 64.7 45.1 29.6 52 207 205 202 200 199 199 199 198 198 196 194 191 187 182 176 169 80.6 61.7 46.4 34.7 25.5 17.8 11.4 6.89 207 207 205 202 200 199 199 199 198 198 196 194 191 187 182 176 169 160 87.5 61.2 42.9 29.9 20.6 14.4 10.3 54

126 126 126 126 126 126 126 126 126 126 125 123 121 119 116 114 110 107 **74.4 49.9 40.7**

126 126 123 122 122 122 121 120 118 116 115 114 112 110 109 106 104 92.1 61.1 40.4 26.4 17.4 11.6 7.58 129 124 122 120 119 119 118 118 117 117 116 114 112 110 106 103 98.3 **83.2 60.2 42.9 29.9 20.6 14.4 10.3**

230 230 230

230 230 230

55

56

58

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size,	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
60	1½Cr-½Mo-Si	Plate	A387	11	K11789	1		4		-29	414	241	649
61	5Cr-½Mo	Plate	A387	5	K41545	1		5B		-29	414	207	649
62	3Cr-1Mo	Plate	A387	21	K31545	1		5A		-29	414	207	649
63	21/4Cr-1Mo	Plate	A387	22	K21590	1	• • • •	5A	(72)	-29	414	207	649
64	21/4Ni	Plate	A203	Α	K21703			9A	(12)(65)	-29	448	255	538
65	3½Ni	Plate	A203	D	K31718	• • •	• • •	9B	(12)(65)	-29	448	255	538
66	C-1/2Mo	Plate	A204	Α	K11820			3	(58)	-29	448	255	593
67	1Cr−¹⁄₂Mo	Plate	A387	12	K11757	2	•••	4	•••	-29	448	276	649
68	21/4Ni	Plate	A203	В	K22103			9A	(12)(65)	-29	483	276	538
69	3½Ni	Plate	A203	E	K32018	• • •	• • •	9B	(12)(65)	-29	483	276	538
70	½Cr-1/2Mo	Plate	A387	2	K12143	2		3	• • •	-29	483	310	538
71	C-1/2M0	Plate	A204	В	K12020	• • •	• • •	3	(58)	-29	483	276	593
72	Mn-1/2Mo	Plate	A302	Α	K12021			3		-29	517	310	538
73	C-1/2M0	Plate	A204	C	K12320		• • •	3	(58)	-29	517	296	593
74	1½Cr-½Mo-Si	Plate	A387	11	K11789	2		4		-29	517	310	649
75	5Cr-1/2Mo	Plate	A387	5	K41545	2		5B		-29	517	310	649
76	3Cr-1Mo	Plate	A387	21	K31545	2	• • •	5A	• • •	-29	517	310	649
77	2 ¹ / ₄ Cr–1Mo	Plate	A387	22	K21590	2	• • •	5A	(72)	-29	517	310	649
78	Mn-1/2Mo	Plate	A302	В	K12022			3	• • •	-29	552	345	538
79	Mn-1/2Mo-1/2Ni	Plate	A302	C	K12039	•••		3	• • •	-29	552	345	538
80	Mn-1/2Mo-3/4Ni	Plate	A302	D	K12054	• • •	• • •	3	•••	-29	552	345	538
81	9Cr-1Mo-V	Plate	A387	91	K90901	2	≤75	15E	•••	-29	586	414	649
82	8Ni	Plate	A553	II	K71340			11A	(47)	-171	689	586	40
83	5Ni-1/4Mo	Plate	A645	Α	K41583		•••	11A	•••	-171	655	448	93
84	9Ni	Plate	A553	I	K81340			11A	(47)	-196	689	586	93
85	9Ni	Plate	A353	•••	K81340		•••	11A	(47)	-196	689	517	93
86	C-1/2M0	Forg. & ftg.	A234	WP1	K12821	• • •	•••	3	(58)	-29	379	207	593
87	1Cr−¹⁄₂Mo	Forg. & ftg.	A182	F12	K11562	1		4	(9)	-29	414	221	649
88	1Cr-½Mo	Forg. & ftg.	A234	WP12	K12062	1	• • • •	4	•••	-29	414	221	649
89	1½Cr-½Mo-Si	Forg. & ftg.	A182	F11	K11597	1		4	(9)	-29	414	207	649
90	1½Cr-½Mo-Si	Forg. & ftg.	A234	WP11	K11597	1	• • •	4	•••	-29	414	207	649

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

•						-	Jusic	711101	·ubic	J. 1. C.	,,,,	u	, at	- Ctat I	cinpe	racare	,	.0103	(I) and	(40)]					
	Min.																								
	Temp.	۲,	100	125	150	475	200	225	250	275	200	225	250	275	400	425	450	475	500	F 2 F		F 7 F	600	(25	(50
-	to 40																								
60																									
61																							17.8		
62																							25.1		
63	138	132	128	126	125	124	124	124	124	124	124	124	124	124	123	122	121	99.6	80.9	63.3	4/.5	34.2	23.5	15.3	9.65
64	149	149	149	149	149	148	146	143	140	136	131	126	120	113	95.1	79.5	64.4	48.8	35.4	22.6	17.2				
65	149	149	149	149	149	148	146	143	140	136	131	126	120	113	95.1	79.5	64.4	48.8	35.4	22.6	17.2				
66	149	149	149	149	149	149	148	146	144	142	140	138	136	133	131	127	124	109	68.0	42.3	30.5	23.2	16.5	• • •	• • •
67	149	149	146	144	144	144	144	144	144	143	141	139	138	136	134	132	129	126	92.1	61.1	40.4	26.4	17.4	11.6	7.58
68	161	161	161	161	161	160	158	155	151	147	142	136	130	113	95.1	79.5	64.4	48.8	35.4	22.6	17.2				
69																									
0)	101	101	101	101	101	100	1,00	100	171	177	172	150	100		-0-	05.0	00.0	77.2	JJ.4			•••	•••	•••	•••
70	161	161	161	161	161	161	161	161	161	161	161	161	161	161	159	155	151	146	93.5	49.9	40.7				
71	161	161	161	161	161	161	161	158	156	154	152	149	147	144	141	138	134	109	68.0	42.3	30.5	23.2	16.5		
72	170	172	172	172	172	170	172	170	172	170	170	170	171	1/0	165	160	154	404		42.2	22.4				
72																			68.0					• • •	• • •
73	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/0	168	165	163	161	158	155	152	148	144	109	68.0	42.3	30.5	23.2	16.5	• • •	• • •
74	172	172	172	172	172	172	172	172	169	166	164	161	159	156	153	149	146	104	73.7	52.0	36.3	25.2	17.6	12.3	8.27
75	172	172	171	169	167	166	165	165	165	164	164	162	159	156	130	126	104	80.6	61.7	46.4	34.7	25.5	17.8	11.4	6.89
76	172	172	171	168	167	167	167	167	167	167	167	167	167	167	167	167	167	98.2	73.5	54.7	40.6	29.2	20.6	15.2	8.96
77	172	172	171	168	167	167	167	167	167	167	167	167	167	167	167	167	167	119	88.4	64.0	44.6	30.0	19.7	12.8	8.27
78																			68.0			• • •	• • •	• • •	• • •
79																			68.0			• • •	• • •	• • •	• • •
80	184	184	184	184	184	184	184	184	184	184	184	184	184	184	183	178	172	104	68.0	42.3	33.1	• • •	• • •	• • •	• • •
81	195	195	195	195	195	195	195	195	194	193	192	190	187	183	178	172	165	156	147	137	115	87.0	64.7	45.1	29.6
									-		-														_,
82	230																								
83	218	218	218	• • •	• • •		• • •			• • •	• • •														
0.4	220	220	220																						
84											• • • •			•••		• • •	• • •	• • • •	• • •	• • • •	• • • •	• • •	• • •	• • • •	• • • •
85	230	230	230	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		• • • •	• • • •		• • • •	• • • •	• • • •	• • •	• • • •	• • • •	• • • •	• • • •
86	126	126	126	126	124	122	120	119	117	115	114	112	110	108	106	103	100	97.1	68.0	42.3	30.5	23.2	16.5		
87																									
88	138	138	132	128	125	122	120	118	116	114	113	112	110	109	107	105	103	101	92.1	61.1	40.4	26.4	17.4	11.6	7.58
80	138	131	126	124	121	119	116	115	113	111	109	107	106	104	102	99 6	97 2	94 5	73 7	52 N	36 3	25.2	17.6	123	8.27
90																									
70	1,70	1)1	120	144	141	11)	110	11)	11)	111	10)	107	100	104	102	,,.u) I . L	∠ + .J	, ,,,	22.0	ر.ن	23.2	17.0	12.7	0.27

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
91	2¹/4Cr-1Mo	Forg. & ftg.	A182	F22	K21590	1		5A	(9)(72)(75)	-29	414	207	649
92	2½Cr-1Mo	Forg. & ftg.	A234	WP22	K21590	1		5A	(72)	-29	414	207	649
93	5Cr−¹⁄₂Mo	Forg. & ftg.	A234	WP5	K41545			5B		-29	414	207	649
94	9Cr–1Mo	Forg. & ftg.	A234	WP9	K90941			5B		-29	414	207	649
95	31∕2Ni	Forg. & ftg.	A420	WPL3	K31918			9B		-101	448	241	343
96	3½Ni	Forg. & ftg.	A350	LF3	K32025	•••		9B	(9)	-101	483	259	343
97	½Cr–½Mo	Forg. & ftg.	A182	F2	K12122			3	(9)	-29	483	276	538
98	C-1/2Mo	Forg. & ftg.	A182	F1	K12822			3	(9)(58)	-29	483	276	593
0.0	16 1/11	F 0.6	4400	F4.0	14454				(0)	2.0		27.	
	1Cr-½Mo	Forg. & ftg.	A182		K11564	2	• • •	4	(9)	-29	483	276	649
100	1Cr−¹⁄₂Mo	Forg. & ftg.	A234	WP12	K12062	2	• • • •	4	•••	-29	483	276	649
101	1¹⁄₄Cr−¹⁄₂Mo−Si	Forg. & ftg.	A182	F11	K11572	2		4	(9)	-29	483	276	649
102	1¹/₄Cr−¹/₂Mo−Si	Forg. & ftg.	A234	WP11	K11572	2	• • •	4	•••	-29	483	276	649
103	5Cr−¹⁄₂Mo	Forg. & ftg.	A182	F5	K41545			5B	(9)	-29	483	276	649
104	3Cr-1Mo	Forg. & ftg.	A182	F21	K31545			5A	(9)	-29	517	310	649
105	2¹/₄Cr–1Mo	Forg. & ftg.	A182	F22	K21590	3		5A	(9)(72)	-29	517	310	649
106	2¹/4Cr-1Mo	Forg. & ftg.	A234	WP22	K21590	3		5A	(72)	-29	517	310	649
107	9Cr–1Mo	Forg. & ftg.	A182	F9	K90941			5B	(9)	-29	586	379	649
	9Cr–1Mo–V	Forg. & ftg.	A182	F91	K90901		≤75	15E		-29	586	414	649
	9Cr–1Mo–V	Forg. & ftg.	A234	WP91	K90901		_, s ≤75	15E		-29	586	414	649
	5Cr–½Mo	Forg. & ftg.	A182	F5a	K42544		_, _	5B	(9)	-29	621	448	649
111	•	Forg. & ftg.	A420	WPL8	K81340				(47)	-196	689	517	93
112	C−¹⁄2Mo	Castings	A252	1.61	14.25.22			2	(2)(0)(50)	50	440	2/4	274
	•	•	A352		J12522	• • •	• • •	3	(2)(9)(58)	-59	448	241	371
113	C−¹⁄2Mo	Castings	A217	WCI	J12524	• • • •	•••	3	(2)(9)(58)	-29	448	241	593
114	2½Ni	Castings	A352	LC2	J22500			9A	(2)(9)	-73	483	276	343
115	3½Ni	Castings	A352	LC3	J31550			9B	(2)(9)	-101	483	276	343

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

																		Notes (uicate		
	Min.																								
Line	Temp.																								
No.	to 40	65	100	125	150	175	200	225	250	275	300	325	350	375	400	425	450	475	500	525	550	575	600	625	650
91	138	132	128	126	125	124	124	124	124	124	124	124	124	124	123	122	121	99.6	80.9	63.3	47.5	34.2	23.5	15.3	9.65
92	138	132	128	126	125	124	124	124	124	124	124	124	124	124	123	122	121	99.6	80.9	63.3	47.5	34.2	23.5	15.3	9.65
0.0	100			400	400												400						47.0		
93	138	129	124	122	120	119	119	118	118	117	117	116	114	112	110	106	103	80.6	61.7	46.4	34.7	25.5	17.8	11.4	6.89
94	138	129	124	122	120	119	119	118	118	117	117	116	114	112	110	106	103	98.3	87.5	61.2	42.9	29.9	20.6	14.4	10.3
	-50					,	,											,							
95	149	149	147	144	142	140	138	135	132	128	124	119	113												
96	161	160	157	155	152	150	148	145	142	137	133	128	122	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		• • •
0.7	1/1	1/1	1/1	1/1	1/1	1/1	1/1	1 0	15/	1	152	140	1.7	1 / /	1 / 1	120	124	120	02.5	40.0	40.7				
97 98																138		129 109			40.7 30.5		16.5		• • •
70	101	101	101	101	101	101	101	150	150	134	1,72	147	147	177	171	100	134	107	00.0	72.5	50.5	23.2	10.5	•••	•••
99	161	161	157	155	155	153	150	147	145	143	141	139	138	136	134	132	129	126	92.1	61.1	40.4	26.4	17.4	11.6	7.58
100	161	161	157	155	155	153	150	147	145	143	141	139	138	136	134	132	129	126	92.1	61.1	40.4	26.4	17.4	11.6	7.58
101																							17.6		
102	161	161	161	161	161	158	155	153	150	148	146	143	141	138	136	133	130	104	73.7	52.0	36.3	25.2	17.6	12.3	8.27
103	161	161	160	157	156	155	155	155	15%	154	152	151	1/10	1/16	1/12	127	121	80 6	61 7	46 4	247	25.5	17.8	11 6	6 90
105	101	101	100	1)/	150	1))	1))	1))	1)4	1,54	1))	1)1	14)	140	142	1)/	1)1	00.0	01.7	40.4	J4.7	23.3	17.0	11.4	0.09
104	172	172	172	169	168	167	166	166	165	165	164	164	162	161	158	155	152	98.2	73.5	54.7	40.6	29.2	20.6	15.2	8.96
105	172	172	171	168	167	167	167	167	167	167	167	167	167	167	167	167	167	119	88.4	64.0	44.6	30.0	19.7	12.8	8.27
106	172	172	171	168	167	167	167	167	167	167	167	167	167	167	167	167	167	119	88.4	64.0	44.6	30.0	19.7	12.8	8.27
407	405	405	407	101	400	400	400	400	407	407	100	407	101	477	470	4//	450	454	00.0			20.0	20.6		40.0
107 108																							20.6 64.7		
109											-												64.7		
110																							17.8		
111	230																								
112	149	149	149	148	145	143	140	138	137	135	133	131	129	127				• • •							
113	149	149	149	148	145	143	140	138	137	135	133	131	129	126	123	120	117	109	68.0	42.3	30.5	23.2	16.5	• • •	• • •
11/	1/1	1/1	1/1	1/1	1/1	1/0	150	155	151	1.47	1.42	127	121												
114 115	161 161																		• • • •	• • • •	• • • •	• • • •	• • • •	• • •	• • •
110	101	101	101	101	101	100	100	100	101	14/	142	130	131	•••	•••	•••	•••	• • • •	•••	•••	• • • •	• • • •		• • •	• • •

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C
116	1Ni-1/2Cr-1/2Mo	Castings	A217	WC4	J12082			4	(2)(9)	-29	483	276	538
117	3/4Ni-1Mo-3/4Cr	Castings	A217	WC5	J22000			4	(2)(9)	-29	483	276	593
118	1 ¹ / ₄ Cr– ¹ / ₂ Mo	Castings	A217	WC6	J12072			4	(2)(9)	-29	483	276	649
119	2½Cr–1Mo	Castings	A217	WC9	J21890	• • • •		5A	(2)(9)	-29	483	276	649
120	5Cr−¹⁄₂Mo	Castings	A217	C5	J42045			5B	(2)(9)	-29	621	414	649
121	9Cr-1Mo	Castings	A217	C12	182090			5B	(2)(9)	-29	621	414	649

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

						E	Basic	Allov	vable	Stres	ss, <i>S</i> ,	MPa	, at M	letal T	empe	rature	, °C [N	lotes ((1) and	l (4b)]					
	Min. Temp. to 40	65	100	125	150	175	200	225	250	275	300	325	350	375	400	425	450	475	500	525	550	575	600	625	650
116	161	161	161	161	161	161	161	161	159	158	156	154	152	149	146	142	137	131	74.4	49.9	40.7				
117	161	161	161	161	161	161	161	161	159	158	156	154	152	149	146	142	137	131	74.4	49.9	34.3	23.2	16.5		
118	161	161	161	161	161	158	155	153	150	148	146	143	141	138	136	133	130	104	73.7	52.0	36.3	25.2	17.6	12.3	8.27
119	161	161	160	157	156	156	156	156	156	156	156	156	156	156	156	156	156	119	88.4	64.0	44.6	30.0	19.7	12.8	8.27
120	207	207	205	202	200	199	199	199	198	198	196	194	191	187	182	176	169	80.6	61.7	46.4	34.7	25.5	17.8	11.4	6.89
121	207	207	205	202	200	199	199	199	198	198	196	194	191	187	182	176	169	160	83.2	60.2	42.9	29.9	20.6	14.4	10.3

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/ Line Spec. Type/ Condition/ Size, P-No. **Product Form** UNS No. No. **Nominal Composition** No. Grade Temper mm (5) 1 18Cr-10Ni-Ti Smls. & wld. pipe TP321 S32100 >10 8 A312 . . . 18Cr-10Ni-Ti >10 Pipe A376 TP321 S32100 8 . . . 3 18Cr-8Ni Tube A213 TP304L S30403 8 18Cr-8Ni TP304L Tube A269 S30403 8 5 18Cr-8Ni Smls. & wld. pipe A312 TP304L S30403 8 18Cr-8Ni Wld. pipe A358 304L S30403 8 16Cr-12Ni-2Mo Tube A213 TP316L S31603 8 . . . 8 16Cr-12Ni-2Mo Tube A269 TP316L S31603 8 9 16Cr-12Ni-2Mo A312 Smls. & wld. pipe TP316L S31603 8 10 16Cr-12Ni-2Mo Wld. pipe A358 316L S31603 8 11 16Cr-12Ni-2Mo-Ti Tube A213 TP316Ti S31635 8 12 18Cr-10Ni-Ti Smls. & wld. pipe A312 TP321 S32100 >10 8 13 18Cr-10Ni-Ti >10 Pipe A376 TP321 S32100 8 >10 18Cr-10Ni-Ti Smls. & wld. pipe A312 TP321H 8 S32109 15 18Cr-10Ni-Ti Pipe A376 TP321H S32109 >10 8 16 25Cr-12Ni A451 CPH8 Pipe & tube J93400 8 17 25Cr-20Ni Pipe & tube A451 CPK20 J94202 8 18 11Cr-Ti Tube A268 TP409 S40900 7 19 18Cr-Ti Tube A268 TP430Ti S43036 7 20 16Cr-14Ni-2Mo Pipe & tube A451 CPF10MC J92971 8 16Cr-8Ni-2Mo Pipe A376 16-8-2H S16800 8 22 12Cr-Al Tube TP405 A268 S40500 7 . . . 23 13Cr Tube A268 TP410 S41000 6 . . . 24 17Cr Tube A268 TP430 S43000 7 25 18Cr-13Ni-3Mo Smls. & wld. pipe A312 TP317L S31703 8 26 25Cr-20Ni TP310 S31009 Smls. & wld. pipe A312 8 . . . 27 25Cr-20Ni Wld. pipe A358 310S S31008 8 28 25Cr-20Ni **TP310S** Pipe A409 S31008 8 . . . 29 18Cr-10Ni-Ti Smls. & wld. pipe A312 TP321 S32100 ≤10 8 18Cr-10Ni-Ti Wld. pipe A358 8 321 S32100 31 18Cr-10Ni-Ti Pipe A376 TP321 S32100 ≤10 8 32 18Cr-10Ni-Ti Pipe A409 TP321 S32100 8 33 23Cr-12Ni Smls. & wld. pipe A312 TP309 8 34 23Cr-12Ni Wld. pipe A358 309S S30908 8 . . .

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line													
No.	225	250	275	300	325	350	375	400	425	450	475	500	525
1	115	112	109	107	104	102	100	98.8	97.5	96.3	95.3	94.4	93.6
2	115	112	109	107	104	102	100	98.8	97.5	96.3	95.3	94.4	93.6
3	106	103	99.9	97.7	95.7	94.1	92.6	91.3	90.0	88.7	87.3	85.6	83.7
4	106	103	99.9	97.7	95.7	94.1	92.6	91.3	90.0	88.7	87.3	85.6	83.7
5	106	103	99.9	97.7	95.7	94.1	92.6	91.3	90.0	88.7	87.3	85.6	83.7
6	106	103	99.9	97.7	95.7	94.1	92.6	91.3	90.0	88.7	87.3	85.6	83.7
7	106	103	100	98.1	96.1	94.3	92.6	90.9	89.3	87.6	85.9	84.2	82.5
8	106	103	100	98.1	96.1	94.3	92.6	90.9	89.3	87.6	85.9	84.2	82.5
9	106	103	100	98.1	96.1	94.3	92.6	90.9	89.3	87.6	85.9	84.2	82.5
10	106	103	100	98.1	96.1	94.3	92.6	90.9	89.3	87.6	85.9	84.2	82.5
11	129	124	120	117	115	113	112	111	110	109	108	107	106
12	115	112	109	107	104	102	100	98.8	97.5	96.3	95.3	94.4	93.6
13	115	112	109	107	104	102	100	98.8	97.5	96.3	95.3	94.4	93.6
14	115	112	109	107	104	102	100	98.8	97.5	96.3	95.3	94.4	93.6
15	115	112	109	107	104	102	100	98.8	97.5	96.3	95.3	94.4	93.6
16	124	123	121	119	117	115	112	109	106	103	100	96.9	93.7
17	124	123	121	119	117	115	112	109	106	103	100	96.9	93.7
18													
19												• • •	
20	• • •				• • •							• • •	
21	• • •	• • •		• • •	• • •	• • •	• • •	• • • •	• • • •	• • • •	•••	• • •	• • •
22	132	131	130	129	127	124	121	118	114	109	103	70.1	38.8
23	132	131	130	129	127	124	121	118	114	109	92.5	68.4	51.1
24	132	131	130	129	127	124	121	118	114	109	88.7	69.8	52.6
25	127	123	120	118	115	113	111	109	107	105	103		
26	137	134	131	129	127	125	123	122	120	119	117	116	84.9
27	137	134	131	129	127	125	123	122	120	119	117	116	84.9
28	137	134	131	129	127	125	123	122	120	119	117	116	84.9
29	138	135	131	128	125	123	120	119	117	116	114	113	112
30	138	135	131	128	125	123	120	119	117	116	114	113	112
31	138	135	131	128	125	123	120	119	117	116	114	113	112
32	138	135	131	128	125	123	120	119	117	116	114	113	112
33	138	135	133	131	129	127	125	124	122	121	119	117	108
34	138	135	133	131	129	127	125	124	122	121	119	117	108

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

ne No.	550	575	600	625	650	675	700	725	750	775	800	82
1	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.0
2	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.0
3	81.4	40.4	33.2	26.7	21.9	18.2	15.0	12.4	8.87	7.20	6.58	6.2
4	81.4	40.4	33.2	26.7	21.9	18.2	15.0	12.4	8.87	7.20	6.58	6.2
5	81.4	40.4	33.2	26.7	21.9	18.2	15.0	12.4	8.87	7.20	6.58	6.2
6	81.4	40.4	33.2	26.7	21.9	18.2	15.0	12.4	8.87	7.20	6.58	6.2
	01.4	40.4	33.2	20.7	21.5	10.2	23.0		0.07	7.20	0.50	0
7	80.8	79.3	77.9	58.0	43.6	33.0	25.3	18.8	14.0	10.4	7.99	6.8
8	80.8	79.3	77.9	58.0	43.6	33.0	25.3	18.8	14.0	10.4	7.99	6.8
9	80.8	79.3	77.9	58.0	43.6	33.0	25.3	18.8	14.0	10.4	7.99	6.8
10	80.8	73.0	67.9	58.0	43.6	33.0	25.3	18.8	14.0	10.4	7.99	6.8
11	106	101	80.3	65.5	50.4	38.6	29.6	23.0	17.7	13.4	10.4	8.0
12	92.7	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
13	92.7	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
14	92.7	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
15	92.7	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
16	68.1	53.5	42.1	33.2	25.9	20.3	16.5	13.2	10.1	7.35	5.89	5.5
17	73.2	64.4	56.5	49.0	41.0	33.5	25.4	18.3	12.8	9.01	6.59	5.5
18												
19												
20												
21												
22	27.6											
23	37.4	26.3	17.8	11.4	6.89							
24	38.1	27.6	20.6	15.9	12.4							
25												
26	59.0	43.5	31.9	23.6	16.9	10.7	6.10	3.90	2.99	2.36	1.73	1.3
27	59.0	43.5	31.9	23.6	16.9	10.7	6.10	3.90	2.99	2.36	1.73	1.3
28	59.0	43.5	31.9	23.6	16.9	10.7	6.10	3.90	2.99	2.36	1.73	1.3
29	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.0
30	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.0
31	89.9	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.0
32	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.0
33	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.1
34	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.1

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd) Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Naminal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/	Size,	P-No.
	Nominal Composition					Temper	mm	(5)
35	18Cr-8Ni	Pipe & tube	A451	CPF8	J92600	• • •	• • •	8
36	18Cr–10Ni–Cb	Smls. & wld. pipe	A312	TP347	S34700	•••		8
37	18Cr-10Ni-Cb	Wld. pipe	A358	347	S34700			8
38	18Cr-10Ni-Cb	Pipe	A376	TP347	S34700			8
39	18Cr–10Ni–Cb	Pipe	A409	TP347	S34700			8
40	18Cr-10Ni-Cb	Smls. & wld. pipe	A312	TP348	S34800			8
41	18Cr-10Ni-Cb	Wld. pipe	A358	348	S34800			8
42	18Cr-10Ni-Cb	Pipe	A376	TP348	S34800			8
43	18Cr–10Ni–Cb	Pipe	A409	TP348	S34800	•••		8
44	25Cr-12Ni	Pipe & tube	A451	CPH10	J93402			8
45	25Cr-12Ni	Pipe & tube	A451	CPH20	J93402	•••		8
46	25Cr–20Ni	Smls. & wld. pipe	A312	TP310H	S31009			8
47	25Cr-20Ni	Wld. pipe	A358	310S	S31008	•••		8
48	18Cr–10Ni–Cb	Pipe & tube	A451	CPF8C	J92710	•••		8
49	18Cr–10Ni–Ti	Smls. & wld. pipe	A312	TP321	S32100		≤10	8
50	18Cr-10Ni-Ti	Wld. pipe	A358	321	S32100			8
51	18Cr-10Ni-Ti	Pipe	A376	TP321	S32100		≤10	8
52	18Cr-10Ni-Ti	Pipe	A409	TP321	S32100			8
53	18Cr-10Ni-Ti	Pipe	A376	TP321H	S32109		≤10	8
54	18Cr-10Ni-Ti	Smls. & wld. pipe	A312	TP321H	S32109	• • • •	≤10	8
55	16Cr-12Ni-2Mo	Tube	A213	TP316	S31600			8
56	16Cr-12Ni-2Mo	Tube	A269	TP316	S31600	•••		8
57	16Cr-12Ni-2Mo	Smls. & wld. pipe	A312	TP316	S31600			8
58	16Cr-12Ni-2Mo	Wld. pipe	A358	316	S31600			8
59	16Cr-12Ni-2Mo	Pipe	A376	TP316	S31600			8
60	16Cr-12Ni-2Mo	Pipe	A409	TP316	S31600			8
61	18Cr-13Ni-3Mo	Smls. & wld. pipe	A312	TP317	S31700			8
62	18Cr-13Ni-3Mo	Pipe	A409	TP317	S31700	• • •		8
63	16Cr-12Ni-2Mo	Pipe	A376	TP316H	S31609	•••		8
64	16Cr-12Ni-2Mo	Smls. & wld. pipe	A312	TP316H	S31609			8

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, *S*, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

(16)

							٥(C [Notes	(1), (3),	and (4b)]	erature,
Line		Min. Temp.,	Min. Tensile Strength,	Min. Yield Strength,	Max. Use Temp.,	Min. Temp. to		-				
No.	Notes	°C (6)	MPa	MPa	°C	40	65	100	125	150	175	200
35	(2)(26)(28)	-254	483	207	816	138	138	138	138	138	134	129
36	(2)	-254	517	207	816	138	138	138	138	138	138	138
	(2)(30)(36)	-254	517	207	816	138	138	138	138	138	138	138
	(2)(30)(36)	-254	517	207	816	138	138	138	138	138	138	138
	(2)(30)(36)	-254	517	207	816	138	138	138	138	138	138	138
	(2)	-198	517	207	816	138	138	138	138	138	138	138
41	(2)(30)(36)	-198	517	207	816	138	138	138	138	138	138	138
	(2)(30)(36)	-198	517	207	816	138	138	138	138	138	138	138
	(2)(30)(36)	-198	517	207	816	138	138	138	138	138	138	138
44	(2)(12)(14)(28)(35)(39)	-198	483	207	816	138	138	138	138	137	135	134
	(2)(12)(14)(28)(35)(39)	-198	483	207	816	138	138	138	138	137	135	134
1.6	(2)(29)(35)(39)	-198	517	207	816	138	138	138	138	138	138	138
	(2)(28)(29)(35)(36)	-198	517	207	816	138	138	138	138	138	138	138
47	(2)(28)(29)(35)(36)	-198	517	207	816	138	138	138	138	138	138	138
48	(2)(28)	-198	483	207	816	138	138	138	138	138	134	129
49	(2)(28)(30)	-254	517	207	816	138	138	138	138	138	138	138
50	(2)(28)(30)(36)	-254	517	207	816	138	138	138	138	138	138	138
51	(2)(28)(30)(36)	-254	517	207	816	138	138	138	138	138	138	138
52	(2)(28)(30)(36)	-254	517	207	816	138	138	138	138	138	138	138
53	(2)(30)(36)	-198	517	207	816	138	138	138	138	138	138	138
54	(2)	-198	517	207	816	138	138	138	138	138	138	138
55	(2)(14)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	138	134
56	(2)(14)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	138	134
57	(2)(26)(28)	-254	517	207	816	138	138	138	138	138	138	134
	(2)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	138	134
	(2)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	138	134
	(2)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	138	134
	(2)(26)(28)	-198	517	207	816	138	138	138	138	138	138	134
	(2)(26)(28)(31)(36)	-198	517	207	816	138	138	138	138	138	138	134
	(2)(26)(31)(36)	-198	517	207	816	138	138	138	138	138	138	134
64	(2)(26)	-198	517	207	816	138	138	138	138	138	138	134

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, $^{\circ}$ C [Notes (1), (3), and (4b)]

Line													
No.	225	250	275	300	325	350	375	400	425	450	475	500	525
35	125	122	119	116	113	111	109	107	105	103	101	99.1	94.4
36	138	138	137	135	132	130	128	127	126	126	125	125	125
37	138	138	137	135	132	130	128	127	126	126	125	125	125
38	138	138	137	135	132	130	128	127	126	126	125	125	125
39	138	138	137	135	132	130	128	127	126	126	125	125	125
40	138	138	137	135	132	130	128	127	126	126	125	125	125
41	138	138	137	135	132	130	128	127	126	126	125	125	125
42	138	138	137	135	132	130	128	127	126	126	125	125	125
43	138	138	137	135	132	130	128	127	126	126	125	125	125
44	133	131	129	128	125	123	120	117	114	111	107	104	100
45	133	131	129	128	125	123	120	117	114	111	107	104	100
73	199	1)1	12)	120	123	123	120	117	117	111	107	104	100
46	137	134	131	129	127	125	123	122	120	119	117	116	108
47	137	134	131	129	127	125	123	122	120	119	117	116	108
48	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
49	138	135	131	128	125	123	120	119	117	116	114	113	112
50	138	135	131	128	125	123	120	119	117	116	114	113	112
51	138	135	131	128	125	123	120	119	117	116	114	113	112
52	138	135	131	128	125	123	120	119	117	116	114	113	112
53	138	135	131	128	125	123	120	119	117	116	114	113	112
54	138	135	131	128	125	123	120	119	117	116	114	113	112
55	129	125	122	119	116	114	112	111	110	109	108	107	106
56	129	125	122	119	116	114	112	111	110	109	108	107	106
50	12)	123	122	117	110	114	112	111	110	10)	100	107	100
57	129	125	122	119	116	114	112	111	110	109	108	107	106
58	129	125	122	119	116	114	112	111	110	109	108	107	106
59	129	125	122	119	116	114	112	111	110	109	108	107	106
60	129	125	122	119	116	114	112	111	110	109	108	107	106
61	129	125	122	119	116	114	112	111	110	109	108	107	106
62	129	125	122	119	116	114	112	111	110	109	108	107	106
63	129	125	122	119	116	114	112	111	110	109	108	107	106
64	129	125	122	119	116	114	112	111	110	109	108	107	106

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, ${}^{\circ}$ C [Notes (1), (3), and (4b)]

ine No.	550	575	600	625	650	675	700	725	750	775	800	825
35	75.3	60.4	49.0	40.1	32.8	27.2	23.4	19.6	16.8	14.7	12.8	11.7
36	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.52
37	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.5
38	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.5
39	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.5
40	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.5
41	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.5
42	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.5
43	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.5
44	68.1	53.5	42.1	33.2	25.9	20.3	16.5	13.2	10.1	7.35	5.89	5.5
45	68.1	53.5	42.1	33.2	25.9	20.3	16.5	13.2	10.1	7.35	5.89	5.5
46	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.1
47	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.1
48	95.5	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.5
49	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
50	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
51	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
52	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
53	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
54	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.5
55	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
56	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
57	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
58	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
59	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
60	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
61	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
62	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
63	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9
64	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.9

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/ Line Spec. Type/ Condition/ Size, P-No. No. **Nominal Composition Product Form** No. Grade UNS No. Temper mm (5) 65 18Cr-10Ni-Cb Pipe A376 TP347H S34709 8 18Cr-10Ni-Cb Smls. & wld. pipe A312 TP347 S34700 8 18Cr-10Ni-Cb Wld. pipe A358 347 S34700 8 . . . 68 18Cr-10Ni-Cb Pipe A376 TP347 S34700 8 . . . 18Cr-10Ni-Cb 69 Pipe A409 TP347 S34700 8 70 18Cr-10Ni-Cb Smls. & wld. pipe A312 TP348 S34800 8 . . . 71 18Cr-10Ni-Cb Wld. pipe A358 348 S34800 8 . . . 18Cr-10Ni-Cb Pipe A376 TP348 S34800 8 73 18Cr-10Ni-Cb A409 TP348 8 Pipe S34800 74 18Cr-10Ni-Cb Smls. & wld. pipe A312 TP347H S34709 8 . . . 75 18Cr-10Ni-Cb Smls. & wld. pipe TP348H A312 S34809 8 76 18Cr-8Ni Tube A213 TP304 S30400 8 . . . 77 18Cr-8Ni Tube A269 TP304 S30400 8 78 18Cr-8Ni A312 TP304 Smls. & wld. pipe S30400 8 79 18Cr-8Ni Wld. pipe A358 304 S30400 8 80 18Cr-8Ni Pipe A376 TP304 S30400 8 81 18Cr-8Ni Pipe A376 TP304H S30409 8 82 18Cr-8Ni Pipe TP304 8 A409 S30400 . . . 83 18Cr-8Ni Smls. & wld. pipe TP304H 8 A312 S30409 . . . 84 18Cr-12Ni-2Mo Pipe & tube CPF8M J92900 A451 8 85 44Fe-25Ni-21Cr-Mo Wld. tube N08904 A249 45 86 44Fe-25Ni-21Cr-Mo Smls. & wld. pipe A312 N08904 45 87 20Cr-Cu Tube A268 TP443 S44300 . . . а 88 27Cr Tube A268 TP446-1 S44600 10I 89 12Cr Wld. pipe A1053 50 S41003 7 90 25Cr-8Ni-N Pipe & tube A451 CPE20N J92802 8 91 23Cr-4Ni-Mo-Cu-N Smls. & wld. tube A789 S32304 10H 92 23Cr-4Ni-Mo-Cu-N Smls. & wld. pipe A790 S32304 10H . . . 93 23Cr-4Ni-Mo-Cu-N Pipe & tube A928 2304 S32304 10H . . . A813 94 20Cr-18Ni-6Mo Pipe & tube S31254 8 95 20Cr-18Ni-6Mo Pipe & tube A814 S31254 8 . . . 96 13Cr CPCA15 Pipe & tube A426 J91150 6 . . . 97 20Cr-18Ni-6Mo Wld. pipe A358 S31254 >5.0 8 . . . 98 20Cr-18Ni-6Mo Wld. pipe A358 S31254 ≤5.0 8

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature,
°C [Notes (1), (3), and (4b)]

						Dasic At	0	C [Notes	(1), (3),	and (4b	p)]	
						Min.						
		Min.	Min. Tensile			•						
Line	Makaa	Temp.,	Strength,	Strength,	Temp.,	to	45	100	425	450	475	200
No.	Notes	°C (6)	MPa 517	MPa	°C	40	65	100	125	150	175	200
	(2)(30)(36) (2)(28)	−198 −254	517	207 207	816 816	138 138						
	(2)(28)(30)(36)	-254 -254	517	207	816	138						138
							138	138	138	138	138	
	(2)(28)(30)(36)	-254	517	207	816	138	138	138	138	138	138	138
	(2)(28)(30)(36)	-254	517	207	816	138	138	138	138	138	138	138
	(2)(28)	-198	517	207	816	138	138	138	138	138	138	138
	(2)(28)(30)(36)	-198	517	207	816	138	138	138	138	138	138	138
	(2)(28)(30)(36)	-198	517	207	816	138	138	138	138	138	138	138
73	(2)(28)(30)(36)	-198	517	207	816	138	138	138	138	138	138	138
74	(2)	-198	517	207	816	138	138	138	138	138	138	138
75	(2)	-198	517	207	816	138	138	138	138	138	138	138
76	(2)(14)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	134	129
77	(2)(14)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	134	129
78	(2)(26)(28)	-254	517	207	816	138	138	138	138	138	134	129
79	(2)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	134	129
80	(2)(20)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	134	129
81	(2)(26)(31)(36)	-198	517	207	816	138	138	138	138	138	134	129
82	(2)(26)(28)(31)(36)	-254	517	207	816	138	138	138	138	138	134	129
	(2)(26)	-198	517	207	816	138	138	138	138	138	134	129
	(2)(26)(28)	-254	483	207	816	138	138	138	138	130	124	118
85	(26)	-198	490	220	260	143	143	143	143	141	135	130
86	(26)	-198	490	220	260	143	143	143	143	141	135	130
87	(2)(7)(35)	-29	483	276	538	161	161	161	161	161	161	161
88	(2)(35)	-29	483	276	538	161	161	161	158	155	153	<i>152</i>
89	(2)	-29	485	350	316	162	162	162	162	162	161	159
90	(2)(35)(39)	-198	552	276	482	184	184	184	184	184	184	184
91	(2)(25)	-51	600	400	316	200	200	191	185	180	175	171
92	(2)(25)	-51	600	400	316	200	200	191	185	180	175	171
93	(25)	-51	600	400	316	200	200	191	185	180	175	171
94	(8)	-198	650	300	454	202	202	202	202	199	192	185
95	(8)	-198	650	300	454	202	202	202	202	199	192	185
96	(2)(10)(35)	-29	621	448	40	207						
97	•••	-198	655	310	475	207	207	207	207	203	196	189
98		-198	690	310	475	207	207	207	207	203	196	189

247

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, 5, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line													
No.	225	250	275	300	325	350	375	400	425	450	475	500	525
65	138	138	137	135	132	130	129	127	126	126	125	125	125
66	138	138	137	135	132	130	129	127	126	126	125	125	125
67	138	138	137	135	132	130	128	127	126	126	125	125	125
68	138	138	137	135	132	130	128	127	126	126	125	125	125
69	138	138	137	135	132	130	128	127	126	126	125	125	125
70	138	138	137	135	132	130	128	127	126	126	125	125	125
71	138	138	137	135	132	130	128	127	126	126	125	125	125
72	138	138	137	135	132	130	128	127	126	126	125	125	125
73	138	138	137	135	132	130	128	127	126	126	125	125	125
74	138	138	137	135	132	130	129	127	126	126	125	125	125
75	138	138	137	135	132	130	129	127	126	126	125	125	125
76	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
77	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
78	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
79	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
80	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
81	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
82	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
83	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
84	114	110	107	104	102	101	99.3	98.1	97.0	95.9	94.7	93.3	91.5
85	125	120	116										
86	125	120	116	• • •	• • •	• • •	•••	• • •	• • •	•••	•••	• • •	• • •
87	161	161	161	161	161	97.0	84.3	73.3	64.0	55.8	43.9	31.7	21.4
88	150	149	147	145	144	141	139	136	132	128	122	116	109
89	156	154	152	149	146								
90	184	184	184	184	184	184	184	184	184	184	184	184	
91	166	161	153	143	111								
92	166	161	153	143	111								
93	166	161	153	143	111		•••	•••			• • •	• • •	
94	180	175	171	168	165	164	162	161	160	159	158		
95	180	175	171	168	165	164	162	161	160	159	158		
			•				-	-					
96	•••	• • • •	• • • •	• • •	• • • •	• • • •	• • • •	• • • •			•••	• • • •	•••
97	184	179	175	172	169	167	165	165	164	163	161		
98	184	179	175	172	169	167	165	165	164	163	161		

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

66	Line No.	550	575	600	625	650	675	700	725	750	775	800	825
67	65	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
68	66	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
69 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 70 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 72 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 73 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 74 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 75 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 76 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 <td< td=""><td>67</td><td>125</td><td>112</td><td>90.6</td><td>69.6</td><td>53.8</td><td>41.4</td><td>31.8</td><td>24.0</td><td>18.8</td><td>14.6</td><td>10.9</td><td>8.96</td></td<>	67	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
70 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 71 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 73 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 74 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 75 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 75 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 76 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 <td< td=""><td>68</td><td>125</td><td>112</td><td>90.6</td><td>69.6</td><td>53.8</td><td>41.4</td><td>31.8</td><td>24.0</td><td>18.8</td><td>14.6</td><td>10.9</td><td>8.96</td></td<>	68	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
71 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 72 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 74 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 74 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 75 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 76 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 <	69	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
72 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 73 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 74 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 75 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 76 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2	70	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
73 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 74 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 75 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 76 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2	71	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
74 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 75 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 76 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 79 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 80 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2	72	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
75 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 76 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 79 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 79 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 80 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 81 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2	73	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
76 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 77 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 79 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 80 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 81 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 83 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2	74	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
77 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 79 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 80 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 81 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 82 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 83 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2	75	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
77 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 79 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 80 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 81 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 82 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 83 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2	76	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
78 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 79 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 80 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 81 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 82 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 83 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 84 89.1 72.7 57.7 46.0 36.9 30.1 24.3 20.3 17.0 14.3 12.1 11.0 85 .	77	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	
79 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 80 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 81 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 82 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 84 89.1 72.7 57.7 46.0 36.9 30.1 24.3 20.3 17.0 14.3 12.1 11.0 85 <	78	95.5	78.9	63.8	51.6	41.6	32.9	26.5		17.2	14.1	11.2	
81 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 82 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 83 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 84 89.1 72.7 57.7 46.0 36.9 30.1 24.3 20.3 17.0 14.3 12.1 11.0 85	79	95.5	78.9	63.8	51.6	41.6		26.5		17.2		11.2	
82 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 83 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 84 89.1 72.7 57.7 46.0 36.9 30.1 24.3 20.3 17.0 14.3 12.1 11.0 85 <td>80</td> <td>95.5</td> <td>78.9</td> <td>63.8</td> <td>51.6</td> <td>41.6</td> <td>32.9</td> <td>26.5</td> <td>21.3</td> <td>17.2</td> <td>14.1</td> <td>11.2</td> <td>9.65</td>	80	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
83 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65 84 89.1 72.7 57.7 46.0 36.9 30.1 24.3 20.3 17.0 14.3 12.1 11.0 85 <td< td=""><td>81</td><td>95.5</td><td>78.9</td><td>63.8</td><td>51.6</td><td>41.6</td><td>32.9</td><td>26.5</td><td>21.3</td><td>17.2</td><td>14.1</td><td>11.2</td><td>9.65</td></td<>	81	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
84 89.1 72.7 57.7 46.0 36.9 30.1 24.3 20.3 17.0 14.3 12.1 11.0 85	82	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
85	83	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
86	84	89.1	72.7	57.7	46.0	36.9	30.1	24.3	20.3	17.0	14.3	12.1	11.0
87 17.2 .	85												
88 104	86	•••					• • •		• • • •			• • • •	
89	87	17.2											
90	88	104	• • • •				• • •		• • •				• • •
91	89												
92	90	• • • •	• • • •				• • •		• • •				• • •
93	91												
94	92												
95	93		• • • •		• • •	• • •		• • • •	• • •			• • •	• • • •
96	94												
97	95												
	96		• • •										
98	97												

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/ Line Spec. Type/ Condition/ Size, P-No. No. **Nominal Composition Product Form** No. Grade UNS No. Temper mm (5) 99 22Cr-5Ni-3Mo-N Smls. & wld. tube A789 S31803 10H 100 22Cr-5Ni-3Mo-N Smls. & wld. pipe A790 S31803 10H 101 22Cr-5Ni-3Mo-N Pipe & tube A928 S31803 10H 102 20Cr-18Ni-6Mo Pipe & tube >5.00 A249 S31254 8 20Cr-18Ni-6Mo Pipe & tube 8 A249 S31254 ≤5.00 104 20Cr-18Ni-6Mo Pipe & tube A312 S31254 >5.00 8 . . . 105 20Cr-18Ni-6Mo Pipe & tube A312 8 S31254 ≤5.00 . . . Smls. & wld. tube A789 106 26Cr-4Ni-Mo S32900 . . . 10H 107 26Cr-4Ni-Mo Smls. & wld. pipe 10H A790 S32900 108 46Fe-24Ni-21Cr-6Mo-Cu-N Smls. & wld. pipe A312 N08367 >5.0 45 109 46Fe-24Ni-21Cr-6Mo-Cu-N Wld. pipe >5.0 A358 N08367 45 >5.0 46Fe-24Ni-21Cr-6Mo-Cu-N Wld. pipe 110 A813 N08367 45 46Fe-24Ni-21Cr-6Mo-Cu-N >5.0 111 Wld. pipe A814 N08367 45 112 46Fe-24Ni-21Cr-6Mo-Cu-N Smls. & wld. pipe A312 N08367 ≤5.0 45 113 46Fe-24Ni-21Cr-6Mo-Cu-N Wld. pipe A358 ≤5.0 N08367 45 46Fe-24Ni-21Cr-6Mo-Cu-N Wld. pipe 114 A813 N08367 ≤5.0 45 115 46Fe-24Ni-21Cr-6Mo-Cu-N Wld. pipe A814 N08367 ≤5.0 45 116 21Cr-5Mn-1½Ni-Cu-N Smls. & wld. tube A789 S32101 >5.0 10H . . . 21Cr-5Mn-1½Ni-Cu-N Smls. & wld. pipe A790 S32101 >5.0 10H 117 118 21Cr-5Mn-11/2Ni-Cu-N Smls. & wld. tube A789 S32101 ≤5.0 10H 119 21Cr-5Mn-1½Ni-Cu-N Smls. & wld. pipe A790 S32101 ≤5.0 10H Smls. & wld. pipe 120 21Cr-3¹/₂Ni-1³/₄Mo-N A790 S32003 10H >5.0 121 21Cr-3¹/₂Ni-1³/₄Mo-N Pipe & tube A928 S32003 10H 122 22Cr-5Ni-3Mo-N Pipe & tube A928 2205 S32205 10H 123 21Cr-3¹/₂Ni-1³/₄Mo-N Smls. & wld. tube A789 ≤5.0 10H S32003 124 21Cr-3¹/₂Ni-1³/₄Mo-N Pipe & tube A928 S32003 ≤5.0 10H 125 25Cr-8Ni-3Mo-W-Cu-N Smls. & wld. tube A789 S32760 10H 126 25Cr-8Ni-3Mo-W-Cu-N Smls. & wld. pipe A790 S32760 10H 127 29Cr-6.5Ni-2Mo-N Smls. & wld. tube A789 S32906 ≥10 10H 128 29Cr-6.5Ni-2Mo-N Smls. & wld. pipe A790 S32906 10H ≥10 129 24Cr-17Ni-6Mn-4½Mo-N Pipe & tube A358 S34565 8 130 25Cr-7Ni-4Mo-N Smls. & wld. tube A789 S32750 10H 131 25Cr-7Ni-4Mo-N Smls. & wld. pipe A790 2507 S32750 10H 132 25Cr-7Ni-4Mo-N Pipe & tube A928 2507 S32750 10H 29Cr-6.5Ni-2Mo-N Smls. & wld. tube S32906 10H 133 A789 <10 134 29Cr-6.5Ni-2Mo-N Smls. & wld. pipe S32906 10H A790 <10 135 18Cr-11Ni Plate & sheet A240 305 S30500 8

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16)

. . .

. . .

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line													
No.	225	250	275	300	325	350	375	400	425	450	475	500	525
99	190	188	187	186	185							• • •	
100	190	188	187	186	185							• • •	
101	190	188	187	186	185	•••	•••	• • •	•••	• • •	•••	• • •	• • •
102	184	179	175	172	169	167	166	165	164	163	161		
103	184	179	175	172	169	167	166	165	164	163	161		
104	184	179	175	172	169	167	166	165	164	163	161		
105	184	179	175	172	169	167	166	165	164	163	161	•••	
106													
107	• • •	• • •		• • •	• • •	•••	• • •		• • •		•••		
108	195	192	188	184	179	176	173	170	167	166			
109	195	192	188	184	179	176	173	170	167	166			
110	195	192	188	184	179	176	173	170	167	166			
111	195	192	188	184	179	176	173	170	167	166			
112	199	194	188	184	179	176	173	170	167	166			
113	199	194	188	184	179	176	173	170	167	166			
114	199	194	188	184	179	176	173	170	167	166			
115	199	194	188	184	179	176	173	170	167	166	• • •	• • • •	
116	199	199	199	199	199								
117	199	199	199	199	199								
118	214	214	214	214	214								
119	214	214	214	214	214	• • •	• • •	• • •	• • •		• • •	• • • •	
120	197	197	197	197	197	197							
121	197	197	197	197	197	197							
122	201	199	197	196	196	195							
123	207	207	207	207	207	207							
124	207	207	207	207	207	207	• • •	•••	• • •	•••		•••	• • •
125													
126													
127	230	228	228	228	228								
128	230	228	228	228	228	• • •							
129													
130	241	238	237	237	236						• • •		
131	241	238	237	237	236								
132	241	238	237	237	236								
133	245	243	243	242	242								
134	245	243	243	242	242							•••	
135													

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, $^{\circ}$ C [Notes (1), (3), and (4b)]

Line No.	550	575	600	625	650	675	700	725	750	775	800	825
99								• • •			• • •	
100	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
101	•••	• • •	• • •	• • •	• • •	•••	• • •	•••	• • •	•••	•••	• • •
102												
103	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		• • •
104	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		• • •
105	• • •	•••	•••	•••	•••	• • •	• • •	•••	•••	• • •	•••	•••
106												
107	•••	•••				• • •	• • •	• • •		• • •	• • • •	
108												
109	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		• • •
110	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
111	• • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • • •
112	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
113	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
114	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
115	•••	•••	• • • •	• • • •	• • • •	• • •	• • •	• • •	• • • •	• • •	•••	• • • •
116	•••	•••	• • •			•••	• • •	• • •		•••	• • • •	
117	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
118	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
119	•••	•••	• • •		•••	•••	•••	•••		•••	•••	
120	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
121	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
122	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
123	• • •	• • •	• • •	• • •	• • •	•••	• • •	•••	• • •	• • •	• • •	• • •
124	•••	•••	• • •		•••	•••	•••	•••		•••	•••	
125	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •
126	•••	•••	•••	•••	•••	•••	• • •	•••	• • •	•••	•••	•••
127												
128	•••	•••				• • •	• • •	• • •		• • • •	• • • •	
129												
130	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
131	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
132	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
133	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
134	• • •	•••	• • •	• • •	•••	• • •	• • •	• • •	• • •	• • •	•••	• • •
135		•••									•••	

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/ Line Spec. Type/ Condition/ Size, P-No. **Nominal Composition Product Form** UNS No. No. No. Grade Temper mm (5) 136 12Cr-Al Plate & sheet A240 405 S40500 7 . . . 137 18Cr-8Ni Plate & sheet A240 304L S30403 8 138 16Cr-12Ni-2Mo Plate & sheet A240 316L S31603 8 139 18Cr-Ti Plate & sheet A240 439 S43035 . . . 140 18Cr-8Ni Plate & sheet A240 302 S30200 8 . . . 141 12Cr-1Ni Plate, sheet, strip A1010 S41003 7 40 142 12Cr-1Ni Plate, sheet, strip A1010 50 S41003 7 143 13Cr Plate & sheet A240 410S S41008 7 144 13Cr Plate & sheet A240 S41000 410 6 145 15Cr Plate & sheet A240 429 S42900 6 146 17Cr Plate & sheet A240 430 S43000 7 147 18Cr-13Ni-3Mo Plate & sheet A240 317L S31703 8 148 25Cr-20Ni Plate & sheet A240 310S S31008 8 . . . 149 18Cr-10Ni-Ti Plate & sheet A240 321 S32100 8 . . . 150 23Cr-12Ni Plate & sheet A240 309S S30908 8 151 18Cr-10Ni-Cb Plate & sheet A240 347 S34700 8 . . . 152 18Cr-10Ni-Cb Plate & sheet A240 348 S34800 8 . . . 153 25Cr-20Ni Plate & sheet A240 310S S31008 8 . . . 154 18Cr-10Ni-Ti Plate & sheet A240 321 S32100 8 155 18Cr-10Ni-Ti Plate & sheet A240 321H S32109 8 156 16Cr-12Ni-2Mo Plate & sheet A240 316 S31600 8 157 18Cr-13Ni-3Mo Plate & sheet A240 317 S31700 8 158 18Cr-10Ni-Cb Plate & sheet A240 347 S34700 8 . . . 159 18Cr-10Ni-Cb Plate & sheet A240 348 S34800 8 18Cr-8Ni Plate & sheet A240 304 S30400 8 . . .

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line													
No.	225	250	275	300	325	350	375	400	425	450	475	500	525
136	99.7	99.1	98.4	97.5	96.2	94.7	92.6	90.1	87.0	83.4	79.2	70.1	38.8
137	106	103	99.9	97.7	95.7	94.1	92.6	91.3	90.0	88.7	87.3	85.6	83.7
138	106	103	100	98.1	96.1	94.3	92.6	90.9	89.3	87.6	85.9	84.2	82.5
139			•••		•••	•••	•••	•••	•••				• • •
140	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
141	147	145	142	140	137								
142	156	154	152	149	146	•••	•••	•••	•••	•••	•••	• • •	• • •
143	120	119	118	117	115	114	111	108	104	100	92.5	68.4	51.1
144	120	119	118	117	115	114	111	108	104	100	92.5	68.4	51.1
145	120	119	118	117	115	114	111	108	104	100	88.7	69.8	52.6
146	120	119	118	117	115	114	111	108	104	100	88.7	69.8	52.6
147	127	123	120	118	115	113	111	109	107	105	103	• • •	• • •
148	137	134	131	129	127	125	123	122	120	119	117	116	84.9
149	138	135	131	128	125	123	120	119	117	116	114	113	112
150	138	135	133	131	129	127	125	124	122	121	119	117	108
151	138	138	137	135	132	130	128	127	126	126	125	125	125
152	138	138	137	135	132	130	128	127	126	126	125	125	125
153	137	134	131	129	127	125	123	122	120	119	117	116	108
154	138	135	131	128	125	123	120	119	117	116	114	113	112
155	138	135	131	128	125	123	120	119	117	116	114	113	112
156	129	125	122	119	116	114	112	111	110	109	108	107	106
157	129	125	122	119	116	114	112	111	110	109	108	107	106
158	138	138	<i>137</i>	135	132	130	128	127	126	126	125	125	125
159	138	138	137 137	135	132	130	128	127	126	126	125	125	125
160	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line No.	550	575	600	625	650	675	700	725	750	775	800	825
136	27.6	•••	• • •			• • •	• • •	•••		•••	•••	
137	81.4	40.4	33.2	26.7	21.9	18.2	15.0	12.4	8.87	7.20	6.58	6.21
138	80.8	73.0	67.9	58.0	43.6	33.0	25.3	18.8	14.0	10.4	7.99	6.89
139		•••										
140	96.4											
141												
142	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
143	37.4	26.3	17.8	11.4	6.89							
144	37.4	26.3	17.8	11.4	6.89							
145	38.1	27.6	20.6	15.9	12.4							
146	38.1	27.6	20.6	15.9	12.4							
147												
148	59.0	43.5	31.9	23.6	16.9	10.7	6.10	3.90	2.99	2.36	1.73	1.38
149	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.07
150	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.17
151	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.52
152	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.52
153	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.17
154	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.58
155	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.58
		,	20	,	20.0							
156	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.96
157	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.96
158	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
159	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
160	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Condition/ Temper	Size, mm	P-No. (5)
161	44Fe-25Ni-21Cr-Mo	Plate & sheet	A240	904L	N08904			45
162	23Cr-4Ni-Mo-Cu-N	Plate & sheet	A240	2304	S32304			10H
163	22Cr-5Ni-3Mo-N	Plate & sheet	A240		S31803			10H
164	16Cr–4Ni–6Mn	Plate & sheet	A240	201LN	S20153			8
165	20Cr-18Ni-6Mo	Plate	A240		S31254		>5.0	8
166	20Cr-18Ni-6Mo	Sheet	A240		S31254		≤5.0	8
167	46Fe-24Ni-21Cr-6Mo-Cu-N	Plate	A240		N08367		>5.0	45
168	46Fe-24Ni-21Cr-6Mo-Cu-N	Sheet & strip	A240	• • •	N08367	•••	≤5.0	45
169	21Cr-5Mn-1.5Ni-Cu-N	Plate & sheet	A240		S32101		>5.0	10H
170	21Cr-5Mn-1.5Ni-Cu-N	Plate & sheet	A240	•••	S32101	•••	≤5.0	10H
171	21Cr-3½Ni-1¾Mo-N	Plate & sheet	A240		S32003		>5.0	10H
172	21Cr-3½Ni-1¾Mo-N	Plate & sheet	A240	• • •	S32003	•••	≤5.0	10H
173	29Cr-6.5Ni-2Mo-N	Plate & sheet	A240		S32906		≥10.0	10H
174	29Cr-6.5Ni-2Mo-N	Plate & sheet	A240	• • •	S32906	•••	≤10.0	10H
175	25Cr-8Ni-3Mo-W-Cu-N	Plate & sheet	A240		S32760			10H
176	25Cr-7Ni-4Mo-N	Plate & sheet	A240	2507	S32750	•••	•••	10H
177	18Cr-13Ni-3Mo	Forgings & fittings	A182	F317L	S31703		≤125	8
178	18Cr-8Ni	Forgings & fittings	A182	F304L	S30403			8
179	18Cr-8Ni	Forgings & fittings	A403	WP304L	S30403	•••	•••	8
180	16Cr-12Ni-2Mo	Forgings & fittings	A182	F316L	S31603			8
181	16Cr-12Ni-2Mo	Forgings & fittings	A403	WP316L	S31603	•••	•••	8
182	20Ni-8Cr	Forgings & fittings	A182	F10	S33100	•••	•••	8
183	18Cr-13Ni-3Mo	Forgings & fittings	A403	WP317L	S31703			8
184	25Cr-20Ni	Forgings & fittings	A182	F310H	S31009			8
185	25Cr-20Ni	Forgings & fittings	A403	WP310	S31008	•••	•••	8
186	18Cr-10Ni-Ti	Forgings & fittings	A182	F321	S32100			8
187	18Cr-10Ni-Ti	Forgings & fittings	A403	WP321	S32100	•••	•••	8
188	23Cr-12Ni	Forgings & fittings	A403	WP309	S30900	•••		8
189	25Cr-20Ni	Forgings & fittings	A182	F310H	S31009			8
190	25Cr-20Ni	Forgings & fittings	A403	WP310	S31008	•••		8
	ı							

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

 (16)

-198

190 (28)(29)(32)(35)(37)(39)

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line													
No.	225	250	275	300	325	350	375	400	425	450	475	500	525
161	125	120	116										
162	166	161	<i>153</i>	143	111								
163	190	188	187	186	185						• • •	• • •	• • •
164	160	159	158	158	158	<i>157</i>	156	154	152	149	146	• • •	• • •
165	184	179	175	172	169	167	166	165	164	163	161	• • •	• • •
166	184	179	175	172	169	167	166	165	164	163	161	• • •	• • •
167	195	192	188	184	179	176	173	170	167	166	• • •	• • • •	• • •
168	199	194	188	184	179	176	173	170	167	166	•••	•••	•••
169	199	199	199	199	199								
170	214	214	214	214	214		•••	•••	•••	• • •	• • •	• • •	•••
171	197	197	197	197	197	197							
172	207	207	207	207	207	207	• • • •	• • •		• • •	• • •		
173	230	228	228	228	228								
174	245	243	243	242	242					• • •			
175	234	234	234	234	234								
176	241	238	237	237	236							• • •	
177	106	103	100	98.1	96.1	94.3	92.6	90.9	89.3	87.6	85.9		
178	106	103	99.9	97.7	95.7	94.1	92.6	91.3	90.0	88.7	87.3	85.6	83.7
179	106	103	99.9	97.7	95.7	94.1	92.6	91.3	90.0	88.7	87.3	85.6	83.7
180	106	103	100	98.1	96.1	94.3	92.6	90.9	89.3	87.6	85.9	84.2	82.5
181	106	103	100	98.1	96.1	94.3	92.6	90.9	89.3	87.6	85.9	84.2	82.5
182													
183	127	123	120	118	115	113	111	109	107	105	103	• • •	
184	137	134	131	129	127	125	123	122	120	119	117	116	84.9
185	137	134	131	129	127	125	123	122	120	119	117	116	84.9
186	138	135	131	128	125	123	120	119	117	116	114	113	112
187	138	135	131	128	125	123	120	119	117	116	114	113	112
188	138	135	133	131	129	127	125	124	122	121	119	117	108
189	137	134	131	129	127	125	123	122	120	119	117	116	108
190	137	134	131	129	127	125	123	122	120	119	117	116	108
Į													

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line No.	550	575	600	625	650	675	700	725	750	775	800	825
161									• • •	• • •		
162	• • •	• • •	• • •	• • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •	• • •
163	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
164	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
165	• • •	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
166	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
167	• • •	• • •	• • •	• • • •	• • • •	• • • •	• • • •	• • • •	• • •	• • •	• • • •	• • •
168	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••
169												
170	• • •	•••	• • •		• • •	• • •	• • •	• • •	•••	•••		• • • •
171												
172	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	•••	• • •	• • •
173												
174	• • •	• • • •	• • •		• • •	• • •			•••	•••		• • • •
175		• • •										
176												
177												
178	81.4	40.4	33.2	26.7	21.9	18.2	15.0	12.4	8.87	7.20	6.58	6.21
179	81.4	40.4	33.2	26.7	21.9	18.2	15.0	12.4	8.87	7.20	6.58	6.21
180	80.8	73.0	67.9	58.0	43.6	33.0	25.3	18.8	14.0	10.4	7.99	6.89
181	80.8	73.0	67.9	58.0	43.6	33.0	25.3	18.8	14.0	10.4	7.99	6.89
182												
183												
184	59.0	43.5	31.9	23.6	16.9	10.7	6.10	3.90	2.99	2.36	1.73	1.38
185	59.0	43.5	31.9	23.6	16.9	10.7	6.10	3.90	2.99	2.36	1.73	1.38
186	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.07
187	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.75	2.07
188	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.17
189	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.17
190	83.7	64.0	48.5	36.3	27.3	21.0	15.9	12.5	9.87	7.65	5.97	5.17

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/ Line Spec. Type/ Condition/ Size, P-No. No. **Nominal Composition Product Form** No. Grade UNS No. Temper mm (5) 18Cr-10Ni-Cb Forgings & fittings F347 S34700 191 A182 8 18Cr-10Ni-Cb WP347 192 Forgings & fittings A403 S34700 . . . 8 . . . 193 18Cr-10Ni-Cb Forgings & fittings A182 F348 S34800 8 . . . 194 18Cr-10Ni-Cb Forgings & fittings A403 WP348 S34800 8 . . . 195 18Cr-10Ni-Ti Forgings & fittings A182 F321 S32100 8 . . . 196 18Cr-10Ni-Ti Forgings & fittings A182 F321H S32109 8 18Cr-10Ni-Ti 197 Forgings & fittings A403 WP321 S32100 8 . . . 198 18Cr-10Ni-Ti Forgings & fittings WP321H 8 A403 S32109 199 16Cr-12Ni-2Mo Forgings & fittings A403 WP316H S31609 8 . . . 200 16Cr-12Ni-2Mo Forgings & fittings A182 F316H S31609 . . . 8 . . . 201 18Cr-10Ni-Cb Forgings & fittings A403 WP347H S34709 8 . . . 202 18Cr-10Ni-Cb Forgings & fittings A182 F347 S34700 8 203 18Cr-10Ni-Cb WP347 Forgings & fittings A403 S34700 8 204 18Cr-10Ni-Cb Forgings & fittings A182 F348 S34800 8 205 18Cr-10Ni-Cb Forgings & fittings A403 WP348 S34800 8 206 18Cr-10Ni-Cb Forgings & fittings A182 F347H S34709 8 207 18Cr-10Ni-Cb Forgings & fittings A182 F348H S34809 8 208 16Cr-12Ni-2Mo Forgings & fittings A182 F316 S31600 8 209 16Cr-12Ni-2Mo Forgings & fittings A403 WP316 S31600 8 . . . 210 18Cr-13Ni-3Mo Forgings & fittings A403 WP317 S31700 8 211 18Cr-8Ni Forgings & fittings A182 F304 \$30400 . . . 8 212 18Cr-8Ni Forgings & fittings A403 WP304 S30400 8 . . . 213 18Cr-8Ni Forgings & fittings A403 WP304H S30409 8 214 18Cr-8Ni Forgings & fittings F304H A182 S30409 8 . . . 215 44Fe-25Ni-21Cr-Mo **Forgings** A182 F904L N08904 45 216 13Cr Forgings & fittings A182 F6a S41000 1 6 . . . 217 13Cr Forgings & fittings A182 S41000 2 F6a 6 . . . 218 20Cr-18Ni-6Mo A182 8 **Forgings** F44 S31254 . . . 219 20Cr-18Ni-6Mo **Fittings** A403 WPS31254 S31254 8 220 20Cr-18Ni-6Mo **Fittings** A403 CRS31254 S31254 8 221 23Cr-4Ni-Mo-Cu-N **Forgings** A182 F68 S32304 10H . . . 222 22Cr-5Ni-3Mo-N **Forgings** A182 F51 S31803 10H . . . 22Cr-5Ni-3Mo-N 223 **Fittings** A815 WPS31803 S31803 10H 224 22Cr-5Ni-3Mo-N **Fittings** A815 CRS31803 10H S31803

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16)

-198

-198

-51

-51

-51

-51

219 (8)

220 (8)

221 (25)

222 (25)

223 (25)

224 (25)

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

·-													
Line													
No.	225	250	275	300	325	350	375	400	425	450	475	500	525
191	138	138	137	135	132	130	128	127	126	126	125	125	125
192	138	138	137	135	132	130	128	127	126	126	125	125	125
193	138	138	137	135	132	130	128	127	126	126	125	125	125
194	138	138	137	135	132	130	128	127	126	126	125	125	125
195	138	135	131	128	125	123	120	119	117	116	114	113	112
196	138	135	131	128	125	123	120	119	117	116	114	113	112
197	138	135	131	128	125	123	120	119	117	116	114	113	112
198	138	135	131	128	125	123	120	119	117	116	114	113	112
199	129	125	122	119	116	114	112	111	110	109	108	107	106
200	129	125	122	119	116	114	112	111	110	109	108	107	106
201	138	138	137	135	132	130	129	127	126	126	125	125	125
202	138	138	137	135	132	130	128	127	126	126	125	125	125
203	138	138	137	135	132	130	129	127	126	126	125	125	125
204	138	138	137	135	132	130	128	127	126	126	125	125	125
205	138	138	137	135	132	130	128	127	126	126	125	125	125
206	420	420	427	425	422	420	420	4.27	426	426	425	425	425
206 207	138	138	137	135	132	130	129	127	126	126	125	125	125
207	138	138	137	135	132	130	129	127	126	126	125	125	125
208	129	125	122	119	116	114	112	111	110	109	108	107	106
209	129	125	122	119	116	114	112	111	110	109	108	107	106
210	129	125	122	119	116	114	112	111	110	109	108	107	106
211	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
212	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
212	125	122	110	116	112	111	100	107	105	102	101	00.1	07.2
213 214	125 125	122	119	116 116	113	111	109 109	107 107	105 105	103 103	101 101	99.1	97.3
214	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
215	125	120	116										
217	123	120	110	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••
216	154	153	152	150	148	145	142	137	133	125	92.5	68.4	51.1
217	187	186	184	182	180	176	172	167	161	125	92.5	68.4	51.1
218	180	175	171	168	165	164	162	161	160	159	158		
219	180	175	171	168	165	164	162	161	160	159	158	• • •	
220	180	175	171	168	165	164	162	161	160	159	158		
221	166	161	153	143	111	• • •	•••	• • •	• • •	• • •	• • •	•••	•••
222	190	188	187	186	185	•••	•••	• • •	•••	• • •	•••	• • •	•••
223	190	188	187	186	185	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
224	190	188	187	186	185	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

(16)

Line No. 550 575 600 625 650 675 700 725 750 775 800 825 191 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 192 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 193 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 194 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 195 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 197 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5													
192 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 193 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 194 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 195 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 196 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 197 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 199 105 97.8 80.8	Line No.	550	575	600	625	650	675	700	725	750	775	800	825
192 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 193 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 194 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 195 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 196 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 197 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 199 105 97.8 80.8	191	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.52
194 97.6 75.9 57.2 40.2 30.3 23.2 16.2 11.4 8.97 7.08 5.89 5.52 195 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 196 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 197 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 199 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 200 105 97.8 80.8 <	192			57.2		30.3			11.4		7.08		5.52
195 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 196 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 197 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 199 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 200 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 201 125 112 90.6 <td< td=""><td>193</td><td></td><td></td><td>57.2</td><td>40.2</td><td>30.3</td><td>23.2</td><td>16.2</td><td>11.4</td><td>8.97</td><td>7.08</td><td></td><td></td></td<>	193			57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08		
196 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 197 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 199 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 200 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 201 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 6	194	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.52
196 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 197 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 199 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 200 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 201 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 6													
197 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 199 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 200 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 201 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 202 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 69	195	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.58
198 100 76.5 58.7 46.0 36.8 28.7 23.0 18.4 14.5 11.5 9.02 7.58 199 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 200 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 201 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 202 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 205 125 112 90.6 69.	196	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.58
199 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 200 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 201 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 202 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 205 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 206 125 112 90.6 69.6	197	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.58
200 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 201 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 202 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 205 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 206 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6<	198	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.58
200 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 201 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 202 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 205 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 206 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6<	199	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.96
201 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 202 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 205 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 206 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 </td <td></td>													
202 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 205 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 206 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 208 105 97.8 80.8 65.0<			2				2010			-,	-5.5		
203 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 204 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 205 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 206 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 208 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 210 105 97.8 80.8 65.0	201	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
204 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 205 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 206 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 208 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 209 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 210 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96	202	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
205 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 206 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 208 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 209 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 210 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96	203	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
206 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 208 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 209 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 210 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96	204	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 208 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 209 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 210 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96	205	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
207 125 112 90.6 69.6 53.8 41.4 31.8 24.0 18.8 14.6 10.9 8.96 208 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 209 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 210 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96	206	125	112	00.6	60.6	E2 0	41.4	21 0	24.0	100	146	10.0	9.06
208 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 209 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 210 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96													
209 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96 210 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96	207	125	112	90.0	09.0	55.6	41.4	J1.6	24.0	10.0	14.0	10.9	6.90
210 105 97.8 80.8 65.0 50.4 38.6 29.6 23.0 17.4 13.3 10.4 8.96	208	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.96
	209	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.96
211 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65	210	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.96
700 700 910 910 910 100	211	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
212 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65													
		73.3	, 0.5	03.0	31.0		32.0	2013		-,			,,,,,
213 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65	213	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
214 95.5 78.9 63.8 51.6 41.6 32.9 26.5 21.3 17.2 14.1 11.2 9.65	214	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
215	21.5												
215	215	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	• • •	•••
216 44.1	216	44.1											
217 37.4 26.3 17.8 11.4 6.89	217	37.4	26.3	17.8	11.4	6.89	• • •						
218			• • •	• • •	•••	• • •	• • •	• • •	•••	• • •	• • •	• • •	• • •
219		• • • •	• • •	• • • •	• • •	• • • •	• • •	• • • •	• • • •	• • • •	• • •	• • •	• • •
220	220	•••	•••	• • •	• • •	•••	• • •	• • •	•••	• • •	• • •	• • •	•••
221	221												
222													
223													
224													
ļ													

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/ Line Spec. Type/ Condition/ Size, P-No. **Product Form** UNS No. No. **Nominal Composition** No. Grade Temper mm (5) 46Fe-24Ni-21Cr-6Mo-Cu-N A182 F62 N08367 225 **Forgings** 45 226 46Fe-24Ni-21Cr-6Mo-Cu-N **Fittings** A403 WP6XN N08367 . . . 45 . . . 227 46Fe-24Ni-21Cr-6Mo-Cu-N **Fittings** A403 CR6XN N08367 45 . . . 228 21Cr-5Mn-11/2Ni-Cu-N **Fittings** A815 S32101 10H 229 25Cr-8Ni-3Mo-W-Cu-N 10H Forgings & fittings A182 S32760 230 25Cr-8Ni-3Mo-W-Cu-N Forgings & fittings A815 S32760 10H 231 13Cr Forgings & fittings A182 F6a S41000 3 6 . . . 232 13Cr-1/2Mo Forgings & fittings A182 F6b S41026 6 233 25Cr-7Ni-4Mo-N Forgings & fittings A182 F53 S32750 10H 234 25Cr-7Ni-4Mo-N Forgings & fittings A815 WPS32750 S32750 10H 235 25Cr-7Ni-4Mo-N Forgings & fittings CRS32750 A815 S32750 10H . . . 236 13Cr Forgings & fittings A182 F6a S41000 4 . . . 6 237 18Cr-8Ni Bar A479 304 S30400 8 238 18Cr-8Ni Bar A479 304H S30409 8 239 18Cr-8Ni Bar A479 304L S30403 8 240 16Cr-12Ni-2Mo Bar A479 316 S31600 8 241 16Cr-12Ni-2Mo Bar A479 316H S31609 8 242 16Cr-12Ni-2Mo Bar A479 316L S31603 8 243 18Cr-10Ni-Ti Bar A479 321 S32100 8 . . . Bar 244 18Cr-10Ni-Ti A479 321 S32100 8 245 18Cr-10Ni-Ti Bar A479 321H S32109 8 246 18Cr-10Ni-Cb Bar A479 347 S34700 8 247 18Cr-10Ni-Cb Bar A479 347 S34700 8 248 18Cr-10Ni-Cb A479 347H S34709 8 Bar 249 44Fe-25Ni-21Cr-Mo Bar A479 904L N08904 45 250 22Cr-5Ni-3Mo-N Bar A479 S31803 10H 251 20Cr-18Ni-6Mo Bar A479 S31254 8 252 46Fe-24Ni-21Cr-6Mo-Cu-N Bar A479 N08367 45 253 21Cr-5Mn-1.5Ni-Cu-N Bar A479 S32101 10H 254 22Cr-13Ni-5Mn Bar A479 XM-19 S20910 8 . . . 255 29Cr-6.5Ni-2Mo-N Bar A479 S32906 10H . . . Bar 256 25Cr-7Ni-4Mo-N A479 S32750 10H ≤50 A351 257 29Ni-20Cr-3Cu-2Mo CN7M N08007 Castings 45 258 35Ni-15Cr-1/2Mo HT30 N08603 Castings A351 45 259 25Cr-12Ni Castings A351 CH8 J93400 8 260 25Cr-20Ni Castings A351 CK20 J94202 8

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line No. 99.1 97.3 99.1 97.3 99.9 97.7 95.7 94.1 92.6 91.3 90.0 88.7 87.3 85.6 83.7 98.1 96.1 94.3 92.6 90.9 89.3 87.6 85.9 84.2 82.5 96.9 93.7 96.9 93.7

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, ${}^{\circ}$ C [Notes (1), (3), and (4b)]

Line No.	550	575	600	625	650	675	700	725	750	775	800	825
225												
226												• • •
227												• • •
228												
223	•••		•••		• • • • • • • • • • • • • • • • • • • •							
229												
230												
231												
232	• • •	•••	• • •	•••	•••	•••	•••	•••	• • •	• • •	• • •	•••
233												
234												
235	•••	• • •	• • •		• • • •				• • •	• • •		• • •
236												
237	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
238	95.5	78.9	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	9.65
239	81.4	40.4	33.2	26.7	21.9	18.2	15.0	12.4	8.87	7.20	6.58	6.21
240	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.96
241	105	97.8	80.8	65.0	50.4	38.6	29.6	23.0	17.4	13.3	10.4	8.96
242	80.8	73.0	67.9	58.0	43.6	33.0	25.3	18.8	14.0	10.4	7.99	6.89
243	88.7	59.2	44.0	32.9	24.5	18.3	12.5	8.49	6.19	4.28	2.78	2.07
244	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.58
245	100	76.5	58.7	46.0	36.8	28.7	23.0	18.4	14.5	11.5	9.02	7.58
246	97.6	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.52
247	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
248	125	112	90.6	69.6	53.8	41.4	31.8	24.0	18.8	14.6	10.9	8.96
249												
250												
251												
252												
253	•••	•••	• • •	•••		•••	•••	• • •	• • •	• • •	•••	• • •
254	179	174	132	83.6	56.1							
255												
256	• • •	• • •	• • •	•••	•••	•••	•••	• • •	• • •		•••	• • •
257												
258	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
259	68.1	53.5	42.1	33.2	25.9	20.3	16.5	13.2	10.1	7.35	5.89	5.52
260	73.2	64.4	56.5	49.0	41.0	33.5	25.4	18.3	12.8	9.01	6.59	5.52

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)
261	16Cr-14Ni-2Mo	Castings	A351	CF10MC				8
262	18Cr-8Ni	Castings	A351	CF3	J92500			8
263	18Cr-12Ni-2Mo	Castings	A351	CF3M	J92800			8
264	18Cr-8Ni	Castings	A351	CF8	J92600	•••	•••	8
265	25Cr-12Ni	Castings	A351	CH10	J93401			8
266	25Cr-12Ni	Castings	A351	CH20	J93402			8
	18Cr-10Ni-Cb	Castings	A351	CF8C	J92710			8
268	18Cr-12Ni-2Mo	Castings	A351	CF8M	J92900	• • •	• • •	8
269	25Cr−20Ni−½Mo	Castings	A351	HK40	J94204			8
270	25Cr-20Ni-1/2Mo	Castings	A351	HK30	J94203	•••	• • •	8
271	18Cr-8Ni	Castings	A351	CF3A	J92500			8
272	18Cr-8Ni	Castings	A351	CF8A	J92600			8
273	25Cr-8Ni-N	Castings	A351	CE20N	J92802			8
	12Cr	Castings	A217	CA15	J91150	• • • •	• • •	6
275	24Cr-10Ni-4Mo-N	Castings	A995	2A	J93345			10H
276	25Cr-8Ni-3Mo-W-Cu-N	Castings	A995	6A	J93380			10H
277	13Cr-4Ni	Castings	A487	CA6NM	J91540	•••		6

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)] Min. Min. Min. Tensile Min. Yield Max. Use Temp. Line Temp., Strength, Strength, Temp., to °C (6) MPa MPa No. Notes °C (2)(30)-198. 262 (2)(9) -254263 (2)(9) -254264 (2)(9)(26)(27)(31) -254265 (2)(27)(31)(35) -198266 (2)(9)(27)(31)(35)(39) -198 267 (2)(9)(27)(30) -198268 (2)(9)(26)(27)(30) -254269 (2)(35)(36)(39) -198. 270 (2)(35)(39) -198. 271 (2)(9)(56) -254272 (2)(9)(26)(56) -254273 (2)(35)(39) -198 274 (2)(35) -29 275 (2)(9) -51276 (2)(9)(25) -51 277 (2)(9)(35) -29

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, 5, MPa, at Metal Temperature, °C [Notes (1), (3), and (4b)]

Line													
No.	225	250	275	300	325	350	375	400	425	450	475	500	525
261													
262	125	122	119	116	113	111	109	107	105	103			
263	129	125	122	119	116	114	112	111	109	108	107	• • •	• • •
264	125	122	119	116	113	111	109	107	105	103	101	99.1	94.4
265	138	138	138	138	138	138	138	138	138	138	138	138	138
266	138	138	138	138	138	138	138	138	138	138	138	138	138
267	138	138	138	138	138	97.0	84.3	73.3	64.0	55.8	43.9	31.7	21.4
268	125	122	119	116	113	111	109	107	105	103	101	99.1	97.3
269													
270													
271	146	142	138	135	132	130	127						
272	146	142	138	135	132	130	127						
273	184	184	184	184	184	184	184	184	184	184	184	184	
274	198	197	195	193	190	187	182	120	116	105	82.1	59.9	41.8
275	194	194	194	194	194								
276	207	206	205	204	204								
277	242	240	238	236	232	228	224						

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, ${}^{\circ}$ C [Notes (1), (3), and (4b)]

Line No.	550	575	600	625	650	675	700	725	750	775	800	825
261												
262												
263	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
264	75.3	60.4	49.0	40.1	32.8	27.2	23.4	19.6	16.8	14.7	12.8	11.7
265	68.1	53.5	42.1	33.2	25.9	20.3	16.5	13.2	10.1	7.35	5.89	5.52
266	68.1	53.5	42.1	33.2	25.9	20.3	16.5	13.2	10.1	7.35	5.89	5.52
267	14.2	9.40	6.16	4.03	2.64	1.73	1.13	0.74	0.49	0.32	0.21	
268	95.5	75.9	57.2	40.2	30.3	23.2	16.2	11.4	8.97	7.08	5.89	5.52
269												• • •
270												
271												
272												
273												
274	28.7	20.1	14.3	9.77	6.89							
275												
276							• • •					
277												

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)(7)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa
1	99.95Cu-P	Pipe	B42	C10200	061		31	(2)	-269	207	62
2	99.9Cu-P	Pipe	B42	C12000	061		31	(2)	-269	207	62
3	99.9Cu-P	Pipe	B42	C12200	061		31	(2)	-269	207	62
4	99.95Cu-P	Tube	B75	C10200	050		31	(2)	-269	207	62
5	99.95Cu-P	Tube	B75	C10200	060		31	(2)	-269	207	62
6	99.9Cu-P	Tube	B75	C12000	050		31	(2)	-269	207	62
7	99.9Cu-P	Tube	B75	C12000	060		31	(2)	-269	207	62
8	99.9Cu-P	Tube	B75	C12200	050		31	(2)	-269	207	62
9	99.9Cu-P	Tube	B75	C12200	060		31	(2)	-269	207	62
10	99.9Cu-P	Tube	B68	C12200	050		31	(2)(24)	-269	207	62
11	99.9Cu-P	Tube	B68	C12200	060		31	(2)(24)	-269	207	62
12	99.9Cu-P	Tube	B88	C12200	050		31	(2)(24)	-269	207	62
13	99.9Cu-P	Tube	B88	C12200	060		31	(2)(24)	-269	207	62
14	99.9Cu-P	Tube	B280	C12200	060		31	(2)(24)	-269	207	62
15	85Cu-15Zn	Pipe	B43	C23000	061		32	(2)	-269	276	83
16	90Cu-10Ni	Pipe & tube	B467	C70600	WO50	>114 O.D.	34	(2)(14)	-269	262	90
17	90Cu-10Ni	Pipe & tube	B467	C70600	W061	>114 O.D.	34	(2)(14)	-269	262	90
18	90Cu-10Ni	Pipe & tube	B466	C70600	Annealed	•••	34	(2)(14)	-269	262	90
19	90Cu-10Ni	Pipe & tube	B467	C70600	WO50	≤114 O.D.	34	(2)(14)	-269	276	103
20	90Cu-10Ni	Pipe & tube	B467	C70600	W061	≤114 O.D.	34	(2)(14)	-269	276	103
21	70Cu-30Ni	Pipe & tube	B467	C71500	WO50	>114 O.D.	34	(2)(14)	-269	310	103
22	70Cu-30Ni	Pipe & tube	B467	C71500	W061	>114 O.D.	34	(2)(14)	-269	310	103
23	80Cu-20Ni	Pipe & tube	B466	C71000	Annealed	≤114 O.D.	34	(2)(14)	-269	310	110
24	99.95Cu-P	Pipe	B42	C10200	H55	DN 64 thru 300	31	(2)(14)(34)	-269	248	207
25	99.9Cu-P	Pipe	B42	C12000	H55	DN 64 thru 300	31	(2)(14)(34)	-269	248	207
26	99.9Cu-P	Pipe	B42	C12200	H55	DN 64 thru 300	31	(2)(14)(34)	-269	248	207
27	99.95Cu-P	Tube	B75	C10200	H58	• • •	31	(2)(14)(34)	-269	248	207
28	99.9Cu-P	Tube	B75	C12000	H58		31	(2)(14)(34)	-269	248	207
29	99.9Cu-P	Tube	B75	C12200	H58		31	(2)(14)(34)	-269	248	207
30	99.9Cu-P	Tube	B88	C12200	H58	•••	31	(2)(14)(24)(34)	-269	248	207
31	70Cu-30Ni	Pipe & tube	B466	C71500	060		34	(2)(14)	-269	359	124
32	70Cu-30Ni	Pipe & tube	B467	C71500	WO50	≤114 O.D.	34	(2)(14)	-269	345	138
33	70Cu-30Ni	Pipe & tube	B467	C71500	W061	≤114 O.D.	34	(2)(14)	-269	345	138

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

				Bas	sic Allowa	ble Stres	s, <i>S</i> , MPa	, at Meta	l Tempera	ature, °C	[Notes (1	l) and (4h	p)]		
ine No.	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225	250	275	300	325	350	375
1	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
2	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
3	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
4	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
5	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
6	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
7	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
8	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
9	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
10	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
11	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
12	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
13	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6				
14	260	41.4	34.9	33.5	32.9	32.2	28.0	21.7	16.7	12.9	11.6	• • •	• • •	•••	
15	232	55.2	54.7	54.7	54.7	54.7	54.7	36.4	17.5	13.8					
16	316	59.8	58.0	56.1	54.9	53.8	52.9	52.0	51.2	50.4	49.7	45.1	39.3		
17	316	59.8	58.0	56.1	54.9	53.8	52.9	52.0	51.2	50.4	49.7	45.1	39.3		
18	316	59.8	58.0	56.1	54.9	53.8	52.9	52.0	51.2	50.4	49.7	45.1	39.3		
19	316	68.9	67.0	65.1	63.7	62.4	61.1	60.0	59.1	58.3	51.3	45.1	39.3		
20	316	68.9	67.0	65.1	63.7	62.4	61.1	60.0	59.1	58.3	51.3	45.1	39.3		
21	371	68.9	66.6	64.6	63.2	61.9	60.7	59.5	58.4	57.4	56.2	55.5	54.9	54.3	53.8
22	371	68.9	66.6	64.6	63.2	61.9	60.7	59.5	58.4	57.4	56.2	55.5	54.9	54.3	53.8
23	371	73.5	72.8	72.1	71.4	70.6	69.6	68.3	66.6	64.7	62.4	60.0	56.2	51.9	48.3
24	204	82.7	80.0	74.1	71.3	69.2	67.4	65.7	65.3						
25	204	82.7	80.0	74.1	71.3	69.2	67.4	65.7	65.3	• • •	• • •	• • •	• • •	• • •	
26	204	82.7	80.0	74.1	71.3	69.2	67.4	65.7	65.3	• • •	• • •	• • •	• • •	• • •	
27	204	82.7	80.0	74.1	71.3	69.2	67.4	65.7	65.3		• • •	• • •	• • •	• • •	
28	204	82.7	80.0	74.1	71.3	69.2	67.4	65.7	65.3			• • •			
29	204	82.7	80.0	74.1	71.3	69.2	67.4	65.7	65.3						
30	204	82.7	80.0	74.1	71.3	69.2	67.4	65.7	65.3	• • •	• • •	• • •	• • • •	• • •	
31	371	82.7	79.8	77.5	75.9	74.3	72.9	71.5	70.2	68.9	67.8	66.8	65.9	65.3	64.8
32	371	91.9	88.7	86.1	84.3	82.6	81.0	79.4	78.0	76.6	75.3	74.2	73.2	72.5	71.7
33	371	91.9	88.7	86.1	84.3	82.6	81.0	79.4	78.0	76.6	75.3	74.2	73.2	72.5	71.7

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)(7)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa
34	99.95Cu-P	Pipe	B42	C10200	H80	DN 6 thru 50	31	(2)(14)(34)	-269	310	276
35	99.9Cu-P	Pipe	B42	C12000	H80	DN 6 thru 50	31	(2)(14)(34)	-269	310	276
36	99.9Cu-P	Pipe	B42	C12200	H80	DN 6 thru 50	31	(2)(14)(34)	-269	310	276
37	99.95Cu-P	Tube	B75	C10200	H80		31	(2)(14)(34)	-269	310	276
38	99.9Cu-P	Tube	B75	C12000	H80		31	(2)(14)(34)	-269	310	276
39	99.9Cu-P	Tube	B75	C12200	H80		31	(2)(14)(34)	-269	310	276
40	99.95Cu-P	Plate & sheet	B152	C10200	025		31	(14)(24)	-269	207	69
41	99.95Cu–Ag	Plate & sheet	B152	C10400	025		31	(14)(24)	-269	207	69
42	99.95Cu–Ag	Plate & sheet	B152	C10500	025		31	(14)(24)	-269	207	69
43	99.95Cu–Ag	Plate & sheet	B152	C10700	025		31	(14)(24)	-269	207	69
44	99.9Cu-P	Plate & sheet	B152	C12200	025		31	(14)(24)	-269	207	69
45	99.9Cu-P	Plate & sheet	B152	C12300	025		31	(14)(24)	-269	207	69
46	90Cu-10Ni	Plate & sheet	B171	C70600		≤64 thk.	34	(14)	-269	276	103
47	97Cu-3Si	Plate & sheet	B96	C65500	061		33		-269	345	124
48	70Cu-30Ni	Plate & sheet	B171	C71500		≤64 thk.	34	(14)	-269	345	138
49	90Cu-7Al-3Fe	Plate & sheet	B169	C61400	025	≤50 thk.	35	(13)	-269	483	207
50	90Cu-7Al-3Fe	Plate & sheet	B169	C61400	060	≤50 thk.	35	(13)	-269	483	207
51	99.9Cu	Forgings	B283	C11000			31	(14)	-269	228	76
52	97Cu-3Si	Forgings	B283	C65500	• • •	• • •	33	(14)	-269	359	124
53	60Cu-38Zn-2Pb	Forgings	B283	C37700	•••		a	(14)	-198	400	159
54	60Cu-37Zn-2Pb-Sn	Forgings	B283	C48500			a	(14)	-198	427	165
55	60Cu-39Zn-Sn	Forgings	B283	C46400	• • •	• • •	32	(14)	-254	441	179
56	59Cu-39Zn-Fe-Sn	Forgings	B283	C67500	•••		32	(14)	-198	496	234
57	85Cu-5Sn-5Zn-5Pb	Castings	B62	C83600			a	(2)(9)	-198	207	97
58	57Cu-20Zn-12Ni-9Pb-2Sn	Castings	B584	C97300	• • •		a	(2)	-198	207	103
59	64Cu-20Ni-8Zn-4Sn-4Pb	Castings	B584	C97600	• • •	• • •	a	(2)	-198	276	117
60	87Cu-8Sn-4Zn-1Pb	Castings	B584	C92300	•••	•••	a	(2)	-198	248	110
61	88Cu-Sn-Zn-Pb	Castings	B584	C92200			a	(2)	-198	234	110
62	88Cu-Sn-Zn-Pb	Castings	B61	C92200			a	(2)(9)	-198	234	110
63	88Cu-8Sn-4Zn	Castings	B584	C90300			b	(2)	-198	276	124
64	88Cu-10Sn-2Zn	Castings	B584	C90500	•••	•••	b	(2)	-198	276	124

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Max. Use Min. Line Temp., Temp. to °C 40 65 100 125 150 175 200 225 250 275 300 325 350 375 No. 34 204 103 100 92.6 89.1 86.5 84.3 35.8 29.6 35 204 92.6 89.1 86.5 84.3 103 100 35.8 29.6 . . . 204 103 100 92.6 89.1 86.5 84.3 35.8 29.6 36 204 89.1 35.8 29.6 37 103 100 92.6 86.5 84.3 204 92.6 89.1 86.5 84.3 35.8 29.6 38 103 100 39 204 103 100 92.6 89.1 86.5 84.3 35.8 29.6 28.0 40 260 46.0 39.1 37.1 36.5 34.2 21.7 16.7 12.9 11.6 . . . 41 260 46.0 39.1 37.1 36.5 34.2 28.0 21.7 16.7 12.9 11.6 28.0 42 260 46.0 39.1 37.1 36.5 34.2 21.7 16.7 12.9 11.6 43 37.1 36.5 34.2 28.0 21.7 16.7 12.9 11.6 260 46.0 39.1 260 46.0 39.1 37.1 36.5 34.2 28.0 21.7 16.7 12.9 11.6 44 260 46.0 39.1 37.1 36.5 34.2 28.0 21.7 16.7 12.9 45 11.6 46 316 68.9 67.0 65.1 63.7 62.4 61.1 60.0 59.1 58.3 51.3 45.1 39.3 . . . 204 82.7 82.7 82.7 75.4 50.8 47 82.7 82.7 31.9 48 371 91.9 88.7 86.1 84.3 82.6 81.0 79.4 78.0 76.6 75.3 74.2 73.2 72.5 71.7 49 260 138 137 136 135 135 134 133 131 130 130 . . . 50 135 134 133 260 138 137 136 135 131 130 130 51 260 50.6 42.8 40.8 40.2 34.2 28.0 21.7 16.7 12.9 11.6 52 204 82.7 82.7 82.7 82.7 82.7 75.4 50.8 31.9 91.1 71.4 52.8 17.0 13.8 53 204 106 99.8 94.5 . . . 54 204 110 110 110 110 110 110 110 110 55 204 120 120 118 118 20.0 17.2 120 120 . . . 204 156 156 156 156 56 156 156 156 156 . . . 57 232 59.1 51.2 50.3 64.4 64.4 62.6 55.7 53.0 50.1 58 40 68.9 59 149 78.1 69.6 64.9 62.5 60.3 204 60 73.5 73.5 73.5 73.5 73.5 73.5 73.5 73.5 204 73.5 65.3 59.6 61 66.4 64.6 63.3 61.5 58.1 62 288 73.5 63.3 61.5 59.6 58.1 66.4 65.3 64.6 57.5 57.5 57.3 204 63 82.7 82.7 82.7 82.7 82.7 82.7 82.7 82.7 64 204 82.7 82.7 82.7 82.7 82.7 82.7 82.7 82.7

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	UNS No.	Class/ Condition/ Temper		Size, mm	P-No. (5)(7)	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa
65	58Cu-38Zn-1Sn-1Pb-1Fe	Castings	B584	C86400				a	(2)(9)	-198	414	138
66	66Cu-25Ni-5Sn-2Pb-2Zn	Castings	B584	C97800				a	(2)	-198	345	152
67	58Cu-39Zn-1Fe-1Al-1Mn	Castings	B584	C86500				b	(2)	-198	448	172
68	88Cu-9Al-3Fe	Castings	B148	C95200				35	(2)(9)	-254	448	172
69	89Cu-10Al-1Fe	Castings	B148	C95300				35	(2)(9)	-254	448	172
70	90Cu-7Al-3Si	Castings	B148	C95600				35	(2)	-198	414	193
71	85Cu-11Al-4Fe	Castings	B148	C95400				35	(2)	-198	517	207
72	58Cu-34Zn-2Fe-2Al-2Mn	Castings	B584	C86700				a	(2)	-198	552	221
73	82Cu-11Al-4Fe-3Mn	Castings	B148	C95500				35	(2)	-269	621	276
74	63Cu-27Zn-4Al-3Fe-3Mn	Castings	B584	C86200				b	(2)	-198	621	310
75	61Cu-27Zn-6Al-3Fe-3Mn	Castings	B584	C86300				b	(2)	-198	758	414
76	75Cu-21.5Zn-3Si	Rod	B371	C69300	H02	≤12		a	• • •	-198	585	310
77	75Cu-21.5Zn-3Si	Rod	B371	C69300	H02	>12,	≤25	a		-198	515	240
78	75Cu-21.5Zn-3Si	Rod	B371	C69300	H02	>25,	≤50	а		-198	480	205

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

				Bas	ic Allowa	ble Stres	s, <i>S</i> , MPa	, at Meta	l Tempera	ature, °C	[Notes (1	l) and (4h	o)]		
Line No.	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225	250	275	300	325	350	375
65	177	91.9	91.9	91.9	91.9	91.9	91.9	91.9							
66	177	101	101	101	101	101	101	101							
67	177	115	115	115	115	115	115	115		• • •	• • •		• • • •		• • • •
68	316	115	108	104	102	99.8	98.6	97.8	97.5	97.4	97.4	65.9	43.7		
69	316	115	115	115	115	115	115	115	115	115	115	115	115		
70	40	129													
71	260	138	131	128	128	128	128	128	128	101	95.8		• • • •	• • •	
72	177	147	147	147	147	147	147	147							
73	260	184	184	184	184	184	184	184	184	184	184				
74	177	207	207	207	207	207	207	207							
75	177	253	253	253	253	253	253	253	•••				• • •		•••
76	149	195	179	176	176	176									
77	149	161	139	137	137	137									
78	149	138	119	117	117	117									

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/Condition/Temper		Size, mm	P-No. (5)
1	99.0Ni–Low C	Pipe & tube	B161		N02201	Annealed	>125		41
2	99.0Ni–Low C	Pipe & tube	B725		N02201	Annealed	>125		41
3	99.0Ni	Pipe & tube	B161		N02200	Annealed	>125		41
4	99.0Ni	Pipe & tube	B725		N02200	Annealed	>125		41
5	99.0Ni–Low C	Pipe & tube	B161		N02201	Annealed	≤125		41
6	99.0Ni–Low C	Pipe & tube	B725		N02201	Annealed	≤125		41
7	99.0Ni	Pipe & tube	B161		N02200	Annealed	≤125		41
8	99.0Ni	Pipe & tube	B725		N02200	Annealed	≤125		41
9	67Ni-30Cu	Pipe & tube	B165		N04400	Annealed	>125		42
10	67Ni-30Cu	Pipe & tube	B725		N04400	Annealed	>125		42
11	33Ni-42Fe-21Cr	Pipe & tube	B407		N08800	H.F. or H.F. ann.			45
12	72Ni-15Cr-8Fe	Pipe & tube	B167		N06600	H.F. or H.F. ann.	>125		43
13	33Ni-42Fe-21Cr	Pipe & tube	B407		N08810	C.D. sol. ann. or H.F. ann.			45
14	33Ni-42Fe-21Cr	Pipe & tube	B514		N08810	Annealed			45
15	33Ni-42Fe-21Cr-Al-Ti	Pipe & tube	B407	•••	N08811	C.D. sol. ann. or H.F. ann.	• • •		45
16	67Ni-30Cu	Pipe & tube	B165		N04400	Annealed	≤125		42
17	67Ni-30Cu	Pipe & tube	B725		N04400	Annealed	≤125		42
18	26Ni-22Cr-5Mo-Ti	Pipe & tube	B619		N08320	Sol. ann.			45
19	26Ni-22Cr-5Mo-Ti	Pipe & tube	B622		N08320	Sol. ann.			45
20	99.0Ni–Low C	Pipe & tube	B161		N02201	Str. rel.			41
21	99.0Ni–Low C	Pipe & tube	B725		N02201	Str. rel.			41
22	33Ni-42Fe-21Cr	Pipe & tube	B514		N08800	Annealed			45
23	72Ni-15Cr-8Fe	Pipe & tube	B167		N06600	H.F. or H.F. ann.	≤125		43
24	72Ni-15Cr-8Fe	Pipe & tube	B167	•••	N06600	C.D. ann.	>125		43
25	33Ni-42Fe-21Cr	Pipe & tube	B407		N08800	C.D. ann.			45
26	31Ni-31Fe-29Cr-Mo	Pipe & tube	B668		N08028	Sol. ann.			45
27	99.0Ni	Pipe & tube	B161		N02200	Str. rel.			41
28	99.0Ni	Pipe & tube	B725		N02200	Str. rel.			41
29	35Ni-35Fe-20Cr-Cb	Pipe & tube	B464		N08020	Annealed			45
30	35Ni-35Fe-20Cr-Cb	Pipe & tube	B474		N08020	Annealed			45
31	35Ni-35Fe-20Cr-Cb	Pipe & tube	B729	•••	N08020	Annealed			45

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

ne o.	275	300	325	350	375	400	425	450	475	500	525	550	575
1	43.2	43.2	43.1	42.9	42.6	42.1	41.5	40.7	33.1	27.4	22.8	18.7	15.
2	43.2	43.2	43.1	42.9	42.6	42.1	41.5	40.7	33.1	27.4	22.8	18.7	15.
3	55.2	55.2	55.2										
4	55.2	55.2	55.2										
5	51.6	51.6	51.6	51.5	51.2	50.7	49.9	41.4	33.1	27.4	22.8	18.7	15
6	51.6	51.6	51.6	51.5	51.2	50.7	49.9	41.4	33.1	27.4	22.8	18.7	15
7	68.9	68.9	68.9										
8	68.9	68.9	68.9	• • •			• • • •		• • •				
9	90.4	90.4	90.4	90.4	89.8	89.0	88.0	79.7	59.9	55.2			
10	90.4	90.4	90.4	90.4	89.8	89.0	88.0	79.7	59.9	55.2			
11	115	115	115	115	115	115	115	115	115	115	115	113	10
12	115	115	115	115	115	115	115	115	115	84.8	58.4	39.7	27
13	115	115	113	110	108	106	104	102	100	98.6	97.1	95.7	91
14	115	115	113	110	108	106	104	102	100	98.6	97.1	95.7	91
15	115	115	113	110	108	106	104	102	100	98.6	97.1	95.7	92
16	101	101	101	101	100	99.6	98.6	79.7	59.9	55.2			
17	101	101	101	101	100	99.6	98.6	79.7	59.9	55.2			
18	129	129	127	125	122	121	119	119					
19	129	129	127	125	122	121	119	119					
20	135	133	130										•
21	135	133	130										
22	138	138	138	138	138	138	138	138	138	138	138	136	10
23	138	138	138	138	138	138	138	138	138	84.8	58.4	39.7	27
24	138	138	138	138	138	138	138	138	138	84.8	58.4	39.7	27
25	138	138	138	138	138	138	138	138	138	138	138	136	10
26	140	137	133	130	125	122	119	116	113	• • •		• • •	•
27	146	144	141			• • •	• • •	• • •	• • •	• • •	• • •	•••	•
28	146	144	141	• • •	•••		• • •	• • •		• • •		• • •	
29	161	161	161	161	161	160	157	156					•
30	161	161	161	161	161	160	157	156					
31	161	161	161	161	161	160	157	156					

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

(16)

lo.	600	625	650	675	700	725	750	775	800	825	850	875	900
1	12.9	10.0	8.27										
2	12.9	10.0	8.27										
3													
4													
5	12.9	10.0	8.27										
6	12.9	10.0	8.27										
7													
8			•••			•••	• • •			• • •		• • •	• •
9													
10													
11	83.8	63.9	44.7	29.8	15.5	11.7	8.68	7.20	6.25	5.11			
12	19.2	15.0	13.8										
13	75.7	62.6	50.6	41.2	33.6	27.7	22.6	18.3	15.0	11.9	9.03	7.35	5.8
14	75.7	62.6	50.6	41.2	33.6	27.7	22.6	18.3	15.0	11.9	9.03	7.35	5.8
15	84.5	69.5	56.7	46.8	38.5	31.5	25.5	20.7	17.0	13.9	11.2	9.33	7.5
16			•••			•••							
17		•••											
18	• • •	•••	• • •				• • •	• • •	• • •				
19		•••											
20	• • •	•••	• • •				• • •	• • •	• • •				
21	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	
22	83.8	63.9	44.7	29.8	15.5	11.7	8.68	7.20	6.25	5.11	• • •	• • •	
23	19.2	15.0	13.8	• • • •	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	
24	19.2	15.0	13.8	• • •	• • •	• • • •	• • •	• • •		• • •	•••	• • •	
25	83.8	63.9	44.7	29.8	15.5	11.7	8.68	7.20	6.25	5.11			
26	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	
27	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		• • • •	• • • •	• • • •	
28	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		• • • •	• • • •	• • • •	
29	• • •		• • •		• • •		• • •	• • •	• • •	• • •	•••	• • •	
30	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		• • • •	• • • •	• • • •	
31													

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/Condition/Temper	Size, mm	P-No. (5)
32	42Ni-21.5Cr-3Mo-2.3Cu	Pipe & tube	B423	•••	N08825	C.D. ann.		45
33	42Ni-21.5Cr-3Mo-2.3Cu	Pipe & tube	B705		N08825	Annealed		45
34	47Ni-22Cr-19Fe-6Mo	Pipe & tube	B619	• • •	N06007	Sol. ann.		45
35	47Ni-22Cr-19Fe-6Mo	Pipe & tube	B622	• • •	N06007	Sol. ann.		45
36	40Ni-29Cr-15Fe-5Mo	Pipe & tube	B619		N06030	Sol. ann.		45
37	40Ni-29Cr-15Fe-5Mo	Pipe & tube	B622		N06030	Sol. ann.		45
38	40Ni-29Cr-15Fe-5Mo	Pipe & tube	B626		N06030	Sol. ann.		45
39	72Ni–15Cr–8Fe	Pipe & tube	B167		N06600	C.D. ann.	≤125	43
40	72Ni–15Cr–8Fe	Pipe & tube	B517		N06600	C.D. ann.		43
41	61Ni-16Mo-16Cr	Pipe & tube	B619	• • •	N06455	Sol. ann.	•••	43
42	47Ni-22Cr-9Mo-18Fe	Pipe & tube	B619		N06002	Sol. ann.		43
43	47Ni–22Cr–9Mo–18Fe	Pipe & tube	B622		N06002	Sol. ann.		43
44	31Ni-33Fe-27Cr-6.5Mo-Cu-N	Pipe & tube	B619		N08031	Annealed		45
45	31Ni-33Fe-27Cr-6.5Mo-Cu-N	Pipe & tube	B622		N08031	Annealed		45
46	61Ni-16Mo-16Cr	Pipe & tube	B622		N06455	Sol. ann.		43
47	54Ni-16Mo-15Cr	Pipe & tube	B619	•••	N10276	Sol. ann.		43
48	54Ni-16Mo-15Cr	Pipe & tube	B622		N10276	Sol. ann.		43
49	54Ni-16Mo-15Cr	Pipe & tube	B626		N10276	Sol. ann.		43
	l							

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Min. Min. Min. Tensile Yield Max. Use Min. Str., Line Temp., Temp., Temp. to Str., °C Notes °C (6) MPa MPa No. 32 (2)(9) -198 33 (2)(9) -198 34 (2) -198 35 (2) -198 36 (2) -19837 (2) -19838 (2) -198 39 (2) -19840 (2) -198 41 (2) -198-198 42 (2) 43 (2) -19844 (2) -19845 (2) -198 46 (2) -19847 (2) -19848 (2) -19849 (2) -198

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Line No. 84.8 39.7 27.0 58.4 84.8 58.4 39.7 27.0 74.2 61.1 50.3 49.6 74.2 61.1 50.3 49.6

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

ine No.	600	625	650	675	700	725	750	775	800	825	850	875	900
32													
33													
34							•••					•••	
35													
36	•••	•••	•••	•••	•••	• • •	•••	•••	•••	•••	•••	•••	• •
	• • •	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	
37	• • •	• • • •	• • •	• • • •	• • •	• • • •	• • •	• • •	• • •	• • • •	• • • •	• • •	• •
38	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	
39	19.2	15.0	13.8										
40	19.2	15.0	13.8										
41												• • •	
42	115	94.2	77.3	64.9	54.7	44.7	36.1	29.2	23.6	20.7			
43	115	94.2	77.3	64.9	54.7	44.7	36.1	29.2	23.6	20.7			
44													
45													
46													
47	99.1	81.6	67.0	54.6	42.2							• • •	
48	99.1	81.6	67.0	54.6	42.2								
49	99.1	81.6	67.0	54.6	42.2								

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/Condition/Temper	Size, mm	P-No. (5)
50	67Ni-30Cu	Pipe & tube	B165		N04400	Str. rel.		42
51	67Ni-30Cu	Pipe & tube	B725		N04400	Str. rel.		42
52	46Fe-24Ni-21Cr-6Mo-Cu-N	Pipe & tube	B675		N08367	Annealed	>5	45
53	46Fe-24Ni-21Cr-6Mo-Cu-N	Pipe & tube	B690		N08367	Annealed	>5	45
54	46Fe-24Ni-21Cr-6Mo-Cu-N	Pipe & tube	B804		N08367	Annealed	>5	45
55	46Fe-24Ni-21Cr-6Mo-Cu-N	Pipe & tube	B675		N08367	Annealed	≤5	45
56	46Fe-24Ni-21Cr-6Mo-Cu-N	Pipe & tube	B690		N08367	Annealed	≤5	45
57	46Fe-24Ni-21Cr-6Mo-Cu-N	Pipe & tube	B804		N08367	Annealed	≤5	45
58	55Ni-21Cr-13.5Mo	Pipe & tube	B619		N06022	Sol. ann.		43
59	55Ni-21Cr-13.5Mo	Pipe & tube	B622		N06022	Sol. ann.		43
60	58Ni-33Cr-8Mo	Pipe & tube	B619		N06035	Sol. ann.		43
61	58Ni-33Cr-8Mo	Pipe & tube	B622		N06035	Sol. ann.		43
62	58Ni-33Cr-8Mo	Pipe & tube	B626		N06035	Sol. ann.		43
63	59Ni-23Cr-16Mo	Pipe & tube	B619		N06059	Sol. ann.		43
64	59Ni-23Cr-16Mo	Pipe & tube	B622		N06059	Sol. ann.		43
65	59Ni-23Cr-16Mo-1.6Cu	Pipe & tube	B619		N06200	Sol. ann.	All	43
66	59Ni-23Cr-16Mo-1.6Cu	Pipe & tube	B622		N06200	Sol. ann.	All	43
67	59Ni-23Cr-16Mo-1.6Cu	Pipe & tube	B626		N06200	Sol. ann.	All	43
68	62Ni-22Mo-15Cr	Pipe & tube	B619		N10362	Sol. ann.	All	43
69	62Ni-22Mo-15Cr	Pipe & tube	B622		N10362	Sol. ann.	All	43
70	62Ni-22Mo-15Cr	Pipe & tube	B626		N10362	Sol. ann.	All	43
71	62Ni-28Mo-5Fe	Pipe & tube	B619		N10001	Sol. ann.		44
72	62Ni-28Mo-5Fe	Pipe & tube	B622		N10001	Sol. ann.		44
73	65Ni-28Mo-2Fe	Pipe & tube	B619		N10665	Sol. ann.		44
74	65Ni-28Mo-2Fe	Pipe & tube	B622		N10665	Sol. ann.		44
75	65Ni-29.5Mo-2Fe-2Cr	Pipe & tube	B619		N10675	Sol. ann.		44
76	65Ni-29.5Mo-2Fe-2Cr	Pipe & tube	B622		N10675	Sol. ann.		44
77	65Ni-29.5Mo-2Fe-2Cr	Pipe & tube	B626		N10675	Sol. ann.		44
78	60Ni-22Cr-9Mo-3.5Cb	Pipe & tube	B444	1	N06625	Annealed	•••	43
79	60Ni-22Cr-9Mo-3.5Cb	Pipe & tube	B705	1	N06625	Annealed		43
80	57Ni-22Cr-14W-2Mo-La	Pipe & tube	B619		N06230	Sol. ann.	•••	43
81	57Ni-22Cr-14W-2Mo-La	Pipe & tube	B622		N06230	Sol. ann.	•••	43
82	57Ni-22Cr-14W-2Mo-La	Pipe & tube	B626		N06230	Sol. ann.		43
ı								

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

									[Notes	s (1) and ((4b)]			
Line No.	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225	250
50	(2)(54)	-198	586	379	260	195	195	195	195	195	195	195	195	195
51	(2)(54)	-198	586	379	260	195	195	195	195	195	195	195	195	195
52	(2)	-198	655	310	427	207	207	207	207	206	202	198	195	192
53	(2)	-198	655	310	427	207	207	207	207	206	202	198	195	192
54	(2)	-198	655	310	427	207	207	207	207	206	202	198	195	192
55	(2)	-198	689	310	427	207	207	207	207	206	202	198	195	192
56	(2)	-198	689	310	427	207	207	207	207	206	202	198	195	192
57	(2)	-198	689	310	427	207	207	207	207	206	202	198	195	192
58	(2)	-198	689	310	427	207	207	207	207	207	207	207	204	202
59	(2)	-198	689	310	427	207	207	207	207	207	207	207	204	202
60	(2)	-198	586	241	427	161	161	161	161	161	161	154	149	144
61	(2)	-198	586	241	427	161	161	161	161	161	161	154	149	144
62	(2)	-198	586	241	427	161	161	161	161	161	161	154	149	144
63	(2)	-198	689	310	427	207	207	207	207	207	207	207	207	206
64	(2)	-198	689	310	427	207	207	207	207	207	207	207	207	206
65	(2)	-198	689	310	427	207	207	207	207	207	207	207	207	200
66	(2)	-198	689	310	427	207	207	207	207	207	207	207	207	200
67	(2)	-198	689	310	427	207	207	207	207	207	207	207	207	200
68		-198	725	310	427	207	207	207	207	207	207	204	202	199
69		-198	725	310	427	207	207	207	207	207	207	204	202	199
70		-198	725	310	427	207	207	207	207	207	207	204	202	199
71	(2)	-198	689	310	427	207	207	207	207	207	207	207	207	207
72	(2)	-198	689	310	427	207	207	207	207	207	207	207	207	207
73	(2)	-198	758	352	427	234	234	234	234	234	234	234	234	234
74	(2)	-198	758	352	427	234	234	234	234	234	234	234	234	234
75	(2)	-198	758	352	427	234	234	234	234	234	234	234	234	234
76	(2)	-198	758	352	427	234	234	234	234	234	234	234	234	234
77	(2)	-198	758	352	427	234	234	234	234	234	234	234	234	234
78	(2)(64)(70)	-198	827	414	649	276	276	276	274	273	272	270	269	267
79	(2)(64)(70)	-198	827	414	649	276	276	276	274	273	272	270	269	267
80	(2)	-198	758	310	899	207	207	207	207	207	207	207	207	207
81	(2)	-198	758	310	899	207	207	207	207	207	207	207	207	207
82	(2)	-198	758	310	899	207	207	207	207	207	207	207	207	207

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

Line													
No.	275	300	325	350	375	400	425	450	475	500	525	550	575
50	195	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • • •	• • •
51	195	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
52	188	183	179	176	173	170	168	167	• • •	• • •	• • •	• • •	• • •
53	188	183	179	176	173	170	168	167	• • •	• • •	• • •	• • •	• • •
54	188	183	179	176	173	170	168	167	• • •	• • •	• • •	• • •	• • •
55	188	183	179	176	173	170	168	167	• • •	• • •	• • •	•••	• • •
56	188	183	179	176	173	170	168	167	• • •	• • •	• • •	• • •	• • •
57	188	183	179	176	173	170	168	167	• • •	• • •	• • •	• • •	• • •
58	197	193	189	185	182	180	177	177	• • •	• • •	• • •	• • •	• • •
59	197	193	189	185	182	180	177	177	• • •	• • •	• • •	• • •	• • •
60	140	137	135	133	132	131	129	128	• • •	• • •	• • •		
61	140	137	135	133	132	131	129	128	• • •	• • •	• • •		
62	140	137	135	133	132	131	129	128	• • •	• • •		•••	
63	202	197	192	188	184	180	176	176		• • •			
64	202	197	192	188	184	180	176	176					
65	194	188	184	180	177	175	174	173				• • •	
66	194	188	184	180	177	175	174	173					
67	194	188	184	180	177	175	174	173					
68	197	193	190	188	186	184	182	180					
69	197	193	190	188	186	184	182	180					
70	197	193	190	188	186	184	182	180					
71	207	207	207	207	207	207	206	206					
72	207	207	207	207	207	207	206	206					
73	234	234	234	234	234	234	234	234					
74	234	234	234	234	234	234	234	234					
75	234	234	234	234	234	233	231	230					
76	234	234	234	234	234	233	231	230					
77	234	234	234	234	234	233	231	230					
78	265	262	260	257	255	252	251	249	247	245	242	215	194
79	265	262	260	257	255	252	251	249	247	245	242	215	194
80	207	207	203	199	197	196	195	195	195	195	195	195	183
81	207	207	203	199	197	196	195	195	195	195	195	195	183
82	207	207	203	199	197	196	195	195	195	195	195	195	183

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

(16)

ne lo.	600	625	650	675	700	725	750	775	800	825	850	875	900
50													
51	•••	•••		• • • •	• • • •	• • • •	• • • •	• • • •		• • •	•••	• • • •	• • •
52	• • • •	•••	•••	•••	•••	•••	• • •	• • •	•••	•••	•••	•••	•••
53	•••	•••	•••	•••	•••	•••	•••	•••	•••	• • •	• • •	•••	• • •
54	•••	•••	•••	•••	•••	•••	• • •	•••	•••	•••	•••	•••	• • •
55	•••	•••	•••	•••	•••	• • •	• • •	•••	•••	•••	• • •	• • •	• • •
56	•••	•••	•••	•••	•••	•••	•••	•••	•••	• • •	•••	•••	• • •
57	•••	•••	•••	•••	•••	•••	• • •	•••	•••	•••	•••	•••	• • •
	• • •	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	• • •
58	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••
59	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	• •
60	• • •	•••	•••	•••	•••	•••	•••	•••	•••	•••	• • •	•••	• • •
61	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	• • •	•••	• • •
62	• • •	• • •	•••	• • •	• • •	• • •	• • •	• • •	•••	• • •	• • •	• • •	••
63	• • •	• • •	• • •	• • • •	• • • •	• • • •	• • •	• • • •	• • • •	• • • •	• • • •	• • •	••
64	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
65	• • •	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
66	•••	•••	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
67	• • •	•••	• • •	• • •	•••	•••	• • • •	• • • •	• • •	• • •	• • •	• • •	• •
68	•••	•••	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
69	• • •	•••	• • •	• • •	•••	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• •
70	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
71	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •	• •
72	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •	• •
73	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •	• •
74	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
75	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •	• •
76	• • •	• • •	•••	•••	• • •	• • •	• • •	• • •	•••	• • •	• • •	• • •	• •
77	• • •	•••	• • •	• • •	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
78	156	136	91.0	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
79	156	136	91.0	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	
80	153	128	107	89.7	74.7	61.9	50.8	41.1	32.6	25.2	18.9	13.8	10.
81	153	128	107	89.7	74.7	61.9	50.8	41.1	32.6	25.2	18.9	13.8	10.
82	153	128	107	89.7	74.7	61.9	50.8	41.1	32.6	25.2	18.9	13.8	10.

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/Condition/Temper		Size, mm	P-No. (5)
83	33Cr-31Ni-32Fe-1.5Mo-0.6Cu-N	Pipe	B619	• • •	R20033	Sol. ann.			45
84	33Cr-31Ni-32Fe-1.5Mo-0.6Cu-N	Pipe & tube	B622		R20033	Sol. ann.			45
85	33Cr-31Ni-32Fe-1.5Mo-0.6Cu-N	Tube	B626		R20033	Sol. ann.	•••		45
86	99.0Ni–Low C	Plate	B162		N02201	H.R. ann.			41
87	99.0Ni–Low C	Plate	B162		N02201	H.R. as R.			41
88	99.0Ni	Plate	B162		N02200	H.R. ann.			41
89	99.0Ni	Plate	B162		N02200	H.R. as R.			41
90	33Ni-42Fe-21Cr	Pl. & sht.	B409		N08810	Annealed	All		45
91	33Ni–42Fe–21Cr–Al–Ti	Pl. & sht.	B409	•••	N08811	Annealed	All		45
92	26Ni–22Cr–5Mo–Ti	Pl. & sht.	B620		N08320	Sol. ann.	All		45
93	67Ni-30Cu	Plate	B127		N04400	H.R. ann.			42
94	47Ni-22Cr-19Fe-6Mo	Pl. & sht.	B582		N06007	Sol. ann.	>19		45
95	33Ni-42Fe-21Cr	Pl. & sht.	B409		N08800	Annealed	All		45
96	31Ni-31Fe-29Cr-Mo	Pl. & sht.	B709		N08028	Sol. ann.	All		45
97	42Ni-21.5Cr-3Mo-2.3Cu	Plate	B424		N08825	Annealed			45
98	35Ni-35Fe-20Cr-Cb	Pl. & sht.	B463		N08020	Annealed	All		45
99	40Ni-29Cr-15Fe-5Mo	Pl. & sht.	B582		N06030	Sol. ann.	All		45
100	47Ni-22Cr-19Fe-6Mo	Pl. & sht.	B582		N06007	Sol. ann.	≤19		45
101	47Ni-22Cr-9Mo-18Fe	Pl. & sht.	B435	•••	N06002	H.R sol. ann.	All		43
102	72Ni–15Cr–8Fe	Plate	B168		N06600	H.R. ann.			43
103	72Ni-15Cr-8Fe	Plate	B168		N06600	H.R. as R.			43
104	67Ni-30Cu	Plate	B127		N04400	H.R. as R.			42
105	31Ni-33Fe-27Cr-6.5Mo-Cu-N	Pl. & sht.	B625		N08031	Annealed	All		45
106	61Ni-16Mo-16Cr	Pl. & sht.	B575		N06455	Sol. ann.	All		43
107	54Ni-16Mo-15Cr	Pl. & sht.	B575	•••	N10276	Sol. ann.	All		43
108	60Ni-22Cr-9Mo-3.5Cb	Plate	B443	1	N06625	Annealed	All		43
109	57Ni-22Cr-14W-2Mo-La	Pl. & sht.	B435		N06230	Sol. ann.	All		43
110	55Ni-21Cr-13.5Mo	Sheet	B575		N06022	Sol. ann.	<5		43
111	58Ni-33Cr-8Mo	Pl. & sht.	B575		N06035	Sol. ann.	All		43

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Line No. 51.6 51.6 51.6 51.5 51.2 50.7 49.9 41.4 33.1 27.4 22.8 18.7 15.6 51.6 51.6 51.5 51.2 50.7 49.9 41.4 33.1 27.4 18.7 51.6 22.8 15.6 68.9 68.9 68.9 91.9 91.9 91.9 98.6 97.1 95.9 91.8 98.6 97.1 96.1 94.1 99.6 98.6 79.7 59.9 55.2 84.8 58.4 39.7 27.0 84.8 27.0 58.4 39.7 63.8 33.5 27.6

. . .

. . .

. . .

. . .

. . .

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

(16)

lo.	600	625	650	675	700	725	750	775	800	825	850	875	90
83													
84													
85													•
86	12.9	10.0	8.27										
87	12.9	10.0	8.27										
88													
89													
90	75.7	62.6	50.6	41.2	33.6	27.7	22.6	18.3	15.0	11.9	9.03	7.35	5.
91	85.5	69.3	56.8	46.8	38.6	31.5	25.5	20.6	17.1	13.8	10.7	7.98	6.
92													
93													
94													
95	83.8	63.9	44.7	29.8	15.5	11.7	8.68	7.20	6.25	5.11			
96													
97													
98													
99													
100													
101				•••		•••			•••		•••		•
102	19.2	15.0	13.8										
103	19.2	15.0	13.8										
104													
105													
106					•••								
107	99.1	81.6	67.0	54.6	42.2	• • •	• • •	• • •		• • •		• • •	•
108	156	136	91.0										
109	153	128	107	89.7	74.7	61.9	50.8	41.1	32.6	25.2	18.9	13.8	10
110													
111													

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/Condition/Temper	Size, mm	P-No. (5)
112	46Fe-24Ni-21Cr-6Mo-Cu-N	Pl. & sht.	B688		N08367	Annealed	>5	45
113	46Fe-24Ni-21Cr-6Mo-Cu-N	Pl. & sht.	B688		N08367	Annealed	≤5	45
114	59Ni-23Cr-16Mo	Pl. & sht.	B575		N06059	Sol. ann.	All	43
115	59Ni-23Cr-16Mo-1.6Cu	Pl. & sht.	B575		N06200	Sol. ann.	All	43
116	62Ni-22Mo-15Cr	Pl. & sht.	B575		N10362	Sol. ann.	All	43
117	62Ni-28Mo-5Fe	Plate	B333		N10001	Sol. ann.	≥5, ≤64	44
118	62Ni-28Mo-5Fe	Sheet	B333		N10001	Sol. ann.	≤5	44
119	65Ni-28Mo-2Fe	Pl. & sht.	B333		N10665	Sol. ann.	All	44
120	65Ni-29.5Mo-2Fe-2Cr	Pl. & sht.	B333		N10675	Sol. ann.	All	44
121	33Cr-31Ni-32Fe-1.5Mo-0.6Cu-N	Pl. & sht.	B625		R20033	Sol. ann.		45
122	99.0Ni–Low C	Forg. & ftg.	B160		N02201	Annealed	All	41
123	99.0Ni–Low C	Forg. & ftg.	B366		N02201	Annealed	All	41
124	99.0Ni	Forg. & ftg.	B366		N02200	Annealed	All	41
125	99.0Ni	Forg. & ftg.	B564		N02200	•••		41
	99.0Ni	Forg. & ftg.	B564	• • •		Annealed	All	41
	33Ni-42Fe-21Cr	Forg. & ftg.	B564	• • •		Annealed	•••	45
	33Ni-42Fe-21Cr-Al-Ti	Forg. & ftg.	B564	• • •		Annealed	•••	45
	33Ni-42Fe-21Cr	Fittings	B366	• • •		Annealed	All	45
	33Ni-42Fe-21Cr-Al-Ti	Fittings	B366	•••		Annealed	All	45
	67Ni-30Cu	Forg. & ftg.	B564	• • •		Annealed	•••	42
132	67Ni-30Cu	Forg. & ftg.	B366	• • •	N04400	Annealed	All	42
133	72Ni-15Cr-8Fe	Forg. & ftg.	B366		N06600	Annealed	All	43
	40Ni-29Cr-15Fe-5Mo	Forg. & ftg.	B366			Sol. ann.	All	45
	40Ni-29Cr-15Fe-5Mo	Forg. & ftg.	B462		N06030	Sol. ann.	All	45
	33Ni-42Fe-21Cr	Forg. & ftg.	B366			C.D. ann.	All	45
	33Ni-42Fe-21Cr	Forg. & ftg.	B564			Annealed		45
138	35Ni-35Fe-20Cr-Cb	Forg. & ftg.	B366		N08020	Annealed	All	45
139	35Ni-35Fe-20Cr-Cb	Forg. & ftg.	B462	• • •	N08020	Annealed		45
140	72Ni-15Cr-8Fe	Forg. & ftg.	B564	• • •	N06600	Annealed	All	43

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

ne	275	200	225	252	275	400	405	450	4	F00	F05	F.F.	
0.	275	300	325	350	375	400	425	450	475	500	525	550	57
112	188	183	179	176	173	170	168	167	• • •	• • •	• • •	• • •	• •
113	188	183	179	176	173	170	168	167	• • •	• • •	• • •	• • • •	• •
114	202	197	192	188	184	180	176	176	• • •	• • •	• • •	•••	• •
115	194	188	184	180	177	175	174	173	• • •	• • •	• • •	• • • •	• •
116	197	193	190	188	186	184	182	180	• • •	• • •	• • •	• • •	
117	207	207	207	207	207	207	206	206	• • •	• • •	• • •	• • •	• •
118	230	230	230	230	230	230	229	229	• • •	• • •	• • •	• • •	• •
119	234	234	234	234	234	234	234	234	• • •	• • •	• • •	• • •	• •
120	234	234	234	234	234	233	231	230	• • •	•••	•••	•••	• •
121	169	165	163	161	159	157	156	155					
122	43.2	43.2	43.1	42.9	42.6	42.1	41.5	40.7	33.1	27.4	22.8	18.7	15
123	43.2	43.2	43.1	42.9	42.6	42.1	41.5	40.7	33.1	27.4	22.8	18.7	15
124	55.2												
125	55.2	• • •	• • •	•••	• • •	• • •	• • •	• • •	• • •	•••	• • •		
126	68.9	68.9	68.9										
127	115	115	113	110	108	105	104	102	100	98.6	97.1	95.9	91
128	115	115	113	110	108	105	104	102	100	98.7	97.1	96.1	94
129	115	115	113	110	108	105	104	102	100	98.6	97.1	95.9	91
130	115	115	113	110	108	105	104	102	100	98.7	97.1	96.1	94
131	90.4	90.4	90.4	90.4	89.8	89.0	88.0	79.7	59.9	55.2			
132	90.4	90.4	90.4	90.4	89.8	89.0	88.0	79.7	59.9	55.2	• • •		•
133	115	115	115	115	115	115	115	115	115	84.8	58.4	39.7	27
134	151	148	146	143	141	138	136	136					•
135	151	148	146	143	141	138	136	136					•
136	138	138	138	138	138	138	138	138	138	138	138	136	10
137	138	138	138	138	138	138	138	138	138	138	138	136	10
138	161	161	161	161	161	160	157	156					
139	161	161	161	161	161	160	157	156					
140	161	161	161	161	161	161	161	161	161	84.8	58.4	39.7	27

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

ine No.	600	625	650	675	700	725	750	775	800	825	850	875	900
112													
113	•••	• • •	• • •	•••	•••	• • • •	•••	• • • •	• • • •	• • •	• • • •	• • • •	••
114	• • •			•••	•••	• • •	•••	•••	• • •	•••	•••	•••	••
115	• • •			•••	•••	• • •	•••	•••	• • •	•••	•••	•••	• •
116													
117													
118													
119													
120													
121													
122	12.9	10.0	8.27							•••			
123	12.9	10.0	8.27										
124													
125	• • •									• • •			
126													
127	75.7	62.6	50.6	41.2	33.6	27.7	22.6	18.3	15.0	11.9	9.03	7.35	5.
128	85.5	69.3	56.8	46.8	38.6	31.5	25.5	20.6	17.1	13.8	10.2	7.98	6.
129	75.7	62.6	50.6	41.2	33.6	27.7	22.6	18.3	15.0	11.9	9.03	7.35	5.8
130	85.5	69.3	56.8	46.8	38.6	31.5	25.5	20.6	17.1	13.8	10.2	7.98	6.2
131													
132	•••	• • •		• • •	• • •	• • •	• • •	• • •		• • •	•••	• • •	•
133	19.2	15.0	13.8										
134													
135													
136	83.8	63.9	44.7	29.8	15.5	11.7	8.68	7.20	6.25	5.11			
137	83.8	63.9	44.7	29.8	15.5	11.7	8.68	7.20	6.25	5.11	• • •	• • •	•
138													
139	• • •					• • •		• • •		• • •			
140	19.2	15.0	13.8										

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/Condition/Temper	Size, mm	P-No. (5)
141	42Ni-21.5Cr-3Mo-2.3Cu	Fittings	B366		N08825	C.D. ann.	All	45
142	42Ni-21.5Cr-3Mo-2.3Cu	Forgings	B564	•••	N08825	Annealed		45
143	47Ni-22Cr-9Mo-18Fe	Forg. & ftg.	B366		N06002	Sol. ann.	All	43
144	31Ni-33Fe-27Cr-6.5Mo-Cu-N	Forg. & ftg.	B366	• • •	N08031	Sol. ann.	All	45
145	31Ni-33Fe-27Cr-6.5Mo-Cu-N	Forg. & ftg.	B564	•••	N08031	Annealed H.W.	All	45
146	54Ni-16Mo-15Cr	Forg. & ftg.	B366		N10276	Sol. ann.	All	43
147	54Ni-16Mo-15Cr	Forg. & ftg.	B462	• • •	N10276	Sol. ann.	All	43
148	54Ni-16Mo-15Cr	Forg. & ftg.	B564		N10276	Sol. ann.	All	43
149	62Ni-28Mo-5Fe	Forg. & ftg.	B366	•••	N10001	Sol. ann.	All	44
150	55Ni-21Cr-13.5Mo	Forg. & ftg.	B366		N06022	Sol. ann.	All	43
151	55Ni-21Cr-13.5Mo	Forg. & ftg.	B462		N06022	Sol. ann.	All	43
152	55Ni-21Cr-13.5Mo	Forg. & ftg.	B564		N06022	Sol. ann.	All	43
153	58Ni-33Cr-8Mo	Forg. & ftg.	B366		N06035	Sol. ann.	All	43
154	58Ni-33Cr-8Mo	Forg. & ftg.	B462		N06035	Sol. ann.	All	43
155	58Ni-33Cr-8Mo	Forg. & ftg.	B564		N06035	Sol. ann.	All	43
156	59Ni-23Cr-16Mo	Forg. & ftg.	B366		N06059	Sol. ann.	All	43
157	59Ni-23Cr-16Mo	Forg. & ftg.	B564		N06059	H.W. sol. ann.	All	43
158	59Ni-23Cr-16Mo-1.6Cu	Forg. & ftg.	B366		N06200	Sol. ann.	All	43
159	59Ni-23Cr-16Mo-1.6Cu	Forg. & ftg.	B462		N06200	Sol. ann.	All	43
160	59Ni-23Cr-16Mo-1.6Cu	Forg. & ftg.	B564		N06200	Sol. ann.	All	43
161	62Ni-22Mo-15Cr	Fittings	B366		N10362	Sol. ann.	All	43
162	62Ni-22Mo-15Cr	Forgings	B462	• • •	N10362	Sol. ann.	All	43
163	62Ni-22Mo-15Cr	Forgings	B564	• • •	N10362	Sol. ann.	All	43
164	60Ni-22Cr-9Mo-3.5Cb	Forg. & ftg.	B564	•••	N06625	Annealed	≤100	43
165	65Ni-28Mo-2Fe	Forg. & ftg.	B366		N10665	Sol. ann.	All	44
166	65Ni-29.5Mo-2Fe-2Cr	Forg. & ftg.	B366		N10675	Sol. ann.	All	44
167	65Ni-29.5Mo-2Fe-2Cr	Forg. & ftg.	B462		N10675	Sol. ann.	All	44
168	65Ni-29.5Mo-2Fe-2Cr	Forg. & ftg.	B564		N10675	Sol. ann.	All	44
169	57Ni-22Cr-14W-2Mo-La	Forg. & ftg.	B564	• • •	N06230	Sol. ann.	All	43
170	57Ni-22Cr-14W-2Mo-La	Forg. & ftg.	B366	• • •	N06230	Sol. ann.	All	43

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16) Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Line No.

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

(16)

ine No.	600	625	650	675	700	725	750	775	800	825	850	875	900
141													
142	• • •						• • • •			• • •	• • • •		
143	115	94.2	77.3	64.9	54.7	44.7	36.1	29.2	23.6	19.1			
144													
145	• • •						• • • •			• • •	• • • •		
146	99.1	81.6	67.0	54.6	42.2								
147	99.1	81.6	67.0	54.6	42.2								
148	99.1	81.6	67.0	54.6	42.2		• • •			• • •	• • •		• •
149			•••	•••									• •
150													
151													
152		• • •											
153		• • •											
154													
155	• • •	• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	
156	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	
157	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	
158	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	
159	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
160	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
161	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
162	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
163		•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• •
164	156	136	91.0	•••	•••	•••	•••	•••	• • •	•••	•••	•••	• •
165					• • •		• • •			• • •	• • •		
166	•••	• • •	• • •	• • •	• • •	•••	• • •	• • •	• • •	• • •	• • •	• • •	• •
167	•••	• • •	• • •	• • •	• • •	•••	• • •	•••	• • •	• • •	• • •	• • •	• •
168													
169 170	153 153	128 128	107 107	89.7 89.7	74.7 74.7	61.9 61.9	50.8 50.8	41.1 41.1	32.6 32.6	25.2 25.2	18.9 18.9	13.8 13.8	10. 10.

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/Condition/Temper	Size, mm	P-No. (5)
171	33Cr-31Ni-32Fe-1.5Mo-0.6Cu-N	Fittings	B366		R20033	Sol. ann.	•••	45
172	33Cr-31Ni-32Fe-1.5Mo-0.6Cu-N	Fittings	B462		R20033	Sol. ann.		45
173	33Cr-31Ni-32Fe-1.5Mo-0.6Cu-N	Forgings	B564		R20033	Sol. ann.		45
174	99.0Ni	Rod & bar	B160		N02200	H.W.	All	41
175	99.0Ni	Rod & bar	B160		N02200	Annealed	All	41
176	67Ni-30Cu	Rod & bar	B164		N04400	Ann. forg.	All	42
						.		
177	33Ni-42Fe-21Cr	Rod & bar	B408		N08810	Sol. trt. or ann.	•••	45
178	33Ni–42Fe–21Cr–Al–Ti	Rod & bar	B408		N08811	Annealed		45
179	33Ni-42Fe-21Cr	Rod & bar	B408		N08800	Annealed		45
180	26Ni-22Cr-5Mo-Ti	Rod & bar	B621		N08320	Sol. ann.	All	45
181	47Ni-22Cr-19Fe-6Mo	Rod & bar	B581		N06007	Sol. ann.	>19	45
182	42Ni-21.5Cr-3Mo-2.3Cu	Rod & bar	B425		N08825	Annealed		45
183	47Ni-22Cr-19Fe-6Mo	Rod & bar	B581		N06007	Sol. ann.	≤19	45
184	40Ni-29Cr-15Fe-5Mo	Rod & bar	B581	• • •	N06030	Sol. ann.	All	45
185	31Ni-33Fe-27Cr-6.5Mo-Cu-N	Rod & bar	B649	• • •	N08031	Annealed	All	45
186	67Ni-30Cu	Rod & bar	B164	• • •	N04400		All except hex >54	42
187	58Ni-33Cr-8Mo	Rod & bar	B574	•••	N06035	Sol. ann.	All	43
188	61Ni-16Mo-16Cr	Rod & bar	B574	•••	N06455	Sol. ann.	All	43
	54Ni-16Mo-15Cr	Rod & bar	B574	• • •		Sol. ann.	All	43
	62Ni-22Mo-15Cr	Rod & bar	B574	• • •		Sol. ann.	All	43
	60Ni-22Cr-9Mo-3.5Cb	Rod & bar	B446	1		Annealed	>100 , ≤250	43
	60Ni-22Cr-9Mo-3.5Cb	Rod & bar	B446	1		Annealed	≤100	43
193	57Ni-22Cr-14W-2Mo-La	Rod & bar	B572	•••	N06230	Sol. ann.	All	43
194	59Ni-23Cr-16Mo	Rod & bar	B574		N06059	Sol. ann.	All	43
195	59Ni-23Cr-16Mo-1.6Cu	Rod & bar	B574		N06200	Sol. ann.	All	43
196	65Ni-29.5Mo-2Fe-2Cr	Rod & bar	B335		N10675	Sol. ann.	All	44
197	33Cr-31Ni-32Fe-1.5Mo-0.6Cu-N	Rod	B649	•••	R20033	Sol. ann.	•••	45

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16)

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Line No. 68.9 68.9 68.9 68.9 68.9 68.9 90.4 90.4 90.4 90.4 89.8 89.0 88.0 79.7 59.9 55.2 98.6 97.1 95.9 91.8 98.7 97.1 96.1 94.1 63.8 33.5 17.0 13.0

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

(16)

ine													
No.	600	625	650	675	700	725	750	775	800	825	850	875	900
171	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
172	• • •	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
173	• • •	•••	•••	•••	•••	• • •	• • •	•••	•••	•••	•••	• • •	• • • •
174													
175	• • • •						• • • •		• • • •			• • • •	• • • •
176													
177	75.7	62.6	50.6	41.2	33.6	27.7	22.6	18.3	15.0	11.9	9.03	7.35	5.86
178	85.5	69.3	56.8	46.8	38.6	31.5	25.5	20.6	17.1	13.8	10.2	7.98	6.20
179	85.0	64.4	44.8	30.0	15.5	11.3	8.82	6.98	6.43	5.00			
180													
181													
182													
183													
184	• • •	• • •		•••	• • •		• • •	• • •	• • •	• • •		• • •	
185													
186													
187													
188													
189	99.1	81.6	67.0	54.6	42.2								
190													
191	156	136	91.0										
192	156	136	91.0										
193	153	128	107	89.7	74.7	61.9	50.8	41.1	32.6	25.2	18.9	13.8	10.2
194													
195													
196	• • •												
197													

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

(16)

Line			Spec.	Type/			Size,	P-No.
No.	Nominal Composition	Product Form	No.	Grade	UNS No.	Class/Condition/Temper	mm	(5)
198	53Ni-17Mo-16Cr-6Fe-5W	Castings	A494	CW12MW	N30002			
199	56Ni-19Mo-18Cr-2Fe	Castings	A494	CW6M	N30107	•••		
200	59Ni-22Cr-14Mo-4Fe-3W	Castings	A494	CX2MW	N26022	Sol. ann.		43

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

							Basic A	llowable		, MPa, at (1) and (emperatu	re, °C	
Line No.	Notes	Min. Temp., °C (6)	Min. Tensile Str., MPa	Min. Yield Str., MPa	Max. Use Temp., °C	Min. Temp. to	65	100	125	150	175	200	225	250
198	(2)(9)(44)	-198	496	276	538	165	165	165	165	165	165	165	165	165
199	(2)(9)	-198	496	276	538	165	165	165	165	165	165	165	165	165
200	(2)(9)	-198	552	310	260	184	184	184	184	184	184	184	184	184

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

Line													
No.	275	300	325	350	375	400	425	450	475	500	525	550	575
198	165	165	165	165	165	165	165	165	165	165	165	157	
199	165	165	165	165	165	165	165	165	165	165	165	157	
200	184												

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]

Line No.	600	625	650	675	700	725	750	775	800	825	850	875	900
198													
199													
200													

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Strength, MPa	Min. Yield Strength, MPa
1	Ti	Pipe & tube	B861	1	R50250	51	(2)	-59	241	138
2	Ti	Pipe & tube	B862	1	R50250	51	(2)	-59	241	138
3	Ti	Pipe & tube	B861	2	R50400	51	(2)	-59	345	276
4	Ti	Pipe & tube	B862	2	R50400	51	(2)	-59	345	276
5	Ti–Pd	Pipe & tube	B861	7	R52400	51	(2)	-59	345	276
6	Ti–Pd	Pipe & tube	B862	7	R52400	51	(2)	-59	345	276
7	Ti	Pipe & tube	B861	3	R50550	52	(2)	-59	448	379
8	Ti	Pipe & tube	B862	3	R50550	52	(2)	-59	448	379
9	Ti	Plate & sheet	B265	1	R50250	51		-59	241	172
10		Plate & sheet	B265	2	R50400	51		-59	345	276
11	ті	Plate & sheet	B265	3	R50550	52		-59	448	379
12	Ti	Forgings	B381	F1	R50250	51		-59	241	172
13	Ti	Forgings	B381	F2	R50400	51		-59	345	276
14	lτi	Forgings	B381	F3	R50550	52		-59	448	379

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

				Basic A	llowable S	tress, <i>S</i> , I	MPa, at Me	tal Tempe	rature, °C	[Notes (1)	and (4b)]		
Line No.	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225	250	275	300	325
1	316	80.4	74.0	62.4	55.5	49.2	43.6	38.5	34.0	30.2	27.2	25.2	24.1
2	316	80.4	74.0	62.4	55.5	49.2	43.6	38.5	34.0	30.2	27.2	25.2	24.1
3	316	115	111	97.8	89.8	82.9	77.0	71.9	67.2	62.9	<i>58.7</i>	<i>54.7</i>	51.3
4	316	115	111	97.8	89.8	82.9	77.0	71.9	67.2	62.9	58.7	<i>54.7</i>	51.3
5	316	115	111	97.8	89.8	82.9	77.0	71.9	67.2	62.9	<i>58.7</i>	<i>54.7</i>	51.3
6	316	115	111	97.8	89.8	82.9	77.0	71.9	67.2	62.9	<i>58.7</i>	<i>54.7</i>	51.3
7	316	149	141	124	112	102	92.8	84.5	77.1	70.8	65.5	61.3	58.2
8	316	149	141	124	112	102	92.8	84.5	77.1	70.8	65.5	61.3	58.2
9	316	80.4	75.0	64.6	<i>58.3</i>	<i>52.9</i>	48.5	44.8	41.7	37.7	34.0	31.5	26.6
10	316	115	111	97.8	89.8	82.9	77.0	71.9	67.2	62.9	58.7	<i>54.7</i>	51.3
11	316	149	141	124	112	102	92.8	84.5	77.1	70.8	65.5	61.3	58.2
12	316	80.4	75.0	64.6	58.3	52.9	48.5	44.8	41.7	37.7	34.0	31.5	26.6
13	316	115	111	97.8	89.8	82.9	77.0	71.9	67.2	62.9	58.7	54.7	51.3
14	316	149	141	124	112	102	92.8	84.5	77.1	70.8	65.5	61.3	58.2

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	UNS No.	P-No. (5)	Notes	Min. Temp., °C (6)	Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C
1	99.2Zr	Pipe & tube	B523	R60702	61	(2)	-59	379	207	371
2	99.2Zr	Pipe & tube	B658	R60702	61	(2)	-59	379	207	371
3	95.5Zr + 2.5Cb	Pipe & tube	B523	R60705	62	(2)(73)	-59	552	379	371
4	95.5Zr + 2.5Cb	Pipe & tube	B658	R60705	62	(2)(73)	-59	552	379	371
5	99.2Zr	Plate & sheet	B551	R60702	61		-59	379	207	371
6	95.5Zr + 2.5Cb	Plate & sheet	B551	R60705	62	(73)	-59	552	379	371
7	99.2Zr	Forgings & bar	B493	R60702	61		-59	379	207	371
8	99.2Zr	Forgings & bar	B550	R60702	61		-59	379	207	371
9	95.5Zr + 2.5Cb	Forgings & bar	B493	R60705	62	(73)	-59	483	379	371
10	95.5Zr + 2.5Cb	Forgings & bar	B550	R60705	62	(73)	-59	552	379	371

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Min. Line Temp. No. to 40 65 100 125 150 175 200 225 250 275 300 325 350 375 1 126 119 103 92.4 82.5 73.6 65.7 58.8 52.8 47.8 43.7 40.4 37.8 36.1 2 40.4 126 119 103 92.4 82.5 73.6 65.7 58.8 52.8 47.8 43.7 37.8 36.1 3 184 169 149 139 130 123 116 111 106 101 97.6 94.6 92.4 91.0 184 169 149 139 130 *123* 106 101 97.6 94.6 92.4 91.0 116 111 5 126 119 103 92.4 82.5 73.6 65.7 58.8 52.8 47.8 43.7 40.4 37.8 36.1 6 184 169 149 139 130 92.4 91.0 *123* 116 111 106 101 97.6 94.6 7 126 119 103 92.4 82.5 73.6 65.7 58.8 52.8 47.8 43.7 40.4 37.8 36.1 8 103 126 119 92.4 82.5 73.6 65.7 58.8 52.8 47.8 43.7 40.4 37.8 36.1 9 184 169 149 139 130 123 116 111 106 101 97.6 94.6 92.4 91.0 10 184 169 149 139 130 123 116 111 106 101 97.6 94.6 92.4 91.0

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

						Class/		
Line	Nominal	B 1 1 -	Spec.	Type/		Condition/	Size,	P-No.
No.	Composition	Product Form	No.	Grade	UNS No.	Temper	mm	(5)
	99.60Al	Smls. pipe & tube	B210	1060	A91060	0	•••	21
	99.60Al	Smls. pipe & tube	B210	1060	A91060	H112	•••	21
	99.60Al	Smls. pipe & tube	B210	1060	A91060	H113	•••	21
4	99.60Al	Smls. pipe & tube	B241	1060	A91060	0	•••	21
5	99.60Al	Smls. pipe & tube	B241	1060	A91060	H112	• • •	21
6	99.60Al	Smls. pipe & tube	B241	1060	A91060	H113	• • •	21
7	99.60Al	Smls. pipe & tube	B345	1060	A91060	0		21
8	99.60Al	Smls. pipe & tube	B345	1060	A91060	H112	• • •	21
9	99.60Al	Smls. pipe & tube	B345	1060	A91060	H113		21
10	99.60Al	Smls. pipe & tube	B210	1060	A91060	H14		21
11	99.0Al-Cu	Smls. pipe & tube	B241	1100	A91100	0		21
12	99.0Al–Cu	Smls. pipe & tube	B241	1100	A91100	H112		21
13	99.0Al–Cu	Smls. pipe & tube	B210	1100	A91100	H113		21
14	99.0Al–Cu	Smls. pipe & tube	B210	1100	A91100	H14		21
15	Al-Mn-Cu	Smls. pipe & tube	B210	3003	A93003	0		21
16	Al-Mn-Cu	Smls. pipe & tube	B210	3003	A93003	H112		21
17	Al-Mn-Cu	Smls. pipe & tube	B241	3003	A93003	0		21
18	Al-Mn-Cu	Smls. pipe & tube	B241	3003	A93003	H112		21
19	Al-Mn-Cu	Smls. pipe & tube	B345	3003	A93003	0		21
20	Al-Mn-Cu	Smls. pipe & tube	B345	3003	A93003	H112		21
21	Al-Mn-Cu	Smls. pipe & tube	B491	3003	A93003	0		21
22	Al-Mn-Cu	Smls. pipe & tube	B491	3003	A93003	H112		21
23	Al-Mn-Cu	Smls. pipe & tube	B210	3003	A93003	H14		21
24	Al-Mn-Cu	Smls. pipe & tube	B210	3003	A93003	H18		21
25	Al-Mn-Cu	Smls. pipe & tube	B241	3003	A93003	H18		21
26	Al-Mn-Cu	Smls. pipe & tube	B345	3003	A93003	H18		21
	I							

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

					Basic Allowable Stress, S, MPa, at Metal Temperature [Notes (1) and (4b)] Max.						ıre, °C		
ine No.	Notes	Min. Temp., °C (6)	Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225
1 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
2 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
3 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
4 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
5 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
6 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
7 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
8 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
9 (14)(33)		-269	59	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
10 (14)(33)		-269	83	69	204	27.6	27.6	27.6	26.6	18.1	12.7	8.4	7.8
11 (14)(33)		-269	76	21	204	13.8	13.8	13.7	13.2	11.8	9.3	7.2	6.9
12 (14)(33)		-269	76	21	204	13.8	13.8	13.7	13.2	11.8	9.3	7.2	6.9
13 (14)(33)		-269	76	24	204	16.1	16.1	16.0	15.6	11.8	9.3	7.2	6.9
14 (14)(33)		-269	110	97	204	36.8	36.8	36.1	33.1	19.0	13.6	8.5	7.8
15 (14)(33)		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
16 (14)(33)		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
17 (14)(33)		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
18 (14)(33)		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
19 (14)(33)		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
20 (14)(33)		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
21 (14)(33)		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
22 (14)(33)		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
23 (14)(33)		-269	138	117	204	46.0	46.0	46.0	43.9	29.0	21.1	16.7	16.
24 (14)(33)		-269	186	165	204	62.1	62.1	60.3	52.1	36.1	24.5	18.0	17.0
25 (14)(33)		-269	186	165	204	62.1	62.1	60.3	52.1	36.1	24.5	18.0	17.0
26 (14)(33)		-269	186	165	204	62.1	62.1	60.3	52.1	36.1	24.5	18.0	17.0

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)
27	Al-Mn-Cu	Smls. pipe & tube	B210	Alclad 3003	A83003	0		21
28	Al-Mn-Cu	Smls. pipe & tube	B210	Alclad 3003	A83003	H112		21
29	Al-Mn-Cu	Smls. pipe & tube	B241	Alclad 3003	A83003	0		21
30	Al-Mn-Cu	Smls. pipe & tube	B241	Alclad 3003	A83003	H112		21
31	Al-Mn-Cu	Smls. pipe & tube	B345	Alclad 3003	A83003	0		21
32	Al-Mn-Cu	Smls. pipe & tube	B345	Alclad 3003	A83003	H112		21
33	Al-Mn-Cu	Smls. pipe & tube	B210	Alclad 3003	A83003	H14		21
34	Al-Mn-Cu	Smls. pipe & tube	B210	Alclad 3003	A83003	H18		21
35	Al-2.5Mg	Smls. pipe & tube	B210	5052	A95052	0		22
36	Al-2.5Mg	Smls. pipe & tube	B241	5052	A95052	0		22
37	Al-2.5Mg	Smls. pipe & tube	B210	5052	A95052	H32		22
38	Al-2.5Mg	Smls. pipe & tube	B210	5052	A95052	H34		22
39	Al-4.4Mg-Mn	Smls. pipe & tube	B241	5083	A95083	0		25
40	Al-4.4Mg-Mn	Smls. pipe & tube	B241	5083	A95083	H112		25
41	Al-4.4Mg-Mn	Smls. pipe & tube	B210	5083	A95083	0		25
42	Al-4.4Mg-Mn	Smls. pipe & tube	B210	5083	A95083	H112		25
43	Al-4.4Mg-Mn	Smls. pipe & tube	B345	5083	A95083	0		25
44	Al-4.4Mg-Mn	Smls. pipe & tube	B345	5083	A95083	H112	•••	25
45	Al-4.0Mg-Mn	Smls. pipe & tube	B241	5086	A95086	0		25
46	Al-4.0Mg-Mn	Smls. pipe & tube	B241	5086	A95086	H112		25
47	Al-4.0Mg-Mn	Smls. pipe & tube	B210	5086	A95086	0		25
48	Al-4.0Mg-Mn	Smls. pipe & tube	B210	5086	A95086	H112		25
49	Al-4.0Mg-Mn	Smls. pipe & tube	B345	5086	A95086	0		25
50	Al-4.0Mg-Mn	Smls. pipe & tube	B345	5086	A95086	H112		25
51	Al-4.0Mg-Mn	Smls. pipe & tube	B210	5086	A95086	H32		25
52	Al-4.0Mg-Mn	Smls. pipe & tube	B210	5086	A95086	H34		25
53	Al-3.5Mg	Smls. pipe & tube	B210	5154	A95154	0		22
54	Al-3.5Mg	Smls. pipe & tube	B210	5154	A95154	H34		22
55	Al-2.7Mg-Mn	Smls. pipe & tube	B241	5454	A95454	0		22
56	Al-2.7Mg-Mn	Smls. pipe & tube	B241	5454	A95454	H112		22

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Basic Allowable Stress, S. MPa, at Metal Temperature, °C

			A4:			Basic A				and (4		•	
ne o.	Notes	Min. Temp., °C (6)	Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225
27 (14)(33)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.
28 (14)(33)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.
29 (14)(33)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.
30 (14)(33)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.
31 (14)(33)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.
32 (14)(33)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.
33 (14)(33)	-269	131	110	204	43.7	43.7	43.7	41.7	29.0	21.1	16.7	16.
34 (14)(33)	-269	179	159	204	59.8	59.8	59.8	57.0	29.0	21.1	16.7	16.
35 (14)		-269	172	69	204	46.0	46.0	46.0	45.9	41.6	28.8	17.6	16.
36 (14)		-269	172	69	204	46.0	46.0	46.0	45.9	41.6	28.8	17.6	16.
37 (14)(33)	-269	214	159	204	71.2	71.2	71.2	71.0	41.6	28.8	17.6	16.
38 (14)(33)	-269	234	179	204	78.1	78.1	78.1	78.1	41.6	28.8	17.6	16.
39 (33)		-269	269	110	65	73.5	73.5						
40 (33)		-269	269	110	65	73.5	73.5						
41 (33)		-269	269	110	65	73.5	73.5						
42 (33)		-269	269	110	65	73.5	73.5						
43 (33)		-269	269	110	65	73.5	73.5						
44 (33)		-269	269	110	65	73.5	73.5	• • • •	• • •	•••	• • •	• • • •	
45 (33)		-269	241	97	65	64.4	64.4						
46 (33)		-269	241	97	65	64.4	64.4				• • •	• • •	
47 (33)		-269	241	97	65	64.4	64.4						
48 (33)		-269	241	97	65	64.4	64.4						
49 (33)		-269	241	97	65	64.4	64.4						
50 (33)		-269	241	97	65	64.4	64.4						
51 (33)		-269	276	193	65	91.9	91.9						
52 (33)		-269	303	234	65	101.1	101.1	•••	•••	•••	•••		• •
53		-269	207	76	65	50.6	50.6						
54 (33)		-269	269	200	65	89.6	89.6	• • •	•••	•••	• • •	• • •	
55 (33)		-269	214	83	204	55.2	55.2	55.2	48.9	37.5	28.6	21.7	20.
56 (33)		-269	214	83	204	55.2	55.2	55.2	48.9	37.5	28.6	21.7	20.

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

ine Io.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No (5)
57	Al-5.1Mg-Mn	Smls. pipe & tube	B210	5456	A95456	0	• • •	25
58	Al-5.1Mg-Mn	Smls. pipe & tube	B210	5456	A95456	H112		25
59	Al-5.1Mg-Mn	Smls. pipe & tube	B241	5456	A95456	0		25
60	Al-5.1Mg-Mn	Smls. pipe & tube	B241	5456	A95456	H112		25
61	Al-Mg-Si-Cu	Smls. pipe & tube	B210	6061	A96061	T4		23
62	Al-Mg-Si-Cu	Smls. pipe & tube	B241	6061	A96061	T4		23
63	Al-Mg-Si-Cu	Smls. pipe & tube	B345	6061	A96061	T4		23
64	Al-Mg-Si-Cu	Smls. pipe & tube	B210	6061	A96061	T6		23
65	Al-Mg-Si-Cu	Smls. pipe & tube	B241	6061	A96061	T6		23
66	Al-Mg-Si-Cu	Smls. pipe & tube	B345	6061	A96061	Т6		23
67	Al-Mg-Si-Cu	Smls. pipe & tube	B210	6061	A96061	T4 wld.		23
68	Al-Mg-Si-Cu	Smls. pipe & tube	B210	6061	A96061	T6 wld.		23
69	Al-Mg-Si-Cu	Smls. pipe & tube	B241	6061	A96061	T4 wld.		23
70	Al-Mg-Si-Cu	Smls. pipe & tube	B241	6061	A96061	T6 wld.		23
71	Al-Mg-Si-Cu	Smls. pipe & tube	B345	6061	A96061	T4 wld.		23
72	Al-Mg-Si-Cu	Smls. pipe & tube	B345	6061	A96061	T6 wld.		23
73	Al-Mg-Si	Smls. pipe & tube	B210	6063	A96063	T4		23
74	Al-Mg-Si	Smls. pipe & tube	B241	6063	A96063	T4	≤13	23
75	Al-Mg-Si	Smls. pipe & tube	B345	6063	A96063	T4	≤13	23
76	Al-Mg-Si	Smls. pipe & tube	B241	6063	A96063	T5	≤13	23
77	Al-Mg-Si	Smls. pipe & tube	B345	6063	A96063	T5	≤13	23
78	Al-Mg-Si	Smls. pipe & tube	B210	6063	A96063	T6		23
79	Al-Mg-Si	Smls. pipe & tube	B241	6063	A96063	T6		23
80	Al-Mg-Si	Smls. pipe & tube	B345	6063	A96063	T6		23

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

						Basic A	llowab			Pa, at M and (4l		nperatı	ıre, °C
.ine No.	Notes	Min. Temp., °C (6)	Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225
57	(33)	-269	283	131	65	87.3	87.3						
58	(33)	-269	283	131	65	87.3	87.3						
59	(33)	-269	283	131	65	87.3	87.3						
60	(33)	-269	283	131	65	87.3	87.3						
61	(33)	-269	207	110	204	68.9	68.9	68.9	67.8	64.8	57.9	40.2	35.9
62	(33)(63)	-269	179	110	204	59.8	59.8	59.8	58.9	56.3	50.2	38.3	35.9
63	(33)(63)	-269	179	110	204	59.8	59.8	59.8	58.9	56.3	50.2	38.3	35.9
64	(33)	-269	290	241	204	96.5	96.5	96.5	92.5	79.9	63.1	40.2	35.9
65	(33)(63)	-269	262	241	204	87.3	87.3	87.3	83.6	72.3	57.2	40.2	35.9
66	(33)(63)	-269	262	241	204	87.3	87.3	87.3	83.6	72.3	57.2	40.2	35.9
67	(22)(63)	-269	165		204	55.2	55.2	55.2	<i>54.3</i>	52.0	46.3	35.3	34.8
68	(22)(63)	-269	165		204	<i>55.2</i>	<i>55.2</i>	<i>55.2</i>	<i>54.3</i>	52.0	46.3	35.3	34.8
69	(22)(63)	-269	165		204	<i>55.2</i>	<i>55.2</i>	<i>55.2</i>	<i>54.3</i>	52.0	46.3	35.3	34.8
70	(22)(63)	-269	165	• • •	204	<i>55.2</i>	<i>55.2</i>	<i>55.2</i>	<i>54.3</i>	52.0	46.3	35.3	34.8
71	(22)(63)	-269	165		204	<i>55.2</i>	<i>55.2</i>	<i>55.2</i>	<i>54.3</i>	52.0	46.3	35.3	34.8
72	(22)(63)	-269	165	• • •	204	55.2	55.2	<i>55.2</i>	<i>54.3</i>	52.0	46.3	35.3	34.8
73	(33)	-269	152	69	204	46.0	45.8	45.8	45.5	45.5	41.5	27.7	12.0
74	(33)	-269	131	69	204	43.7	<i>43.7</i>	43.7	43.7	<i>43.7</i>	35.8	23.9	10.3
75	(33)	-269	131	69	204	43.7	<i>43.7</i>	43.7	43.7	43.7	35.8	23.9	10.3
76	(33)	-269	152	110	204	50.6	50.6	48.7	46.6	41.4	27.5	15.3	13.8
77	(33)	-269	152	110	204	50.6	50.6	48.7	46.6	41.4	27.5	15.3	13.8
78	(33)	-269	228	193	204	75.8	75.8	74.8	64.0	49.2	27.5	15.3	13.8
79	(33)	-269	207	172	204	68.9	68.9	67.7	59.0	45.9	27.5	15.3	49.3
80	(33)	-269	207	172	204	68.9	68.9	67.7	59.0	45.9	27.5	15.3	49.3

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Condition/ Temper	Size, mm	P-No. (5)
81	Al-Mg-Si	Smls. pipe & tube	B210	6063	A96063	T4 wld.		23
82	Al-Mg-Si	Smls. pipe & tube	B210	6063	A96063	T5 wld.		23
83	Al-Mg-Si	Smls. pipe & tube	B210	6063	A96063	T6 wld.		23
84	Al-Mg-Si	Smls. pipe & tube	B241	6063	A96063	T4 wld.		23
85	Al-Mg-Si	Smls. pipe & tube	B241	6063	A96063	T5 wld.		23
86	Al-Mg-Si	Smls. pipe & tube	B241	6063	A96063	T6 wld.		23
87	Al-Mg-Si	Smls. pipe & tube	B345	6063	A96063	T4 wld.		23
88	Al-Mg-Si	Smls. pipe & tube	B345	6063	A96063	T5 wld.		23
89	Al-Mg-Si	Smls. pipe & tube	B345	6063	A96063	T6 wld.	•••	23
90	Al-4.4Mg-Mn	Wld. pipe & tube	B547	5083	A95083	0		25
91	99.0Al	Structural tube	B221	1060	A91060	0		21
92	99.0Al	Structural tube	B221	1060	A91060	H112		21
93	99.0Al-Cu	Structural tube	B221	1100	A91100	0		21
94	99.0Al–Cu	Structural tube	B221	1100	A91100	H112	• • •	21
95	Al-Mn-Cu	Structural tube	B221	3003	A93003	0		21
	Al-Mn-Cu	Structural tube	B221	3003	A93003	H112	•••	21
	Al-Mn-Cu	Structural tube	B221	Alclad 3003	A83003	0	•••	21
	Al-Mn-Cu	Structural tube	B221	Alclad 3003	A83003	H112	•••	21
70	At Mill Cu	Structural tube	DZZI	Alcida 9009	7105005	11112	•••	21
99	Al-2.5Mg	Structural tube	B221	5052	A95052	0		22
100	Al-4.4Mg-Mn	Structural tube	B221	5083	A95083	0		25
101	Al-4.0Mg-Mn	Structural tube	B221	5086	A95086	0		25
102	Al-3.5Mg	Structural tube	B221	5154	A95154	0	•••	22
103	Al-2.7Mg-Mn	Structural tube	B221	5454	A95454	0		22
	Al-5.1Mg-Mn	Structural tube	B221	5456	A95456	0		25
104	7.1 Mg MII	Structural tube	DZZI	3430	705450	O	•••	23
105	Al-Mg-Si-Cu	Structural tube	B221	6061	A96061	T4		23
106	Al-Mg-Si-Cu	Structural tube	B221	6061	A96061	T6		23
107	Al-Mg-Si-Cu	Structural tube	B221	6061	A96061	T4 wld.		23
108	Al-Mg-Si-Cu	Structural tube	B221	6061	A96061	T6 wld.	•••	23
	I							

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)] Min. Max. Min. Tensile Min. Yield Use Min. Line Strength, Temp., Temp. Temp., Strength, No. Notes °C (6) MPa MPa °C to 40 65 100 125 150 175 200 225 204 39.1 37.9 35.9 32.1 17.6 13.8 81 -269 117 39.1 25.7 82 -269 117 204 39.1 39.1 37.9 35.9 32.1 25.7 17.6 13.8 . . . 32.1 83 -269117 204 39.1 39.1 37.9 35.9 25.7 17.6 13.8 84 -269 117 204 39.1 39.1 37.9 35.9 32.1 25.7 17.6 13.8 . . . 85 -269 117 204 39.1 39.1 37.9 35.9 32.1 25.7 17.6 13.8 . . . 86 -269117 204 39.1 39.1 37.9 35.9 32.1 25.7 17.6 13.8 . . . 32.1 87 -269117 204 39.1 39.1 37.9 35.9 25.7 17.6 13.8 88 -269 117 204 39.1 39.1 37.9 35.9 32.1 25.7 17.6 13.8 . . . 89 -269204 39.1 39.1 37.9 35.9 32.1 25.7 17.6 117 . . . 13.8 90 -269 276 124 82.7 65 82.7 91 (33)(69) -269 59 17 204 11.5 11.5 10.9 9.8 8.8 7.5 5.8 5.5 (33)(69)-26959 17 204 11.5 11.5 10.9 9.8 8.8 7.5 5.8 5.5 6.9 93 (33)(69)-26976 21 204 13.8 13.8 13.7 13.2 11.8 9.3 7.2 (33)(69)-269 76 21 204 13.8 13.8 13.7 13.2 11.8 9.3 7.2 6.9 95 (33)(69) -269 97 34 204 23.0 22.1 21.4 20.5 18.2 13.6 10.9 10.5 (33)(69) 96 97 34 204 23.0 22.1 21.4 20.5 18.2 13.6 10.9 10.5 -26997 (33)(69)-26990 31 204 20.7 19.9 19.3 18.4 17.3 13.6 10.9 10.5 98 (33)(69) 20.7 19.9 19.3 17.3 10.9 -26990 31 204 18.4 13.6 10.5 172 69 204 46.0 46.0 99 (69)-26946.0 45.9 41.6 28.8 17.6 16.1 100 (69)-269 269 110 65 73.5 73.5 101 (69)97 -269241 65 64.4 64.4 102 (69)-269 207 76 50.6 50.6 65 103 (69)-269214 83 204 55.2 55.2 55.2 48.9 37.5 28.6 21.7 20.7 (69)104 -269283 131 65 87.3 87.3 105 (33)(63)(69) 179 204 -269110 59.8 59.8 59.8 58.9 56.3 50.2 38.3 35.9 (33)(63)(69) -269 262 241 204 87.3 87.3 87.3 83.6 72.3 57.2 40.2 35.9 (22)(63)(69) 107 55.2 -269165 204 55.2 55.2 54.3 52.0 46.3 35.3 34.8

. . .

204

55.2

55.2

55.2

54.3

52.0

46.3

35.3

34.8

-269

165

108 (22)(63)(69)

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)
109	Al-Mg-Si	Structural tube	B221	6063	A96063	T4	≤13	23
110	Al-Mg-Si	Structural tube	B221	6063	A96063	T5	≤13	23
111	Al-Mg-Si	Structural tube	B221	6063	A96063	T6		23
112	Al-Mg-Si	Structural tube	B221	6063	A96063	T4 wld.		23
113	Al-Mg-Si	Structural tube	B221	6063	A96063	T5 wld.		23
114	Al-Mg-Si	Structural tube	B221	6063	A96063	T6 wld.	•••	23
115	99.60Al	Plate & sheet	B209	1060	A91060	0		21
116	99.60Al	Plate & sheet	B209	1060	A91060	H112	≥13 , ≤25	21
117	99.60Al	Plate & sheet	B209	1060	A91060	H12		21
118	99.60Al	Plate & sheet	B209	1060	A91060	H14	•••	21
119	99.0Al–Cu	Plate & sheet	B209	1100	A91100	0		21
120	99.0Al-Cu	Plate & sheet	B209	1100	A91100	H112	≥13 , ≤50	21
121	99.0Al-Cu	Plate & sheet	B209	1100	A91100	H12		21
122	99.0Al–Cu	Plate & sheet	B209	1100	A91100	H14	• • • •	21
123	Al-Mn-Cu	Plate & sheet	B209	3003	A93003	0		21
124	Al-Mn-Cu	Plate & sheet	B209	3003	A93003	H112	≥13 , ≤50	21
125	Al-Mn-Cu	Plate & sheet	B209	3003	A93003	H12		21
126	Al-Mn-Cu	Plate & sheet	B209	3003	A93003	H14		21
127	Al-Mn-Cu	Plate & sheet	B209	Alclad 3003	A83003	0	≥0.15 , <13	21
128	Al-Mn-Cu	Plate & sheet	B209	Alclad 3003	A83003	0	≥13 , ≤75	21
129	Al-Mn-Cu	Plate & sheet	B209	Alclad 3003	A83003	H112	≥13 , ≤50	21
130	Al-Mn-Cu	Plate & sheet	B209	Alclad 3003	A83003	H12	≥0.43 , <13	21
131	Al-Mn-Cu	Plate & sheet	B209	Alclad 3003	A83003	H12	≥13 , ≤50	21
132	Al-Mn-Cu	Plate & sheet	B209	Alclad 3003	A83003	H14	≥0.23 , <13	21
133	Al-Mn-Cu	Plate & sheet	B209	Alclad 3003	A83003	H14	≥13 , ≤25	21
134	Al-Mn-Mg	Plate & sheet	B209	3004	A93004	0		22
135	Al-Mn-Mg	Plate & sheet	B209	3004	A93004	H112		22
136	Al-Mn-Mg	Plate & sheet	B209	3004	A93004	H32		22
137	Al-Mn-Mg	Plate & sheet	B209	3004	A93004	H34	•••	22

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

	Notes		Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C	Basic Allowable Stress, <i>S</i> , MPa, at Metal Temperature, °C [Notes (1) and (4b)]							
Line No.		Min. Temp., °C (6)				Min. Temp. to 40	65	100	125	150	175	200	225
109	(13)(33)(69)	-269	131	69	204	43.7	43.7	43.7	43.7	43.7	35.8	23.9	10.3
110	(13)(33)(69)	-269	152	110	204	50.6	50.6	48.7	46.6	41.4	27.5	15.3	13.8
111	(33)(69)	-269	207	172	204	68.9	68.9	67.7	59.0	45.9	27.5	15.3	49.3
112	(69)	-269	117		204	39.1	39.1	37.9	35.9	32.1	25.7	17.6	13.8
113	(69)	-269	117		204	39.1	39.1	37.9	35.9	32.1	25.7	17.6	13.8
114	(69)	-269	117		204	39.1	39.1	37.9	35.9	32.1	25.7	17.6	13.8
115	•••	-269	55	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
116	(13)(33)	-269	69	34	204	23.0	21.8	19.1	17.0	15.0	11.8	7.5	5.9
117	(33)	-269	76	62	204	25.3	25.3	23.1	21.0	18.1	12.7	8.4	7.8
118	(33)	-269	83	69	204	27.6	27.6	27.6	26.6	18.1	12.7	8.4	7.8
119		-269	76	24	204	16.1	16.1	16.0	15.6	11.8	9.3	7.2	6.9
120	(13)(33)	-269	83	34	204	23.0	23.0	22.7	21.6	16.3	11.8	7.5	6.9
121	(33)	-269	97	76	204	32.2	32.2	31.3	25.2	19.0	13.6	8.5	7.8
122	(33)	-269	110	97	204	36.8	36.8	36.1	33.1	19.0	13.6	8.5	7.8
123		-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.5
124	(13)(33)	-269	103	41	204	27.6	26.6	25.6	24.4	18.2	13.6	10.9	10.5
125	(33)	-269	117	83	204	39.1	39.1	38.1	35.8	29.0	21.1	16.7	16.1
126	(33)	-269	138	117	204	46.0	46.0	46.0	43.9	29.0	21.1	16.7	16.1
127	(66)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.5
128	(68)	-269	97	34	204	23.0	22.2	21.3	20.4	18.2	13.6	10.9	10.5
129	(33)(66)	-269	103	41	204	27.6	26.6	25.6	24.4	18.2	13.6	10.9	10.5
130	(33)(66)	-269	110	76	204	36.8	36.8	35.9	33.7	29.0	21.1	16.7	16.1
131	(33)(68)	-269	117	83	204	39.1	39.1	39.1	39.1	29.0	21.1	16.7	16.1
132	(33)(66)	-269	131	110	204	43.7	43.7	43.7	41.7	29.0	21.1	16.7	16.1
133	(33)(68)	-269	138	117	204	46.0	46.0	46.0	43.9	29.0	21.1	16.7	16.1
134	•••	-269	152	59	204	39.1	39.1	39.1	39.0	38.9	26.9	17.4	16.1
135	(33)	-269	159	62	204	41.4	41.4	41.4	41.4	38.9	26.9	17.4	16.1
136	(33)	-269	193	145	204	64.4	64.4	64.4	60.4	38.9	26.9	17.4	16.1
137	(33)	-269	221	172	204	73.5	73.5	73.5	73.5	38.9	26.9	17.4	16.1

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

138 Al-Mn-Mg	Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size, mm	P-No. (5)
140 Al-Mn-Mg Plate & sheet B209 Alclad 3004 A83004 H112 ≥6, <13	138 A	Al-Mn-Mg	Plate & sheet	B209	Alclad 3004	A83004	0	≥0.15, <13	22
141 Al-Mn-Mg Plate & sheet B209 Alclad 3004 A83004 H112 ≥13, ≤75 142 Al-Mn-Mg Plate & sheet B209 Alclad 3004 A83004 H32 ≥0.43, <13	139 A	Al-Mn-Mg	Plate & sheet	B209	Alclad 3004	A83004	0	≥13 , ≤75	22
142 Al-Mn-Mg Plate & sheet B209 Alclad 3004 A83004 H32 ≥0.43, <13	140 A	Al-Mn-Mg	Plate & sheet	B209	Alclad 3004	A83004	H112	≥6 , < 13	22
143 Al-Mn-Mg Plate & sheet B209 Alclad 3004 A83004 H32 ≥13, ≤50 144 Al-Mn-Mg Plate & sheet B209 Alclad 3004 A83004 H34 ≥0.23, <13	141 A	Al-Mn-Mg	Plate & sheet	B209	Alclad 3004	A83004	H112	≥13, ≤75	22
144 Al-Mn-Mg Plate & sheet B209 Alclad 3004 A83004 H34 ≥0.23, <13	142 A	Al-Mn-Mg	Plate & sheet	B209	Alclad 3004	A83004	H32	≥0.43, <13	22
145 Al-Mn-Mg Plate & sheet B209 Alclad 3004 A83004 H34 ≥13,≤25 146 Al-1.5Mg Plate & sheet B209 5050 A95050 O 147 Al-1.5Mg Plate & sheet B209 5050 A95050 H112 148 Al-1.5Mg Plate & sheet B209 5050 A95050 H32 150 Al-2.5Mg Plate & sheet B209 5050 A95050 H34 150 Al-2.5Mg Plate & sheet B209 5052 A95052 O 151 Al-2.5Mg Plate & sheet B209 5652 A95652 O 152 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13,≤75 153 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13,≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209	143 A	Al-Mn-Mg	Plate & sheet	B209	Alclad 3004	A83004	H32	≥13 , ≤50	22
146 Al-1.5Mg Plate & sheet B209 5050 A95050 O 147 Al-1.5Mg Plate & sheet B209 5050 A95050 H112 148 Al-1.5Mg Plate & sheet B209 5050 A95050 H32 149 Al-1.5Mg Plate & sheet B209 5050 A95050 H32 150 Al-2.5Mg Plate & sheet B209 5050 A95050 H34 151 Al-2.5Mg Plate & sheet B209 5052 A95052 O 152 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13,≤75 153 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13,≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13,≤75 155 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13,≤75 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 157 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 158 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 159 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 150 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 151 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 152 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 153 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3,≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13,≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13,≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13,≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13,≤25	144 A	Al-Mn-Mg	Plate & sheet	B209	Alclad 3004	A83004	H34	≥0.23, <13	22
147 Al-1.5Mg Plate & sheet B209 5050 A95050 H112 148 Al-1.5Mg Plate & sheet B209 5050 A95050 H32 149 Al-1.5Mg Plate & sheet B209 5050 A95050 H34 150 Al-2.5Mg Plate & sheet B209 5052 A95052 O 151 Al-2.5Mg Plate & sheet B209 5652 A95652 O 152 Al-2.5Mg Plate & sheet B209 5652 A95052 H112 ≥13, ≤75 153 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13, ≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209 5652 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 508	145 A	Al-Mn-Mg	Plate & sheet	B209	Alclad 3004	A83004	H34	≥13 , ≤25	22
148 Al-1.5Mg Plate & sheet B209 5050 A95050 H32 149 Al-1.5Mg Plate & sheet B209 5050 A95050 H34 150 Al-2.5Mg Plate & sheet B209 5052 A95052 O 151 Al-2.5Mg Plate & sheet B209 5652 A95652 O 152 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13, ≤75 153 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13, ≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209 5652 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5052 A95652 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5	146 A	Al-1.5Mg	Plate & sheet	B209	5050	A95050	0		21
149 Al-1.5Mg Plate & sheet B209 5050 A95050 H34 150 Al-2.5Mg Plate & sheet B209 5052 A95052 0 151 Al-2.5Mg Plate & sheet B209 5652 A95652 0 152 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13, ≤75 153 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13, ≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209 5652 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5652 A95052 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3, ≤38 159 Al-4.4Mg-Mn Plate & sheet B209	147 A	Al−1.5Mg	Plate & sheet	B209	5050	A95050	H112	•••	21
150 Al-2.5Mg Plate & sheet B209 5052 A95052 O 151 Al-2.5Mg Plate & sheet B209 5652 A95652 O 152 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13,≤75 153 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13,≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13,≤75 155 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209 5652 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5652 A95652 H34 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3,≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5,≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13,≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	148 A	Al−1.5Mg	Plate & sheet	B209	5050	A95050	H32		21
151 Al-2.5Mg Plate & sheet B209 5652 A95652 O 152 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13, ≤75 153 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13, ≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209 5652 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5652 A95652 H34 158 Al-2.5Mg Plate & sheet B209 5083 A95083 O ≥1.3, ≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5, ≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet <td< td=""><td>149 A</td><td>Al-1.5Mg</td><td>Plate & sheet</td><td>B209</td><td>5050</td><td>A95050</td><td>H34</td><td>•••</td><td>21</td></td<>	149 A	Al-1.5Mg	Plate & sheet	B209	5050	A95050	H34	•••	21
152 Al-2.5Mg Plate & sheet B209 5052 A95052 H112 ≥13, ≤75 153 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13, ≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209 5652 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5652 A95652 H34 157 Al-2.5Mg Plate & sheet B209 5652 A95652 H34 157 Al-2.5Mg Plate & sheet B209 5083 A95083 O ≥1.3, ≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5, ≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209<	150 A	Al-2.5Mg	Plate & sheet	B209	5052	A95052	0		22
153 Al-2.5Mg Plate & sheet B209 5652 A95652 H112 ≥13, ≤75 154 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209 5652 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5652 A95652 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3, ≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5, ≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	151 A	Al-2.5Mg	Plate & sheet	B209	5652	A95652	0	•••	22
154 Al-2.5Mg Plate & sheet B209 5052 A95052 H32 155 Al-2.5Mg Plate & sheet B209 5652 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5652 A95652 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5652 A95652 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3, ≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5, ≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	152 A	Al-2.5Mg	Plate & sheet	B209	5052	A95052	H112	≥13 , ≤75	22
155 Al-2.5Mg Plate & sheet B209 5052 A95652 H32 156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5652 A95652 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3,≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5,≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13,≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	153 A	Al-2.5Mg	Plate & sheet	B209	5652	A95652	H112	≥13 , ≤75	22
156 Al-2.5Mg Plate & sheet B209 5052 A95052 H34 157 Al-2.5Mg Plate & sheet B209 5652 A95652 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3, ≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5, ≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	154 A	Al-2.5Mg	Plate & sheet	B209	5052	A95052	H32		22
157 Al-2.5Mg Plate & sheet B209 5652 A95652 H34 158 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3, ≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5, ≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	155 A	Al−2.5Mg	Plate & sheet	B209	5652	A95652	H32		22
158 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 O ≥1.3, ≤38 159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5, ≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	156 A	Al−2.5Mg	Plate & sheet	B209	5052	A95052	H34		22
159 Al-4.4Mg-Mn Plate & sheet B209 5083 A95083 H32 ≥5, ≤38 160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	157 A	Al-2.5Mg	Plate & sheet	B209	5652	A95652	H34		22
160 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 O 161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	158 A	Al-4.4Mg-Mn	Plate & sheet	B209	5083	A95083	0	≥1.3, ≤38	25
161 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H112 ≥13, ≤25 162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	159 A	Al-4.4Mg-Mn	Plate & sheet	B209	5083	A95083	H32	≥5, ≤38	25
162 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H32	160 A	Al-4.0Mg-Mn	Plate & sheet	B209	5086	A95086	0		25
	161 A	Al-4.0Mg-Mn	Plate & sheet	B209	5086	A95086	H112	≥13 , ≤25	25
163 Al-4.0Mg-Mn Plate & sheet B209 5086 A95086 H34	162 A	Al-4.0Mg-Mn	Plate & sheet	B209	5086	A95086	H32		25
1	163 A	Al-4.0Mg-Mn	Plate & sheet	B209	5086	A95086	H34	• • •	25

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

	Notes		Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C	Basic Allowable Stress, S, MPa, at Metal Temperature, °C [Notes (1) and (4b)]							
Line No.		Min. Temp., °C (6)				Min. Temp. to 40	65	100	125	150	175	200	225
138 ((66)	-269	145	55	204	36.8	36.8	36.8	36.8	36.8	26.9	17.4	16.1
139 ((68)	-269	152	59	204	39.1	39.1	39.1	39.1	38.9	26.9	17.4	16.1
140 ((33)(66)	-269	152	59	204	39.1	39.1	39.1	39.1	38.9	26.9	17.4	16.1
141 ((33)(68)	-269	159	62	204	41.4	41.4	41.4	41.4	38.9	26.9	17.4	16.1
142 ((33)(66)	-269	186	138	204	62.1	62.1	62.1	60.4	38.9	26.9	17.4	16.1
143 ((33)(68)	-269	193	145	204	64.4	64.4	64.4	60.4	38.9	26.9	17.4	16.1
144 ((33)(66)	-269	214	165	204	71.2	71.2	71.2	71.2	38.9	26.9	17.4	16.1
145 ((33)(68)	-269	221	172	204	73.5	73.5	73.5	73.5	38.9	26.9	17.4	16.1
146 .	••	-269	124	41	204	27.6	27.6	27.5	27.5	27.5	20.1	10.8	9.7
147 ((33)	-269	138	55	204	36.8	36.7	36.7	36.6	35.8	20.1	10.8	9.7
148 ((33)	-269	152	110	204	50.6	50.6	50.6	50.6	35.8	20.1	10.8	9.7
149 ((33)	-269	172	138	204	57.5	57.5	57.5	57.5	35.8	20.1	10.8	9.7
150.		-269	172	65	204	43.7	43.7	43.7	43.6	41.6	28.8	17.6	16.1
151.		-269	172	65	204	43.7	43.7	43.7	43.6	41.6	28.8	17.6	16.1
152 ((13)(33)	-269	172	65	204	43.7	43.7	43.7	43.6	41.6	28.8	17.6	16.1
153 ((13)(33)	-269	172	65	204	43.7	43.7	43.7	43.6	41.6	28.8	17.6	16.1
154 ((33)	-269	214	159	204	71.2	71.2	71.2	71.0	41.6	28.8	17.6	16.1
155 ((33)	-269	214	159	204	71.2	71.2	71.2	71.0	41.6	28.8	17.6	16.1
156 ((33)	-269	234	179	204	78.1	78.1	78.1	78.1	41.6	28.8	17.6	16.1
157 ((33)	-269	234	179	204	78.1	78.1	78.1	78.1	41.6	28.8	17.6	16.1
158 ((13)	-269	276	124	65	82.7	82.7						
159 ((13)(33)	-269	303	214	65	101.1	101.1						
160 .	••	-269	241	97	65	64.4	64.4						
161 ((13)(33)	-269	241	110	65	73.5	73.5						
162 ((33)	-269	276	193	65	91.9	91.9						
163 ((33)	-269	303	234	65	101.1	101.1						

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

						Class/		
Line	Nominal		Spec.	Type/		Condition/	•	P-No.
No.	Composition	Product Form	No.	Grade	UNS No.	Temper	mm	(5)
	Al-3.5Mg	Plate & sheet	B209	5154	A95154	0	•••	22
	Al-3.5Mg	Plate & sheet	B209	5254	A95254	0	• • •	22
	Al-3.5Mg	Plate & sheet	B209	5154	A95154	H112	≥13, ≤75	22
	Al-3.5Mg	Plate & sheet	B209	5254	A95254	H112	≥13, ≤75	22
168	Al-3.5Mg	Plate & sheet	B209	5154	A95154	H32	• • •	22
169	Al-3.5Mg	Plate & sheet	B209	5254	A95254	H32	•••	22
170	Al-3.5Mg	Plate & sheet	B209	5154	A95154	H34	• • •	22
171	Al-3.5Mg	Plate & sheet	B209	5254	A95254	H34	•••	22
172	Al-2.7Mg-Mn	Plate & sheet	B209	5454	A95454	0		22
173	Al-2.7Mg-Mn	Plate & sheet	B209	5454	A95454	H112	≥13 , ≤75	22
174	Al-2.7Mg-Mn	Plate & sheet	B209	5454	A95454	H32		22
175	Al-2.7Mg-Mn	Plate & sheet	B209	5454	A95454	H34		22
176	Al-5.1Mg-Mn	Plate & sheet	B209	5456	A95456	0	≥1.3 , ≤38	25
177	Al-5.1Mg-Mn	Plate & sheet	B209	5456	A95456	H32	≥5, <13	25
178	Al-Mg-Si-Cu	Plate & sheet	B209	6061	A96061	T4		23
179	Al-Mg-Si-Cu	Plate & sheet	B209	6061	A96061	T6		23
180	Al-Mg-Si-Cu	Plate & sheet	B209	6061	A96061	T651	≥6, ≤100	23
181	Al-Mg-Si-Cu	Plate & sheet	B209	6061	A96061	T4 wld.		23
182	Al-Mg-Si-Cu	Plate & sheet	B209	6061	A96061	T6 wld.	•••	23
183	Al-Mg-Si-Cu	Plate & sheet	B209	Alclad 6061	A86061	T4		23
184	Al-Mg-Si-Cu	Plate & sheet	B209	Alclad 6061	A86061	T451	≥6 , < 13	23
185	Al-Mg-Si-Cu	Plate & sheet	B209	Alclad 6061	A86061	T451	≥13 , ≤75	23
186	Al-Mg-Si-Cu	Plate & sheet	B209	Alclad 6061	A86061	T6		23
187	Al-Mg-Si-Cu	Plate & sheet	B209	Alclad 6061	A86061	T651	≥6 , < 13	23
188	Al-Mg-Si-Cu	Plate & sheet	B209	Alclad 6061	A86061	T651	≥13, ≤100	23
189	Al-Mg-Si-Cu	Plate & sheet	B209	Alclad 6061	A86061	T4 wld.		23
190	Al-Mg-Si-Cu	Plate & sheet	B209	Alclad 6061	A86061	T6 wld.		23

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

						Basic A	Allowabl			Pa, at N and (41		nperatı	ıre, °C
ine No.	Notes	Min. Temp., °C (6)	Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225
164		-269	207	76	65	50.6	50.4						
165		-269	207	76	65	50.6	50.4						
166 (13)(33)	-269	207	76	65	50.6	50.4						
167 (13)(33)	-269	207	76	65	50.6	50.4						
168 (33)		-269	248	179	65	82.7	82.7						
169 (33)		-269	248	179	65	82.7	82.7						
170 (33)		-269	269	200	65	89.6	89.6						
171 (33)		-269	269	200	65	89.6	89.6	• • •			• • •		
172		-269	214	83	204	55.2	55.2	55.2	48.9	37.5	28.6	21.7	20.7
173 (13)(33)	-269	214	83	204	55.2	55.2	55.2	48.9	37.5	28.6	21.7	20.7
174 (33)		-269	248	179	204	82.7	82.7	82.7	49.5	37.5	28.6	21.7	20.
175 (33)		-269	269	200	204	89.6	89.6	89.6	49.5	37.5	28.6	21.7	20.7
176 (13)		-269	290	131	65	87.3	87.3						
177 (13)(33)	-269	317	228	65	105.7	105.7	• • •	•••	•••	•••	•••	
178 (33)(63)	-269	207	110	204	68.9	68.9	68.9	67.8	64.8	57.9	40.2	35.
179 (33)		-269	290	241	204	96.5	96.5	96.5	92.5	79.9	63.1	40.2	35.
180 (13)(33)	-269	290	241	204	96.5	96.5	96.5	92.5	79.9	63.1	40.2	35.
181 (22)(63)	-269	165	• • •	204	55.2	<i>55.2</i>	<i>55.2</i>	54.3	52.0	46.3	35.3	34.8
182 (22)(63)	-269	165	• • •	204	55.2	55.2	<i>55.2</i>	<i>54.3</i>	52.0	46.3	35.3	34.8
183 (33)(66)	-269	186	97	204	62.1	62.1	62.1	61.0	58.3	52.1	39.7	35.5
184 (33)(66)	-269	186	97	204	62.1	62.1	62.1	61.0	<i>58.3</i>	52.1	39.7	35.
185 (33)(68)	-269	207	110	204	68.9	68.9	68.9	67.8	64.8	57.9	40.2	35.
186 (33)(66)	-269	262	221	204	87.3	87.3	87.3	83.8	72.3	57.2	40.2	35.
187 (33)(66)	-269	262	221	204	87.3	87.3	87.3	83.8	72.3	<i>57.2</i>	40.2	35.
188 (33)(68)	-269	290	241	204	96.5	96.5	96.5	92.5	79.9	63.1	40.2	35.
189 (22)(63)	-269	165		204	<i>55.2</i>	<i>55.2</i>	<i>55.2</i>	<i>54.3</i>	52.0	46.3	35.3	34.
190 (22)(63)	-269	165		204	55.2	55.2	<i>55.2</i>	54.3	52.0	46.3	35.3	34.8

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Class/ Line Nominal Spec. Type/ Condition/ Size, P-No. Composition No. **Product Form** No. Grade UNS No. Temper mm (5) 191 Al-Mn-Cu Forgings & fittings B247 3003 A93003 H112 21 . . . 192 Al-Mn-Cu Forgings & fittings 21 B247 3003 A93003 H112 wld. . . . 193 Al-Mn-Cu Forgings & fittings B247 5083 A95083 0 25 . . . Forgings & fittings 194 Al-Mn-Cu B247 5083 A95083 H112 25 . . . 195 Al-Mn-Cu Forgings & fittings B247 5083 A95083 H112 wld. 25 . . . 196 Al-Mg-Si-Cu Forgings & fittings B247 6061 A96061 T6 23 . . . 197 Al-Mg-Si-Cu Forgings & fittings B247 6061 A96061 T6 wld. 23 198 99.60Al Forgings & fittings B361 WP1060 A91060 0 21 199 99.60Al Forgings & fittings B361 WP1060 A91060 H112 21 . . . 200 99.0Al-Cu Forgings & fittings B361 WP1100 A91100 0 21 . . . 201 99.0Al-Cu Forgings & fittings WP1100 A91100 H112 21 B361 202 Al-Mn-Cu Forgings & fittings WP3003 0 21 B361 A93003 . . . B361 203 Al-Mn-Cu Forgings & fittings WP3003 A93003 H112 21 204 Al-Mn-Cu Forgings & fittings B361 WP Alclad 3003 A83003 0 21 . . . 205 Al-Mn-Cu Forgings & fittings WP Alclad 3003 A83003 B361 H112 21 206 Al-4.4Mg-Mn Forgings & fittings B361 WP5083 A95083 0 25 207 Al-4.4Mg-Mn Forgings & fittings B361 WP5083 A95083 H112 25 . . . 208 Al-3.5Mg Forgings & fittings B361 WP5154 A95154 0 22 . . . 209 Al-3.5Mg Forgings & fittings B361 WP5154 A95154 H112 22 210 Al-Mg-Si-Cu Forgings & fittings B361 WP6061 A96061 T4 23 . . .

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

						Basic A	Allowab			Pa, at M and (4l	letal Ter o)]	nperatu	ıre, °C
ne o.	Notes	Min. Temp., °C (6)	Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225
191 (9)	(45)	-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
192 (9)	(45)	-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
193 (9)	(32)(33)	-269	268	110	65	73.5	73.5						
194 (9)	(32)(33)	-269	268	110	65	73.5	73.5						
195 (9)	(32)(33)	-269	268	110	65	73.5	73.5			•••		•••	• • •
196 (9)	(33)	-269	262	241	204	87.3	87.3	87.3	83.6	72.3	57.2	40.2	35.9
197 (9)	(22)	-269	165		204	55.2	55.2	55.2	54.3	52.0	46.3	35.3	34.
198 (13	3)(14)(32)(33)	-269	55	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
199 (13	3)(14)(32)(33)	-269	55	17	204	11.5	11.5	10.9	9.8	8.8	7.5	5.8	5.5
200 (13	3)(14)(32)(33)	-269	76	21	204	13.8	13.8	13.7	13.2	11.8	9.3	7.2	6.9
201 (13	3)(14)(32)(33)	-269	76	21	204	13.8	13.8	13.7	13.2	11.8	9.3	7.2	6.9
202 (13	3)(14)(32)(33)	-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
203 (13	3)(14)(32)(33)	-269	97	34	204	23.0	22.1	21.4	20.5	18.2	13.6	10.9	10.
204 (13	3)(14)(32)(33)(66)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.
205 (13	3)(14)(32)(33)(66)	-269	90	31	204	20.7	19.9	19.3	18.4	17.3	13.6	10.9	10.
206 (13	3)(32)(33)	-269	269	110	65	73.5	73.5						
207 (13	3)(32)(33)	-269	269	110	65	73.5	73.5				• • •	• • •	
208 (32	2)(33)	-269	207	76	65	50.6	50.6						
209 (32	2)(33)	-269	207	76	65	50.6	50.6	• • •	•••	• • •	• • •	• • •	• •
210 (13	3)(32)(33)(63)	-269	179	110	204	59.8	59.8	59.8	58.9	56.3	50.2	38.3	35.

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

						Class/		
Line	Nominal	Product Form	Spec.	Type/ Grade	UNS No.	Condition/	Size,	P-No.
No.	Composition		No.		UNS NO.	Temper	mm	(5)
211	Al-Mg-Si-Cu	Forgings & fittings	B361	WP6061	A96061	T6	• • •	23
212	Al-Mg-Si-Cu	Forgings & fittings	B361	WP6061	A96061	T4 wld.		23
213	Al-Mg-Si-Cu	Forgings & fittings	B361	WP6061	A96061	T6 wld.		23
214	Al-Mg-Si	Forgings & fittings	B361	WP6063	A96063	T4		23
215	Al-Mg-Si	Forgings & fittings	B361	WP6063	A96063	T6		23
213	At Mg 31	roigings & nittings	DJ01	WIOOOJ	A70003	10	•••	23
24.6	AL M. C:	Familiana O filliana	D2/4	WDC0C2	10000	T/l.d		22
216	Al-Mg-Si	Forgings & fittings	B361	WP6063	A96063	T4 wld.	• • •	23
217	Al-Mg-Si	Forgings & fittings	B361	WP6063	A96063	T6 wld.		23
218	Al-Si	Castings	B26	443.0	A04430	F		
219	Al-Si-Mg	Castings	B26	356.0	A03560	T6		
220	Al-Si-Mg	Castings	B26	356.0	A03560	T71		
	1							

Table A-1M Basic Allowable Stresses in Tension for Metals (Metric) (Cont'd)

						Basic A	Allowab			Pa, at M and (4l		nperatu	ıre, °C
Line No.	Notes	Min. Temp., °C (6)	Min. Tensile Strength, MPa	Min. Yield Strength, MPa	Max. Use Temp., °C	Min. Temp. to 40	65	100	125	150	175	200	225
211	(13)(32)(33)(63)	-269	262	241	204	87.3	87.3	87.3	83.6	72.3	57.2	40.2	35.9
	(22)(32)(63)	-269	165		204	55.2	<i>55.2</i>	<i>55.2</i>	54.3	52.0	46.3	<i>35.3</i>	34.8
213	(22)(32)(63)	-269	165	•••	204	55.2	55.2	55.2	<i>54.3</i>	52.0	46.3	35.3	34.8
214	(13)(32)(33)	-269	124	62	204	41.4	41.3	41.3	41.0	41.0	33.9	22.6	9.8
215	(13)(32)(33)	-269	207	172	204	68.9	68.9	67.7	59.0	45.9	27.5	15.3	13.8
216	(32)	-269	117		204	39.1	39.1	37.6	36.0	32.0	24.7	15.3	13.8
217	(32)	-269	117		204	39.1	39.1	37.6	36.0	32.0	24.7	15.3	13.8
218	(2)(9)(43)	-269	117	48	204	32.0	32.0	32.0	32.0	32.0	32.0	32.0	24.1
	(2)(9)(43)	-269	207	138	121	68.9	68.9	68.9	57.9				
	(2)(9)(43)	-269	172	124	204	57.5	57.5	57.5	55.0	49.8	38.6	18.9	16.5

333

Table A-1A Basic Casting Quality Factors, E_c

These quality factors are determined in accordance with para. 302.3.3(b). See also para. 302.3.3(c) and Table 302.3.3C for increased quality factors applicable in special cases. Specifications are ASTM.

Spec. No.	Description	<i>E_c</i> [Note (2)]	Appendix A Notes
Iron			
A47	Malleable iron castings	1.00	(9)
A48	Gray iron castings	1.00	(9)
A126	Gray iron castings	1.00	(9)
A197	Cupola malleable iron castings	1.00	(9)
A278	Gray iron castings	1.00	(9)
A395	Ductile and ferritic ductile iron castings	0.80	(9), (40)
A536	Ductile iron castings	0.80	(9), (40)
A571	Austenitic ductile iron castings	0.80	(9), (40)
Carbon Steel			
A216	Carbon steel castings	0.80	(9), (40)
A352	Ferritic steel castings	0.80	(9), (40)
Low and Intermediate A	Alloy Steel		
A217	Martensitic stainless and alloy castings	0.80	(9), (40)
A352	Ferritic steel castings	0.80	(9), (40)
A426	Centrifugally cast pipe	1.00	(10)
Stainless Steel			
A351	Austenitic steel castings	0.80	(9), (40)
A451	Centrifugally cast pipe	0.90	(10), (40)
A487	Steel castings	0.80	(9), (40)
Copper and Copper Allo	у		
B61	Steam bronze castings	0.80	(9), (40)
B62	Composition bronze castings	0.80	(9), (40)
B148	Al-bronze and Si-Al-bronze castings	0.80	(9), (40)
B584	Copper alloy castings	0.80	(9), (40)
Nickel and Nickel Alloy			
A494	Nickel and nickel alloy castings	0.80	(9), (40)
Aluminum Alloy			
B26, Temper F	Aluminum alloy castings	1.00	(9), (10)
B26, Temper T6, T71	Aluminum alloy castings	0.80	(9), (40)

Table A-1B Basic Quality Factors for Longitudinal Weld Joints in Pipes and Tubes, E_j These quality factors are determined in accordance with para. 302.3.4(a). See also para. 302.3.4(b) and Table 302.3.4 for increased quality factors applicable in special cases. Specifications, except API, are ASTM.

Spec. No.	Class (or Type)	Description	<i>E_j</i> [Note (2)]	Appendix A Notes
Carbon Steel				
API 5L		Seamless pipe	1.00	
711 32	•••	Electric fusion welded pipe, 100% radiographed	1.00	
		Electric resistance welded pipe	0.85	
		Electric fusion welded pipe, double butt seam	0.95	
		Continuous welded (furnace butt welded) pipe	0.60	
A53	Type S	Seamless pipe	1.00	
	Type E	Electric resistance welded pipe	0.85	
	Type F	Furnace butt welded pipe	0.60	
A105		Forgings	1.00	(9)
A106	• • •	Seamless pipe	1.00	
A134		Electric fusion welded pipe, single butt, straight	0.80	
		or spiral (helical) seam		
A135	• • •	Electric resistance welded pipe	0.85	
A139	• • •	Electric fusion welded pipe, straight or spiral (helical) seam	0.80	• • •
A179	• • •	Seamless tube	1.00	
A181	•••	Forgings	1.00	(9)
A333		Seamless pipe	1.00	
,,,,,,	•••	Electric resistance welded pipe	0.85	
A334		Seamless tube	1.00	
A350	• • •	Forgings	1.00	(9)
A369		Seamless pipe	1.00	
A381		Electric fusion welded pipe, 100% radiographed	1.00	• • •
		Electric fusion welded pipe, spot radiographed	0.90	(19)
		Electric fusion welded pipe, as manufactured	0.85	• • •
A524	• • •	Seamless pipe	1.00	• • •
A587	•••	Electric resistance welded pipe	0.85	• • •
A671	12, 22, 32, 42, 52	Electric fusion welded pipe, 100% radiographed	1.00	
	13, 23, 33, 43, 53	Electric fusion welded pipe, double butt seam	0.85	• • •
A672	12, 22, 32, 42, 52	Electric fusion welded pipe, 100% radiographed	1.00	• • •
A C O 1	13, 23, 33, 43, 53	Electric fusion welded pipe, double butt seam	0.85	• • •
A691	12, 22, 32, 42, 52	Electric fusion welded pipe, 100% radiographed Electric fusion welded pipe, double butt seam	1.00 0.85	• • •
	13, 23, 33, 43, 53	Liectife fusion welded pipe, double butt seam	0.65	• • •
Low and Intern	nediate Alloy Steel			
A182		Forgings	1.00	(9)
A333		Seamless pipe	1.00	
		Electric resistance welded pipe	0.85	(78)
A334		Seamless tube	1.00	
A335		Seamless pipe	1.00	
A350	• • •	Forgings	1.00	
A369	• • •	Seamless pipe	1.00	• • •
A671	12, 22, 32, 42, 52	Electric fusion welded pipe, 100% radiographed	1.00	
	13, 23, 33, 43, 53	Electric fusion welded pipe, double butt seam	0.85	(78)
A672	12, 22, 32, 42, 52	Electric fusion welded pipe, 100% radiographed	1.00	(=0)
1.01	13, 23, 33, 43, 53	Electric fusion welded pipe, double butt seam	0.85	(78)
A691	12, 22, 32, 42, 52	Electric fusion welded pipe, 100% radiographed	1.00	(70)
	13, 23, 33, 43, 53	Electric fusion welded pipe, double butt seam	0.85	(78)

Spec. No.	Class (or Type)	Description	<i>E_j</i> [Note (2)]	Appendix A Notes
Stainless Steel	l			
A182		Forgings	1.00	
A249		Electric fusion welded tube, single butt seam	0.80	
A268	• • •	Seamless tube	1.00	
		Electric fusion welded tube, double butt seam	0.85	
		Electric fusion welded tube, single butt seam	0.80	
A269	• • •	Seamless tube	1.00	• • •
		Electric fusion welded tube, double butt seam Electric fusion welded tube, single butt seam	0.85 0.80	• • •
1212				• • •
A312	• • •	Seamless pipe	1.00	• • •
		Electric fusion welded pipe, double butt seam Electric fusion welded pipe, single butt seam	0.85 0.80	• • •
		Electric fusion welded pipe, 100% radiographed	1.00	(46)
A358	1, 3, 4	Electric fusion welded pipe, 100% radiographed	1.00	(40)
A330	5	Electric fusion welded pipe, spot radiographed	0.90	
	2	Electric fusion welded pipe, double butt seam	0.85	
A376		Seamless pipe	1.00	
A409		Electric fusion welded pipe, double butt seam	0.85	
71407	• • •	Electric fusion welded pipe, single butt seam	0.80	
A487		Steel castings	0.80	(9)(40)
A789		Seamless tube	1.00	
		Electric fusion welded tube, 100% radiographed	1.00	
		Electric fusion welded tube, double butt	0.85	• • •
		Electric fusion welded tube, single butt	0.80	
A790		Seamless pipe	1.00	
		Electric fusion welded pipe, 100% radiographed	1.00	
		Electric fusion welded pipe, double butt	0.85	
		Electric fusion welded pipe, single butt	0.80	• • •
A813	DW	Electric fusion welded, double butt	0.85	
	SW	Electric fusion welded, single butt	0.80	
A814	DW	Electric fusion welded, double butt	0.85	
	SW	Electric fusion welded, single butt	0.80	• • •
A928	1, 3, 4	Electric fusion welded pipe, 100% radiographed	1.00	
	5	Electric fusion welded pipe, spot radiographed	0.90	
	2	Electric fusion welded pipe, double butt seam	0.85	
Copper and Co	pper Alloy			
B42		Seamless pipe	1.00	
B43		Seamless pipe	1.00	
B68		Seamless tube	1.00	
B75		Seamless tube	1.00	
B88	• • •	Seamless water tube	1.00	• • •
B280		Seamless tube	1.00	
B466		Seamless pipe and tube	1.00	
B467		Electric resistance welded pipe	0.85	
		Electric fusion welded pipe, double butt seam	0.85	
		Electric fusion welded pipe, single butt seam	0.80	

Table A-1B Basic Quality Factors for Longitudinal Weld Joints in Pipes and Tubes, E_j (Cont'd) These quality factors are determined in accordance with para. 302.3.4(a). See also para. 302.3.4(b) and Table 302.3.4 for increased quality factors applicable in special cases. Specifications, except API, are ASTM.

Spec. No.	Class (or Type)	Description	<i>E_j</i> [Note (2)]	Appendix A Notes
Nickel and Nic	kel Alloy			
B160	•	Forgings	1.00	(9)
B161	• • •	Seamless pipe and tube	1.00	•••
B164		Forgings	1.00	(9)
B165	• • •	Seamless pipe and tube	1.00	
B167	• • •	Seamless pipe and tube	1.00	• • •
B407	• • •	Seamless pipe and tube	1.00	• • •
B444	• • •	Seamless pipe and tube	1.00	• • •
B464		Welded pipe	0.80	• • •
B474	1, 3, 4	Welded pipe, 100% radiographed Electric fusion welded pipe, double butt seam	1.00	• • •
	2	• • •	0.85	• • •
B514	• • •	Welded pipe	0.80	
B517	• • •	Welded pipe	0.80	• • •
B564	• • •	Nickel alloy forgings	1.00	(9)
B619	•••	Electric resistance welded pipe	0.85	
		Electric fusion welded pipe, double butt seam	0.85	
		Electric fusion welded pipe, single butt seam	0.80	
B622	• • •	Seamless pipe and tube	1.00	
P.626		Electric resistance welded tube	0.05	
B626	All		0.85	• • •
		Electric fusion welded tube, double butt seam	0.85	• • •
		Electric fusion welded tube, single butt seam	0.80	• • •
B668	All	Seamless pipe and tube	1.00	• • •
B675	All	Welded pipe	0.80	
B690	• • •	Seamless pipe and tube	1.00	• • •
B705		Welded pipe	0.80	
B725	• • •	Electric fusion welded pipe, double butt seam	0.85	
		Electric fusion welded pipe, single butt seam	0.80	
B729		Seamless pipe and tube	1.00	
D00/		W. I. I	4.00	
B804	1, 3, 5	Welded pipe, 100% radiographed	1.00	• • •
	2, 4	Welded pipe, double fusion welded	0.85	• • •
	6	Welded pipe, single fusion welded	0.80	• • •
itanium and T	Titanium Alloy			
B861		Seamless pipe	1.00	
B862		Welded pipe, double butt seam	0.85	
		Welded pipe, single butt seam	0.80	
irconium and	Zirconium Alloy			
B523	•	Seamless tube	1.00	
D323	• • •			• • •
		Electric fusion welded tube	0.80	• • •
B658	• • •	Seamless pipe	1.00	
		Electric fusion welded pipe	0.80	• • •
luminum Allo	у			
B210	• • •	Seamless tube	1.00	
B241		Seamless pipe and tube	1.00	
B247	• • •	Forgings and fittings	1.00	(9)
		Seamless pipe and tube		
B345	• • •	Seamless pipe and tube	1.00	• • •
B547	• • •	Welded pipe and tube, 100% radiographed	1.00	
		Welded pipe, double butt seam	0.85	
		Welded pipe, single butt seam	0.80	

Table A-2 Design Stress Values for Bolting Materials
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM

									Specifi	ed Min.					
		_			Class/			Min.	•	eu Mill. gth, ksi	Min.				
Nominal	Product	Spec.	Type/	LINC No.	Condition/	Size Range,	Notes	Temp.,			Temp.	200	200	400	F00
Composition	Form	No.	Grade	UNS No.	Temper	Dia., in.	Notes	°F (6)	Tensile	Yield	to 100	200	300	400	500
Carbon Steel															
	Bolts	A675	45	D40450			(8f)(8g)	-20	45	22.5	11.3	11.3	11.3	11.3	11.3
	Bolts	A675	50	D40500			(8f)(8g)	-20	50	25	12.5	12.5	12.5	12.5	12.5
•••	Bolts	A675	55	D40550			(8f)(8g)	-20	55	27.5	13.8	13.8	13.8	13.8	13.8
	Bolts	A307	В				(8f)(8g)	-20	60		15.0	15.0	15.0	15.0	15.0
	Bolts	A675	60	D40600			(8f)(8g)	-20	60	30	15.0	15.0	15.0	15.0	15.0
• • •	Bolts	A675	65	D40650			(8g)	-20	65	32.5	16.3	16.3	16.3	16.3	16.3
	Bolts	A675	70	D40700			(8g)	-20	70	35	17.5	17.5	17.5	17.5	17.5
•••	Bolts	A325					(8g)	-20	105	81	20.3	20.3	20.3	20.3	20.3
	Bolts	A675	80	D40800			(8g)	-20	80	40	20.0	20.0	20.0	20.0	20.0
	Norte	A10/	4	V01502			(12)	20							
• • •	Nuts Nuts	A194 A194	1 2	K01503 K04002	• • •	• • •	(42) (42)	-20 -55	• • •	• • •	• • •	• • • •	• • • •	• • •	• • • •
• • •	Nuts	A194	2 2H	K04002 K04002	• • •	• • •	(42)	-55 -55		• • • •		• • •	• • •	• • •	•••
• • •	Nuts	A194	2HM	K04002 K04002			(42)	-55 -55							
	Nuts,	A563	A	K05802			(42b)	-20							
	hvy.						(1=2)								
	hex														
Alloy Steel															
Cr-1/5Mo	Bolts	A193	B7M	G41400		≤4		-55	100	80	20.0	20.0	20.0	20.0	20.0
Cr-1/5Mo	Bolts	A320	L7M	G41400		≤2 ¹ / ₂		-100	100	80	20.0	20.0	20.0	20.0	20.0
5Cr	Bolts	A193	B5	S50100		≤4	(15)	-20	100	80	20.0	20.0	20.0	20.0	20.0
Cr-Mo-V	Bolts	A193	B16	K14072		$>2^{1}/_{2}$, ≤ 4	(15)	-20	110	95	22.0	22.0	22.0	22.0	22.0
	Bolts	A354	BC				(15)	0	115	99	23.0	23.0	23.0	23.0	23.0
Cr–Mo	Bolts	A193	B7	G41400		$>2^{1}/_{2}$, ≤ 4	(15)	-40	115	95	23.0	23.0	23.0	23.0	23.0
Ni-Cr-Mo	Bolts	A320	L43	G43400		≤4	(15)	-150	125	105	25.0	25.0	25.0	25.0	25.0
Cr-Mo	Bolts	A320	L7	G41400		≤2 ¹ / ₂	(15)	-150	125	105	25.0	25.0	25.0	25.0	25.0
Cr-Mo	Bolts	A320	L7A	G40370		≤2 ¹ / ₂	(15)	-150	125	105	25.0	25.0	25.0	25.0	25.0
Cr-Mo	Bolts	A320	L7B	G41370		≤2 ¹ / ₂	(15)	-150	125	105	25.0	25.0	25.0	25.0	25.0
Cr-Mo	Bolts	A320	L7C	G87400		≤2 ¹ / ₂	(15)	-150	125	105	25.0	25.0	25.0	25.0	25.0
Cr–Mo	Bolts	A193	B7	G41400		≤2 ¹ / ₂		-55	125	105	25.0	25.0	25.0	25.0	25.0
Cr-Mo-V	Bolts	A193	B16	K14072		$\leq 2^{1}/_{2}$	(15)	-20	125	105	25.0	25.0	25.0	25.0	25.0
•••	Bolts	A354	BD			≤2 ¹ / ₂	(15)	-20	150	130	30.0	30.0	30.0	30.0	30.0
5Cr	Nuts	A194	3	S50100			(42)	-20							
C-Mo	Nuts	A194	4	K14510			(42)	-55				• • •	• • •		
C-Mo	Nuts	A194	4L	K14510	• • •		(42)	-150	• • • •	• • • •	• • • •	• • • •			
Cr–Mo	Nuts	A194	7	G41400			(42)	-55	•••	•••	•••	• • • •		• • • •	
Cr–Mo	Nuts	A194	, 7L	G41400			(42)	-150							
Cr–Mo	Nuts	A194	7M	G41400			(42)	-55							
Cr–Mo	Nuts	A194	7ML	G41400			(42)	-100							
Stainless Steel															
16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	2	>1 ¹ / ₄ , ≤1 ¹ / ₂	(15)(60)	-325	90	50	18.8	17.3	15.6	14.3	13.3
16Cr-12Ni-2Mo	Bolts	A320	B8M	S31600	2	$>1\frac{7}{4}, \le 1\frac{7}{2}$ $>1\frac{1}{4}, \le 1\frac{1}{2}$	(15)(60)	-325	90	50	18.8	17.3	15.6	14.3	13.3
18Cr-8Ni	Bolts	A193	B8	S30400	2	$>1\frac{1}{4}, \le 1\frac{1}{2}$	(15)(60)	-325	100	50	18.8	16.7	15.0	13.8	12.9
18Cr-8Ni	Bolts	A320	B8	S30400	2	$>1\frac{1}{4}, \le 1\frac{1}{2}$	(15)(60)	-325	100	50	18.8	16.7	15.0	13.8	12.9
18Cr-10Ni-Cb	Bolts	A193	B8C		2	$>1\frac{1}{4}$, $\leq 1\frac{1}{2}$	(15)(60)	-325	100	50	18.8	17.9	16.5	15.5	15.0
18Cr-10Ni-Cb	Bolts	A320	B8C	S34700	2	$>1\frac{1}{4}, \le 1\frac{1}{2}$	(15)(60)	-325	100	50	18.8	17.9	16.5	15.5	15.0
18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	2	$>1\frac{1}{4}$, $\leq 1\frac{1}{2}$	(15)(60)	-325	100	50	18.8	17.8	16.5	15.3	14.3
18Cr-10Ni-Ti	Bolts	A320	B8T	S32100	2	$>1\frac{1}{4}, \le 1\frac{1}{2}$	(15)(60)	-325	100	50	18.8	17.8	16.5	15.3	14.3
18Cr-9Ni	Bolts	A320	B8F	S30300	1		(8f)(15)(39)	-325	75	30	18.8	16.7	15.0	13.8	

Table A-2 Design Stress Values for Bolting Materials Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM

							1)]	F [Note (rature, °	al Tempe	, at Meta	ress, ksi	sign St	De						
Sp:	Type/ Grade	1,500	1,450	1,400	1,350	1,300	1,250	1,200	1,150	1,100	1,050	1,000	950	900	850	800	750	700	650	500
bon St	Carl																			
A67	45												4.0	5.9	7.9	9.2	10.4	10.7	11.1	11.3
A67	50												4.0	5.9	7.9	9.2	10.7	11.9	12.4	12.5
A67	55												4.0	5.9	8.7	10.8	12.7	13.1	13.6	3.8
A30	В	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	
A67	60												4.0	5.9	8.7	11.4	13.8	14.3	14.8	5.0
A67	65												4.0	6.3	9.0	11.4	13.9	15.5	16.1	6.3
A67	70												4.0	6.7	9.3	12.0	14.8	16.7	17.3	7.5
A32				• • •		• • •												20.3	20.3	0.3
A67	80	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	19.1	19.8	20.0
A19	1																			
A19	2																			
A19	2H																			
A19	2HM																			
A56	Α	• • • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
lloy St	Α																			
A19	B7M										2.4	4.5	8.5	12.5	16.3	18.5	20.0	20.0	20.0	0.0
A32	L7M									• • •	2.4	4.5	8.5	12.5	16.3	18.5	20.0	20.0	20.0	0.0
A19	B5	• • •	• • •		• • •	• • •	0.6	1.0	1.8	2.9	4.2	5.8	8.0	10.9	14.3	20.0	20.0	20.0	20.0	0.0
A19	B16	• • •	• • •	• • •	• • •	• • •	• • •	• • •	1.2	2.8	6.3	11.0	15.3	18.5	21.0	22.0	22.0	22.0	22.0	2.0
A35	BC	• • •			• • •	• • •							• • •	• • •				23.0	23.0	3.0
A19	B7	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	2.4	4.5	8.5	12.5	16.3	20.0	23.0	23.0	23.0	3.0
A32	L43				• • •	• • •			• • •		• • •	• • •	• • •	• • •	• • •	• • •	25.0	25.0	25.0	5.0
A32	L7	• • • •	• • •		• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • • •	• • • •	• • •	• • •	25.0	25.0	25.0 25.0	5.0 5.0
A32	L7A L7B	• • •	• • •		• • •	• • •			• • • •				• • •	• • •	• • •	• • •	• • • •	25.0 25.0	25.0	5.0
A32	L7C																	25.0	25.0	5.0
						•••			• • • •											
A19	B7 B16	• • • •	• • •		• • •	• • •	• • •	• • •	1 2	2.8	2.4 6.3	4.5 11.0	8.5	12.5 20.5	17.0	21.0	25.0 25.0	25.0 25.0	25.0 25.0	5.0 5.0
A19 A35	BD	• • •			• • •	• • •	• • •	• • •	1.2				16.0		23.5	25.0	25.0	30.0	30.0	0.0
7133	DD		• • •	• • • •	•••	•••		• • •		•••	• • •	•••	• • •			• • •	•••	50.0	50.0	0.0
A19	3																			
A19	4																			
A19	4L	• • •			• • •	• • •							• • •	• • •			• • •			
A19	7	• • •			• • •	• • •			• • •	• • •		• • •	• • •	• • •	• • •		• • •	• • •	• • •	
A19	7L	• • •			• • •	• • •			• • •	• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	
A19	7M	• • •			• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • • •	••
A19	7ML	•••	• • •	• • •	•••	•••	•••	•••	• • • •	•••	•••	• • • •	• • •	• • •	• • •	• • •		• • •	• • •	• •
less St																				
A19	B8M Cl. 2	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	12.5	12.5	12.5	12.5		12.5			12.5	2.6
A32	B8M Cl. 2	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	12.5	12.5	12.5	12.5	12.5				12.5	2.6
A19 A32	B8 Cl. 2 B8 Cl. 2	• • • •	• • • •	• • • •	• • •	• • •	• • •	• • •	• • • •	• • •	12.5 12.5	12.5 12.5	12.5 12.5	12.5 12.5	12.5	12.5 12.5	12.5	12.5 12.5	12.5 12.5	2.5
A32	B8C Cl. 2	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	12.5	13.4	13.4	13.4	13.5	13.6	13.7	13.8	14.0	2.5 4.3
A32	B8C Cl. 2										12.5	13.4	13.4	13.4	13.5	13.6	13.7	13.8	14.0	4.3
A19	B8T Cl. 2										12.5	12.5	12.5	12.5	12.5	12.6	12.7	13.0		3.5
	B8T Cl. 2										12.5	12.5	12.5	12.5	12.5	12.6	12.7	13.0	13.2	3.5
A32																11.2				

Table A-2 Design Stress Values for Bolting Materials (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM

Nominal	Product	Spec.	Type/		Class/ Condition/	Size Range,		Min. Temp.,		ed Min. th, ksi	Min. Temp.				
Composition	Form	No.	Grade	UNS No.	Temper	Dia., in.	Notes	°F (6)	Tensile	Yield	to 100	200	300	400	500
Stainless Steel (Cont'd)														
19Cr-9Ni	Bolts	A453	651B			>3	(15)(35)	-20	95	50	23.8	23.4	22.1	21.3	20.8
19Cr-9Ni	Bolts	A453	651B			≤3	(15)(35)	-20	95	60	23.8	23.4	22.1	21.3	20.8
19Cr-9Ni	Bolts	A453	651A			>3	(15)(35)	-20	100	60	23.8	23.4	22.1	21.3	20.8
19Cr-9Ni	Bolts	A453	651A		• • •	≤3	(15)(35)	-20	100	70	23.8	23.4	22.1	21.3	20.8
16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	2	>1, ≤1 ¹ / ₄	(15)(60)	-325	105	65	18.8	17.3	16.3	16.3	16.3
16Cr-12Ni-2Mo	Bolts	A320	B8M	S31600	2	>1, ≤1 ¹ / ₄	(15)(60)	-325	105	65	18.8	17.3	16.3	16.3	16.3
18Cr-10Ni-Cb	Bolts	A193	B8C		2	>1, ≤1 ¹ / ₄	(15)(60)	-325	105	65	18.8	17.9	16.5	16.3	16.3
18Cr-10Ni-Cb	Bolts	A320	B8C	S34700	2	>1, ≤1 ¹ / ₄	(15)(60)	-325	105	65	18.8	17.9	16.5	16.3	16.3
18Cr-8Ni	Bolts	A193	B8	S30400	2	$>1, \le 1^{1}/_{4}$	(15)(60)	-325	105	65	18.8	16.7	16.3	16.3	16.3
18Cr-8Ni	Bolts	A320	B8	S30400	2	$>1, \le 1^{1}/_{4}$	(15)(60)	-325	105	65	18.8	16.7	16.3	16.3	16.3
18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	2	>1, ≤1 ¹ / ₄	(15)(60)	-325	105	65	18.8	17.8	16.5	16.3	16.3
18Cr-10Ni-Ti	Bolts	A320	B8T	S32100	2	$>1, \le 1^{1/4}$	(15)(60)	-325	105	65	18.8	17.8	16.5	16.3	16.3
18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	1		(8f)(15)(28)	-325	75	30	18.8	17.8	16.5	15.3	14.3
18Cr-8Ni	Bolts	A320	B8	S30400	1		(8f)(15)(28)	-425	75	30	18.8	16.7	15.0	13.8	12.9
18Cr-10Ni-Cb	Bolts	A193	B8C		1		(8f)(15)(28)	-425	75	30	18.8	17.9	16.5	15.5	15.0
16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	1		(8f)(15)(28)	-325	75	30	18.8	17.3	15.6	14.3	13.3
16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	2	>³/₄, ≤1	(15)(60)	-325	100	80	20.0	20.0	20.0	20.0	20.0
16Cr-12Ni-2Mo		A320		S31600	2	$>^{7/4}$, ≤ 1 $>^{3}/_{4}$, ≤ 1					20.0	20.0	20.0	20.0	20.0
	Bolts		B8M				(15)(60)	-325	100	80					
18Cr-10Ni-Cb	Bolts	A193	B8C		2	> ³ / ₄ , ≤1	(15)(60)	-325	115	80	20.0	20.0	20.0	20.0	20.0
18Cr-10Ni-Cb	Bolts	A320	B8C	S34700	2	> ³ / ₄ , ≤1	(15)(60)	-325	115	80	20.0	20.0	20.0	20.0	20.0
18Cr-8Ni	Bolts	A193	B8	S30400	2	> ³ / ₄ , ≤1	(15)(60)	-325	115	80	20.0	20.0	20.0	20.0	20.0
18Cr-8Ni	Bolts	A320	B8	S30400	2	>³/ ₄ , ≤1	(15)(60)	-325	115	80	20.0	20.0	20.0	20.0	20.0
18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	2	>³/ ₄ , ≤1	(15)(60)	-325	115	80	20.0	20.0	20.0	20.0	20.0
18Cr-10Ni-Ti	Bolts	A320	B8T	S32100	2	>³/ ₄ , ≤1	(15)(60)	-325	115	80	20.0	20.0	20.0	20.0	20.0
12Cr	Bolts	A437	B4C	S42200		• • •	(35)	-20	115	85	21.3	21.3	21.3	21.3	21.3
13Cr	Bolts	A193	В6	S41000		≤4	(15)(35)	-20	110	85	21.3	21.3	21.3	21.3	21.3
14Cr-24Ni	Bolts	A453	660	S66286	Α		(15)(35)	-325	130	85	21.3	21.3	21.3	21.3	21.3
14Cr-24Ni	Bolts	A453	660	S66286	В		(15)(35)	-325	130	85	21.3	21.3	21.3	21.3	21.3
16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	2	≤ ³ / ₄	(15)(60)	-325	110	95	22.0	22.0	22.0	22.0	22.0
16Cr-12Ni-2Mo	Bolts	A320	B8M	S31600	2	≤ ³ / ₄	(15)(60)	-325	110	95	22.0	22.0	22.0	22.0	22.0
18Cr-10Ni-Cb	Bolts	A193	B8C		2	≤3/4	(15)(60)	-325	125	100	25.0	25.0	25.0	25.0	25.0
18Cr-10Ni-Cb	Bolts	A320	B8C	S34700	2	≤3/4	(15)(60)	-325	125	100	25.0	25.0	25.0	25.0	25.0
18Cr-8Ni	Bolts	A193	B8	S30400	2	≤ ³ / ₄	(15)(60)	-325	125	100	25.0	25.0	25.0	25.0	25.0
18Cr-8Ni	Bolts	A320	B8	S30400	2	≤ ³ / ₄	(15)(60)	-325	125	100	25.0	25.0	25.0	25.0	25.0
18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	2	=74 ≤ ³ / ₄	(15)(60)	-325	125	100	25.0	25.0		25.0	25.0
18Cr-10Ni-Ti	Bolts	A320	B8T	S32100	2	-74 ≤ ³ / ₄	(15)(60)	-325	125	100	25.0	25.0	25.0	25.0	25.0
12Cr	Bolts	A437	B4B	S42225			(35)	-20	145	105	26.3	26.3	26.3	26.3	26.3
12Cr	Nuts	A194	6	S41000			(35)(42)	-20							
18Cr-9Ni	Nuts	A194	8FA	S30300			(42)	-20							
16Cr-12Ni-2Mo	Nuts	A194	8MA	S31600			(42)	-325							
18Cr-10Ni-Ti	Nuts	A194 A194	8TA	S32100			(42)	-325 -325							
10C* ON:	No.4-	A10/	0	630400			(42)	/25							
18Cr-8Ni	Nuts	A194	8	S30400	• • •	• • •	(42)	-425	• • •	• • •	• • • •	• • • •		• • •	• • •
18Cr-8Ni	Nuts	A194	8A	S30400	• • •	• • •	(42)	-425	• • •	• • •	• • •	• • •	• • •	• • •	• • •
18Cr-10Ni-Cb	Nuts	A194	8CA	S34700	• • •	• • •	(42)	-425	• • •	• • •	• • • •			• • •	

Table A-2 Design Stress Values for Bolting Materials (Cont'd) Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM

						יט	esign S	uess, Ks	i, at Met	at tempe	erature, '	F [Note (, 1)]							
600	650	700	750	800	850	900	950	1,000	1,050	1,100	1,150	1,200	1,250	1,300	1,350	1,400	1,450	1,500	Type/ Grade	Spec No.
																			Stainless Stee	el (Cont'c
20.5	20.4	20.3	20.2	20.0	19.7	19.3	18.9	18.2	17 [651B	•
20.5	20.4	20.3	20.2	20.0	19.7	19.3	18.9	18.2	17.5 17.5	• • • •	• • •	• • • •	• • • •	• • •	• • •	• • • •	• • •		651B	A453 A453
20.5	20.4	20.3	20.2	20.0	19.7	19.3	18.9	18.2	17.5										651A	A453
20.5	20.4	20.3	20.2	20.0	19.7	19.3	18.9	18.2	17.5										651A	A453
16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3				• • •	• • •		• • •		• • •	B8M Cl. 2	A193
16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	• • •	• • •	• • •	• • •		• • •		• • •	• • •	B8M Cl. 2	A320
16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •	B8C Cl. 2	A193
16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3			• • •		• • •			• • •		B8C Cl. 2	A320
16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	• • •	• • •	• • •		• • •	• • •	• • •	• • •	• • •	B8 Cl. 2	A193
16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	• • •		• • •	• • •	• • •	• • •		• • •	• • •	B8 Cl. 2	A320
16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3			• • •		• • •			• • •		B8T Cl. 2	A193
16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	16.3	• • • •	• • • •	• • •	• • •	• • •	• • • •	• • • •	• • •	• • •	B8T Cl. 2	A320
13.5	13.2	13.0	12.7	12.6	12.4	12.3	12.1	12.0	9.6	6.9	5.0	3.6	2.6	1.7	1.1	0.8	0.5	0.3	B8T Cl. 1	A193
12.3	12.0	11.7	11.5	11.2	11.0	10.8	10.6	10.4	10.1	9.8	7.7	6.1	4.7	3.7	2.9	2.3	1.8	1.4	B8 Cl. 1	A320
14.3	14.0	13.8	13.7	13.6	13.5	13.4	13.4	13.4	12.1	9.1	6.1	4.4	3.3	2.2	1.5	1.2	0.9	0.8	B8C Cl. 1	A193
12.6	12.3	12.1	11.9	11.8	11.6	11.5	11.4	11.3	11.2	11.1	9.8	7.4	5.6	4.2	3.2	2.4	1.8	1.4	B8M Cl. 1	A193
20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0										B8M Cl. 2	A193
20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	• • • •		• • • •			• • • •	• • •	• • •	• • •	B8M Cl. 2	A320
										• • •		• • •					• • •	• • •		
20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0 20.0	20.0	• • •		• • •		• • •	• • •	• • •	• • •	• • •	B8C Cl. 2	A193
20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0 20.0	• • •		• • •			• • •		• • •	• • •	B8C Cl. 2 B8 Cl. 2	A320 A193
20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0			• • • •		• • • •			• • • •	• • • •	B8 Cl. 2	A320
20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	•••		• • • •	• • •	• • • •	• • • •	• • • •	• • • •	• • •	B8T Cl. 2	A193
20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0										B8T Cl. 2	A320
	21.3																			
21.3	21.5	21.3	21.3	• • • •	• • • •		• • • •		• • • •	•••	• • •	•••		• • • •	• • • •	•••	• • • •	• • • •	B4C	A437
21.3	21.3	21.3	21.3	21.3	21.3	20.2	18.7												B6	A193
21.3	21.3	21.3	21.3	21.3	21.3	21.3	21.3	21.3	21.3										660 Cl. A	A453
21.3	21.3	21.3	21.3	21.3	21.3	21.3	21.3	21.3	21.3										660 Cl. B	A453
22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0										B8M Cl. 2	A193
22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0										B8M Cl. 2	A320
24.6	24.5	24.5	24.5	24.5	24.5	24.4	24.2	23.9	23.5										B8C Cl. 2	A193
24.6	24.5	24.5	24.5	24.5	24.5	24.4	24.2	23.9	23.5										B8C Cl. 2	A320
25.0	25.0	25.0	25.0	25.0	25.0	25.0	24.7	23.9	22.9										B8 Cl. 2	A193
25.0	25.0	25.0	25.0	25.0	25.0	25.0	24.7	23.9	22.9										B8 Cl. 2	A320
25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0										B8T Cl. 2	A193
25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0			• • •		• • •			• • •		B8T Cl. 2	A320
26.3	26.3	26.3																	B4B	A437
																			6	Λ10 <i>/</i> -
• • •	• • •	• • • •	• • • •	• • • •	• • • •	• • •	• • •	• • • •	•••	• • •	• • • •	• • •	• • • •	•••		• • • •	• • •	• • • •	6 8FA	A194 A194
• • •									• • • •			• • • •		• • •	• • • •	• • • •	• • •	•••	OIA	A174
																			8MA	A194
• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • • •	8TA	A194
																			8	A194
																			8A	A194
																			8CA	A194
																			J	

Table A-2 Design Stress Values for Bolting Materials (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM

Nominal	Product		Type/		Class/ Condition/	Size Range,		Min. Temp.,	Specifie Strengt		Min. Temp. to			
Composition	Form	Spec. No.	Grade	UNS No.	Temper	Dia., in.	Notes	°F (6)	Tensile	Yield	100	200	300	400
Copper and Co	opper Alloy													
Naval brass	Bolts	B21		C46400	060		(8f)	-325	50	20	12.5	12.5	12.5	
Naval brass	Bolts	B21		C48200	060		(8f)	-325	50	20	12.5	12.5	12.5	
Naval brass	Bolts	B21		C48500	060		(8f)	-325	50	20	12.5	12.5	12.5	
Cu	Bolts	B187		C10200	060		(8f)	-325	30	10	6.7	5.4	5.0	
Cu	Bolts	B187		C11000	060		(8f)	-325	30	10	6.7	5.4	5.0	
Cu	Bolts	B187		C12000	060		(8f)	-325	30	10	6.7	5.4	5.0	
Cu	Bolts	B187		C12200	060		(8f)	-325	30	10	6.7	5.4	5.0	
Cu-Si	Bolts	B98		C65100	060		(8f)(52)	-325	40	12	8.0	8.0	7.1	
Cu-Si	Bolts	B98		C65500	060		(8f)(52)	-325	52	15	10.0	10.0	10.0	
Cu-Si	Bolts	B98		C66100	060		(8f)(52)	-325	52	15	10.0	10.0	10.0	
Cu-Si	Bolts	B98		C65500	H01		(8f)	-325	55	24	10.0	10.0	10.0	
Cu-Si	Bolts	B98		C66100	H01		(8f)	-325	55	24	10.0	10.0	10.0	
Cu-Si	Bolts	B98		C65500	H02	≤2		-325	70	38	10.0	10.0	10.0	
Cu-Si	Bolts	B98		C66100	H02	<u></u> ≤2		-325	70	38	10.0	10.0	10.0	
Cu-Si	Bolts	B98		C65100	H06	>1, ≤1 ¹ / ₂		-325	75	40	10.0	10.0	10.0	
Cu-Si	Bolts	B98		C65100	H06	>¹/ ₂ , ≤1		-325	75	45	11.3	11.3	11.3	
	201.0	2,0		003100		7 / 25 ===	•••	323	, ,	.,		11.5	11.5	• • • •
Cu-Si	Bolts	B98	• • • •	C65100	H06	≤ ¹ / ₂		-325	85	55	13.8	13.8	13.8	
Al-Si-bronze	Bolts	B150		C64200	HR50	>1, ≤2		-325	80	42	16.7	13.9	13.4	10.8
Al-Si-bronze	Bolts	B150		C64200	HR50	>¹/ ₂ , ≤1		-325	85	42	16.7	13.9	13.4	10.8
Al-Si-bronze	Bolts	B150		C64200	HR50	≤1/2		-325	90	42	16.7	13.9	13.4	10.8
Al-bronze	Bolts	B150		C61400	HR50	>1, ≤2		-325	70	32	17.5	17.5	17.5	17.2
Al-bronze	Bolts	B150		C61400	HR50	>¹/ ₂ , ≤1		-325	75	35	17.5	17.5	17.5	17.2
Al-bronze	Bolts	B150		C61400	HR50	≥/2, ≤1 ≤ ¹ / ₂	• • •	-325 -325	80	40	18.0	18.0	18.0	17.7
At biolize	Dolls	B130		C01400	ПКЭО	=/2	•••	723	00	40	10.0	10.0	10.0	17.7
Al-bronze	Bolts	B150		C63000	HR50	>2, ≤3		-325	85	42.5	21.3	21.3	21.0	20.7
Al-bronze	Bolts	B150		C63000	M20	>3, ≤4		-325	85	42.5	20.0	19.6	19.1	18.8
Al-bronze	Bolts	B150		C63000	HR50	>1, ≤2		-325	90	45	22.5	22.5	22.5	22.5
Al-bronze	Bolts	B150		C63000	HR50	>¹/ ₂ , ≤1		-325	100	50	22.5	22.5	22.5	22.5
Nickel and Nic	kel Alloy													
Low C-Ni	Bolts	B160		N02201	Hot fin./ann.		(8f)	-325	50	10	6.7	6.4	6.3	6.2
Ni	Bolts	B160		N02200	Hot fin.		(8f)	-325	60	15	10.0	10.0	10.0	10.0
Ni	Bolts	B160		N02200	Annealed	• • •	(8f)	-325	55	15	10.0	10.0	10.0	10.0
Ni	Bolts	B160		N02200	Cold drawn			-325	65	40	10.0	10.0	10.0	10.0
Ni-Cu	Bolts	B164		N04400	C.D./str. rel.		(54)	_375	9.4	50	16 7	1/- 6	13.6	12.1
			• • •		•	• • •		-325	84	50	16.7	14.6		13.2
Ni-Cu	Bolts	B164	• • •	N04405	Cold drawn	• • •	(54)	-325	85	50	16.7	14.6	13.6	13.2
Ni-Cu	Bolts	B164	• • •	N04400	Cold drawn	• • •	(54)	-325	85	55	16.7	14.6	13.8	13.8
Ni-Cu	Bolts	B164	• • •	N04400	Annealed	• • •	(8f)	-325	70	25	16.7	14.6	13.6	13.2
Ni-Cu	Bolts	B164	• • •	N04405	Annealed	• • •	(8f)	-325	70	25	16.7	14.6	13.6	13.2
Ni-Cu	Rod	B164		N04405	Hot fin.	≤3		-325	75	35	16.7	14.6	13.6	13.2
Ni-Cu	Hex	B164		N04400	Hot fin.	$\geq 2^{1}/_{8}, \leq 4$	(8f)	-325	75	30	16.7	14.6	13.6	13.2
	All except hex	B164		N04400	Hot fin.	>21/8		-325	80	40	16.7	14.6		13.2

Table A-2 Design Stress Values for Bolting Materials (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM

Design Stress, ksi, at Metal Temperature, °F [Note (1)] Spec. 500 600 650 700 750 800 850 900 950 1,000 1,050 1,100 1,150 1,200 1,250 1,300 UNS No. No. Copper and Copper Alloy C46400 B21 C48200 B21 C48500 B21 B187 C10200 C11000 B187 C12000 B187 C12200 B187 B98 C65100 B98 C65500 C66100 B98 C65500 B98 C66100 **B98** . . . C65500 **B98** C66100 B98 C65100 B98 C65100 B98 B98 C65100 5.2 1.7 1.2 C64200 B150 5.2 B150 1.7 1.2 C64200 5.2 1.7 1.2 C64200 B150 . . . 16.0 C61400 B150 16.0 . . . C61400 B150 B150 16.4 C61400 19.4 12.0 8.6 6.0 4.2 C63000 B150 17.6 12.0 8.6 6.0 4.2 C63000 B150 21.1 12.0 8.6 6.0 4.2 C63000 B150 12.0 8.6 C63000 B150 21.1 6.0 4.2 Nickel and Nickel Alloy 6.2 6.2 N02201 B160 6.2 6.2 6.1 6.0 5.8 4.5 3.7 3.0 2.4 2.0 1.5 1.2 1.0 10.0 10.0 10.0 N02200 B160 10.0 10.0 10.0 N02200 B160 10.0 10.0 10.0 N02200 B160 N04400 B164 13.1 13.1 13.1 13.1 N04405 B164 13.8 N04400 B164 13.1 13.1 13.1 13.0 12.9 12.7 12.6 12.5 9.2 N04400 B164 13.1 13.1 13.1 12.9 12.7 12.6 12.5 9.2 N04405 B164 13.0 13.1 13.1 13.1 13.0 12.9 12.7 12.6 12.5 9.2 N04405 B164 13.1 13.1 13.1 13.0 12.9 12.7 12.6 12.5 9.2 N04400 B164 13.1 13.1 13.1 12.9 12.6 12.5 N04400 B164 13.0 12.7 9.2

ASME B31.3-2016

Table A-2 Design Stress Values for Bolting Materials (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM

Nominal	Product		Type/		Class/ Condition/	Size Range,		Min. Temp.,	Specifie Strengt		Min. Temp. to			
Composition	Form	Spec. No.	Grade	UNS No.	Temper	Dia., in.	Notes	°F (6)	Tensile	Yield	100	200	300	400
Nickel and Ni	ckel Alloy (Cont'	d)												
Ni-Cr-Fe	Rod	B166		N06600	Cold drawn	≤3	(41)(54)	-325	105	80	20.0	20.0	20.0	20.0
Ni-Cr-Fe	Rod	B166		N06600	Hot fin.	≤3		-325	90	40	16.7	15.9	15.2	14.6
Ni-Cr-Fe	Bolts	B166		N06600	Annealed			-325	80	35	16.7	15.9	15.2	14.6
Ni-Cr-Fe	Rod	B166	• • • •	N06600	Hot fin.	>3	•••	-325	85	35	16.7	15.9	15.2	14.6
Ni-Mo	Bolts	B335		N10001	Annealed		•••	-325	100	46	25.0	25.0	25.0	24.6
Ni-Mo-Cr	Bolts	B574		N10276	Sol. ann.	•••		-325	100	41	25.0	24.9	23.0	21.3
Aluminum All	ру													
	Bolts	B211	6061	A96061	T6, T651 wld.	$\geq^{1}/_{8}$, ≤ 8	(8f)(43)(63)	-452	24		4.8	4.8	4.8	3.6
	Bolts	B211	6061	A96061	T6, T651	$\geq 1/8, \leq 8$	(43)(63)	-452	42	35	8.4	8.4	8.4	4.8
	Bolts	B211	2024	A92024	T4	>6 ¹ / ₂ , ≤8	(43)(63)	-452	58	38	9.5	9.5	9.5	4.2
• • •	Bolts	B211	2024	A92024	T4	$>4^{1}/_{2}, \leq 6^{1}/_{2}$	(43)(63)	-452	62	40	10.0	10.0	10.0	4.5
	Bolts	B211	2024	A92024	T4	$\geq^1/_2$, $\leq 4^1/_2$	(43)(63)	-452	62	42	10.5	10.5	10.3	4.5
	Bolts	B211	2024	A92024	T4	$\geq 1/8$, $< 1/2$	(43)(63)	-452	62	45	11.3	11.3	10.3	4.5
	Bolts	B211	2014	A92014	T6, T651	≥1/8, ≤8	(43)(63)	-452	65	55	13.0	13.0	12.4	4.3

Table A-2 Design Stress Values for Bolting Materials (Cont'd)
Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM

						Desig	n Stres	ss, ksi,	at Meta	l Tempei	rature, °	F [Note ([1)]				
500	600	650	700	750	800	850	900	950	1,000	1,050	1,100	1,150	1,200	1,250	1,300	UNS No.	Spec No.
															Nicke	el and Nickel All	ov (Cont'c
20.0																	
20.0	13.5	13.3	 13.1	 12.9	12.7	12.5	12.4	10.0	7.0	٠	3.0	2.2	2.0	1.0	• • •	N06600	B166
14.0						12.5		10.0		4.5			2.0	1.8	• • •	N06600	B166
14.0	13.5	13.3	13.1	12.9	12.7	12.5	12.4	9.2	7.0	4.5	3.0	2.2	2.0	1.8	• • •	N06600	B166
14.0	13.5	13.3	13.1	12.9	12.7	12.5	12.4	9.2	7.0	4.5	3.0	2.2	2.0	1.8	•••	N06600	B166
24.3	23.6	23.3	23.0	22.8	22.6	22.5										N10001	B335
19.9	18.7	18.2	17.8	17.4	17.1	16.9	16.7	16.6	16.5	16.5						N10276	B574
																Alum	inum Allo
																A96061	B211
																A96061	B211
																A92024	B211
																A92024	B211
																A92024	B211
	• • •	• • •	• • • •	• • •			• • • •		•••	• • •	• • •	• • •	• • • •	• • •	• • •	A92024	B211
																A92014	B211

Table A-2M Design Stress Values for Bolting Materials (Metric)

ine No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size Range, Dia mm	., Notes
	Carbon steel	Bolts	A675	45	D40450			(8f)(8g)
	Carbon steel	Bolts	A675	50	D40500		•••	(8f)(8g)
3	Carbon steel	Bolts	A675	55	D40550		•••	(8f)(8g)
	Carbon steel	Bolts	A307	В		•••		(8f)(8g)
5	Carbon steel	Bolts	A675	60	D40600			(8f)(8g)
6	Carbon steel	Bolts	A675	65	D40650			(8g)
7	Carbon steel	Bolts	A675	70	D40700			(8g)
8	Carbon steel	Bolts	A325					(8g)
9	Carbon steel	Bolts	A675	80	D40800	•••	•••	(8g)
10	Carbon steel	Nuts	A194	1	K01503			(42)
11	Carbon steel	Nuts	A194	2, 2H	K04002			(42)
12	Carbon steel	Nuts	A194	2HM	K04002			(42)
13	Carbon steel	Nuts	A563	A, hvy. hex	K05802	•••	•••	(42b)
14	Cr-0.2Mo	Bolts	A193	B7M	G41400		≤100	
15	Cr-0.2Mo	Bolts	A320	L7M	G41400		≤64	
16	5Cr	Bolts	A193	B5	S50100		≤100	(15)
17	Cr–Mo–V	Bolts	A193	B16	K14072	•••	>64 , ≤100	(15)
18	Alloy steel	Bolts	A354	ВС				(15)
19	Cr-Mo	Bolts	A193	B7	G41400		>64 , ≤100	(15)
20	Ni-Cr-Mo	Bolts	A320	L43	G43400		≤100	(15)
21	Cr-Mo	Bolts	A320	L7	G41400		≤64	(15)
22	Cr-Mo	Bolts	A320	L7A	G40370		≤64	(15)
23	Cr-Mo	Bolts	A320	L7B	G41370		≤64	(15)
24	Cr–Mo	Bolts	A320	L7C	G87400	•••	≤64	(15)
25	Cr–Mo	Bolts	A193	B7	G41400		≤64	
26	Cr-Mo-V	Bolts	A193	B16	K14072		≤64	(15)
27	Alloy steel	Bolts	A354	BD		•••	≤64	(15)
28	5Cr	Nuts	A194	3	S50100		• • •	(42)
29	C-Mo	Nuts	A194	4	K14510			(42)
30	C-Mo	Nuts	A194	4L	K14510	• • •	•••	(42)
31	Cr–Mo	Nuts	A194	7	G41400			(42)
32	Cr–Mo	Nuts	A194	7L	G41400			(42)
33	Cr–Mo	Nuts	A194	7M	G41400			(42)
34	Cr–Mo	Nuts	A194	7ML	G41400			(42)

Table A-2M Design Stress Values for Bolting Materials (Metric)

Design Stress, MPa, at Metal Temperature, °C [Note (1)] Min. Min. Min. Tensile Yield Max. Use Min. Line Temp., Strength, Strength, Temp., Temp. to °C (6) MPa MPa °C No. 77.6 77.6 77.6 77.6 77.6 77.6 77.6 77.6 -29-29 86.2 86.2 86.2 86.2 86.2 86.2 86.2 86.2 94.8 94.8 -2994.8 94.8 94.8 94.8 94.8 94.8 -29-29-29-29-29-29-29. -48 . . . -48. -29. -48 -73 -29-29-18-40 -101-101-101-101-101-48-29-29-29. -48-101. -48-101. -48. -73

Table A-2M Design Stress Values for Bolting Materials (Metric)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Design Stress, MPa, at Metal Temperature, °C [Note (1)]

Line												
No.	250	275	300	325	350	375	400	425	450	475	500	525
1	77.6	77.6	77.6	77.6	76.0	73.7	71.5	64.0	55.8	43.9	31.7	• • •
2	86.2	86.2	86.2	86.2	84.5	81.9	73.3	64.0	55.8	43.9	31.7	• • •
3	94.8	94.8	94.8	94.8	92.9	90.1	87.4	75.3	62.1	45.0	31.7	• • •
4	103	103	• • •	• • •	• • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •
5	103	103	103	103	101	98.3	95.1	79.5	62.6	45.0	31.7	
6	112	112	112	112	110	106	95.1	79.5	64.4	47.7	32.5	21.4
7	121	121	121	121	118	115	101	83.8	66.8	50.3	33.2	21.4
8	140	140	140	140	140							
9	138	138	138	138	135							
10												• • •
11	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
12	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
13	• • •	• • •	•••	•••	• • •	•••	•••	• • •	•••	•••	•••	• • •
14	138	138	138	138	138	138	138	138	115	92.3	67.3	41.6
15	138	138	138	138	138	138	138	138	115	92.3	67.3	41.6
16	138	138	138	138	138	138	138	138	138	80.6	61.7	46.4
17	152	152	152	152	152	152	152	152	148	132	113	88.3
18	159	159	159	159	159							
19	159	159	159	159	159	159	159	159	116	92.3	67.3	41.6
20	172	172	172	172	172	172	• • •	• • •	• • •	• • •	• • •	• • •
21	172	172	172	172	172	172	•••	•••	• • •	• • •	• • •	• • •
22	172	172	172	172	172	• • •	• • •	• • •	• • •	• • •	• • •	• • •
23	172	172	172	172	172	• • •	• • •	• • •	• • •	• • •	• • •	• • •
24	172	172	172	172	172	• • •	• • •	• • •	• • •	• • •	• • •	• • •
25	172	172	172	172	172	172	172	172	121	93.4	67.3	41.6
26	172	172	172	172	172	172	172	172	166	146	121	90.1
27	207	207	207	207	207							
28												
29												
30		• • •										• • •
31	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
32	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	•••	•••	• • •	• • •
33	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
34	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •

Table A-2M Design Stress Values for Bolting Materials (Metric)

Design Stress, MPa, at Metal Temperature, °C [Note (1)]

l in a												
Line No.	550	575	600	625	650	675	700	725	750	775	800	825
1		• • •	• • •		• • •	•••	•••	• • •	• • •			
2	• • •											
3	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
4	• • •	• • •	•••	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
5												
6	14.2				• • •							
7	14.2				• • •							
8					• • •							
9	• • •	• • •	• • •		•••	• • •	• • •	• • •	• • •	• • •	• • •	•••
10												
11												
12												
13	• • •	• • •	• • •	• • •	• • •	•••	•••	• • •	• • •	• • •		•••
14	23.5											
15	23.5											
16	34.7	25.5	17.8	11.4	6.7							
17	59.3	33.0	15.9	• • •	•••	•••	•••	•••	•••	• • •	• • •	•••
18												
19	23.5											
20												
21												
22												
23												
24	• • •	• • •	• • •		•••	• • •	• • •	• • •	• • •	• • •	• • •	•••
25	23.5											
26	59.3	33.0	15.9									
27	• • •	• • •	• • •	• • • •	•••	• • •	• • •	• • •	• • •	• • •		•••
28												
29												
30	• • •				•••							•••
31												
32		•••	•••					•••	• • •			
33		•••	•••					•••				
34	•••	•••			•••	•••	•••		•••			

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line	Nominal		Spec.	Type/		Class/ Condition/	Size Range, Dia	
No.	Composition	Product Form	No.	Grade	UNS No.	Temper	mm	Notes
	16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	2	>32, ≤38	(15)(60)
	16Cr-12Ni-2Mo	Bolts	A320	B8M	S31600	2	>32, ≤38	(15)(60)
	18Cr-8Ni	Bolts	A193	B8	S30400	2	>32, ≤38	(15)(60)
	18Cr-8Ni	Bolts	A320	B8	S30400	2	>32, ≤38	(15)(60)
	18Cr–10Ni–Cb	Bolts	A193	B8C	• • •	2	>32, ≤38	(15)(60)
	18Cr–10Ni–Cb	Bolts	A320	B8C	S34700	2	>32, ≤38	(15)(60)
	18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	2	>32, ≤38	(15)(60)
42	18Cr-10Ni-Ti	Bolts	A320	B8T	S32100	2	>32 , ≤38	(15)(60)
43	18Cr-9Ni	Bolts	A320	B8F	S30300	1	• • • •	(8f)(15)(39)
44	19Cr-9Ni	Bolts	A453	651B		• • •	>75	(15)(35)
45	19Cr-9Ni	Bolts	A453	651B			≤75	(15)(35)
46	19Cr-9Ni	Bolts	A453	651A			>75	(15)(35)
47	19Cr-9Ni	Bolts	A453	651A	•••	•••	≤75	(15)(35)
48	16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	2	>25 , ≤32	(15)(60)
49	16Cr-12Ni-2Mo	Bolts	A320	B8M	S31600	2	>25 , ≤32	(15)(60)
50	18Cr-10Ni-Cb	Bolts	A193	B8C		2	>25 , ≤32	(15)(60)
51	18Cr-10Ni-Cb	Bolts	A320	B8C	S34700	2	>25 , ≤32	(15)(60)
52	18Cr-8Ni	Bolts	A193	B8	S30400	2	>25 , ≤32	(15)(60)
53	18Cr-8Ni	Bolts	A320	B8	S30400	2	>25 , ≤32	(15)(60)
54	18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	2	>25 , ≤32	(15)(60)
55	18Cr-10Ni-Ti	Bolts	A320	B8T	S32100	2	>25 , ≤32	(15)(60)
56	18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	1	•••	(8f)(15)(28)
57	18Cr-8Ni	Bolts	A320	B8	S30400	1		(8f)(15)(28)
58	18Cr-10Ni-Cb	Bolts	A193	B8C		1		(8f)(15)(28)
59	16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	1		(8f)(15)(28)
60	16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	2	>19 , ≤25	(15)(60)
61	16Cr-12Ni-2Mo	Bolts	A320	B8M	S31600	2	>19, ≤25	(15)(60)
62	18Cr-10Ni-Cb	Bolts	A193	B8C		2	>19, ≤25	(15)(60)
63	18Cr-10Ni-Cb	Bolts	A320	B8C	S34700	2	>19, ≤25	(15)(60)
64	18Cr-8Ni	Bolts	A193	B8	S30400	2	>19, ≤25	(15)(60)
65	18Cr-8Ni	Bolts	A320	B8	S30400	2	>19, ≤25	(15)(60)
66	18Cr-10Ni-Ti	Bolts	A193	B8T	S32100	2	>19, ≤25	(15)(60)
67	18Cr-10Ni-Ti	Bolts	A320	B8T	S32100	2	>19, ≤25	(15)(60)
68	12Cr	Bolts	A437	B4C	S42200			(35)

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Design Stress, MPa, at Metal Temperature, °C [Note (1)]

Line												
No.	250	275	300	325	350	375	400	425	450	475	500	525
35	92.8	90.3	88.1	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2
36	92.8	90.3	88.1	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2
37	90.1	87.9	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2
38	90.1	87.9	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2	86.2
39	104	102	99.9	98.0	96.4	95.2	94.2	93.5	93.0	92.7	92.6	92.4
40	104	102	99.9	98.0	96.4	95.2	94.2	93.5	93.0	92.7	92.6	92.4
41	100	97.2	94.7	92.6	90.8	89.2	87.8	86.6	86.2	86.2	86.2	86.2
42	100	97.2	94.7	92.6	90.8	89.2	87.8	86.6	86.2	86.2	86.2	86.2
43	90.1	87.9	85.8	84.0	82.3	80.6	79.1	77.6	76.2	• • •	•••	• • •
44	144	143	142	141	141	140	139	138	136	134	131	128
45	144	143	142	141	141	140	139	138	136	134	131	128
46	144	143	142	141	141	140	139	138	136	134	131	128
47	144	143	142	141	141	140	139	138	136	134	131	128
48	112	112	112	112	112	112	112	112	112	112	112	112
49	112	112	112	112	112	112	112	112	112	112	112	112
50	112	112	112	112	112	112	112	112	112	112	112	112
51	112	112	112	112	112	112	112	112	112	112	112	112
52	112	112	112	112	112	112	112	112	112	112	112	112
53	112	112	112	112	112	112	112	112	112	112	112	112
54	112	112	112	112	112	112	112	112	112	112	112	112
55	112	112	112	112	112	112	112	112	112	112	112	112
56	99.9	97.2	94.7	92.6	90.8	89.2	87.8	86.6	85.6	84.7	84.0	83.2
57	90.1	87.9	85.8	84.0	82.3	80.6	79.1	77.6	76.2	74.8	73.4	72.1
58	104	102	99.9	98.0	96.4	95.2	94.2	93.5	93.0	92.7	92.6	92.4
59	92.8	90.3	88.1	86.2	84.6	83.3	82.2	81.2	80.4	79.7	79.0	78.4
60	138	138	138	138	138	138	138	138	138	138	138	138
61	138	138	138	138	138	138	138	138	138	138	138	138
62	138	138	138	138	138	138	138	138	138	138	138	138
63	138	138	138	138	138	138	138	138	138	138	138	138
64	138	138	138	138	138	138	138	138	138	138	138	138
65	138	138	138	138	138	138	138	138	138	138	138	138
66	138	138	138	138	138	138	138	138	138	138	138	138
67	138	138	138	138	138	138	138	138	138	138	138	138
68	147	147	147	147	147	147						

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Design Stress, MPa, at Metal Temperature, °C [Note (1)]

ine No.	550	575	600	625	650	675	700	725	750	775	800	82
35	86.2											
36	86.2											
37	86.2			•••								
38	86.2			•••								
39	92.2											
40	92.2			•••								
41	86.2			•••								
42	86.2											
43												
7,5	•••	•••	•••	•••	• • •	•••	•••	•••	•••	•••	•••	••
44	124											
45	124			•••								
46	124											
47	124			•••								
48	112											
49	112											
50	112											
51	112											
52	112											
53	112											
54	112											
55	112											
56	82.4	59.2	44.0	32.9	24.5	18.3	12.5	8.5	6.2	4.3	2.8	1.
57	70.7	69.4	63.8	51.6	41.6	32.9	26.5	21.3	17.2	14.1	11.2	8.
58	92.2	75.9	57.2	40.2	30.3	23.2	16.2	11.4	9.0	7.1	5.9	5.
59	77.7	76.9	75.9	65.0	50.5	39.2	30.4	23.6	18.4	14.3	11.1	8.
60	138											
61	138	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	• •
62	138	•••	•••	• • • •	•••	•••	•••	•••	•••	•••	•••	
63	138	• • • •	•••	• • • •	•••	•••	•••	•••	•••	•••	•••	• •
64	138	• • • •	• • •	•••	• • •	• • • •		• • •	• • • •	•••	•••	
65	138	•••	•••	•••	• • •	•••		•••	•••	• • •	•••	• •
66	138	•••	•••	•••	•••	•••	•••	•••	• • •	•••	•••	••
67	138	•••	• • •	•••	• • •	• • •	•••	• • •	• • •	•••	•••	• • •
37	1,0	•••	•••	•••	• • •	•••	•••	•••	•••	•••	•••	• •
68												

(16) Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size Range, Dia., mm	Notes
	13Cr	Bolts	A193	B6	S41000		<u>≤100</u>	(15)(35)
	14Cr-24Ni	Bolts	A453	660	S66286	Α	_100	(15)(35)
	14Cr-24Ni	Bolts	A453	660	S66286	В	•••	(15)(35)
	16Cr-12Ni-2Mo	Bolts	A193	B8M	S31600	2	··· ≤19	(15)(60)
	16Cr-12Ni-2Mo	Bolts	A320	B8M	S31600	2	≤19	(15)(60)
	18Cr–10Ni–Cb	Bolts	A193	B8C		2	_19 ≤19	(15)(60)
	18Cr–10Ni–Cb	Bolts	A320	B8C	S34700	2	_19 ≤19	(15)(60)
	18Cr–8Ni	Bolts	A193	B8	S30400	2	_19 ≤19	(15)(60)
	18Cr–8Ni	Bolts	A320	B8	S30400	2	_19 ≤19	(15)(60)
	18Cr–10Ni–Ti	Bolts	A193	B8T	S32100	2	≤19	(15)(60)
	18Cr–10Ni–Ti	Bolts	A320	B8T	S32100	2	≤19	(15)(60)
00	126-	Dolto	A 4 2 7	D / D	C4222F			(25)
80	12Cr	Bolts	A437	B4B	S42225	•••	•••	(35)
81	12Cr	Nuts	A194	6	S41000			(35)(42)
82	18Cr-9Ni	Nuts	A194	8FA	S30300	• • •		(42)
83	16Cr-12Ni-2Mo	Nuts	A194	8MA	S31600			(42)
84	18Cr-10Ni-Ti	Nuts	A194	8TA	S32100			(42)
85	18Cr–8Ni	Nuts	A194	8	S30400		•••	(42)
86	18Cr-8Ni	Nuts	A194	8A	S30400			(42)
87	18Cr–10Ni–Cb	Nuts	A194	8CA	S34700			(42)
88	Naval brass	Bolts	B21		C46400	060	•••	(8f)
89	Naval brass	Bolts	B21	• • •	C48200	060		(8f)
	Naval brass	Bolts	B21	•••	C48500	060	•••	(8f)
91		Bolts	B187		C10200	060	•••	(8f)
92		Bolts	B187	• • •	C11000	060		(8f)
93		Bolts	B187	• • •	C12000	060		(8f)
94	Cu	Bolts	B187	• • •	C12200	060		(8f)
95	Cu-Si	Bolts	B98		C65100	060		(8f)(52)
96	Cu-Si	Bolts	B98		C65500	060		(8f)(52)
	Cu-Si	Bolts	B98		C66100	060		(8f)(52)
	Cu-Si	Bolts	B98		C65500	H01		(8f)
	Cu-Si	Bolts	B98		C66100	H01		(8f)
	Cu-Si	Bolts	B98		C65500	H02	≤50	
101	Cu-Si	Bolts	B98		C66100	H02	≤50	
	Cu-Si	Bolts	B98		C65100	H06	->25 , ≤38	
	Cu–Si	Bolts	B98		C65100	H06	>13, ≤25	
	Cu-Si	Bolts	B98		C65100	H06	≤13	

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

						Desig	gn Stress, N	MPa, at Meta	al Temperat	ure, °C [Not	te (1)]	
Line	Min. Temp.,	Min. Tensile Strength,	Min. Yield Strength,	Max. Use Temp.,	Min. Temp. to				·			
No.	°C (6)	MPa	MPa	°C	40	65	100	125	150	175	200	225
69	-29	758	586	482	147	147	147	147	147	147	147	147
70	-198	896	586	538	147	147	147	147	147	147	147	147
71	-198	896	586	538	147	147	147	147	147	147	147	147
72	-198	758	655	538	152	152	152	152	152	152	152	152
73	-198	758	655	538	152	152	152	152	152	152	152	152
74	-198	862	689	538	172	172	172	172	172	172	172	172
75	-198	862	689	538	172	172	172	172	172	172	172	172
76	-198	862	689	538	172	172	172	172	172	172	172	172
77	-198	862	689	538	172	172	172	172	172	172	172	172
78	-198	862	689	538	172	172	172	172	172	172	172	172
79	-198	862	689	538	172	172	172	172	172	172	172	172
80	-29	1000	724	343	181	181	181	181	181	181	181	181
81	-29			40								
82	-29	• • •		40								
83	-198			40								
84	-198	•••		40	• • •	• • •	• • •	• • •	• • •	• • •	• • •	•••
85	-254			40								
86	-254			40								
87	-254	•••		40				• • •				
88	-198	345	138	149	86.2	86.2	86.2	86.2	86.2			
89	-198	345	138	149	86.2	86.2	86.2	86.2	86.2			•••
90	-198	345	138	149	86.2	86.2	86.2	86.2	86.2			
91	-198	207	69	149	46.0	38.8	37.2	36.5	34.2			• • •
92	-198	207	69	149	46.0	38.8	37.2	36.5	34.2	•••	•••	•••
93	-198	207	69	149	46.0	38.8	37.2	36.5	34.2			•••
94	-198	207	69	149	46.0	38.8	37.2	36.5	34.2			•••
95	-198	276	83	149	55.2	55.2	55.2	54.0	48.3	•••	•••	• • •
96	-198	359	103	149	68.9	68.9	68.9	68.9	68.8	•••	•••	• • •
97	-198 -198	359	103	149	68.9	68.9	68.9	68.9	68.8	•••	•••	•••
98	-198	379								•••	•••	•••
98			165 165	149	68.9	68.9	68.9	68.9	68.8	• • • •	• • • •	•••
	-198	379	165	149	68.9	68.9	68.9	68.9	68.8	• • • •	• • • •	•••
100	-198	483	262	149	68.9	68.9	68.9	68.9	68.8	• • •	• • •	•••
101	-198	483	262	149	68.9	68.9	68.9	68.9	68.8	• • •	• • •	• • •
102	-198	517	276	149	68.9	68.9	68.9	68.9	68.9	• • •	• • •	• • •
103	-198	517	310	149	77.6	77.6	77.6	77.6	77.6	• • •	•••	•••
104	-198	586	379	149	94.8	94.8	94.8	94.8	94.8			

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Design Stress, MPa, at Metal Temperature, °C [Note (1)]

Line No.	250	275	300	325	350	375	400	425	450	475	500	525
69	147	147	147	147	147	147	147	147	147	141	133	
70	147	147	147	147	147	147	147	147	147	147	147	147
71	147	147	147	147	147	147	147	147	147	147	147	147
72	152	152	152	152	152	152	152	152	152	152	152	152
73	152	152	152	152	152	152	152	152	152	152	152	152
74	172	171	170	170	169	169	169	169	169	168	167	166
75	172	171	170	170	169	169	169	169	169	168	167	166
76	172	172	172	172	172	172	172	172	172	172	172	168
77	172	172	172	172	172	172	172	172	172	172	172	168
78	172	172	172	172	172	172	172	172	172	172	172	172
79	172	172	172	172	172	172	172	172	172	172	172	172
80	181	181	181	181	181	• • •	• • •	• • •	• • •	• • •	•••	• • •
0.1												
81	• • •	• • •	• • •	• • •	• • •	•••	• • •	• • •	• • •	• • •	• • •	• • •
82	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •
83												
84												
04	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••	•••
85												
86												
87												
88												
89		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		
90		• • •	• • •									
91	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
92	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
93	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	•••
94	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
95	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
96	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
97	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	•••	•••
98	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	•••	• • •
99	• • •	• • •	• • •	• • •	• • •	•••	• • •	• • •	• • •	• • •	•••	•••
100	• • •	• • •	• • •	• • •	• • •	•••	•••	• • •	• • •	• • •	• • •	•••
101	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
102	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
103	• • •	•••	• • •	•••	•••	•••	•••	•••	• • •	•••	•••	•••
104												
104	• • •	•••	•••	• • •	•••	•••	•••	•••	•••	• • •	•••	• • •
I												

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Design Stress, MPa, at Metal Temperature, °C [Note (1)]

Line No.	550	575	600	625	650	675	700	725	750	775	800	825
69												
70	147			•••			•••					
71	147											
72	152											
73	152											
74	164											
75	164											
76	162											
77	162											
78	172											
79	172											
80												
81												
82				• • •								
83												
84		• • •	• • •	• • •		• • •	• • •		• • •		• • •	• • •
85		• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	•••	• • •
86	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
87	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
88	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
89	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	•••	• • •
90	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
91	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
92	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
93	• • •	• • •	•••	• • •	• • •	• • •	• • •	• • •	• • •	•••	•••	• • •
94	•••	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	•••	• • •
95	• • •	• • •	•••	• • •	• • •	• • •	• • •	• • •	• • •	•••	•••	• • •
96	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
97	• • •	• • • •	• • •	• • •	• • •	• • • •	• • •	• • •	• • •	• • •	• • •	• • •
98 99	• • •	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	•••	•••
100	• • •	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	•••	•••
100	• • •	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	•••	•••
101	•••	• • •	•••	•••	• • •	• • •	•••	• • •	• • •	• • •	•••	•••
102	•••	• • •	•••	•••	• • •	• • •	•••	• • •	• • •	• • •	•••	•••
100	• • •	• • •	•••	•••	•••	• • •	•••	• • •	• • •	• • •	•••	•••
104												
104	• • •	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	•••	•••
ı												

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Line No.	Nominal Composition	Product Form	Spec. No.	Type/ Grade	UNS No.	Class/ Condition/ Temper	Size Range, Dia	., Notes
105 A	l–Si–bronze	Bolts	B150		C64200	HR50	>25,≤50	
106 A	l-Si-bronze	Bolts	B150		C64200	HR50	>13, ≤25	
107 A	l-Si-bronze	Bolts	B150	•••	C64200	HR50	≤13	•••
108 A	l-bronze	Bolts	B150		C61400	HR50	>25,≤50	
109 A	l-bronze	Bolts	B150		C61400	HR50	>13,≤25	
110 A	l-bronze	Bolts	B150	•••	C61400	HR50	≤13	
111 A	l-bronze	Bolts	B150		C63000	HR50	>50 , ≤75	
112 A	l-bronze	Bolts	B150		C63000	M20	>75 , ≤100	
113 A	l-bronze	Bolts	B150		C63000	HR50	>25,≤50	
114 A	l-bronze	Bolts	B150	•••	C63000	HR50	>13, ≤25	• • •
115 L	ow C-Ni	Bolts	B160		N02201	Hot fin./ann.		(8f)
116 N	li	Bolts	B160		N02200	Hot fin.		(8f)
117 N	li	Bolts	B160		N02200	Annealed		(8f)
118 N	li	Bolts	B160	•••	N02200	Cold drawn	•••	
119 N	Ii–Cu	Bolts	B164		N04400	C.D./str. rel.		(54)
120 N	Ii–Cu	Bolts	B164		N04405	Cold drawn		(54)
121 N	li–Cu	Bolts	B164		N04400	Cold drawn		(54)
122 N	li–Cu	Bolts	B164		N04400	Annealed		(8f)
123 N	Ii–Cu	Bolts	B164	•••	N04405	Annealed	•••	(8f)
124 N	Ii–Cu	Rod	B164		N04405	Hot fin.	≤75	
125 N	Ii–Cu	Hex	B164		N04400	Hot fin.	≥54, ≤100	(8f)
126 N	Ii–Cu	All except hex	B164	•••	N04400	Hot fin.	>54	•••
127 N	Ii–Cr–Fe	Rod	B166		N06600	Cold drawn	≤75	(41)(54)
128 N	li–Cr–Fe	Rod	B166		N06600	Hot fin.	≤75	
129 N	li–Cr–Fe	Bolts	B166		N06600	Annealed		
130 N	li–Cr–Fe	Rod	B166	•••	N06600	Hot fin.	>75	•••
131 N	li–Mo	Bolts	B335	•••	N10001	Annealed		•••
132 N	li–Mo–Cr	Bolts	B574		N10276	Sol. ann.		
133 A	luminum alloy	Bolts	B211	6061	A96061	T6, T651 wld.	≥3, ≤200	(8f)(43)(63)
134 A	luminum alloy	Bolts	B211	6061	A96061	T6, T651	≥3, ≤200	(43)(63)
135 A	luminum alloy	Bolts	B211	2024	A92024	T4	>165 , ≤200	(43)(63)
136 A	luminum alloy	Bolts	B211	2024	A92024	T4	>114 , ≤165	(43)(63)
137 A	luminum alloy	Bolts	B211	2024	A92024	T4	>13, ≤114	(43)(63)
138 A	luminum alloy	Bolts	B211	2024	A92024	T4	≥3, <13	(43)(63)
139 A	luminum alloy	Bolts	B211	2014	A92014	T6, T651	≥3,≤200	(43)(63)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Design Stress, MPa, at Metal Temperature, °C [Note (1)] Min. Min. Min. Tensile Yield Max. Use Min. Line Temp., Strength, Strength, Temp., Temp. to °C (6) MPa MPa °C 40 65 100 125 150 175 200 225 No. 105 290 316 115 100 95.2 93.6 92.1 89.1 76.9 57.7 -198552 106 -198 290 316 100 95.2 93.6 89.1 76.9 57.7 586 115 92.1 107 -19895.2 89.1 621 290 316 115 100 93.6 92.1 76.9 57.7 108 -198483 221 260 121 121 121 121 121 121 119 115 109 -198517 241 260 121 121 121 121 121 121 119 115 110 -198552 276 260 124 124 124 124 124 124 122 118 111 -198586 293 371 147 147 147 146 145 144 143 140 112 -198 586 293 371 138 137 134 133 132 131 130 128 113 -198310 371 155 155 155 621 155 155 155 155 153 -198371 114 689 345 155 155 155 155 155 155 155 153 -19846.0 115 345 69 649 44.8 44.0 43.6 43.3 43.1 43.0 43.0 -198 103 316 68.9 68.9 68.9 68.9 68.9 116 414 68.9 68.9 68.9 117 -198103 68.9 68.9 68.9 68.9 379 316 68.9 68.9 68.9 68.9 118 -198448 276 316 68.9 68.9 68.9 68.9 68.9 68.9 68.9 68.9 119 -198579 345 316 115 106 99.7 96.2 93.6 91.9 90.9 90.4 -198 345 260 99.7 90.9 120 586 115 106 96.2 93.6 91.9 90.4 121 -198586 379 260 115 106 99.7 96.2 94.8 94.8 94.8 94.8 -19899.7 96.2 91.9 90.9 122 483 172 482 115 106 93.6 90.4 123 -198483 172 482 115 106 99.7 96.2 93.6 91.9 90.9 90.4 124 -198517 241 482 115 106 99.7 96.2 93.6 91.9 90.9 90.4 125 -198517 207 482 115 106 99.7 96.2 93.6 91.9 90.9 90.4 126 -198552 276 482 115 106 99.7 96.2 93.6 91.9 90.9 90.4 127 -198724 552 260 138 138 138 138 138 138 138 138 -198276 109 107 101 128 621 649 115 112 105 103 99.0 129 -198552 241 649 115 112 109 107 105 103 101 99.0 130 -198586 241 649 115 112 109 107 105 103 101 99.0 131 -198689 317 427 172 172 172 172 172 171 170 169 132 -198689 283 538 172 172 170 164 153 148 143 158 133 -269 165 204 33.1 33.1 33.1 33.1 33.1 33.1 26.4 16.1 . . . 57.9 57.9 34.9 134 -269290 241 204 57.9 57.9 57.9 47.3 21.1 135 -269400 262 204 65.5 65.5 43.1 29.3 29.3 65.5 65.5 65.5 136 -269427 276 204 68.9 68.9 68.9 68.9 68.9 46.1 31.3 31.3 137 -269427 290 204 72.4 72.4 72.4 72.4 70.2 46.2 31.2 31.2 138 -269 427 310 204 77.6 77.6 77.6 77.6 70.2 46.2 31.2 31.2 139 -269448 379 204 89.6 89.6 89.6 89.6 84.2 46.9 26.2 20.2

137

138

139

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix A Tables; Specifications Are ASTM Unless Otherwise Indicated

Design Stress, MPa, at Metal Temperature, °C [Note (1)] Line No. 250 275 300 325 350 375 400 425 450 475 500 525 105 40.9 24.1 14.5 10.3 106 40.9 24.1 14.5 10.3 107 24.1 40.9 14.5 10.3 108 111 109 109 109 111 110 115 112 111 136 126 97.2 73.9 54.4 39.3 . . . 112 124 117 97.2 73.9 54.4 39.3 113 148 126 97.2 73.9 54.4 39.3 97.2 114 148 126 73.9 54.4 39.3 115 43.0 43.0 43.0 43.0 42.9 42.7 42.2 41.6 40.7 33.1 27.4 22.8 116 68.9 68.9 68.9 68.9 117 68.9 68.9 68.9 68.9 118 68.9 68.9 68.9 68.9 119 90.4 90.4 90.4 90.4 120 90.4 90.4 121 94.8 94.8 90.4 90.4 90.4 89.8 122 90.4 90.4 89.0 88.0 87.0 86.4 75.6 123 90.4 90.4 90.4 90.4 90.4 89.8 89.0 88.0 87.0 86.4 75.6 124 90.4 90.4 90.4 90.4 90.4 89.8 89.0 88.0 87.0 86.4 75.6 . . . 125 90.4 90.4 90.4 90.4 90.4 89.8 89.0 88.0 87.0 86.4 75.6 . . . 126 90.4 90.4 90.4 90.4 90.4 89.8 89.0 88.0 87.0 86.4 75.6 127 138 138 97.3 128 95.6 94.0 92.6 88.7 86.7 91.2 89.9 87.7 85.8 75.6 58.4 129 97.3 95.6 94.0 92.6 91.2 89.9 88.7 87.7 86.7 85.8 75.6 58.4 130 97.3 95.6 94.0 92.6 91.2 89.9 88.7 87.7 86.7 85.8 75.6 58.4 131 168 166 164 162 160 158 157 156 155 132 139 135 131 128 125 122 120 118 117 115 115 114 133 134 135 . . . 136

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

. . .

Table A-2M Design Stress Values for Bolting Materials (Metric) (Cont'd)

Design Stress, MPa, at Metal Temperature, °C [Note (1)]

Line No.	550	575	600	625	650	675	700	725	750	775	800	825
105												
106												
107												
108	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
109	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
110	• • •	• • •	• • •	• • • •	• • • •	• • •	• • •	• • •	• • •	• • •	•••	• • •
111												
112												
113												
14												
4.5	40.7	45.6	42.0	40.0	0.2							
.15	18.7	15.6	12.9	10.0	8.2	• • •	• • •	• • •	• • •	• • •	• • •	• • •
16	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
17	• • •	• • •	•••	•••	• • •	• • •	• • •	• • •	• • •	• • •	•••	• • •
18	• • • •	•••	•••	•••	•••	•••	•••	• • •	•••	•••	•••	• • •
19												
20								• • •				
21								• • •				
.22												
.23	•••	• • •				• • •	• • •	• • •	• • •	• • •	•••	• • •
.24												
25												
26						•••		•••				
27						• • •	• • •	• • •	• • •	• • •	• • •	• • •
28	39.7	27.0	19.2	15.0	13.7	• • •	• • •	• • •	• • •	• • •	• • •	• • •
29	39.7	27.0	19.2	15.0	13.7	• • •	• • •	• • •	• • •	• • •	•••	• • •
30	39.7	27.0	19.2	15.0	13.7	• • •	•••	• • •	•••	• • •	• • • •	• • •
31												
32	114											
33												
34												
35												
36								•••				
37	•••											
38	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •
139												

APPENDIX B STRESS TABLES AND ALLOWABLE PRESSURE TABLES FOR NONMETALS

The data and Notes in Appendix B are requirements of this Code.

Specification Index for Appendix B

	• • • • • • • • • • • • • • • • • • • •								
Spec. No.	Title [Note (1)]								
ASTM									
C361	Reinforced Concrete Low-Head Pressure Pipe								
C582	Contact-Molded Reinforced Thermosetting Plastic (RTP) Laminates for Corrosion Resistant Equipment								
C599	Process Glass Pipe and Fittings								
D1785	PVC Plastic Pipe, Schedules 40, 80, and 120								
D2239	PE Plastic Pipe (SIDR-PR) Based on Controlled Inside Diameter								
D2241	PVC Plastic Pressure-Rated Pipe (SDR Series)								
D2447	PE Plastic Pipe, Schedules 40 and 80, Based on Outside Diameter								
D2513	Thermoplastic Gas Pressure Pipe, Tubing and Fittings								
D2517	Reinforced Epoxy Resin Gas Pressure Pipe and Fittings								
D2662	PB Plastic Pipe (SDR-PR)								
D2666	PB Plastic Tubing								
D2672	Joints for IPS PVC Pipe Using Solvent Cement								
D2737	PE Plastic Tubing								
D2846	CPVC Plastic Hot- and Cold-Water Distribution Systems								
D2996	Filament-Wound Fiberglass RTR Pipe [Note (2)]								
D2997	Centrifugally Cast RTR Pipe [Note (2)]								
D3000	PB Plastic Pipe (SDR-PR) Based on Outside Diameter								
D3035	PE Plastic Pipe (DR-PR) Based on Controlled Outside Diameter								
D3309	PB Plastic Hot- and Cold-Water Distribution Systems								
D3517	Fiberglass RTR Pressure Pipe [Note (2)]								
D3754	Fiberglass RTR Sewer and Industrial Pressure Pipe [Note (2)]								
F441	CPVC Plastic Pipe, Schedules 40 and 80								
F442	CPVC Plastic Pipe (SDR-PR)								
F2389	Pressure-Rated Polypropylene (PP) Piping Systems								
F2788/F2788M	Metric and Inch-sized Crosslinked Polyethylene (PEX) Pipe								
AWWA									
C300	Reinforced Concrete Pressure Pipe, Steel Cylinder Type, for Water and Other								
C301	Liquids Prestressed Concrete Pressure, Pipe Steel Cylinder Type, for Water and Other								
C)01	Liquids								
C302	Reinforced Concrete Pressure Pipe, Noncylinder Type								
C950	Fiberglass Pressure Pipe								

GENERAL NOTE: It is not practical to refer to a specific edition of each standard throughout the Code text. Instead, the approved edition references, along with the names and addresses of the sponsoring organizations, are shown in Appendix E.

NOTES

- (1) For names of plastics identified only by abbreviation, see para. A326.4.
- (2) The term fiberglass RTR takes the place of the ASTM designation "fiberglass" (glass-fiber-reinforced thermosetting resin).

Table B-1 Hydrostatic Design Stresses (HDS) and Recommended Temperature Limits for Thermoplastic Pipe

				Temp	mended erature ts, °F	Hydrosta	atic Desig	n Stress, l	csi, at
ASTM		Material	Cell	[Notes	(1), (2)]	73°F			
Spec. No.	Pipe Designation	Designation	Class	Minimum	Maximum	[Note (3)]	100°F	180°F	200°F
	PR	ABS	43232	-40	176				
D2846	SDR11	CPVC4120	23447		180	2.0		0.5	
F441	Sch. 40	CPVC4120	23447	 73	200	2.0		0.5	
F441	Sch. 80	CPVC4120	23447	73	200	2.0		0.5	• • •
F442	SDR-PR	CPVC4120	23447	73	200	2.0	 1.64	0.5	
D3309	SDR11	PB2110		73	200	1.0		0.5	
03309	JUNII	FB2110	• • •	7.5	200	1.0	• • •	0.5	• • •
D2239	SIDR-PR	PE1404		73		0.40			
D2239	SIDR-PR	PE2305		73		0.50			
D2239	SIDR-PR	PE2306		73		0.63			
D2239	SIDR-PR	PE2406		73		0.63			
D2239	SIDR-PR	PE3306		73		0.63			
D2239	SIDR-PR	PE3406		73		0.63			
D2239	SIDR-PR	PE3408		73		0.80			
D2447	Sch. 40 and 80	PE1404	• • •	73	• • •	0.40	• • •	• • •	• • •
D2447	Sch. 40 and 80	PE2305	• • •	73	• • •	0.50	• • •	• • •	• • •
D2447	Sch. 40 and 80	PE2306	• • •	73		0.63			
D2447	Sch. 40 and 80	PE2406		73		0.63			
D2447	Sch. 40 and 80	PE3306		73		0.63			
D2447	Sch. 40 and 80	PE3406	• • •	73	• • •	0.63			
D2737	SDR7.3, SDR9, SDR11	PE2305		73		0.50			
D2737	SDR7.3, SDR9, SDR11	PE2306		73		0.63			
D2737	SDR7.3, SDR9, SDR11	PE2406		73		0.63			
D2737	SDR7.3, SDR9, SDR11	PE3306		73		0.63			
D2737	SDR7.3, SDR9, SDR11	PE3406		73		0.63			
D2737	SDR7.3, SDR9, SDR11	PE3408		73		0.80			
D3035	DR-PR	PE1404		73		0.40			
D3035	DR-PR	PE2606	• • •	73	• • •	0.63	• • •	• • •	• • •
	DR-PR	PE2708	• • •		• • •		• • •	• • •	• • •
D3035 D3035	DR-PR DR-PR	PE3608	• • •	73 73	• • •	0.80	• • •	• • •	• • •
03033	טוי-רוג	FE3006	• • •	73	• • •	0.80	• • •	• • •	• • •
D3035	DR-PR	PE3708		73		0.80			
D3035	DR-PR	PE3710		73		1.00			
D3035	DR-PR	PE4608		73		0.80			
D3035	DR-PR	PE4708		73		0.80			
D3035	DR-PR	PE4710		73		1.00			
F714	SDR-PR	PE1404		73		0.40			
F714	SDR-PR	PE2606		73	• • •	0.63	• • •	• • •	• • •
	SDR-PR	PE2708	• • •		• • •		• • •	• • •	• • •
F714			• • •	73 73	• • •	0.80	• • •	• • •	• • •
F714	SDR-PR	PE3608	• • •	73	• • •	0.80	• • •	• • •	• • •
F714	SDR-PR	PE3708		73		0.80			
F714	SDR-PR	PE3710		73		1.00			
F714	SDR-PR	PE4608		73		0.80			
F714	SDR-PR	PE4708		73		0.80			
F714	SDR-PR	PE4710		73		1.00			

				Temp	mended erature ts, °F	Hydrostatic Design Stress, ksi, at						
ASTM		Material	Cell	[Notes	(1), (2)]	73°F						
Spec. No.	Pipe Designation	Designation	Class	Minimum	Maximum	[Note (3)]	100°F	180°F	200°F			
F2788/F2788M	SDR/DR-PR	PEX0006		-58	230	0.63		0.40	0.31			
F2788/F2788M	SDR/DR-PR	PEX0008		-58	230	0.80		0.40	0.31			
F2389	SDR6, SDR7.3, SDR11	PP		0	210	0.63	0.50	0.20				
D1785	Sch. 40, 80, 120	PVC1120	12454	73		2.00						
D1785	Sch. 40, 80, 120	PVC1220	12454	73		2.00						
D1785	Sch. 40, 80, 120	PVC2120	14333	73		2.00						
D1785	Sch. 40, 80, 120	PVC2116	14333	73		1.60						
D1785	Sch. 40, 80, 120	PVC2112	14333	73		1.25						
D1785	Sch. 40, 80, 120	PVC2110	14333	73		1.00						
D2241	PR (SDR series)	PVC1120	12454	73		2.00						
D2241	PR (SDR series)	PVC1220	12454	73		2.00						
D2241	PR (SDR series)	PVC2120	14333	73		2.00						
D2241	PR (SDR series)	PVC2116	14333	73		1.60						
D2241	PR (SDR series)	PVC2112	14333	73		1.25						
D2241	PR (SDR series)	PVC2110	14333	73		1.00						

NOTES:

- (1) These recommended limits are for low pressure applications with water and other fluids that do not significantly affect the properties of the thermoplastic. The upper temperature limits are reduced at higher pressures, depending on the combination of fluid and expected service life. Lower temperature limits are affected more by the environment, safeguarding, and installation conditions than by strength.
- (2) These recommended limits apply only to materials listed. Manufacturers should be consulted for temperature limits on specific types and kinds of materials not listed.
- (3) Use these hydrostatic design stress (HDS) values at all lower temperatures.

Table B-1M Hydrostatic Design Stresses (HDS) and Recommended Temperature Limits for Thermoplastic Pipe (SI Units)

				Temp	mended erature ts, °C	Hydrosta	tic Nesign	ı Stress, M	MPa at
					(1), (2)]		tic Desigi	1 Juess, 1	nra, at
ASTM Spec. No.	Pipe Designation	Material Designation	Cell Class	Minimum	Maximum	23°C [Note (3)]	38°C	82°C	93°C
	PR	ABS	43232	-40	80				
D2846	SDR11	CPVC4120	23447		82	13.8		3.45	
F441	Sch. 40	CPVC4120	23447	23	93.3	13.8		3.45	
F441	Sch. 80	CPVC4120	23447	23	93.3	13.8		3.45	
F442	SDR-PR	CPVC4120	23447	23	93.3	13.8	11.3	3.45	
D3309	SDR11	PB2110		23	93.3	6.9		3.45	
D2220		DE1 40 4		22					
D2239	SIDR-PR	PE1404	• • •	23	• • •	2.76	• • •	• • •	• • •
D2239	SIDR-PR	PE2305	• • •	23	• • •	3.45	• • •	• • •	• • •
D2239	SIDR-PR	PE2306	• • •	23	• • •	4.34	• • •	• • •	• • •
D2239	SIDR-PR	PE2406	• • •	23	• • •	4.34			• • •
D2239	SIDR-PR	PE3306		23		4.34			
D2239	SIDR-PR	PE3406		23		4.34			
D2239	SIDR-PR	PE3408	• • •	23	• • •	5.51		• • •	
D2447	Sch. 40 and 80	PE1404		23		2.76			
D2447	Sch. 40 and 80	PE2305		23		3.45			
D2447	Sch. 40 and 80	PE2306		23		4.34			
D2447	Sch. 40 and 80	PE2406		23		4.34			
D2447	Sch. 40 and 80	PE3306		23		4.34			
D2447	Sch. 40 and 80	PE3406		23	•••	4.34			
D2737	SDR7.3, SDR9, SDR11	PE2305		23		3.45			
D2737	SDR7.3, SDR9, SDR11	PE2306		23		4.34			
D2737	SDR7.3, SDR9, SDR11	PE2406		23		4.34			
D2737	SDR7.3, SDR9, SDR11	PE3306		23		4.34			
D2737	SDR7.3, SDR9, SDR11	PE3406		23		4.34		• • •	• • •
	SDR7.3, SDR9, SDR11				• • •		• • •	• • •	• • •
D2737	30K7.3, 30K9, 30K11	PE3408	• • •	23	• • •	5.51	• • •	•••	• • •
D3035	DR-PR	PE1404		23		2.76			
D3035	DR-PR	PE2606		23		4.34			
D3035	DR-PR	PE2708		23		5.51			
D3035	DR-PR	PE3608	• • •	23	• • •	5.51		• • •	
D3035	DR-PR	PE3708		23		5.51			
D3035	DR-PR	PE3710		23		6.89			
D3035	DR-PR	PE4608		23		5.51			
D3035	DR-PR	PE4708		23		5.51			
D3035	DR-PR	PE4710		23		6.89			
F714	SDR-PR	PE1404		23		2.76			
F714	SDR-PR	PE2606		23		4.34			
F714	SDR-PR	PE2708		23		5.51		• • •	• • •
F714	SDR-PR	PE3608		23		5.51			
F714	SDR-PR	PE3708		23					
			• • •		• • •	5.51		• • •	• • •
F714	SDR-PR	PE3710	• • •	23		6.89	• • •	• • •	• • •
F714	SDR-PR	PE4608	• • •	23	• • •	5.51		• • •	• • •
F714	SDR-PR	PE4708	• • •	23	• • •	5.51		• • •	• • •
F714	SDR-PR	PE4710		23		6.89			

Table B-1M Hydrostatic Design Stresses (HDS) and Recommended Temperature Limits for Thermoplastic Pipe (SI Units) (Cont'd)

				Temp	mended erature ts, °C	Hydrostatic Design Stress, MPa						
ASTM		Material	Cell		(1), (2)]	23°C						
Spec. No.	Pipe Designation	Designation	Class	Minimum	Maximum	[Note (3)]	38°C	82°C	93°C			
F2788/F2788M	SDR/DR-PR	PEX0006		-50	110	4.34		2.76	2.17			
F2788/F2788M	SDR/DR-PR	PEX0008		-50	110	5.51		2.76	2.17			
F2389	SDR6, SDR7.3, SDR11	PP		-18	99	4.34	3.45	1.38				
D1785	Sch. 40, 80, 120	PVC1120	12454	23		13.8						
D1785	Sch. 40, 80, 120	PVC1220	12454	23		13.8						
D1785	Sch. 40, 80, 120	PVC2120	14333	23		13.8						
D1785	Sch. 40, 80, 120	PVC2116	14333	23		11.0						
D1785	Sch. 40, 80, 120	PVC2112	14333	23		8.6						
D1785	Sch. 40, 80, 120	PVC2110	14333	23		6.9						
D2241	PR (SDR series)	PVC1120	12454	23		13.8						
D2241	PR (SDR series)	PVC1220	12454	23		13.8						
D2241	PR (SDR series)	PVC2120	14333	23		13.8						
D2241	PR (SDR series)	PVC2116	14333	23		11.0						
D2241	PR (SDR series)	PVC2112	14333	23		8.6						
D2241	PR (SDR series)	PVC2110	14333	23		6.9						

NOTES:

- (1) These recommended limits are for low pressure applications with water and other fluids that do not significantly affect the properties of the thermoplastic. The upper temperature limits are reduced at higher pressures, depending on the combination of fluid and expected service life. Lower temperature limits are affected more by the environment, safeguarding, and installation conditions than by strength.
- (2) These recommended limits apply only to materials listed. Manufacturers should be consulted for temperature limits on specific types and kinds of materials not listed.
- (3) Use these hydrostatic design stress (HDS) values at all lower temperatures.

Table B-2 Listed Specifications for Laminated Reinforced Thermosetting Resin Pipe

Spec. No.	
ASTM C582	

GENERAL NOTE: The intent of listing in this Table is to include all the types, grades, classes, and hydrostatic design bases in the listed specifications.

Table B-3 Listed Specifications for Filament Wound and Centrifugally Cast Reinforced Thermosetting Resin and Reinforced Plastic Mortar Pipe

	Spec. Nos. (ASTM Except as Noted)										
D2517	D2997	D3754									
D2996	D3517	AWWA C950									

GENERAL NOTE: The intent of listing in this Table is to include all the types, grades, classes, and hydrostatic design bases in the listed specifications.

Table B-4 Allowable Pressures and Recommended Temperature Limits for Concrete Pipe

			Allowabl	е Сабе	Т		ommended e Limits [Note (1)]		
			Press	•	Minimum		Maximum		
Spec. No.	Material	Class	kPa	psi	°C	°F	°C	°F	
ASTM C361	Reinforced concrete	25	69	10					
		50	138	20					
		75	205	30					
		100	275	40					
		125	345	50	• • •	• • •	• • •		
AWWA C300	Reinforced concrete	•••	1 795	260			• • •		
AWWA C301	Reinforced concrete	Lined cylinder	1 725	250			•••		
		Embedded cylinder	2 415	350	• • •	•••	• • •	•••	
AWWA C302	Reinforced concrete		310	45					

NOTE

Table B-5 Allowable Pressures and Recommended Temperature Limits for Borosilicate Glass Pipe

				Allov	vable	Т		nmended Limits [Note	(1)]	
ASTM Spec.	Spec.	Size F	Range		ressure	Min	mum	Maximum		
No.	Material	DN	NPS	kPa	psi	°C	°F	°C	°F	
C599	Borosilicate glass	8-15	1/4-1/2	690	100			232	450	
		20	3/4	515	75			232	450	
		25-80	1-3	345	50			232	450	
		100	4	240	35			232	450	
		150	6	138	20			232	450	

NOTE:

⁽¹⁾ These recommended limits apply only to materials listed. Manufacturers should be consulted for temperature limits on specific types and kinds of materials not listed.

⁽¹⁾ These recommended limits apply only to materials listed. Manufacturers should be consulted for temperature limits on specific types and kinds of materials not listed.

Table B-6 Allowable Pressures and Recommended Temperature Limits for PEX-AL-PEX and PE-AL-PE Pipe

ASTM		Size Ra	nge	Allowabl Press	•	Maximum Temperature Limits [Note (1)]		
Spec. No.	Material	mm	in.	kPa	psi	°C	°F	
F1281	PEX-AL-PEX	9.12-60.75	$\frac{3}{8}-2\frac{1}{2}$	1 379	200	23	73.4	
				1 103	160	60	140	
				862	125	82.2	180	
F1282	PE-AL-PE	9.12-60.75	$\frac{3}{8}-2\frac{1}{2}$	1 379	200	23	73.4	
				1 103	160	60	140	
				862	100	82.2	180	
F1974	Metal insert fittings for PEX-AL-PEX systems	12.16-25.32	1/2-1	862	125	82	180	
	Metal insert fittings for	12.16-25.32	1/2-1	1 103	160	60	140	
	PE-AL-PE systems			862	125	82	180	

NOTE

⁽¹⁾ These recommended limits apply only to materials listed. Manufacturers should be consulted for temperature limits on specific types and kinds of materials not listed.

APPENDIX C PHYSICAL PROPERTIES OF PIPING MATERIALS

Begins on the next page.

A = Mean Coefficient of Thermal Expansion, 10⁻⁶in./in./oF

B = Linear Thermal Expansion, in./100 ft

in Going From 70°F to Indicated Temperature [Note (1)]

ASME B31.3-2016

	Coef-								Tempera	ture Ra	inge 70°	F to						
Material	ficient	-325	-150	-50	70	200	300	400	500	600	700	800	900	1,000	1,100	1,200	1,300	1,400
Group 1 carbon and low alloy	Α	5.5	5.9	6.2	6.4	6.7	6.9	7.1	7.3	7.4	7.6	7.8	7.9	8.1	8.2	8.3	8.4	8.4
steels [Note (2)]	В	-2.6	-1.6	-0.9	0	1.0	1.9	2.8	3.7	4.7	5.7	6.8	7.9	9.0	10.1	11.3	12.4	14.7
Group 2 low alloy steels [Note (3)]	Α	6.0	6.5	6.7	7.0	7.3	7.4	7.6	7.7	7.8	7.9	8.0	8.1	8.2	8.3	8.4	8.4	8.5
	В	-2.9	-1.7	-1.0	0	1.1	2.0	3.0	4.0	5.0	6.0	7.0	8.1	9.2	10.3	11.4	12.5	13.5
5Cr-1Mo steels	Α	5.6	6.0	6.2	6.4	6.7	6.9	7.0	7.1	7.2	7.2	7.3	7.4	7.5	7.6	7.6	7.7	7.8
	В	-2.7	-1.6	-0.9	0	1.0	1.9	2.8	3.7	4.6	5.5	6.4	7.4	8.4	9.3	10.3	11.4	12.4
9Cr-1Mo steels	Α	5.0	5.4	5.6	5.8	6.0	6.2	6.3	6.4	6.5	6.6	6.7	6.8	6.9	7.0	7.1	7.2	7.2
	В	-2.4	-1.4	-0.8	0	0.9	1.7	2.5	3.3	4.1	5.0	5.9	6.8	7.7	8.7	9.7	10.6	11.6
Straight chromium stainless steels																		
12Cr to 13Cr steels	Α	5.1	5.5	5.7	5.9	6.2	6.3	6.4	6.5	6.5	6.6	6.7	6.7	6.8	6.8	6.9	6.9	7.0
	В	-2.4	-1.5	-0.8	0	1.0	1.7	2.5	3.3	4.2	5.0	5.8	6.7	7.6	8.5	9.4	10.2	11.1
15Cr to 17Cr steels	Α	4.5	4.9	5.1	5.3	5.5	5.7	5.8	5.9	6.0	6.1	6.2	6.2	6.3	6.4	6.4	6.5	6.5
	В	-2.1	-1.3	-0.7	0	0.9	1.6	2.3	3.0	3.8	4.6	5.4	6.2	7.0	7.9	8.7	9.5	10.4
27Cr steels	Α	4.3	4.7	4.9	5.0	5.2	5.2	5.3	5.4	5.4	5.5	5.6	5.7	5.7	5.8	5.9	5.9	6.0
	В	-2.0	-1.2	-0.7	0	8.0	1.4	2.1	2.8	3.5	4.2	4.9	5.6	6.4	7.2	8.0	8.7	9.6
Austenitic stainless steels (304,	Α	7.5	8.0	8.2	8.5	8.9	9.2	9.5	9.7	9.9	10.0	10.1	10.2	10.3	10.4	10.6	10.7	10.8
305, 316, 317, 321, 347, 348 19-9DL, XM-15, etc.)	В	-3.6	-2.1	-1.2	0	1.4	2.5	3.8	5.0	6.3	7.5	8.8	10.2	11.5	12.9	14.3	15.8	17.2
Other austenitic stainless steels	Α	7.1	7.6	7.8	8.2	8.5	8.7	8.9	9.1	9.2	9.3	9.4	9.5	9.6	9.7	9.8	9.9	10.1
(309, 310, 315, XM-19, etc.)	В	-3.4	-2.0	-1.1	0	1.3	2.4	3.5	4.7	5.8	7.0	8.2	9.5	10.7	12.0	13.3	14.7	16.1
Gray iron	Α					5.8	5.9	6.1	6.3	6.5	6.7	6.8	7.0	7.2				
	В	• • •	• • •	• • •	0	0.9	1.6	2.4	3.2	4.1	5.0	6.0	7.0	8.0	• • •	• • •	• • •	• • •
Ductile cast iron	Α		4.9	5.3	5.7	6.0	6.3	6.6	6.8	7.0	7.1	7.3	7.4	7.5				
	В		-1.3	-0.8	0	0.9	1.7	2.6	3.5	4.5	5.4	6.4	7.3	8.4				

Table C-1 Thermal Expansion Data (Cont'd)

 $A = \text{Mean Coefficient of Thermal Expansion, } 10^{-6} \text{in./in./oF}$

B = Linear Thermal Expansion, in./100 ft

in Going From 70°F to Indicated Temperature [Note (1)]

	Coef-								Tempera	ature Ra	ange 70	°F to						
Material	ficient	-325	-150	-50	70	200	300	400	500	600	700	800	900	1,000	1,100	1,200	1,300	1,400
Monel (67Ni-30Cu) N04400	A B	5.8 -2.7	6.8 -1.8	7.2 -1.0	7.7 0	8.1 1.3	8.3 2.3	8.5 3.4	8.7 4.5	8.8 5.6	8.9 6.7	8.9 7.8	9.0 9.0	9.1 10.1	9.1 11.3	9.2 12.4	9.2 13.6	9.3 14.8
Nickel alloys N02200 and N02201	A B	5.3 -2.7	6.0 -1.7	6.3 -1.0	6.6 0	7.2 1.1	7.5 2.1	7.7 3.1	7.9 4.1	8.0 5.1	8.2 6.2	8.3 7.3	8.4 8.4	8.5 9.5	8.6 10.7	8.7 11.8	8.8 13.0	8.9 14.2
Nickel alloy N06022	A B				6.9 0	6.9 1.1	6.9 1.9	6.9 2.7	7.0 3.6	7.0 4.5	7.2 5.4	7.3 6.4	7.5 7.5	7.7 8.6	7.9 9.8	8.1 11.0	8.3 12.2	8.5 13.6
Nickel alloy N06600	A B	5.5 -2.6	6.1 -1.6	6.4 -0.9	6.8 0	7.1 1.1	7.3 2.0	7.5 3.0	7.6 3.9	7.8 5.0	7.9 6.0	8.0 7.0	8.2 8.1	8.3 9.3	8.4 10.4	8.6 11.6	8.7 12.9	8.9 14.2
Nickel alloy N06625	A B				6.7 0	7.1 1.1	7.2 2.0	7.3 2.9	7.4 3.8	7.4 4.7	7.5 5.6	7.6 6.6	7.7 7.7	7.9 8.8	8.0 9.9	8.2 11.1	8.4 12.3	8.5 13.6
Nickel alloys N08800 and N08810	A B	5.9 -2.8	6.9 -1.7	7.4 -1.1	7.9 0	8.4 1.3	8.6 2.4	8.8 3.5	8.9 4.6	9.0 5.7	9.1 6.9	9.2 8.1	9.3 9.3	9.4 10.5	9.5 11.8	9.6 13.0	9.7 14.4	9.8 15.7
Nickel alloy N08825	A B			7.2 -1.0	7.5 0	7.7 1.2	7.9 2.2	8.0 3.2	8.1 4.2	8.2 5.2	8.3 6.3	8.4 7.4	8.5 8.5	8.6 9.6				
Nickel alloy N10276	A B				6.0 0	6.3 1.0	6.5 1.8	6.7 2.7	6.9 3.6	7.1 4.5	7.2 5.5	7.4 6.4	7.5 7.5	7.6 8.5	7.7 9.5	7.8 10.6	7.9 11.7	8.0 12.8
Copper alloys C1XXXX series	A B	7.7 -3.7	8.7 -2.3	9.0 -1.3	9.3 0	9.6 1.5	9.7 2.7	9.8 3.9	9.9 5.1	10.0 6.4								
Bronze alloys	A B	8.4 -4.0	8.8 -2.3	9.2 -1.3	9.6 0	10.0 1.6	10.1 2.8	10.2 4.0	10.3 5.3	10.4 6.6	10.5 8.0	10.6 9.3	10.7 10.7	10.8 12.1	10.9 13.5	11.0 14.9		
Brass alloys	A B	8.2 -3.9	8.5 -2.2	9.0 -1.3	9.3 0	9.8 1.5	10.0 2.8	10.2 4.1	10.5 5.4	10.7 6.8	10.9 8.2	11.2 9.8	11.4 11.4	11.6 13.0	11.9 14.7	12.1 16.4		
Copper-nickel (70Cu-30Ni)	A B	6.7 -3.2	7.4 -2.0	7.8 -1.1	8.1 0	8.5 1.3	8.7 2.4	8.9 3.5	9.1 4.7	9.2 5.8	9.2 7.0							
Aluminum alloys	A B	9.9 -4.7	10.9 -2.9	11.6 -1.7	12.1 0	13.0 2.0	13.3 3.7	13.6 5.4	13.9 7.2	14.2 9.0								
Titanium alloys (Grades 1, 2, 3, 7, and 12)	A B			4.5 -0.6	4.6 0	4.7 0.7	4.8 1.3	4.8 1.9	4.9 2.5	4.9 3.1	5.0 3.8	5.1 4.5						

Table C-1 Thermal Expansion Data (Cont'd)

NOTES:

- (1) These data are for information and it is not to be implied that materials are suitable for all the temperature ranges shown.
- (2) Group 1 alloys (by nominal composition):

```
2<sup>1</sup>/<sub>4</sub>Cr–1Mo
3Cr–1Mo
  Carbon steels
          (C, C-Si, C-Mn, and C-Mn-Si)
  C - \frac{1}{2}Mo
                                                                                                                                                                        ^{1}/_{2}Ni-^{1}/_{2}Mo-V
  \frac{1}{2}Cr - \frac{1}{5}Mo - V
                                                                                                                                                                       \frac{1}{2}Ni-\frac{1}{2}Cr-\frac{1}{4}Mo-V
  \frac{1}{2}Cr-\frac{1}{4}Mo-Si
                                                                                                                                                                       \frac{3}{4}Ni-\frac{1}{2}Mo-Cr-V
  \frac{1}{2}Cr-\frac{1}{2}Mo
                                                                                                                                                                       ^{3}/_{4}Ni-^{1}/_{2}Mo-^{1}/_{3}Cr-V
  \frac{1}{2}Cr-\frac{1}{2}Ni-\frac{1}{4}Mo
                                                                                                                                                                       ^{3}/_{4}Ni-^{1}/_{2}Cu-Mo
7<sub>2</sub>Cr-7<sub>2</sub>Ni-7<sub>4</sub>Mo
3/<sub>4</sub>Cr-1/<sub>2</sub>Ni-Cu
3/<sub>4</sub>Cr-3/<sub>4</sub>Ni-Cu-Al
1Cr-1/<sub>5</sub>Mo
1Cr-1/<sub>5</sub>Mo-Si
1Cr-1/<sub>2</sub>Mo-V
11/<sub>5</sub>-1/<sub>4</sub>Mo-V
                                                                                                                                                                     <sup>3</sup>/<sub>4</sub>Ni-<sup>1</sup>/<sub>2</sub>Cr-<sup>1</sup>/<sub>2</sub>Mo-V

<sup>3</sup>/<sub>4</sub>Ni-1Mo-<sup>3</sup>/<sub>4</sub>Cr

1Ni-<sup>1</sup>/<sub>2</sub>Cr-<sup>1</sup>/<sub>2</sub>Mo

1<sup>1</sup>/<sub>4</sub>Ni-1Cr-<sup>1</sup>/<sub>2</sub>Mo
                                                                                                                                                                     1<sup>3</sup>/<sub>4</sub>Ni-<sup>3</sup>/<sub>4</sub>Cr-<sup>1</sup>/<sub>4</sub>Mo
2Ni-<sup>3</sup>/<sub>4</sub>Cr-<sup>1</sup>/<sub>4</sub>Mo
2Ni-<sup>3</sup>/<sub>4</sub>Cr-<sup>1</sup>/<sub>3</sub>Mo
 1\frac{1}{4}Cr - \frac{1}{2}Mo

1\frac{1}{4}Cr - \frac{1}{2}Mo - Si
                                                                                                                                                                      2^{1}/_{2}Ni
 1^{3}/_{4}Cr-\frac{1}{2}Mo-Cu
                                                                                                                                                                       3\frac{1}{2}Ni
 2Cr-\frac{1}{2}Mo
                                                                                                                                                                      3\frac{1}{2}Ni-1\frac{3}{4}Cr-\frac{1}{2}Mo-V
```

(3) Group 2 alloys (by nominal composition):

 $\begin{array}{l} Mn-V \\ Mn-\frac{1}{4}Mo \\ Mn-\frac{1}{2}Mo \\ Mn-\frac{1}{2}Mo-\frac{1}{4}Ni \\ Mn-\frac{1}{2}Mo-\frac{1}{2}Ni \\ Mn-\frac{1}{2}Mo-\frac{3}{4}Ni \end{array}$

Table C-2 Thermal Expansion Data (SI Units)

 $A = \text{Mean Coefficient of Thermal Expansion, } 10^{-6} \text{ mm/mm/}^{\circ}\text{C}$ B = Linear Thermal Expansion, mm/m

in Going From 20°C to Indicated Temperature [Note (1)]

·			Temperature Range 20°C to Indicated Temperature [Note (1)]													
Material	Coef- ficient	-200	-100	-50	20	50	75	100	125	150	175	200	225	250	275	
Group 1 carbon and low alloy	A	9.9	10.7	11.1	11.5	11.8	11.9	12.1	12.3	12.4	12.6	12.7	12.9	13.0	13.2	
steels [Note (2)]	В	-2.2	-1.3	-0.8	0	0.4	0.7	1.0	1.3	1.6	2.0	2.3	2.6	3.0	3.4	
Group 2 low alloy steels [Note (3)]	Α	10.8	11.7	12.0	12.6	12.8	13.0	13.1	13.2	13.4	13.5	13.6	13.7	13.8	13.9	
	В	-2.4	-1.4	-0.8	0	0.4	0.7	1.0	1.4	1.7	2.1	2.4	2.8	3.2	3.6	
5Cr-1Mo steels	Α	10.1	10.8	11.2	11.5	11.8	12.0	12.1	12.3	12.4	12.5	12.6	12.6	12.7	12.8	
	В	-2.2	-1.3	-0.8	0	0.4	0.7	1.0	1.3	1.6	1.9	2.3	2.6	2.9	3.3	
9Cr-1Mo steels	A	9.0	9.8	10.1	10.5	10.6	10.7	10.9	11.0	11.1	11.2	11.3	11.4	11.5	11.6	
	В	-2.0	-1.2	-0.7	0	0.3	0.6	0.9	1.2	1.4	1.7	2.0	2.3	2.6	3.0	
Straight chromium stainless steels	4	0.1	0.0	10.2	10.6	10.0	11.0	111	11.2	11 (11 /	11 5	11.6	11.6	11 7	
12Cr to 13Cr steels	A B	9.1 -2.0	9.9 -1.2	10.2 -0.7	10.6 0	10.9 0.3	11.0 0.6	11.1 0.9	11.3	11.4 1.5	11.4 1.8	11.5 2.1	11.6 2.4	11.6 2.7	11.7 3.0	
15Cr to 17Cr steels	Α	8.1	8.8	9.1	9.6	9.7	9.9	10.0	10.1	10.2	10.3	10.4	10.5	10.6	10.7	
1701 10 1701 310013	В	-1.8	-1.1	-0.6	0	0.3	0.5	0.8	1.1	1.3	1.6	1.9	2.2	2.4	2.7	
27Cr steels	Α	7.7	8.5	8.7	9.0	9.2	9.2	9.3	9.4	9.4	9.5	9.5	9.6	9.6	9.7	
2, 6. 5.66.6	В	-1.7	-1.0	-0.6	0	0.3	0.5	0.7	1.0	1.2	1.5	1.7	2.0	2.2	2.5	
Austenitic stainless steels (304,	Α	13.5	14.3	14.7	15.3	15.6	15.9	16.2	16.4	16.6	16.8	17.0	17.2	17.4	17.5	
(305, 316, 317, 321, 347, 348 19-9DL XM-15, etc.)	В	-3.0	-1.7	-1.0	0	0.5	0.9	1.3	1.7	2.2	2.6	3.1	3.5	4.0	4.5	
Other austenitic stainless steels	Α	12.8	13.6	14.1	14.7	15.0	15.2	15.4	15.6	15.7	15.9	16.0	16.1	16.3	16.4	
(309, 310, 315, XM-19, etc.)	В	-2.8	-1.6	-1.0	0	0.4	0.8	1.2	1.6	2.0	2.5	2.9	3.3	3.7	4.2	
Gray iron	Α				9.8	10.1	10.2	10.4	10.5	10.7	10.8	11.0	11.1	11.2	11.4	
	В	• • •	• • •	• • •	0	0.3	0.6	0.8	1.1	1.4	1.7	2.0	2.3	2.6	2.9	
Ductile cast iron	A		8.8	9.5	10.3	10.5	10.7	10.9	11.1	11.3	11.6	11.8	12.0	12.2	12.4	
	В	• • •	-1.1	-0.7	0	0.3	0.6	0.9	1.2	1.5	1.8	2.1	2.5	2.8	3.1	
Monel (67Ni-30Cu) N04400	A B	10.4	12.2	13.0	13.8 0	14.1 0.4	14.4 0.8	14.6 1.2	14.8 1.6	15.0 1.9	15.1 2.3	15.3 2.8	15.4	15.5 3.6	15.6	
	D	-2.3	-1.5	-0.9	U	0.4	0.6	1.2	1.6	1.9	2.3	2.0	3.2	3.0	4.0	
Nickel alloys N02200 and N02201	<i>А</i> В	9.6 -2.2	10.8 -1.4	11.4 -0.8	11.9 0	12.4 0.4	12.7 0.7	13.0 1.0	13.3 1.4	13.5 1.8	13.7 2.1	13.9 2.5	14.0 2.9	14.2 3.3	14.3 3.6	
		2.2	1.7	0.0												
Nickel alloy N06022	A B				12.4 0	12.4 0.4	12.4 0.7	12.4	12.4 1.3	12.4 1.6	12.4 1.9	12.4 2.2	12.5 2.6	12.5 2.9	12.6 3.2	
Nickel allow NOCCOO	Α							12.8								
Nickel alloy N06600	В	9.9 -2.2	10.8 -1.3	11.5 -0.8	12.3 0	12.5 0.4	0.7	1.0	13.0 1.4	1.7	13.3 2.1	13.5 2.4	13.6 2.8	13.7 3.2	13.8 3.5	
Nickel alloy N06625	Α				12.0	12.4	12.6	12.8	12.9	13.0	13.1	13.2	13.2	13.2	13.3	
Weket unoy NOOD25	В				0	0.4	0.7	1.0	1.4	1.7	2.0	2.4	2.7	3.0	3.4	
Nickel alloys N08800 and N08810	Α	10.6	12.5	13.3	14.2	14.6	14.9	15.1	15.3	15.5	15.6	15.8	15.9	16.0	16.1	
,	В	-2.3	-1.5	-0.9	0	0.4	0.8	1.2	1.6	2.0	2.4	2.8	3.3	3.7	4.1	
Nickel alloy N08825	Α			12.9	13.5	13.6	13.7	13.9	14.0	14.2	14.3	14.4	14.4	14.5	14.6	
,	В			-0.9	0	0.4	0.8	1.1	1.5	1.8	2.2	2.6	3.0	3.3	3.7	
Nickel alloy N10276	Α				10.8	11.0	11.2	11.4	11.6	11.7	11.9	12.0	12.2	12.4	12.5	
	В				0	0.3	0.6	0.9	1.2	1.5	1.8	2.2	2.5	2.8	3.2	

Table C-2 Thermal Expansion Data (SI Units)

 $A = \text{Mean Coefficient of Thermal Expansion, } 10^{-6} \text{mm/mm/}^{\circ}\text{C}$ B = Linear Thermal Expansion, mm/m

in Going From 20°C to Indicated Temperature [Note (1)]

	B =	Linear	Therma	al Expa	nsion,	mm/m				j	in	Going	From 2	0°C to	Indicat	ed Ten	ıperatu	ire [Not	ie (1)]	
								Ten	peratu	re Ran	ge 20°	C to								
300	325	350	375	400	425	450	475	500	525	550	575	600	625	650	675	700	725	750	775	800
13.3 3.7	13.4 4.1	13.6 4.5	13.7 4.9	13.8 5.3	14.0 5.7	14.1 6.1	14.2 6.5	14.4 6.9	14.5 7.3	14.6 7.7	14.7 8.2	14.8 8.6	14.9 9.0	15.0 9.4					15.3 11.6	
14.0 3.9	14.1 4.3	14.2 4.7	14.3 5.1	14.4 5.5	14.5 5.9	14.6 6.3	14.6 6.7	14.7 7.1	14.8 7.5	14.8 7.9	14.9 8.3	15.0 8.7	15.0 9.1	15.1 9.5					15.3 11.1	
12.8 3.6	12.9 3.9	13.0 4.3	13.0 4.6	13.1 5.0	13.2 5.3	13.2 5.7	13.3 6.1	13.4 6.4	13.4 6.8	13.5 7.2	13.6 7.5	13.6 7.9	13.7 8.3	13.7 8.7	13.8 9.0	13.9 9.4	13.9 9.8	14.0 10.2	14.0 10.6	14.1 11.0
11.7 3.3	11.8 3.6	11.9 3.9	11.9 4.2	12.0 4.6	12.1 4.9	12.2 5.2	12.3 5.6	12.3 5.9	12.4 6.3	12.5 6.6	12.6 7.0	12.7 7.3	12.7 7.7	12.8 8.1	12.9 8.5	13.0 8.9	13.1 9.3	13.3 9.7	13.4 10.1	13.6 10.6
11.7 3.3	11.8 3.6	11.8 3.9	11.9 4.2	11.9 4.5	12.0 4.9	12.0 5.2	12.1 5.5	12.1 5.8	12.2 6.2	12.2 6.5	12.3 6.8	12.3 7.2	12.4 7.5	12.4 7.8	12.5 8.2	12.5 8.5	12.5 8.8	12.5 9.2	12.6 9.5	12.6 9.8
10.8 3.0	10.8 3.3	10.9 3.6	11.0 3.9	11.0 4.2	11.1 4.5	11.2 4.8	11.2 5.1	11.3 5.4	11.3 5.7	11.4 6.0	11.4 6.3	11.5 6.6	11.5 7.0	11.5 7.3	11.6 7.6	11.6 7.9	11.7 8.2	11.7 8.6	11.8 8.9	11.9 9.3
9.7 2.7	9.8 3.0	9.9 3.3	9.9 3.5	10.0 3.8	10.0 4.1	10.1 4.3	10.2 4.6	10.2 4.9	10.3 5.2	10.4 5.5	10.4 5.8	10.5 6.1	10.5 6.4	10.6 6.7	10.6 7.0	10.7 7.2	10.7 7.6	10.8 7.9	10.8 8.2	10.9 8.5
17.7 4.9	17.8 5.4	17.9 5.9	18.0 6.4	18.1 6.9	18.2 7.4	18.3 7.9	18.4 8.3	18.4 8.9	18.5 9.4		18.7 10.4									19.4 15.2
16.5 4.6	16.6 5.0	16.6 5.5	16.7 5.9	16.8 6.4	16.9 6.8	17.0 7.3	17.1 7.8	17.2 8.2	17.2 8.7	17.3 9.2	17.4 9.7		17.6 10.6						18.2 13.7	
11.5 3.2	11.7 3.6	11.8 3.9	12.0 4.2	12.1 4.6	12.3 5.0	12.4 5.3	12.6 5.7	12.7 6.1	12.9 6.5	13.0 6.9										
12.5 3.5	12.6 3.9	12.8 4.2	12.9 4.6	13.0 4.9	13.1 5.3	13.2 5.7	13.2 6.0	13.3 6.4	13.4 6.8	13.5 7.2										
15.7 4.4	15.8 4.8	15.9 5.2	16.0 5.7	16.0 6.1	16.1 6.5	16.1 6.9	16.2 7.4	16.2 7.8	16.3 8.2	16.3 8.6	16.4 9.1	16.4 9.5		16.5 10.4	16.5 10.8		16.6 11.7	16.7 12.2	16.7 12.6	16.8 13.1
14.4 4.0	14.5 4.4	14.6 4.8	14.7 5.2	14.8 5.6	14.9 6.0	15.0 6.5	15.1 6.9	15.2 7.3	15.3 7.7	15.4 8.2	15.5 8.6	15.6 9.0	15.6 9.5						16.1 12.2	
	12.7 3.9			13.0 5.0			13.5 6.1				14.1 7.8									
14.0 3.9	14.1 4.3	14.2 4.7	14.3 5.1	14.4 5.5	14.5 5.9	14.6 6.3					15.1 8.4									
13.3 3.7	13.3 4.1	13.4 4.4	13.5 4.8	13.5 5.1	13.6 5.5	13.7 5.9	13.8 6.3	14.0 6.7		14.2 7.5	14.3 8.0	14.5 8.4							15.4 11.6	
16.2 4.5	16.3 5.0	16.4 5.4	16.5 5.8	16.5 6.3		16.7 7.2	16.8 7.6	16.8 8.1			17.1 9.5								17.8 13.4	
14.7 4.1	14.8 4.5	14.9 4.9	15.0 5.3		15.1 6.1	15.2 6.5	15.3 7.0	15.4 7.4												
12.6 3.5	12.8 3.9	12.9 4.3	13.0 4.6	13.1 5.0	13.2 5.4	13.3 5.7	13.4 6.1	13.5 6.5	13.6 6.9		13.8 7.7	13.9 8.1		14.1 8.9	14.2 9.3				14.5 10.9	

Table C-2 Thermal Expansion Data (SI Units) (Cont'd)

 $A = \text{Mean Coefficient of Thermal Expansion, } 10^{-6} \, \text{mm/mm/°C}$ B = Linear Thermal Expansion, mm/m

in Going From 20°C to Indicated Temperature [Note (1)]

	Coef-					Т	emper	ature R	ange 2	20°C to					
Material	ficient	-200	-100	-50	20	50	75	100	125	150	175	200	225	250	275
Copper alloys C1XXXX series	Α	13.9	15.7	16.2	16.7	17.0	17.2	17.3	17.4	17.5	17.6	17.7	17.8	17.8	17.9
	В	-3.1	-1.9	-1.1	0	0.5	0.9	1.4	1.8	2.3	2.7	3.2	3.6	4.1	4.6
Bronze alloys	Α	15.1	15.8	16.4	17.2	17.6	17.9	18.0	18.2	18.2	18.3	18.4	18.5	18.5	18.6
	В	-3.3	-1.9	-1.1	0	0.5	1.0	1.4	1.9	2.4	2.8	3.3	3.8	4.3	4.7
Brass alloys	Α	14.7	15.4	16.0	16.7	17.1	17.4	17.6	17.8	18.0	18.2	18.4	18.6	18.8	19.0
	В	-3.2	-1.9	-1.1	0	0.5	1.0	1.4	1.9	2.3	2.8	3.3	3.8	4.3	4.8
Copper-nickel (70Cu-30Ni)	Α	11.9	13.4	14.0	14.5	14.9	15.2	15.3	15.5	15.7	15.8	16.0	16.1	16.3	16.4
	В	-2.6	-1.6	-1.0	0	0.4	0.8	1.2	1.6	2.0	2.5	2.9	3.3	3.7	4.2
Aluminum alloys	Α	18.0	19.7	20.8	21.7	22.6	23.1	23.4	23.7	23.9	24.2	24.4	24.7	25.0	25.2
·	В	-4.0	-2.4	-1.5	0	0.7	1.3	1.9	2.5	3.1	3.7	4.4	5.1	5.7	6.4
Titanium alloys (Grades 1, 2, 3, 7,	Α			8.2	8.3	8.4	8.5	8.5	8.6	8.6	8.6	8.7	8.7	8.7	8.8
and 12)	В			-0.6	0	0.3	0.5	0.7	0.9	1.1	1.3	1.6	1.8	2.0	2.2

NOTES:

- (1) These data are for information and it is not to be implied that materials are suitable for all the temperature ranges shown.
- (2) Group 1 alloys (by nominal composition):

Carbon steels (C, C-Si, C-Mn, and C-Mn-Si)	2 ¹ / ₄ Cr–1Mo 3Cr–1Mo
C-\frac{1}{2}Mo	¹ / ₂ Ni- ¹ / ₂ Mo-V
¹ / ₂ Cr- ¹ / ₅ Mo-V	¹ / ₂ Ni- ¹ / ₂ Cr- ¹ / ₄ Mo-V
$\frac{1}{2}$ Cr $-\frac{1}{4}$ Mo $-$ Si	$\frac{3}{4}$ Ni $-\frac{1}{2}$ Mo-Cr-V
$\frac{1}{2}$ Cr $-\frac{1}{2}$ Mo	$^{3}/_{4}Ni-^{1}/_{2}Mo-^{1}/_{3}Cr-V$
$^{1}/_{2}$ Cr $-^{1}/_{2}$ Ni $-^{1}/_{4}$ Mo	$\frac{3}{4}$ Ni $-\frac{1}{2}$ Cu $-$ Mo
$\frac{3}{4}$ Cr $-\frac{1}{2}$ Ni $-$ Cu	$^{3}/_{4}$ Ni $-^{1}/_{2}$ Cr $-^{1}/_{2}$ Mo $-$ V
³ / ₄ Cr– ³ / ₄ Ni–Cu–Al	³⁄₄Ni−1Mo−³∕₄Cr
1Cr- ¹ / ₅ Mo	$1 \text{Ni} - \frac{1}{2} \text{Cr} - \frac{1}{2} \text{Mo}$
1Cr− ¹ / ₅ Mo−Si	$1\frac{1}{4}$ Ni-1Cr- $\frac{1}{2}$ Mo
$1Cr-\frac{1}{2}Mo$	$1^{3}/_{4}Ni-^{3}/_{4}Cr-^{1}/_{4}Mo$
$1Cr-\frac{1}{2}Mo-V$	$2Ni-\frac{3}{4}Cr-\frac{1}{4}Mo$
$1\frac{1}{4}Cr - \frac{1}{2}Mo$	$2Ni-\frac{3}{4}Cr-\frac{1}{3}Mo$
$1\frac{1}{4}Cr - \frac{1}{2}Mo - Si$	$2\frac{1}{2}$ Ni
$1\frac{3}{4}$ Cr $-\frac{1}{2}$ Mo $-$ Cu	3½Ni
$2Cr-\frac{1}{2}Mo$	$3\frac{1}{2}$ Ni- $1\frac{3}{4}$ Cr- $\frac{1}{2}$ Mo-V

(3) Group 2 alloys (by nominal composition):

 $\begin{array}{l} Mn-V \\ Mn-\frac{1}{4}Mo \\ Mn-\frac{1}{2}Mo \\ Mn-\frac{1}{2}Mo-\frac{1}{4}Ni \\ Mn-\frac{1}{2}Mo-\frac{1}{2}Ni \\ Mn-\frac{1}{2}Mo-\frac{3}{4}Ni \end{array}$

Table C-2 Thermal Expansion Data (SI Units) (Cont'd)

 $A = \text{Mean Coefficient of Thermal Expansion, } 10^{-6} \text{mm/mm/}^{\circ}\text{C}$ B = Linear Thermal Expansion, mm/min Going From 20°C to Indicated Temperature [Note (1)]

										_										
								Ten	peratu	re Ran	ge 20°	C to								
300	325	350	375	400	425	450	475	500	525	550	575	600	625	650	675	700	725	750	775	800
18.0	18.0																			
5.0	5.5	• • •	• • •	• • •		• • •	• • •	• • •	• • •	• • •	• • •	• • •				• • •		• • •		
18.7	18.8	18.9	19.0	19.0	19.1	19.2	19.3	19.4	19.4	19.5	19.6	19.7	19.7	19.8						
5.2	5.7	6.2	6.7	7.2	7.7	8.3	8.8	9.3	9.8	10.3	10.9	11.4	11.9	12.5						
19.2	19.3	19.5	19.6	19.8	20.1	20.3	20.5	20.7	20.8	21.0	21.2	21.4	21.6	21.8						
5.4	5.9	6.4	7.0	7.5	8.2	8.7	9.3	9.9	10.5	11.1	11.8	12.4	13.1	13.7						
16.5	16.5	16.6	16.6	16.7																
4.6	5.0	5.5	5.9	6.3																
25.5	25.6																			
7.1	7.8																			
8.8	8.8	8.9	8.9	9.0	9.2															
2.5	2.7	2.9	3.2	3.4	3.7															

Table C-5 Thermal Expansion Coefficients, Nonmetals

		Mean Coefficients (Div	vide Table Values by 10 ⁶)	
Material Description	in./in., °F	Range, °F	mm/mm, °C	Range, °C
Thermoplastics				
Acetal AP2012	2		3.6	
Acrylonitrile-butadiene-styrene				
ABS 1208	60		108	
ABS 1210	55	45-55	99	7-13
ABS 1316	40		72	
ABS 2112	40	• • •	72	
Cellulose acetate butyrate				
CAB MH08	80		144	
CAB S004	95	• • •	171	
Chlorinated poly(vinyl chloride)				
CPVC 4120	35	• • •	63	
Polybutylene PB 2110	72		130	
Polyether, chlorinated	45		81	
Polyethylene				
PE2606	100	46-100	180	8-38
PE2706	100	46-100	180	8-38
PE3608	90	46-100	162	8-38
PE3708	90	46-100	162	8-38
PE3710	90	46-100	162	8-38
PE4708	80	46-100	144	8-38
PE4710	80	46–100	144	8–38
Cross-linked polyethylene				
PEX0006	78	-58 to 212	140	-50 to 100
PEX0008	78	-58 to 212	140	-50 to 100
Polyphenylene POP 2125	30		54	
Polypropylene				
PP1110	48	33-67	86	1-19
PP1208	43		77	
PP2105	40		72	
PP0210B44002	80		144	
PP0210G07G11030	19	•••	35	
Poly(vinyl chloride)				
PVC1120	30	23-37	54	−5 to 3
PVC1220	35	34–40	63	1-4
PVC2110	50	• • •	90	• • •
PVC2112	45	• • •	81	
PVC2116	40	37-45	72	3–7
PVC2120	30	• • •	54	• • •
Poly(vinylidene fluoride)	79		142	
Poly(vinylidene chloride)	100	• • •	180	
Polytetrafluoroethylene	55	73–140	99	23-60
Poly(fluorinated ethylenepropylene)	46-58	73–140	83-104	23-60
Poly(perfluoroalkoxy alkane)	67	70-212	121	21–100
Poly(perfluoroalkoxy alkane)	94	212-300	169	100-149
Poly(perfluoroalkoxy alkane)	111	300-408	200	149-209

Table C-5 Thermal Expansion Coefficients, Nonmetals (Cont'd)

		Mean Coefficients (Di	vide Table Values by 10 ⁶)	
Material Description	in./in., °F	Range, °F	mm/mm, °C	Range, °C
Reinforced Thermosetting Resins and Reinforced Plastic Mortars				
Glass-epoxy, centrifugally cast	9–13		16-23.5	
Glass-polyester, centrifugally cast	9-15		16-27	
Glass-polyester, filament-wound	9-11		16-20	
Glass-polyester, hand lay-up	12-15	• • •	21.5-27	
Glass-epoxy, filament-wound	9–13	•••	16-23.5	
Other Nonmetallic Materials				
Borosilicate glass	1.8		3.25	

GENERAL NOTES:

⁽a) For Code references to this Appendix, see para. A319.3.1. These data are for use in the absence of more applicable data. It is the designer's responsibility to verify that materials are suitable for the intended service at the temperatures shown.

⁽b) Individual compounds may vary from the values shown. Consult manufacturer for specific values for products.

Table C-6 Modulus of Elasticity, U.S. Units, for Metals

	E= Modulus of Elasticity, Msi (Millions of psi), at Temperature, °F											
Material	-425	-400	-350	-325	-200	-100	70	200	300	400		
Ferrous Metals												
Gray iron							13.4	13.2	12.9	12.6		
Carbon steels, C ≤ 0.3%	31.9			31.4	30.8	30.2	29.5	28.8	28.3	27.7		
Carbon steels, C > 0.3%	31.7			31.2	30.6	30.0	29.3	28.6	28.1	27.5		
Carbon-moly steels	31.7			31.1	30.5	29.9	29.2	28.5	28.0	27.4		
Nickel steels, Ni 2%–9%	30.1			29.6	29.1	28.5	27.8	27.1	26.7	26.1		
Cr–Mo steels, Cr $\frac{1}{2}$ %–2%	32.1			31.6	31.0	30.4	29.7	29.0	28.5	27.9		
Cr-Mo steels, Cr $2\frac{1}{4}\%$ -3%	33.1			32.6	32.0	31.4	30.6	29.8	29.4	28.8		
Cr-Mo steels, Cr 5%-9%	33.4	• • •	• • •	32.9	32.3	31.7	30.9	30.1	29.7	29.0		
Chromium steels, Cr 12%, 17%, 27%	31.8			31.2	30.7	30.1	29.2	28.5	27.9	27.3		
Austenitic steels (TP304, 310, 316, 321, 347)	30.8	• • •	• • •	30.3	29.7	29.0	28.3	27.6	27.0	26.5		
Copper and Copper Alloys (UNS Nos.)												
Comp. and leaded Sn-bronze (C83600, C92200)				14.8	14.6	14.4	14.0	13.7	13.4	13.2		
Naval and Si-brass, Si- & Al-bronze (C46400, C65500, C95200, C95400)		• • •	• • •	15.9	15.6	15.4	15.0	14.6	14.4	14.1		
Copper (C11000)				16.9	16.6	16.5	16.0	15.6	15.4	15.0		
Copper, red brass, Al-bronze (C10200, C12000,				18.0	17.7	17.5	17.0	16.6	16.3	16.0		
C12200, C12500, C14200, C23000, C61400)												
90Cu-10Ni (C70600)				19.0	18.7	18.5	18.0	17.6	17.3	16.9		
Leaded Ni-bronze				20.1	19.8	19.6	19.0	18.5	18.2	17.9		
80Cu-20Ni (C71000)				21.2	20.8	20.6	20.0	19.5	19.2	18.8		
70Cu-30Ni (C71500)	• • •	• • •	• • •	23.3	22.9	22.7	22.0	21.5	21.1	20.7		
Nickel and Nickel Alloys (UNS Nos.)												
Alloy 400 N04400	28.3			27.8	27.3	26.8	26.0	25.4	25.0	24.7		
Alloy N06035	29.2			29.1	29.0	28.8	28.5	28.1	27.8	27.5		
Alloys N06007, N08320	30.3			29.5	29.2	28.6	27.8	27.1	26.7	26.4		
Alloys N08800, N08810, N06002	31.1			30.5	29.9	29.4	28.5	27.8	27.4	27.1		
Alloys N06455, N10276	32.5			31.6	31.3	30.6	29.8	29.1	28.6	28.3		
Alloys N02200, N02201, N06625	32.7			32.1	31.5	30.9	30.0	29.3	28.8	28.5		
Alloy N06600	33.8			33.2	32.6	31.9	31.0	30.2	29.9	29.5		
Alloy N10001	33.9			33.3	32.7	32.0	31.1	30.3	29.9	29.5		
Alloy N10665	34.2			33.3	33.0	32.3	31.4	30.6	30.1	29.8		
Alloy N10675	• • •	• • •	• • •	33.7	32.9	32.3	31.4	30.7	30.2	29.8		
Unalloyed Titanium												
Grades 1, 2, 3, and 7							15.5	15.0	14.6	14.0		
Zirconium Alloys												
R60702							14.4	14.4	14.4	14.4		
R60705							14.2	14.2	14.2	14.2		

Table C-6 Modulus of Elasticity, U.S. Units, for Metals

	E = Modulus of Elasticity, Msi (Millions of psi), at Temperature, °F										
Material	1500	1400	1300	1200	1100	1000	900	800	700	600	500
Ferrous Metals											
Gray iron								10.2	11.0	11.7	12.2
Carbon steels, $C \le 0.3\%$					18.0	20.4	22.4	24.2	25.5	26.7	27.3
Carbon steels, C > 0.3%				15.4	17.9	20.2	22.2	24.0	25.3	26.5	27.1
Carbon-moly steels				15.3	17.8	20.1	22.2	23.9	25.3	26.4	27.0
Nickel steels, Ni 2%-9%								23.0	24.6	25.2	25.7
Cr–Mo steels, Cr $\frac{1}{2}$ %–2%		18.9	20.5	21.8	23.0	23.9	24.8	25.5	26.3	26.9	27.5
Cr-Mo steels, Cr $2\frac{1}{4}\%-3\%$		19.4	21.1	22.5	23.7	24.6	25.6	26.3	27.1	27.7	28.3
Cr-Mo steels, Cr 5%-9%	• • •	12.7	15.5	18.2	20.4	22.7	24.7	26.1	27.3	28.0	28.6
Chromium steels, Cr 12%, 17%, 27% Austenitic steels (TP304, 310, 316, 321, 347)	 18.1	 19.2	20.2	16.6 21.2	19.1 22.1	21.5 22.8	22.2 23.5	24.7 24.1	25.6 24.8	26.1 25.3	26.7 25.8
Copper and Copper Alloys (UNS Nos.)											
Comp. and leaded Sn-bronze (C83600, C92200)									12.0	12.5	12.9
Naval and Si-brass, Si- & Al-bronze (C46400									12.8	13.4	13.8
C65500, C95200, C95400)	• • •			• • •				• • •	12.0	13.4	15.0
Copper (C11000)									13.7	14.2	14.7
Copper, red brass, Al-bronze (C10200, C12000,									14.5	15.1	15.6
C12200, C12500, C14200, C23000, C61400)											
90Cu-10Ni (C70600)									15.4	16.0	16.6
Leaded Ni-bronze									16.2	16.9	17.5
80Cu-20Ni (C71000)									17.1	17.8	18.4
70Cu-30Ni (C71500)	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	18.8	19.6	20.2
Nickel and Nickel Alloys (UNS Nos.)											
Alloy 400 N04400				21.2	21.7	22.1	22.6	23.1	23.7	24.1	24.3
Alloy N06035	• • •			23.6	24.2	24.8	25.3	25.8	26.3	26.7	27.1
Alloys N06007, N08320				22.7	23.2	23.6	24.2	24.7	25.3	25.7	26.0
Alloys N08800, N08810, N06002				23.2	23.8	24.2	24.8	25.4	25.9	26.4	26.6
Alloys N06455, N10276				24.3	24.9	25.3	25.9	26.5	27.1	27.6	27.9
Alloys N02200, N02201, N06625				24.5	25.1	25.5	26.1	26.7	27.3	27.8	28.1
Alloy N06600				25.3	25.9	26.4	27.0	27.6	28.2	28.7	29.0
Alloy N10001				25.3	26.0	26.4	27.1	27.7	28.3	28.8	29.1
Alloy N10665				25.6	26.2	26.7	27.3	27.9	28.6	29.0	29.4
Alloy N10675	23.4	24.2	24.9	25.6	26.2	26.8	27.4	27.9	28.4	28.9	29.3
Unalloyed Titanium											
Grades 1, 2, 3, and 7								11.2	11.9	12.6	13.3
Glades 1, 2, 3, allu 7	•••	•••	•••	•••	• • •	•••	•••	11.4	11.7	12.0	1,,,
Zirconium Alloys											
R60702								14.4	14.4	14.4	14.4
R60705								14.2	14.2	14.2	14.2

Table C-6 Modulus of Elasticity, U.S. Units, for Metals (Cont'd)

		E = M	odulus o	f Elasticit	y, Msi (N	lillions of	f psi), at	Tempera	300 400									
Material	-425	-400	-350	-325	-200	-100	70	200	300	400								
Aluminum and Aluminum Alloys (UNS Nos.)																		
Grades 443, 1060, 1100, 3003, 3004, 6061, 6063 (A24430, A91060, A91100, A93003, A93004, A96061, A96063)	11.4			11.1	10.8	10.5	10.0	9.6	9.2	8.7								
Grades 5052, 5154, 5454, 5652 (A95052, A95154, A95454, A95652)	11.6	• • •	• • •	11.3	11.0	10.7	10.2	9.7	9.4	8.9								
Grades 356, 5083, 5086, 5456 (A03560, A95083, A95086, A95456)	11.7	• • •	• • •	11.4	11.1	10.8	10.3	9.8	9.5	9.0								

GENERAL NOTES:

- (a) For Code references to this Appendix, see para. 319.3.2. These data are for use in the absence of more applicable data. It is the designer's responsibility to verify that materials are suitable for the intended service at the temperatures shown.
- (b) Table C-7 containing data in SI units is not included at this time. To convert data in U.S. Customary units to SI metric units
 - (1) determine the Fahrenheit equivalent of the given Celsius temperature
 - (2) interpolate to calculate the expansion or modulus value in U.S. units
 - (3) multiply the value in Msi by 6 895 to obtain the modulus of elasticity in MPa at the given temperature

Table C-8 Modulus of Elasticity, Nonmetals

Table C-8	modulus of Elasticity, Nonmetals	
Material Description	<i>E</i> , ksi (73.4°F)	E, MPa (23°C)
Thermoplastics [Note (1)]		
Acetal	410	2 830
ABS, Type 1210	250	1 725
ABS, Type 1316	340	2 345
CAB	120	825
PVC, Type 1120	420	2 895
PVC, Type 1220	410	2 825
PVC, Type 2110	340	2 345
PVC, Type 2116	380	2 620
Chlorinated PVC	420	2 895
Chlorinated polyether	160	1 105
PE2606	100	690
PE2706	100	690
PE3608	125	860
PE3708	125	860
PE3710	125	860
PE4708 PE4710	130	895
PE4/10	130	895
PEX0006	71	440
PEX0008	88	490
Polypropylene	120	825
Poly(vinylidene chloride)	100	690
Poly(vinylidene fluoride)	194	1 340
Poly(tetrafluorethylene)	57	395
Poly(fluorinated ethylenepropylene)	67	460
Poly(perfluoroalkoxy alkane)	100	690
Thermosetting Resins, Axially Reinforced		
Epoxy-glass, centrifugally cast	1,200-1,900	8 275-13 100
Epoxy-glass, filament-wound	1,100-2,000	7 585–13 790
Polyester-glass, centrifugally cast	1,200-1,900	8 275-13 100
Polyester-glass, hand lay-up	800-1,000	5 515–6 895
Other		
Borosilicate glass	9,800	67 570
	· · · · · · · · · · · · · · · · · · ·	

GENERAL NOTE: For Code references to this Appendix, see para. A319.3.2. These data are for use in the absence of more applicable data. It is the designer's responsibility to verify that materials are suitable for the intended service at the temperatures shown.

⁽¹⁾ The modulus of elasticity data shown for thermoplastics are based on short-term tests. The manufacturer should be consulted to obtain values for use under long-term loading.

APPENDIX D FLEXIBILITY AND STRESS INTENSIFICATION FACTORS

See Table D300.

Table D300 Flexibility Factor, k, and Stress Intensification Factor, i

	Flexibility	Stress Inte Factor [Not		Flexibility	
Description	Factor,	Out-of-Plane, i_o	In-Plane, i _i	Characteristic,	Sketch
Welding elbow or pipe bend [Notes (1), (3)–(6)]	1.65 h	$\frac{0.75}{h^{2/3}}$	$\frac{0.9}{h^{2/3}}$	$\frac{\overline{T}R_1}{{r_2}^2}$	\overline{T} $R_1 = \text{bend}$ radius
Closely spaced miter bend $s < r_2 (1 + \tan \theta)$ [Notes (1), (3), (4), (6)]	1.52 h ^{5/6}	$\frac{0.9}{h^{2/3}}$	$\frac{0.9}{h^{2/3}}$	$\frac{\cot \theta}{2} \left(\frac{s\overline{T}}{r_2^2} \right)$	$R_1 = \frac{s \cot \theta}{2}$
Single miter bend or widely spaced miter bend $s \ge r_2 (1 + \tan \theta)$ [Notes (1), (3), (6)]	1.52 h ^{5/6}	$\frac{0.9}{h^{2/3}}$	$\frac{0.9}{h^{2/3}}$	$\frac{1+\cot\theta}{2}\left(\frac{\overline{T}}{r_2}\right)$	$\theta = \frac{\sqrt{\frac{1}{1}} r_2}{\sqrt{1 + \cot \theta}}$
Welding tee in accordance with ASME B16.9 [Notes (1), (3), (5), (7), (8)]	1	$\frac{0.9}{h^{2/3}}$	$^{3}/_{4}i_{o} + ^{1}/_{4}$	$3.1 \frac{\overline{T}}{r_2}$	r_2
Reinforced fabricated tee with pad or saddle [Notes (1), (3), (8), (9), (10)]	1	$\frac{0.9}{h^{2/3}}$	$^{3}/_{4}i_{0}+^{1}/_{4}$	$\frac{(\overline{T} + \frac{1}{2} \overline{T}_r)^{2.5}}{\overline{T}^{1.5} r_2}$	\overline{T}_r Pad Saddle

Table D300 Flexibility Factor, k, and Stress Intensification Factor, i (Cont'd)

	Flexibility	Stress Inte Factor [Note		Flexibility	
Description	Factor,	Out-of-Plane, i _o	In-Plane, i_i	Characteristic,	Sketch
Unreinforced fabricated tee [Notes (1), (3), (8), (10)]	1	$\frac{0.9}{h^{2/3}}$	$^{3}/_{4}i_{o} + ^{1}/_{4}$	$\frac{\overline{T}}{r_2}$	7 ₂
Extruded welding tee with $r_x \ge 0.05 \frac{D_b}{T_c} < 1.5 \frac{T}{T}$ [Notes (1), (3), (8)]	1	$\frac{0.9}{h^{2/3}}$	³ / ₄ i _o + ¹ / ₄	$\left(1+\frac{r_x}{r_2}\right)\frac{\overline{T}}{r_2}$	7c 77 72
Welded-in contour insert [Notes (1), (3), (7), (8)]	1	$\frac{0.9}{h^{2/3}}$	$^{3}/_{4}i_{o} + ^{1}/_{4}$	$3.1 \frac{\overline{T}}{r_2}$	r_{x}
Branch welded-on fitting (integrally reinforced) [Notes (1), (3), (10), (11)]	1	$\frac{0.9}{h^{2/3}}$	$\frac{0.9}{h^{2/3}}$	3.3 $\frac{\overline{T}}{r_2}$	r_2

Description	Flexibility Factor, <i>k</i>	Stress Intensification Factor, <i>i</i>
Butt welded joint, reducer, or weld neck flange	1	1.0
Double-welded slip-on flange	1	1.2
Fillet or socket weld	1	1.3 [Note (12)]
Lap joint flange (with ASME B16.9 lap joint stub)	1	1.6
Threaded pipe joint or threaded flange	1	2.3
Corrugated straight pipe, or corrugated or creased bend [Note (13)]	5	2.5

Table D300 Flexibility Factor, k, and Stress Intensification Factor, i (Cont'd)




Table D300 Flexibility Factor, k, and Stress Intensification Factor, i (Cont'd)

GENERAL NOTE: Stress intensification and flexibility factor data in Table D300 are for use in the absence of more directly applicable data (see para. 319.3.6). Their validity has been demonstrated for $D/\overline{T} \leq 100$. NOTES:

- (1) The flexibility factor, k, in the Table applies to bending in any plane; also see para. 319.3.6. The flexibility factors, k, and stress intensification factors, i, shall apply over the effective arc length (shown by heavy centerlines in the illustrations) for curved and miter bends, and to the intersection point for tees.
- (2) A single intensification factor equal to $0.9/h^{2/3}$ may be used for both i_i and i_o if desired.
- (3) The values of k and i can be read directly from Chart A by entering with the characteristic h computed from the formulas given above. Nomenclature is as follows:

 D_b = outside diameter of branch

 R_1 = bend radius of welding elbow or pipe bend

 r_x = see definition in para. 304.3.4(c)

 r_2 = mean radius of matching pipe

 $\frac{s}{T}$ = miter spacing at centerline $\frac{s}{T}$ = for elbows and miter bends, the nominal wall thickness of the fitting

= for tees, the nominal wall thickness of the matching pipe

 $\frac{T_c}{T_r} = \text{crotch thickness of branch connections measured at the center of the crotch where shown in the illustrations } \frac{T_c}{T_r} = \text{pad or saddle thickness}$

 θ = one-half angle between adjacent miter axes

- (4) Where flanges are attached to one or both ends, the values of k and i in the Table shall be corrected by the factors C_1 , which can be read directly from Chart B, entering with the computed h.
- (5) The designer is cautioned that cast buttwelded fittings may have considerably heavier walls than that of the pipe with which they are used. Large errors may be introduced unless the effect of these greater thicknesses is considered.
- In large diameter thin-wall elbows and bends, pressure can significantly affect the magnitudes of k and i. To correct values from the Table, divide k by

$$1 + 6 \left(\frac{P_j}{E_j} \right) \left(\frac{r_2}{\overline{T}} \right)^{7/3} \left(\frac{R_1}{r_2} \right)^{1/3}$$

divide *i* by

$$1 + 3.25 \left(\frac{P_j}{E_j}\right) \left(\frac{r_2}{\overline{T}}\right)^{5/2} \left(\frac{R_1}{r_2}\right)^{2/3}$$

For consistency, use kPa and mm for SI metric, and psi and in. for U.S. customary notation.

- (7) If $r_x \ge \frac{1}{8} D_h$ and $T_c \ge 1.5 \overline{T}$, a flexibility characteristic of 4.4 \overline{T}/r_2 may be used.
- (8) Stress intensification factors for branch connections are based on tests with at least two diameters of straight run pipe on each side of the branch centerline. More closely loaded branches may require special consideration.
- (9) When \overline{T}_r is $> 1^1/2 \overline{T}$, use $h = 4 \overline{T}/r_2$.
- (10) The out-of-plane stress intensification factor (SIF) for a reducing branch connection with branch-to-run diameter ratio of 0.5 < d / D < 1.0 may be nonconservative. A smooth concave weld contour has been shown to reduce the SIF. Selection of the appropriate SIF is the designer's responsibility.
- (11) The designer must be satisfied that this fabrication has a pressure rating equivalent to straight pipe.
- (12) For welds to socket welded fittings, the stress intensification factor is based on the assumption that the pipe and fitting are matched in accordance with ASME B16.11 and a fillet weld is made between the pipe and fitting as shown in Fig. 328.5.2C. For welds to socket welded flanges, the stress intensification factor is based on the weld geometry shown in Fig. 328.5.2B, illustration (3) and has been shown to envelope the results of the pipe to socket welded fitting tests. Blending the toe of the fillet weld smoothly into the pipe wall, as shown in the concave fillet welds in Fig. 328.5.2A, has been shown to improve the fatigue performance of the weld.
- (13) Factors shown apply to bending. Flexibility factor for torsion equals 0.9.

APPENDIX E REFERENCE STANDARDS

Standards incorporated in this Code by reference, and the names and addresses of the sponsoring organizations, are shown in this Appendix. It is not practical to refer to a specific edition of each standard throughout the Code text; instead, the specific edition reference dates are shown here. Specific edition reference dates are not provided for ASME codes and standards. For ASME codes and standards, the latest published edition in effect at the time this Code is specified is the specific edition referenced by this Code unless otherwise specified in the engineering design. Subsequent issues and revisions of these referenced standards and any new standards incorporated in the Code by reference in Code Addenda will be listed (after review and acceptance by the Code Committee) in revisions of this Appendix E.

A component ordinarily is not marked to indicate the edition date of the standard to which it is manufactured. It is therefore possible that an item taken from inventory was produced in accordance with a superseded edition, or an edition not yet approved by the Code (because it is of later date than that listed and is in use). If compliance with a specific edition is a requirement of the intended service, it usually will be necessary to state the specific requirement in the purchase specification and to maintain identification of the component until it is put in service.

ASTM Specifications	ASTM Specifications (Cont'd)	ASTM Specifications (Cont'd)
A20-96a	A285/A285M-03 (R2007)	A516/A516M-06
A36/A36M-08	A299/A299M-04	A524-96 (R2005)
A47/A47M-99 (R2004)		A530-98
A48/A48M-03 (R2008)	A302/A302M-03 (R2007)	A536-84 (R2014)
	A307-07b	A537/A537M-08
A53/A53M-07	A312/A312M-09	AFF2/AFF2M 04
A405/A405M 00	A320/A320M-10	A553/A553M-06
A105/A105M-09	A325-97	A563-07a
A106/A106M-08	A333/A333M-05	A571/A571M-01 (R2006)
A126-04	A334/A334M-04a	A587-96 (R2005)
A134-96 (R2005)	A335/A335M-06	A645/A645M-05
A135/A135M-06	A350/A350M-07	A671-06
A139/A139M-04		A672-08
1.70 00 (D0005)	A351/A351M-14	A675/A675M-03 (R2009)
A179-90a (R2005)	A352/A352M-06	A691-98 (R2007)
A181/A181M-06	A353/A353M-04	A694/A694M-13
A182/A182M-09a	A354-07a	A696-90a (R2012)
A193/A193M-10a	A358/A358M-08a	• •
A194/A194M-10	A369/A369M-06	A723/A723M-10 (R2015)
A197/A197M-00 (R2006)	A370-11	A789/A789M-10a
1000 (1000 H 07 (D0007)	A376/A376M-06	A790/A790M-11
A203/A203M-97 (R2007)	A381-96 (R2005)	A813/A813M-09
A204/A204M-03 (R2007)	A387/A387M-06a	A814/A814M-08
A210/A210M-02 (R2012)	A395/A395M-99 (R2009)	A814/A814M-08 A815/A815M-10a
A213-09b		A928/A928M-11
A216/A216M-08	A403/A403M-07a	A992-06a
A217/A217M-08	A409/A409M-08a	A995/A995M-13
A234/A234M-07	A420/A420M-07	MJJJJMJJJMI-1J
A240/A240M-11b	A426/A426M-08	A1010/A1010M-01 (R2009)
A249/A249M-08	A437/A437M-10a	A1011/A1011M-10
A263-94a		A1053/A1053M-11
A264-94a	A451/A451M-06	
A265-94a	A453/A453M-12	B21/B21M-06
A268/A268M-05	A479/A479M-11	B26/B26M-09
A260/A266WI-U3 A269-08	A487/A487M-93 (R2007)	B32-08
A269-08 A276-97	A494/A494M-09	B42-02 ^{€1}
A276-97 A278/A278M-01 (R2006)	4500/45004444	B43-98 (R2004)
A278/A278M-01 (R2006) A283/A283M-03 (R2007)	A508/A508M-14	
MZOJ/MZOJIVI-OJ (NZOU/)	A515/A515M-03 (R2007)	

REFERENCE STANDARDS (CONT'D)

ASTM Specifications (Cont'd)	ASTM Specifications (Cont'd)	ASTM Specifications (Cont'd)
B61-08	B466/B466M-07	D2321-08
B62-09	B467-88 (R2003)	D2447-03
B68-02/B68M-99 (R2005)	B474/B474M-15	D2464-06
B75-02/B75M-99 (R2005)	B491/B491M-06	D2466-06
B88-03/B88M-05	B493/B493M-08	D2467-06
B96/B96M-11	B514-05	D2468-96a
B98/B98M-08	B517-05	,_,_
2,0,2,0 00	B523/B523M-07	D2513-09
B127-05	B547/B547M-02	D2517-06
B148-97 (R2009)	B550/B550M-07	D2564-04 ^{€1}
B150/B150M-08	2330/2330M 07	D2609-02 (R2008)
2130/2130 00	B551/B551M-07	D2657-07
B152/B152M-06a ^{€1}	B564-11 ^{€1}	D2662-96a
B160-05 (R2009)	B572-06	D2666-96a
B161-05 ⁶¹	B574-10	D2672-96a (R2003)
B162-99 (R2005) ^{€1}	B575-10	D2683-04
B164-03 (R2008)	B581-02 (R2008)	D2737-03
B165-05	B582-07	02/3/ 03
B166-08	B584-08a	D2837-08
B167-06	B304-00a	D2846/D2846M-09b
B168-08	B619-10 ^{€1}	D2855-96 (R2002)
B169/B169M-05	B620-03 (R2008)	D2992-06
B171/B171M-09	B621-02 (R2006)	D2996-01 (R2007) ^{€1}
B187/B187M-06	B622-10	D2997-01 (R2007)
B10//B10/WI-00	B625-05	D3000-95a
B209-07	B626-10 ^{€1}	D3000-93a
B210-04	B649-06	D3035-08
	B049-00	
B211-03	DCF0/DCF0M OC	D3139-98 (R2005)
B221-08	B658/B658M-06	D3261-03
B241/B241M-02	B668-05 B675-02 (R2007)	D3309-96a (R2002)
B247-02a		D3517-06
B265-09a ^{€1}	B688-96 (R2009)	
	B690-02 (R2007)	D3754-06
B280-08	P705 05 (P2014)	D3839-08
B283/B283M-14a	B705-05 (R2014)	D3840-01 (R2005)
D222 02 (D2000)	B709-04	D4024-05
B333-03 (R2008)	B725-05	
B335-03 (R2008)	B729-05	D4161-01 (R2005)
B336-04b	B804-02 (R2007)	DE (24.05
B338-14	B813-10	D5421-05
B345/B345M-02	B828-02	D5685-05
D2 (4, 00	B861-14	D6041-97 (R2002)
B361-08	B862-08a	F20.42
B363-14	C4 / O7	E29-13
B366-10a	C14-07	E94-04 (R2010)
B371/B371M-08	C301-04	E112-13
B381-09	C361-08	E114-10
D/07.00-	CF02.00	E125-63 (R2013)
B407-08a	C582-09	E155-15
B409-06 ^{£1}	C599-91 (R1995)	E165/E165M-12
B423-05	D4.537.00 (D3005)	E186-15
B424-05	D1527-99 (R2005)	E213-14 ^{£1}
B425-99 (R2005)	D1600-08	E272-15
B435-06	D1694-95 (R2000)	E280-15
B443-00 (R2005)	D1785-06	E310-15
B444-06	D2225 0/	E446-15
B446-03 (R2008)	D2235-04	E709-15
D.((2.40f)	D2239-03	F22 (02 (F2222)
B462-10 ^{€2}	D2241-05	F336-02 (R2009)
B463-04	D2282-99 ⁶	F437-09
B464-05	D2310-06	F438-09

REFERENCE STANDARDS (CONT'D)

ASTM Specifications (Cont'd)	ASME Standards (Cont'd)	AWS Standards (Cont'd)
F439-09	B16.26	A5.8:2004
F441/F441M-09	B16.34	A5.9/A5.9M:2006
F442/F442M-09	B16.36	A5.11/A5.11M:2010
F493-04	B16.39	A5.14/A5.14M:2009
F714-08	B16.42	A5.22:2010
1714-06		A5.31:2001
F1055-98 (R2006)	B16.47	QC1:2007
F1281-03 ⁶¹	B16.48	QC1.2007
F1282-03 ^{<i>c</i>1}	B16.50	ANADAYA SI III II
F1290-98a (R2004)	B18.2.1	AWWA Standards
F1412-09		C110.03
F1498-08	B18.2.2	C110-03
F1545-97 (R2003)	P3/ 40M	C111-07
F1673-04	B36.10M	C115-05
F1970-05	B36.19M	C150/A21.50-08
F1974-04	D// 1	C151/A21.51-04
F2389-07 ^{¢1}	B46.1	C200-05
	BPE	C207-07
F2788/F2788M-13	PCC-1	C208-07
	PCC-2	C300-07
AISC Publication	PTC 19.3 TW	C301-07
		C302-04
325-05 (Steel Construction Manual, 2006)	API Specifications	C500-02
	All Specifications	
ASCE Standard	5B, 2008	C504-06
ASCE Standard	5L, 2009	C606-11
ASCE/SEI 7-10	6D, 2008 with Errata 1–6 and Addenda 1–3	C900-07 and Errata 2008
,,	15LE, 2008	C950-07
1015 C (1) (1 (1 1 1 1 1 1 1 1	15LR, 2001	
ASME Codes (Use Latest Edition)	13LK, 2001	CEN Technical Report
ASME Boiler and Pressure Vessel Code		CLN Technical Report
	API Standards	CEN/TR 14549:2004
Section II, Part D		•
Section III, Division 1	526, 2009	CCA Dublication
Section V	570, 2009	CGA Publication
Section VIII, Division 1	594, 2010	G-4.1-2009
Section VIII, Division 2	599, 2007	d 4.1 200)
Section VIII, Division 3	600, 2009	
Section IX		CSA Publication
	602, 2005	72.45.4.07.(D204.2)
ASME Standards (Use Latest Edition)	603, 2007	Z245.1-07 (R2012)
ASME Standards (OSC Edition)	608, 2008	
A13.1	609, 2009	EJMA Publication
B1.1	•	
B1.20.1	ABI B	EJMA Standards, Tenth Edition, 2015
B1.20.3	API Recommended Practice	
B1.20.7	DD 0/1 5th Ed 1007	ISO Standard
B1.20./	RP 941, 5th Ed., 1997	
B16.1		ISO 15649:2001
B16.3	ASQ Standards	
B16.4		MSS Standard Practices
B16.5	Q9000-1: 1994	M33 Statiuatu Flactices
B16.9	Q9000-2: 1997	SP-6-2007
B16.10	Q9000-3: 1997	SP-9-2008
B16.11	Q9001: 2008	SP-25-2008
B16.14	Q9002: 1994	SP-42-2009
	Q9003: 1994	
B16.15	Q7003: 1774	SP-43-2008
B16.18		SP-44-2006
B16.20	AWS Standards	SP-45-2003 (R2008)
D1 (24	A2 0M/A2 0 2040	SP-51-2007
B16.21	A3.0M/A3.0:2010	SP-53-2012
B16.22	A5.1/A5.1M:2004	SP-55-2011
B16.24	A5.4/A5.4M:2006	SP-58-2002
B16.25	A5.5/A5.5M:2006	SP-65-2008

REFERENCE STANDARDS (CONT'D)

MSS Standard Practices (Cont'd)	MSS Standard Practices (Cont'd)	PFI Standards
SP-70-2006	SP-105-1996 (R2005)	ES-7-2013
SP-71-2005	SP-106-2003	ES-24-2013
SP-72-1999	SP-119-2003	ES-48-2013
SP-75-2008	SP-122-2005	
SP-78-2005a		
SP-79-2004		PPI Technical Report
SP-80-2008	NACE Standards and Publications	
SP-81-2006a		TR-21-2001
SP-83-2006	MR0103-2012	
SP-85-2002	MR0175/ISO 15156-2:2009/Cir.2:2014	
SP-88-1993 (R2001)	MR0175/ISO 15156-3:2009/Cir.4:2014	SAE Specifications
SP-93-2014	SP0170-2012	
SP-95-2006	SP0472-2010	J513-1999
SP-97-2006	37519, Sixth Edition, 1985	J514-2004
		J518-1993
	NFPA Specifications	
	54/Z223.1-2012 1963-2009	

GENERAL NOTE: The issue date shown immediately following the hyphen after the number of the standard (e.g., C207-07 and SP-6-2007) is the effective date of the issue (edition) of the standard. Any additional number shown following the issue date and prefixed by the letter "R" is the latest date of reaffirmation [e.g., A5.22-1995 (R2005)].

Specifications and standards of the following organizations appear in Appendix E:

Brussels, Belgium

+32 2 550 08 11

Compressed Gas Association, Inc.

14501 George Carter Way,

Chantilly, Virginia 20151 (703) 788-2700 www.cganet.com

www.cen.eu

Suite 103

CGA

AISC American Institute of Steel Construction CSA CSA Group 1 East Wacker Drive, Suite 700 178 Rexdale Boulevard Chicago, Illinois 60601-1802 Toronto, Ontario (312) 670-2400 M9W 1R3, Canada (416) 747-4044 or (800) 463-6727 www.aisc.org www.csagroup.org API American Petroleum Institute Publications and Distribution Section EJMA Expansion Joint Manufacturers Association, Inc. 1220 L Street, NW 25 North Broadway Washington, DC 20005-4070 Tarrytown, New York 10591 (202) 682-8375 (914) 332-0040 www.api.org www.ejma.org **ASCE** American Society of Civil Engineers IS₀ International Organization for Standardization 1801 Alexander Bell Drive Central Secretariat Reston, Virginia 20191-4400 Chemin de Blandonnet 8 (800) 548-2723 Case Postale 401 www.asce.org 1214 Vernier, Geneva Switzerland +41 22 749 01 11 **ASME ASME International** Two Park Avenue www.iso.org New York, New York 10016-5990 MSS Manufacturers Standardization Society of the Valve (800) 843-2763 www.asme.org and Fittings Industry, Inc. 127 Park Street, NE ASQ American Society for Quality Vienna, Virginia 22180-4602 (703) 281-6613 P.O. Box 3005 Milwaukee, WI 53201 www.msshq.org (800) 248-1946 www.asq.org NACE **NACE International** 15835 Park Ten Place ASTM American Society for Testing and Materials Houston, Texas 77084-5145 (ASTM International) (281) 228-6200 100 Barr Harbor Drive www.nace.org West Conshohocken, Pennsylvania NFPA National Fire Protection Association 19428-2951 (610) 832-9585 1 Batterymarch Park Quincy, Massachusetts 02169-7471 www.astm.org (617) 770-3000 or (800) 344-3555 **AWWA** American Water Works Association www.nfpa.org 6666 W. Quincy Avenue Denver, Colorado 80235 PFI Pipe Fabrication Institute 655-32nd Avenue, Suite 201 (800) 926-7337 www.awwa.org Lachine, Quebec H8T 3G6 Canada AWS American Welding Society (514) 634-3434 8669 NW 36 Street, No. 130 www.pfi-institute.org Miami, Florida 33166 (800) 443-9353 PPI Plastics Pipe Institute 105 Decker Court, Suite 825 www.aws.org Irving, Texas 75062 CEN European Committee for Standardization (469) 499-1044 Avenue Marnix 17, B-1000 www.plasticpipe.org

SAE

Society of Automotive Engineers

Warrendale, Pennsylvania 15096-0001

(724) 776-4841 or (877) 606-7323

(SAE International) 400 Commonwealth Drive

www.sae.org

SEMI Semiconductor Equipment and Materials International 3081 Zanker Road San Jose, California 95134 (408) 943-6900 www.semi.org

GENERAL NOTE TO LIST OF ORGANIZATIONS: Some of the organizations listed above publish standards that have been approved as American National Standards. Copies of these standards may also be obtained from:

ANSI American National Standards Institute, Inc. 25 West 43rd Street New York, New York 10036 (212) 642-4900 www.ansi.org

(16) APPENDIX F GUIDANCE AND PRECAUTIONARY CONSIDERATIONS

(16) F300 GENERAL

This Appendix provides guidance and precautionary considerations relating to particular fluid services and piping applications. These are not Code requirements but should be taken into account as applicable in the engineering design. Further information on these subjects can be found in the literature.

(16) F300.1 Piping That Has Been Placed in Service

Examples of industry standards that address piping that has been placed in service are ASME PCC-2, Repair of Pressure Equipment and Piping, and API 570, Piping Inspection Code: In-service Inspection, Rating, Repair, and Alteration of Piping Systems.

F301 DESIGN CONDITIONS

Selection of pressures, temperatures, forces, and other conditions that may apply to the design of piping can be influenced by unusual requirements that should be considered when applicable. These include but are not limited to the following.

F301.4 Ambient Effects

Where fluids can be trapped (e.g., in double seated valves) and subjected to heating and consequent expansion, means of pressure relief should be considered to avoid excessive pressure buildup.

F301.5 Dynamic Effects

geysering: an effect that can occur in piping handling fluids at or near their boiling temperatures under conditions when rapid evolution of vapor within the piping causes rapid expulsion of liquid. In such cases, a pressure surge can be generated that may be destructive to the piping. (Geysering usually is associated with vertical pipelines but may occur in inclined lines under certain conditions.)

F301.7 Thermal Expansion and Contraction Effects

bowing during cooldown: an effect that can occur, usually in horizontal piping, on introduction of a fluid at or near its boiling temperature and at a flow rate that allows stratified two-phase flow, causing large circumferential temperature gradients and possibly unacceptable stresses at anchors, supports, guides, and within pipe

walls. (Two-phase flow can also generate excessive pressure oscillations and surges that may damage the piping.)

F301.10 Cyclic Effects

F301.10.1 Pressure Cycling. The rules in para. K304.8 may be considered where fatigue due to pressure cycling is a concern.

F301.10.2 Thermal Fatigue at Mixing Points.

Consideration should be given to the potential for thermal fatigue on surfaces exposed to the fluid when mixing fluids of different temperatures (e.g., cold droplets impinging on the pipe wall of a hot gas stream).

F301.10.3 Severe Cyclic Conditions. Designating piping as being under severe cyclic conditions should be considered when piping is subjected to both a high stress range and many cycles. The phrase *many cycles* can be taken as when the stress range factor, f, is less than the maximum, f_m . The phrase *high stress range* is normally taken as when the calculated stress range approaches the allowable stress range. Examples include piping associated with batch chemical reactors that cycle more frequently than once a day and piping that has a reasonable likelihood of vibrating.

Frequently, failures occur at small branch connections attached to main piping runs that do not have a high stress range. When experience shows that these small branch connections might be vulnerable to fatigue failure, consideration should be given to designating such piping as being under severe cyclic conditions. See the following references for guidance on the design of small branch connections to avoid fatigue failure:

- (a) Guidelines for the Avoidance of Vibration Induced Fatigue Failure in Process Pipework, published by Energy Institute
- (b) Design Guideline for Small Diameter Branch Connections, published jointly by Gas Machinery Research Council, Pipeline Research Council International, and Southwest Research Institute

More conservative approaches to designating piping as being under severe cyclic conditions should be taken when the fluid handled is toxic, flammable, or damaging to human tissue; when failure of the piping would be costly; and also when examination of the piping during operation or normal outages is impracticable.

(16)

F301.11 Condensation Effects

Where there is a possibility of condensation occurring inside gaseous fluid piping, means should be considered to provide drainage from low areas to avoid damage from water hammer or corrosion.

F304 PRESSURE DESIGN

F304.7 Pressure Design of Other Metallic Components

- **F304.7.4 Expansion Joints.** The following are specific considerations to be evaluated by the designer when specifying expansion joint requirements, in addition to the guidelines given in EJMA Standards:
- (a) susceptibility to stress corrosion cracking of the materials of construction, considering specific alloy content, method of manufacture, and final heat treated condition.
- (b) consideration of not only the properties of the flowing medium but also the environment external to the expansion joint and the possibility of condensation or ice formation due to the operation of the bellows at a reduced temperature.
- (c) consideration of specifying a minimum bellows or ply thickness. The designer is cautioned that requiring excessive bellows thickness may reduce the fatigue life of the expansion joint and increase end reactions.
- (*d*) accessibility of the expansion joint for maintenance and inspection.
- (e) need for leak tightness criteria for mechanical seals on slip type joints.
- (f) specification of installation procedures and shipping or preset bars so that the expansion joint will not be extended, compressed, or offset to compensate for improper alignment of piping, other than the intentional offset specified by the piping designer.
- (g) need to request data from the expansion joint manufacturer, including
 - (1) effective thrust area
- (2) lateral, axial, and rotational stiffness (spring constant)
- (3) calculated design cycle life under specified design conditions
 - (4) friction force in hinges, tie rods, etc.
 - (5) installed length and weight
- (6) requirements for additional support or restraint in the piping
- (7) expansion joint elements that are designed to be uninsulated during operation
- (8) certification of pressure containing and/or restraining materials of construction
 - (9) maximum test pressure
 - (10) design calculations

F307 VALVES

- (a) Extended bonnet valves are recommended where necessary to establish a temperature differential between the valve stem packing and the fluid in the piping, to avoid packing leakage and external icing or other heat flux problems. The valve should be positioned to provide this temperature differential. Consideration should be given to possible packing shrinkage in low temperature fluid service.
- (b) The effect of external loads on valve operability and leak tightness should be considered.

F308 FLANGES AND GASKETS

F308.2 Specific Flanges

Slip-On Flanges. The need for venting the space between the welds in double-welded slip-on flanges should be considered for fluid services (including vacuum) that require leak testing of the inner fillet weld, or when fluid handled can diffuse into the enclosed space, resulting in possible failure.

F308.4 Gaskets

- (a) Gasket materials not subject to cold flow should be considered for use with raised face flanges for fluid services at elevated pressures with temperatures significantly above or below ambient.
- (b) Use of full face gaskets with flat faced flanges should be considered when using gasket materials subject to cold flow for low pressure and vacuum services at moderate temperatures. When such gasket materials are used in other fluid services, the use of tongue-and-groove or other gasket-confining flange facings should be considered.
- (c) The effect of flange facing finish should be considered in gasket material selection.

F309 BOLTING

F309.1 General

The use of controlled bolting procedures should be considered in high, low, and cycling temperature services, and under conditions involving vibration or fatigue, to reduce

- (a) the potential for joint leakage due to differential thermal expansion
- (b) the possibility of stress relaxation and loss of bolt tension

F312 FLANGED JOINTS

F312.1 General

Three distinct elements of a flanged joint must act together to provide a leak-free joint — the flanges, the

gasket, and the bolting. Factors that affect performance include the following:

- (a) Selection and Design
- (1) consideration of service conditions (including external loads, bending moments, and application of thermal insulation)
- (2) flange rating, type, material, facing, and facing finish (see para. F308.2)
- (3) gasket type, material, thickness, and design (see para. F308.4)
- (4) bolt material, strength (cold and at temperature), and specifications for tightening of bolts (see para. F309.1)
 - (5) design for access to the joint
 - (b) Installation
 - (1) condition of flange mating surfaces
- (2) joint alignment and gasket placement before boltup
 - (3) implementation of specified bolting procedures

F321 PIPING SUPPORT

F321.4 Wear of Piping at Support Points

The use of pads or other means of pipe attachment at support points should be considered for piping systems subject to wear and pipe wall metal loss from relative movement between the pipe and its supports (e.g., from wave action on offshore production applications).

F322 DESIGN CONSIDERATIONS FOR SPECIFIC SYSTEMS

F322.6 Pressure Relief Piping

Stop Valves in Pressure Relief Piping. If stop valves are located in pressure relief piping in accordance with para. 322.6.1(a), and if any of these stop valves are to be closed while the equipment is in operation, an authorized person should be present. The authorized person should remain in attendance at a location where the operating pressure can be observed and should have access to means for relieving the system pressure in the event of overpressure. Before leaving the station the authorized person should lock or seal the stop valves in the open position.

(16) F323 MATERIALS

(a) Selection of materials to resist deterioration in service is not within the scope of this Code. However, suitable materials should be specified or selected for use in piping and associated facilities not covered by this Code but that affect the safety of the piping. Consideration should be given to allowances made for temperature and pressure effects of process reactions, for properties of reaction or decomposition products, and for hazards from instability of contained fluids. Consideration should be given to the use of cladding, lining, or other protective materials to reduce the effects of corrosion, erosion, and abrasion.

(b) Information on material performance in corrosive environments can be found in publications such as Corrosion Data Survey — Metals Section, published by the National Association of Corrosion Engineers as report no. 37519.

F323.1 General Considerations

The following are some general considerations that should be evaluated when selecting and applying materials in piping (see also para. FA323.4):

- (a) the possibility of exposure of the piping to fire and the melting point, degradation temperature, loss of strength at elevated temperature, and combustibility of the piping material under such exposure
- (b) the susceptibility to brittle failure or failure from thermal shock of the piping material when exposed to fire or to fire-fighting measures, and possible hazards from fragmentation of the material in the event of failure
- (c) the ability of thermal insulation to protect piping against failure under fire exposure (e.g., its stability, fire resistance, and ability to remain in place during a fire)
- (d) the susceptibility of the piping material to crevice corrosion under backing rings, in threaded joints, in socket welded joints, and in other stagnant, confined areas
- (e) the possibility of adverse electrolytic effects if the metal is subject to contact with a dissimilar metal
- (f) the compatibility of lubricants or sealants used on threads with the fluid service
- (g) the compatibility of packing, seals, and O-rings with the fluid service
- (h) the compatibility of materials, such as cements, solvents, solders, and brazing materials, with the fluid service
- (i) the chilling effect of sudden loss of pressure on highly volatile fluids as a factor in determining the lowest expected service temperature
- (*j*) the possibility of pipe support failure resulting from exposure to low temperatures (which may embrittle the supports) or high temperatures (which may weaken them)
- (k) the compatibility of materials, including sealants, gaskets, lubricants, and insulation, used in strong oxidizer fluid service (e.g., oxygen or fluorine)
- (*l*) the possibility of adverse effects from microbiologically influenced corrosion (MIC) or its remediation

F323.2 Temperature Limitations

F323.2.2 Lower Temperature Limits. Regarding materials considered for use at a lower exemption temperature without impact testing using para. 323.2.2(d)(1), the simplified rules of para. 323.2.2 should not be used for piping systems that are anticipated to experience shock loading or thermal bowing, or if they contain welds between dissimilar materials, especially welds between austenitic and ferritic materials. More

rigorous means of testing or analysis should be used for such piping systems. For example, the additional stress due to circumferential shear near a dissimilar weld due to differential thermal contraction and its effect on the combined stress should be determined.

The modulus of elasticity for the condition under consideration should be used when evaluating the reactions.

Cold springing or misalignment can result in significant stresses in the ambient condition. The designer is responsible for ensuring that such stresses are accounted for before any credit is taken for reduction in minimum design temperature without impact testing.

(16) F323.4 Specific Material Considerations — Metals

The following are some specific considerations that should be evaluated when applying certain metals in piping:

- (a) Irons Cast, Malleable, and High Silicon (14.5%). Their lack of ductility and their sensitivity to thermal and mechanical shock.
 - (b) Carbon Steel, and Low and Intermediate Alloy Steels
- (1) the possibility of embrittlement when handling alkaline or strong caustic fluids
- (2) the possible conversion of carbides to graphite during long time exposure to temperatures above 427°C (800°F) of carbon steels, plain nickel steel, carbon-manganese steel, manganese-vanadium steel, and carbon-silicon steel
- (3) the possible conversion of carbides to graphite during long time exposure to temperatures above 468°C (875°F) of carbon-molybdenum steel, manganese-molybdenum-vanadium steel, and chromium-vanadium steel
- (4) the advantages of silicon-killed carbon steel (0.1% silicon minimum) for temperatures above 482°C (900°F)
- (5) the possibility of damage due to hydrogen exposure at elevated temperature (see API RP 941); hydrogen damage (blistering) may occur at lower temperatures under exposure to aqueous acid solutions¹

API RP 941, Steels for Hydrogen Service at Elevated Temperatures and Pressures in Petroleum Refineries and Petrochemical Plants

NACE MR0103, Materials Resistant to Sulfide Stress Cracking in Corrosive Petroleum Refining Environments

NACE MR0175/ISO 15156-2, Petroleum and natural gas industries — Materials for use in H₂S-containing environments in oil and gas production — Part 2: Cracking-resistant carbon and low alloy steels, and the use of cast irons

NACE MR0175/ISO 15156-3, Petroleum and natural gas industries — Materials for use in H₂S-containing environments in oil and gas production — Part 3: Cracking-resistant CRAs (corrosion-resistant alloys) and other alloys

NACE SP0472, Methods and Controls to Prevent In-Service Environmental Cracking of Carbon Steel Weldments in Corrosive Petroleum Refining Environments

NACE SP0170, Protection of Austenitic Stainless Steels and Other Austenitic Alloys from Polythionic Acid Stress Corrosion Cracking During a Shutdown of Refinery Equipment

- (6) the possibility of stress corrosion cracking when exposed to cyanides, acids, acid salts, or wet hydrogen sulfide; a maximum hardness limit is usually specified (see NACE MR0175/ISO 15156-2 or MR0103 and SP0472)¹
- (7) the possibility of sulfidation in the presence of hydrogen sulfide at elevated temperatures
 - (c) High Alloy (Stainless) Steels
- (1) the possibility of stress corrosion cracking of austenitic stainless steels exposed to media such as chlorides and other halides either internally or externally; the latter can result from improper selection or application of thermal insulation, or from use of marking inks, paints, labels, tapes, adhesives, and other accessory materials containing chlorides or other halides (see NACE MR0175/ISO 15156-3)¹
- (2) the susceptibility to intergranular corrosion of austenitic stainless steels sensitized by exposure to temperatures between 427°C and 871°C (800°F and 1,600°F); as an example, stress corrosion cracking of sensitized metal at room temperature by polythionic acid (reaction of oxidizable sulfur compound, water, and air); stabilized or low carbon grades may provide improved resistance (see NACE SP0170)¹
- (3) the susceptibility to intercrystalline attack of austenitic stainless steels on contact with liquid metals (including aluminum, antimony, bismuth, cadmium, gallium, lead, magnesium, tin, and zinc) or their compounds
- (4) the brittleness of ferritic stainless steels at room temperature after service at temperature above 371°C (700°F)
 - (d) Nickel and Nickel Base Alloys
- (1) the susceptibility to grain boundary attack of nickel and nickel base alloys not containing chromium when exposed to small quantities of sulfur at temperatures above 316°C (600°F)
- (2) the susceptibility to grain boundary attack of nickel base alloys containing chromium at temperatures above 593°C (1,100°F) under reducing conditions and above 760°C (1,400°F) under oxidizing conditions
- (3) the possibility of stress corrosion cracking of nickel-copper Alloy 400 in hydrofluoric acid vapor in the presence of air, if the alloy is highly stressed (including residual stresses from forming or welding)
 - (e) Aluminum and Aluminum Alloys
- (1) the compatibility with aluminum of thread compounds used in aluminum threaded joints to prevent seizing and galling
- (2) the possibility of corrosion from concrete, mortar, lime, plaster, or other alkaline materials used in buildings or structures
- (3) the susceptibility of Alloy Nos. 5083, 5086, 5154, and 5456 to exfoliation or intergranular attack; and the upper temperature limit of 66°C (150°F) shown in Appendix A to avoid such deterioration

¹ Titles of referenced documents are

- (f) Copper and Copper Alloys
 - (1) the possibility of dezincification of brass alloys
- (2) the susceptibility to stress-corrosion cracking of copper-based alloys exposed to fluids such as ammonia or ammonium compounds
- (3) the possibility of unstable acetylide formation when exposed to acetylene
- (g) Titanium and Titanium Alloys. The possibility of deterioration of titanium and its alloys above 316°C (600°F).
- (h) Zirconium and Zirconium Alloys. The possibility of deterioration of zirconium and zirconium alloys above 316°C (600°F).
- (i) Tantalum. Above 299°C (570°F), the possibility of reactivity of tantalum with all gases except the inert gases. Below 299°C, the possibility of embrittlement of tantalum by nascent (monatomic) hydrogen (but not molecular hydrogen). Nascent hydrogen is produced by galvanic action, or as a product of corrosion by certain chemicals.
- (j) Metals With Enhanced Properties. The possible loss of strength, in a material whose properties have been enhanced by heat treatment, during longcontinued exposure to temperatures above its tempering temperature.
- (k) The desirability of specifying some degree of production impact testing, in addition to the weld procedure qualification tests, when using materials with limited low temperature service experience below the minimum temperature stated in Table A-1 or Table A-1M.

F331 HEAT TREATMENT

F331.1 Heat Treatment Considerations

Heat treatment temperatures listed in Table 331.1.1 for some P-No. 4 and P-No. 5 materials may be higher than the minimum tempering temperatures specified in the ASTM specifications for the base material. For higher-strength normalized and tempered materials, there is consequently a possibility of reducing tensile properties of the base material, particularly if long holding times at the higher temperatures are used.

F335 ASSEMBLY AND ERECTION

F335.9 Cleaning of Piping

The following are some general considerations that may be evaluated in determining the need for cleaning of piping:

- (a) requirements of the service, including possible contaminants and corrosion products during fabrication, assembly, storage, erection, and testing.
- (b) for low temperature service, removal of moisture, oil, grease, and other contaminants to prevent sticking of valves or blockage of piping and small cavities.

- (c) for strong oxidizer fluid service (e.g., oxygen or fluorine), special cleaning and inspection. Reference may be made to the Compressed Gas Association's Pamphlet G-4.1 Cleaning Equipment for Oxygen Service.
- (d) purging, flushing, or blowing down unwanted dirt, debris, and residual fluid from the inside of a piping system should be performed with caution and control. It is left to the discretion, knowledge, and responsibility of the owner or designer as to the degree of caution and control necessary for a safe work environment. The fluid selected for the purpose of purging, flushing, or blowing down shall preferably be inert. However, for cases in which the use of a flammable or toxic fluid is unavoidable, e.g., when displacing residual testing or flushing fluid with the service fluid, the implementation of additional precautionary considerations may be necessary. Those precautionary considerations should include
 - (1) the discharge of liquids to a safe collection point
- (2) the discharge of flammable liquids away from ignition sources and personnel
 - (3) venting of gases to a safe outdoor location
- (4) venting of flammable gases away from ignition sources and personnel
- (5) further protection of personnel via controlled access of the work area, including perimeter warning signs for personnel not involved in the purging process
- (6) for precautionary requirements and recommendations regarding the displacement of flushing and testing fluids using a flammable gas, refer to ANSI Z223.1/ NFPA 54, National Fuel Gas Code

F335.10 Identification of Piping

Consideration should be given to identifying the contents of piping, with special consideration given to piping conveying flammable, hazardous, or fire-quenching fluids. Reference may be made to ASME A13.1, Scheme for the Identification of Piping Systems.

F345 TESTING

F345.2.3 Special Provisions for Testing. When pip- (16) ing subassemblies are tested separately, consideration should be given to performing an additional leak test of the assembled piping system prior to initial operation. The test fluid should be nonhazardous to the process and the people performing the examination. Examination for leaks should be at all joints that have not been previously examined for leaks, or that have been reassembled after being examined for leaks. Examples include flanges where isolation blanks were removed after the leak test and joints where instrumentation or other components were removed for the leak test.

F345.4 Hydrostatic Leak Test

F345.4.1 Test Fluid. Consideration should be given to susceptibility to microbiologically influenced corrosion (MIC). This condition is especially prevalent in noflow, high moisture environments. Internal MIC may also depend on the characteristics of the treated or untreated test fluid.

Internal MIC may be lessened or possibly eliminated by properly draining and drying systems and/or by proper selection of test fluid.

F345.5 Pneumatic Leak Test

F345.5.1 Precautions. Consideration should be given to the risk associated with the release of stored energy and to the establishment of the minimum safe distance between personnel and the equipment being tested. Equations and considerations are available in ASME PCC-2, Repair of Pressure Equipment and Piping, Article 5.1.

FA323 MATERIALS

FA323.4 Material Considerations — Nonmetals

The following are some considerations to be evaluated when applying nonmetals in piping. See also paras. F323 and F323.1.

- (a) Static Charges. Because of the possibility of producing hazardous electrostatic charges in nonmetallic piping and metallic piping lined with nonmetals, consideration should be given to grounding such systems conveying nonconductive fluids.
- (b) Compressed Gases. If nonmetallic piping is used above ground for compressed air or other compressed gases, special precautions should be observed. In determining the needed safeguarding for such services, the energetics and the specific failure mechanism need to be evaluated. Encasement of the plastic piping in shatter-resistant material may be considered.
- (c) Brittle Piping. If borosilicate glass or other brittle piping material is used, take into account its lack of ductility and its sensitivity to thermal and mechanical shock.

FU315 HYGIENIC CLAMP JOINTS

To lower the probability of leaks in piping that is subject to transient temperature and pressure fluctuations, consider the use of a two-bolt clamp to increase clamping force in lieu of a hinged clamp for those processes that require

- (a) passivation
- (b) clean-in-place (CIP)
- (c) steam- (or sterilize-) in-place (SIP)

APPENDIX G SAFEGUARDING

G300 SCOPE

- (a) Safeguarding is the provision of protective measures to minimize the risk of accidental damage to the piping or to minimize the harmful consequences of possible piping failure.
- (b) In most instances, the safeguarding inherent in the facility (the piping, the plant layout, and its operating practices) is sufficient without need for additional safeguarding. In some instances, however, engineered safeguards must be provided.
- (c) Appendix G outlines some considerations pertaining to the selection and utilization of safeguarding. Where safeguarding is required by the Code, it is necessary to consider only the safeguarding that will be suitable and effective for the purposes and functions stated in the Code or evident from the designer's analysis of the application.

G300.1 General Considerations

In evaluating a piping installation design to determine what safeguarding may exist or is necessary, the following should be reviewed:

- (a) the hazardous properties of the fluid, considered under the most severe combination of temperature, pressure, and composition in the range of expected operating conditions.
- (b) the quantity of fluid that could be released by piping failure, considered in relation to the environment, recognizing the possible hazards ranging from large releases of otherwise innocuous fluids to small leakages of toxic fluids.
- (c) expected conditions in the environment, evaluated for their possible effect on the hazards caused by a possible piping failure. This includes consideration of ambient or surface temperature extremes, degree of ventilation, proximity of fired equipment, etc.
- (d) the probable extent of operating, maintenance, and other personnel exposure, as well as reasonably probable sources of damage to the piping from direct or indirect causes.
- (e) the probable need for grounding of static charges to prevent ignition of flammable vapors.
- (f) the safety inherent in the piping by virtue of materials of construction, methods of joining, and history of service reliability.

G300.2 Safeguarding by Plant Layout and Operation

Representative features of plant layout and operation that may be evaluated and selectively utilized as safeguarding include

(a) plant layout features, such as open-air process equipment structures; spacing and isolation of

hazardous areas; slope and drainage; buffer areas between plant operations and populated communities; or control over plant access

- (b) protective installations, such as fire protection systems; barricades or shields; ventilation to remove corrosive or flammable vapors; instruments for remote monitoring and control; containment and/or recovery facilities; or facilities (e.g., incinerators) for emergency disposal of hazardous materials
- (c) operating practices, such as restricted access to processing areas; work permit system for hazardous work; or special training for operating, maintenance, and emergency crews
- (d) means for safe discharge of fluids released during pressure relief device operation, blowdown, cleanout, etc.
- (e) procedures for startup, shutdown, and management of operating conditions, such as gradual pressurization or depressurization, and gradual warmup or cooldown, to minimize the possibility of piping failure, e.g., brittle fracture

G300.3 Engineered Safeguards

Engineered safeguards that may be evaluated and selectively applied to provide added safeguarding include

- (a) means to protect piping against possible failures, such as
- (1) thermal insulation, shields, or process controls to protect from excessively high or low temperature and thermal shock
- (2) armor, guards, barricades, or other protection from mechanical abuse
- (3) damping or stabilization of process or fluid flow dynamics to eliminate or to minimize or protect against destructive loads (e.g., severe vibration pulsations, cyclic operating conditions)
- (b) means to protect people and property against harmful consequences of possible piping failure, such as confining and safely disposing of escaped fluid by shields for flanged joints, valve bonnets, gages, or sight glasses; or for the entire piping system if of frangible material; limiting the quantity or rate of fluid escaping by automatic shutoff or excess flow valves, additional block valves, flow-limiting orifices, or automatic shutdown of pressure source; limiting the quantity of fluid in process at any time, where feasible

APPENDIX H SAMPLE CALCULATIONS FOR BRANCH REINFORCEMENT

H300 INTRODUCTION (METRIC)

The following examples are intended to illustrate the application of the rules and definitions in para. 304.3.3 for welded branch connections.

(16) H301 EXAMPLE 1

A DN 200 (NPS 8) run (header) in an oil piping system has a DN 100 (NPS 4) branch at right angles (see Fig. H301). Both pipes are Schedule 40 API 5L Grade A seamless. The design conditions are 2 068 kPa at 200°C. The fillet welds at the crotch are minimum size in accordance with para. 328.5.4. A corrosion allowance of 2.5 mm is specified. Is additional reinforcement necessary?

Solution

From Appendix A, S = 110 MPa for API 5L Grade A (Table A-1M); E = 1.0 for API 5L seamless (Table A-1B); W = 1.0.

$$T_h = (8.18)(0.875) = 7.16 \text{ mm}$$

$$T_b = (6.02)(0.875) = 5.27 \text{ mm}$$

$$L_4 = (2.5)(7.16 - 2.5) = 11.65 \text{ mm}$$

or $(2.5)(5.27 - 2.5) = 6.93 \text{ mm}$,
whichever is less
= 6.93 mm

$$d_1 = [114.3 - (2)(5.27 - 2.5)]/(\sin 90 \text{ deg}) = 108.8 \text{ mm}$$

$$d_2 = (5.27 - 2.5) + (7.16 - 2.5) + 109/2$$

= 61.9 mm

Use d_1 or d_2 , whichever is greater.

$$d_1 = 108.8 \text{ mm}$$

$$t_h = \frac{(2.068)(219.1)}{(2)(110,000)(1.0)(1.00) + (2)(0.4)(2.068)} = 2.04 \text{ mm}$$

$$t_b = \frac{(2.068)(114.3)}{(2)(110,000)(1.0)(1.00) + (2)(0.4)(2.068)} = 1.07 \text{ mm}$$

$$t_c = (0.7)(6.02) = 4.21$$
 mm, or 6 mm, whichever is less = 4.21 mm

Minimum leg dimension of fillet weld

$$4.21/0.707 = 6.0 \text{ mm}$$

Thus, the required area

$$A_1 = (2.04)(108.8)(2 - \sin 90 \text{ deg}) = 222 \text{ mm}^2$$

The reinforcement area in run wall

$$A_2 = (108.8)(7.16 - 2.04 - 2.5) = 285 \text{ mm}^2$$

in branch wall

$$A_3 = (2)(6.93)[(5.27 - 1.07) - 2.5] = 24 \text{ mm}^2$$

in branch welds

$$A_4 = (2)(\frac{1}{2})(6.0)^2 = 36 \text{ mm}^2$$

The total reinforcement area = 345 mm^2 . This is more than the 222 mm² so that no additional reinforcement is required to sustain the internal pressure.

H302 EXAMPLE 2


There is a DN 200 (NPS 8) branch at right angles to a DN 300 (NPS 12) header (Fig. H301). Both run and branch are of aluminum alloy Schedule 80 ASTM B241 6061-T6 seamless pipe. The connection is reinforced by a ring 350 mm O.D. (measured along the run) cut from a piece of DN 300 (NPS 12) Schedule 80 ASTM B241 6063-T6 seamless pipe and opened slightly to fit over the run pipe. Allowable stresses for welded construction apply in accordance with Appendix A, Note (33). The fillet welds have the minimum dimensions permitted in para. 328.5.4. A zero corrosion allowance is specified. What is the maximum permissible design pressure if the design temperature is -195°C ?

Solution

From Table A-1, S = 55.2 MPa for Grade 6061-T6 (welded) pipe and S = 39.3 MPa for Grade 6063-T6 (welded) pad, both at -195° C. From Table A-1B, E = 1.0 for ASTM B241; W = 1.0.

(16)

Fig. H301 Illustrations for Metric Examples in Appendix H



Leg dimensions of welds to the branch

$$t_c = \text{lesser of } 0.7\overline{T}_b \text{ or } 6 \text{ mm}$$

= 6 mm

$$\frac{12.7}{0.707}$$
 or $\frac{6}{0.707} = 8.5$ mm

and to the reinforcing pad

$$\frac{0.5\overline{T}_r}{0.707} = \frac{(0.5)(17.48)}{0.707} = 12.36 \text{ mm}$$

$$T_h = (17.48)(0.875) = 15.3 \text{ mm}$$

$$T_b = (12.7)(0.875) = 11.1 \text{ mm}$$

$$T_r = (17.48)(0.875) = 15.3 \text{ mm}$$

$$L_4 = (2.5)(15.3 - 0.0) = 38.25 \text{ mm}$$

[This is smaller than (2.5)(11.1 - 0) + 15.3 = 43.05 mm]

$$d_1 = 219.1 - (2)(11.1 - 0) = 197 \text{ mm}$$

 $d_2 = d_1$ because it is greater than $T_b + T_c + d_1/2$

$$t_h = \frac{323.8P}{(2)(55\,200)(1.0)(1.0) + (2)(0.4)P}$$

$$t_b = \frac{219.1P}{(2)(55\ 200)(1.0)(1.0) + (2)(0.4)P}$$

Using the symbol

$$q = \frac{P}{110,400 + 0.8P}$$

we can briefly write

$$t_h = 323.8q$$
 and $t_h = 219.1q$

The required area

$$A_1 = 197t_h = 63789q$$

The reinforcement area in the run wall

$$A_2 = (197)(15.3 - 323.8q - 0)$$
$$= 3014 - 63789q$$

in branch wall

$$A_3 = (2)(38.25)(11.1 - 219.1q - 0)$$

= 849 - 16 761q

in reinforcing ring

$$A_4 = (15.3)(350 - 219.1)(39300/55200) = 1426 \text{ mm}^2$$

in fillet welds

$$A_4 = (2)(\frac{1}{2})(8.5)^2 + (2)(\frac{1}{2})(12.36)^2 = 225 \text{ mm}^2$$

The total reinforcement area = 5514 - 80550q.

At the maximum permissible normal operating pressure, the required area and the reinforcement area are equal; thus

$$63\ 789q = 5\ 514 - 80\ 550q$$

$$144\ 339q = 5\ 514$$

$$q = 0.0382$$

But also

$$q = \frac{P}{(110\,400 + 0.8P)}$$

Thus

$$P = (0.0382)(110\ 400\ + 0.8P) = 4\ 217\ + 0.03P$$

$$0.97P = 4217$$

$$P = 4347 \text{ kPa}$$

H303 EXAMPLE 3

A DN 150 (NPS 6) Schedule 40 branch has its axis at a 60 deg angle to the axis of a DN 400 (NPS 16) Schedule 40 run (header) in an oil piping system (Fig. H301). Both pipes are API 5L Grade A seamless. The connection is reinforced with a ring 305 mm O.D. (measured along the run) made from 12.7 mm ASTM A285 Grade C plate. All fillet welds are equivalent to 45 deg fillet welds with 10 mm legs. Corrosion allowance = 2.5 mm. The design pressure is 3 450 kPa at 370°C. Is the design adequate for the internal pressure?

Solution

From Appendix A, S = 99.3 MPa for API 5L Grade A and ASTM A285 Grade C (Table A-1); E = 1.0 for API 5L seamless pipe (Table A-1B); W = 1.0.

$$T_h = (12.7)(0.875) = 11.1 \text{ mm}$$

$$T_h = (7.11)(0.875) = 6.22 \text{ mm}$$

$$T_r = 12.7 \text{ mm}$$

$$L_4$$
 = lesser of $(2.5)(6.22 - 2.5) + 12.7 = 22 \text{ mm}$
or $(2.5)(11.1 - 2.5) = 21.5 \text{ mm}$
= 21.5 mm

$$t_h = \frac{(3\,450)(406.4)}{(2)(99\,300)(1.0)(1.0) + (2)(0.4)(3\,450)} = 6.96 \text{ mm}$$

$$t_b = \frac{(3.450)(168.3)}{(2)(99.300)(1.0)(1.0) + (2)(0.4)(3.450)} = 2.88 \text{ mm}$$

$$d_1 = d_2 = \frac{168.3 - (2)(6.22 - 2.5)}{\sin 60 \text{ deg}} = \frac{160.9}{0.866} = 185.7 \text{ mm}$$

The required area

$$A_1 = (6.96)(185.7)(2 - 0.866) = 1466 \text{ mm}^2$$

The reinforcement in the run wall

$$A_2 = (185.7)(11.1 - 6.96 - 2.5) = 305 \text{ mm}^2$$

in branch wall

$$A_3 = (2) \left(\frac{21.5}{0.866} \right) (6.22 - 2.88 - 2.5) = 41.7 \text{ mm}^2$$

in ring

$$A_4 = (12.7) \left(305 - \frac{168.3}{0.866} \right) = 1405 \text{ mm}^2$$

in fillet welds

$$A_4 = (4)(\frac{1}{2})(10)^2 = 200 \text{ mm}^2$$

The total reinforcement is

$$200 + 1405 + 41.7 + 305 = 1952 \text{ mm}^2$$

This total is greater than the 1466 mm², so that no additional reinforcement is required.

H304 EXAMPLE 4

A DN 200 (NPS 8) run (header) in an oil piping system has a DN 100 (NPS 4) branch at right angles (Fig. H301). Both pipes are Schedule 40 API 5L Grade A seamless. The design conditions are 2 400 kPa at 205°C. It is assumed that the piping system is to remain in service until all metal thickness, in both branch and run, in excess of that required by eq. (3a) of para. 304.1.2 has corroded away so that area A_2 as defined in para. 304.3.3(c)(1) is zero. What reinforcement is required for this connection?

Solution

From Appendix A, S = 110 MPa for API 5L Grade A (Table A-1); E = 1.0 for API 5L seamless (Table A-1B); W = 1.0.

$$t_h = \frac{(2\,400)(219.1)}{(2)(110\,000)(1.0)(1.0) + (2)(0.4)(2\,400)} = 2.37 \text{ mm}$$

$$t_b = \frac{(2\,400)(114.3)}{(2)(110\,000)(1.0)(1.0) + (2)(0.4)(2\,400)} = 1.24 \text{ mm}$$

$$d_1 = 114.3 - (2)(1.24) = 112 \text{ mm}$$

Required reinforcement area

$$A_1 = (2.37)(112) = 265 \text{ mm}^2$$

Try fillet welds only

$$L_4 = (2.5)(2.37) = 5.9 \text{ mm}$$

or
$$(2.5)(1.24) = 3.1 \text{ mm}$$

Use 3.1 mm.

Due to limitation in the height at the reinforcement zone, no practical fillet weld size will supply enough reinforcement area; therefore, the connection must be further reinforced. Try a 160 mm O.D. reinforcing ring (measured along the run). Assume the ring to be cut from a piece of DN 200 (NPS 8) Schedule 40 API 5L Grade A seamless pipe and welded to the connection with minimum size fillet welds.

Minimum ring thickness

$$T_r = (8.18)(0.875) = 7.16 \text{ mm}$$

New $L_4 = (2.5)(1.24) + 7.16 = 10.3 \text{ mm}$
or $(2.5)(2.37) = 5.9 \text{ mm}$

Use 5.9 mm.

Reinforcement area in the ring (considering only the thickness within L_4)

$$X_1 = (5.9)(160 - 114.3) = 270 \text{ mm}^2$$

Leg dimension of weld =
$$\frac{(0.5)(8.18)}{0.707}$$
 = 5.8 mm

Reinforcement area in fillet welds

$$X_2 = (2)(\frac{1}{2})(5.8)^2 = 34 \text{ mm}^2$$

Total reinforcement area

$$A_4 = X_1 + X_2 = 304 \text{ mm}^2$$

This total reinforcement area is greater than the required area; therefore, a reinforcing ring 160 mm O.D., cut from a piece of DN 200 (NPS 8) Schedule 40 API 5L Grade A seamless pipe and welded to the connection with minimum size fillet welds would provide adequate reinforcement for this connection.

H305 EXAMPLE 5 (Not Illustrated)

A DN 40 (NPS 1½) Class 3000 forged steel socket welding coupling has been welded at right angles to a DN 200 (NPS 8) Schedule 40 run (header) in oil service, using a weld conforming to sketch (1) of Fig. 328.5.4D. The run is ASTM A53 Grade B seamless pipe. The design pressure is 2 760 kPa and the design temperature is

230°C. The corrosion allowance is 2.5 mm. Is additional reinforcement required?

Solution

No. According to para. 304.3.2(b), the design is adequate to sustain the internal pressure and no calculations are necessary. It is presumed, of course, that calculations have shown the run pipe to be satisfactory for the service conditions according to eqs. (2) and (3).

H310 INTRODUCTION (U.S. CUSTOMARY)

The following examples are intended to illustrate the application of the rules and definitions in para. 304.3.3 for welded branch connections.

H311 EXAMPLE 1

An NPS 8 run (header) in an oil piping system has an NPS 4 branch at right angles (see Fig. H311). Both pipes are Schedule 40 API 5L Grade A seamless. The design conditions are 300 psig at 400°F. The fillet welds at the crotch are minimum size in accordance with para. 328.5.4. A corrosion allowance of 0.10 in. is specified. Is additional reinforcement necessary?

Solution

From Appendix A, S = 16.0 ksi for API 5L Grade A (Table A-1); E = 1.0 for API 5L seamless (Table A-1B); W = 1.0.

$$T_h = (0.322)(0.875) = 0.282 \text{ in.}$$

$$T_b = (0.237)(0.875) = 0.207$$
 in.

$$L_4 = (2.5)(0.282 - 0.1) = 0.455$$
 in.
or $(2.5)(0.207 - 0.1) + 0 = 0.268$ in.,
whichever is less
= 0.268 in.

$$d_1 = [4.5 - (2)(0.207 - 0.1)]/\sin 90 \text{ deg} = 4.286 \text{ in.}$$

$$d_2 = (0.207 - 0.1) + (0.282 - 0.1) + 4.286/2$$

= 2.432 in.

Use d_1 or d_2 , whichever is greater.

$$d_1 = 4.286$$
 in.

$$t_h = \frac{(300)(8.625)}{(2)(16,000)(1.0)(1.0) + (2)(0.4)(300)} = 0.080 \text{ in.}$$

$$t_b = \frac{(300)(4.500)}{(2)(16,000)(1.0)(1.0) + (2)(0.4)(300)} = 0.042 \text{ in.}$$

$$t_c = (0.7)(0.237) = 0.166$$
 in., or 0.25, whichever is less = 0.166 in.

Minimum leg dimension of fillet weld

$$0.166/0.707 = 0.235$$
 in.

Thus, the required area

$$A_1 = (0.080)(4.286)(2 - \sin 90 \deg) = 0.343 \operatorname{sq} \operatorname{in}.$$

The reinforcement area in run wall

$$A_2 = (4.286)(0.282 - 0.08 - 0.10) = 0.437$$
 sq in.

in branch wall

$$A_3 = (2)(0.268)[(0.207 - 0.042) - 0.10] = 0.035 \text{ sq in.}$$

in branch welds

$$A_4 = (2)(\frac{1}{2})(0.235)^2 = 0.055 \text{ sq in.}$$

The total reinforcement area = 0.527 sq in. This is more than 0.343 sq in. so that no additional reinforcement is required to sustain the internal pressure.


H312 EXAMPLE 2

There is an NPS 8 branch at right angles to an NPS 12 header (Fig. H311). Both run and branch are of aluminum alloy Schedule 80 ASTM B241 6061-T6 seamless pipe. The connection is reinforced by a ring 14 in. O.D. (measured along the run) cut from a piece of NPS 12 Schedule 80 ASTM B241 6063-T6 seamless pipe and opened slightly to fit over the run pipe. Allowable stresses for welded construction apply in accordance with Appendix A, Note (33). The fillet welds have the minimum dimensions permitted in para. 328.5.4. A zero corrosion allowance is specified. What is the maximum permissible design pressure if the design temperature is $-320^{\circ}F$?

Solution

From Table A-1, S = 8.0 ksi for Grade 6061-T6 (welded) pipe and S = 5.7 ksi for Grade 6063-T6 (welded) pad, both at -320° F. From Table A-1B, E = 1.0 for ASTM B241; W = 1.0.

Fig. H311 Illustrations for U.S. Customary Examples in Appendix H



Leg dimensions of welds

$$\frac{t_c}{0.707} = \frac{0.250}{0.707} = 0.354$$
 in.

$$\frac{(0.5)(0.687)}{0.707} = 0.486$$
 in.

$$T_h = (0.687)(0.875) = 0.601$$
 in.

$$T_b = (0.500)(0.875) = 0.438$$
 in.

$$T_r = (0.687)(0.875) = 0.601$$
 in.

$$L_4 = (2.5)(0.601 - 0.00) = 1.503$$
 in.

[This is smaller than (2.5)(0.438 - 0.00) + 0.601 = 1.696 in.]

$$d_2 = d_1 = 8.625 - (2)(0.438 - 0.00) = 7.749 \text{ in.}$$

$$t_h = \frac{12.75P}{(2)(8,000)(1.0)(1.0) + (2)(0.4)(P)}$$

$$t_b = \frac{8.625P}{(2)(8,000)(1.0)(1.0) + (2)(0.4)(P)}$$

Using the symbol

$$q = \frac{P}{16,000 + 0.8P}$$

we can briefly write

$$t_h = 12.75q$$
 and $t_h = 8.625q$

The required area

$$A_1 = 7.749t_h = 98.80q$$

The reinforcement area in run wall

$$A_2 = (7.749)(0.601 - 12.75q - 0.00)$$
$$= 4.657 - 98.80q$$

in branch wall

$$A_3 = (2)(1.503)(0.438 - 8.625q - 0.00)$$

= 1.317 - 25.93q

in ring

$$A_4 = (0.601)(14 - 8.625)(5,700/8,000) = 2.302$$

in fillet welds

$$A_4 = (2)(\frac{1}{2})(0.354)^2 + (2)(\frac{1}{2})(0.486)^2 = 0.362$$

The total reinforcement area = 8.638 - 124.73q.

At the maximum permissible normal operating pressure, the required area and the reinforcement area are equal; thus

$$98.80q = 8.638 - 124.73q$$

$$223.53q = 8.638$$

$$q = 0.0386$$

But also

$$q = \frac{P}{16.000 + 0.8P}$$

Thus

$$P = (0.0386)(16,000 + 0.8P) = 618.3 + 0.0309P$$

$$0.961P = 618.3$$

$$P = 643.1 \text{ psig}$$

which is the maximum permissible design pressure.

H313 EXAMPLE 3

An NPS 6 Schedule 40 branch has its axis at a 60 deg angle to the axis of an NPS 16 Schedule 40 run (header) in an oil piping system (Fig. H311). Both pipes are API 5L Grade A seamless. The connection is reinforced with a ring 12 in. O.D. (measured along the run) made from $\frac{1}{2}$ in. ASTM A285 Grade C plate. All fillet welds are equivalent to 45 deg fillet welds with $\frac{3}{8}$ in. legs. Corrosion allowance = 0.10 in. The design pressure is 500 psig at 700°F. Is the design adequate for the internal pressure?

Solution

From Appendix A, S = 14.4 ksi for API 5L Grade A and ASTM A285 Grade C (Table A-1); E = 1.0 for API 5L seamless pipe (Table A-1B); W = 1.0.

$$T_h = (0.500)(0.875) = 0.438$$
 in.

$$T_b = (0.280)(0.875) = 0.245$$
 in.

$$T_r = 0.500 \text{ in.}$$

$$L_4 = (2.5)(0.245 - 0.10) + 0.500 = 0.8625$$

This is greater than 2.5(0.438 - 0.10) = 0.845 in.

$$t_h = \frac{(500)(16)}{(2)(14,400)(1.0)(1.0) + (2)(0.4)(500)} = 0.274 \text{ in.}$$

$$t_b = \frac{(500)(6.625)}{(2)(14,400)(1.0)(1.0) + (2)(0.4)(500)} = 0.113 \text{ in.}$$

$$d_2 = d_1 = \frac{6.625 - (2)(0.245 - 0.10)}{\sin 60 \text{ deg}} = \frac{6.335}{0.866} = 7.315 \text{ in.}$$

The required area

$$A_1 = (0.274)(7.315)(2 - 0.866) = 2.27 \text{ sq in.}$$

The reinforcement in the run wall

$$A_2 = (7.315)(0.438 - 0.274 - 0.10) = 0.468 \text{ sq in.}$$

in branch wall

$$A_3 = (2) \left(\frac{0.845}{0.866} \right) (0.245 - 0.113 - 0.10) = 0.062 \text{ sq in.}$$

in ring

$$A_4 = (0.500) \left(12 - \frac{6.625}{0.866} \right) = 2.175 \text{ sq in.}$$

in fillet welds

$$A_4 = (4)(\frac{1}{2})(\frac{3}{8})^2 = 0.281 \text{ sq in.}$$

The total reinforcement = 2.986 sq in. This total is greater than 2.27 sq in., so that no additional reinforcement is required.

H314 EXAMPLE 4

An NPS 8 run (header) in an oil piping system has an NPS 4 branch at right angles (Fig. H311). Both pipes are Schedule 40 API 5L Grade A seamless. The design conditions are 350 psig at 400° F. It is assumed that the piping system is to remain in service until all metal thickness, in both branch and run, in excess of that required by eq. (3a) of para. 304.1.2 has corroded away so that area A_2 as defined in para. 304.3.3(c)(1) is zero. What reinforcement is required for this connection?

Solution

From Appendix A, S = 16.0 ksi for API 5L Grade A (Table A-1); E = 1.0 for API 5L seamless (Table A-1B); W = 1.0.

$$t_h = \frac{(350)(8.625)}{(2)(16,000)(1.0)(1.0) + (2)(0.4)(350)} = 0.0935 \text{ in.}$$

$$t_b = \frac{(350)(4.500)}{(2)(16,000)(1.0)(1.0) + (2)(0.4)(350)} = 0.0488 \text{ in}$$
$$d_1 = 4.500 - (2)(0.0488) = 4.402 \text{ in}.$$

Required reinforcement area

$$A_1 = (0.0935)(4.402) = 0.412 \text{ sq in.}$$

Try fillet welds only

$$L_4 = (2.5)(0.0935) = 0.234$$
 in.

or
$$(2.5)(0.0488) = 0.122$$
 in.

Use 0.122 in.

Due to limitation in the height at the reinforcement zone, no practical fillet weld size will supply enough reinforcement area; therefore, the connection must be further reinforced. Try a $6\frac{1}{4}$ in. O.D. reinforcing ring (measured along the run). Assume the ring to be cut from a piece of NPS 8 Schedule 40 API 5L Grade A seamless pipe and welded to the connection with minimum size fillet welds.

Minimum ring thickness

$$T_r = (0.322)(0.875) = 0.282$$
 in.
New $L_4 = (2.5)(0.0488) + 0.282 = 0.404$ in.
or $(2.5)(0.0935) = 0.234$ in.

Use 0.234 in.

Reinforcement area in the ring (considering only the thickness within L_4)

$$X_1 = (0.234)(6.25 - 4.5) = 0.410 \text{ sq in.}$$

Leg dimension of weld =
$$\frac{(0.5)(0.322)}{0.707}$$
 = 0.228 in.

Reinforcement area in fillet welds

$$X_2 = (2)(\frac{1}{2})(0.228)^2 = 0.052$$
 sq in.

Total reinforcement area

$$A_4 = X_1 + X_2 = 0.462$$
 sq in.

This total reinforcement area is greater than the required area; therefore, a reinforcing ring $6\frac{1}{4}$ in. O.D., cut from a piece of NPS 8 Schedule 40 API 5L Grade A seamless pipe and welded to the connection with minimum size fillet welds would provide adequate reinforcement for this connection.

H315 EXAMPLE 5 (Not Illustrated)

An NPS $1\frac{1}{2}$ Class 3000 forged steel socket welding coupling has been welded at right angles to an NPS 8

Schedule 40 run (header) in oil service, using a weld conforming to sketch (1) of Fig. 328.5.4D. The run is ASTM A53 Grade B seamless pipe. The design pressure is 400 psi and the design temperature is 450°F. The corrosion allowance is 0.10 in. Is additional reinforcement required?

Solution

No. According to para. 304.3.2(b), the design is adequate to sustain the internal pressure and no calculations are necessary. It is presumed, of course, that calculations have shown the run pipe to be satisfactory for the service conditions according to eqs. (2) and (3).

(16)

APPENDIX J NOMENCLATURE

	Definition	Unit	s [Note (1)]	Reference		
Symbol		SI	U.S.	Paragraph	Table/Fig./App.	Equation
Α	Factor for determining minimum value of R_1			304.2.3	• • •	(5)
A_f	Conveyed fluid cross-sectional area considering nominal pipe thickness less allowances	mm ²	in. ²	320.2		(23d)
A_p	Pipe cross-sectional area considering nominal pipe thickness less allowances	mm ²	in. ²	320.2		(23d)
A_p	Cross-sectional area of pipe	mm^2	in. ²	319.4.4		(17)
<i>A</i> ₁	Area required for branch reinforcement	mm ²	in. ²	304.3.3 304.3.4	304.3.3 304.3.4 App. H	(6) (6a) (9) (9a)
A_1	Lower transformation or lower critical tem- perature	°C	°F	•••	331.1.1	• • •
<i>A</i> ₂	Area available for branch reinforcement in run pipe	mm ²	in. ²	304.3.3 304.3.4	304.3.3 304.3.4 App. H	(6a) (7) (9a) (10)
<i>A</i> ₃	Area available for branch reinforcement in branch pipe	mm ²	in. ²	304.3.3 304.3.4	304.3.3 304.3.4 App. H	(6a) (8) (9a) (11)
A_4	Area available for branch reinforcement in pad or connection	mm ²	in. ²	304.3.3 304.3.4	304.3.3 304.3.4 App. H	(6a) (9a) (12)
а	Rupture life exponent			V303.1.4 V304		(V3)
С	Cold spring factor			319.5.1	• • •	(21)
С	Material constant used in computing Larson-Miller parameter	•••	•••	V303.1.3 V303.1.4	•••	(V2) (V3)
C_x	Size of fillet weld, socket welds other than flanges	mm	in.	•••	328.5.2C	
C_1	Estimated self-spring or relaxation factor			319.5.1		(22)

		Units [Note (1)]		Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
c	Sum of mechanical allowances (thread or groove depth) plus corrosion and erosion allowances	mm	in.	302.4 304.1.1 304.1.2 304.2.3 304.3.3 304.3.4 304.4.1 304.5.2 304.5.3 A304.1.1 K302.3.5 K302.4 K304.1.1 K304.5.2 K304.5.3 K304.8.3 S301.2 V303.1.1	304.3.3 304.3.4 328.5.5 H301	(2) (3b) (4a) (4b) (4c) (7) (8) (10) (11) (12) (13) (14) (15) (25) (33) (36) (37)
Ci	Sum of internal allowances	mm	in.	K304.1.1 K304.1.2		(34b) (34d) (35a) (35b) (35c) (35d)
Co	Sum of external allowances	mm	in.	K304.1.1 K304.1.2	•••	(34a) (34c) (35a) (35b) (35c) (35d)
<i>c</i> ₁	Correction factor		•••		D300	
D	Outside diameter of pipe as listed in tables of standards and specifications or as measured	mm	in.	304.1.1 304.1.2 304.1.3 304.2.1 304.2.3 319.4.1 A304.1.1 A304.1.2 A328.2.5 K304.1.1 K304.1.2 K304.1.3 K304.8.3 S301.2	304.1.1 304.2.3 341.3.2 D300 K305.1.2 App. A Notes	(3a) (3c) (3d) (3e) (5) (16) (26a) (26b) (26c) (27) (34a) (34c) (35a) (35c) (37)
D_b	Outside diameter of branch pipe	mm	in.	304.3.1 304.3.3 304.3.4	304.3.3 304.3.4 D300	•••
D_h	Outside diameter of header pipe	mm	in.	304.3.1 304.3.3 304.3.4	304.3.3 304.3.4	•••
D_{x}	Distance from node to node (for stress analysis)	m	ft		S301.3.2 S303.3	
D_y	Distance from node to node (for stress analysis)	m	ft		S301.3.2 S303.3	

_		Unit	s [Note (1)]	Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
D_z	Distance from node to node (for stress analysis)	m	ft	• • •	S301.3.2 S303.3	
d	Inside diameter of pipe (note differences in definition between paras. 304.1.1 and K304.1.1)	mm	in.	304.1.1 304.1.2 K304.1.1 K304.1.2	D300 K305.1.2	(3b) (34b) (34d) (35b) (35d)
d	Pipe inside diameter considering nominal pipe thickness less allowances	mm	in.	320.2	•••	(23d)
d_b	Inside diameter of branch pipe	mm	in.		304.3.4	
d_g	Inside or pitch diameter of gasket	mm	in.	304.5.3	304.5.3 U304.5.3	(15)
d_h	Inside diameter of header pipe	mm	in.		304.3.4	
d_{x}	Design inside diameter of extruded outlet	mm	in.	304.3.4	304.3.4	(9) (10)
d_1	Effective length removed from pipe at branch	mm	in.	304.3.3	304.3.3 App. H	(6) (7)
d_2	Half-width of reinforcement zone	mm	in.	304.3.3 304.3.4	304.3.3 304.3.4 App. H	(7) (10)
E	Quality factor			302.3.1 304.1.1 304.1.2 304.2.3 304.3.3 304.4.1 304.5.1 304.5.2 304.5.3 K304.5.3 S301.1 S301.2 S303.1	App. A Notes App. H	(3a) (3b) (3c) (4a) (4b) (4c) (15)
Ε	Modulus of elasticity (at specified condition)	MPa	ksi	A319.3.2 X302.2.3	App. C	(X1)
E _a	Reference modulus of elasticity at 21°C (70°F)	MPa	ksi	319.3.2 319.4.1 319.4.4 319.5.1		(21) (22)
E_c	Casting quality factor			302.3.1 302.3.3 302.3.5 302.3.6 305.2.3 306.1.4 K302.3.3 K306.1.1 V303.1.1	302.3.3C Table A-1A	

		Unit	ts [Note (1)]	Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
E _j	Joint quality factor			302.3.1 302.3.4 302.3.5 305.2.3 306.1.4 321.1.3 341.4.1 341.5.1 K302.3.4 K305.1.1 K306.1.1 V303.1.1 X302.2.2	302.3.4 App. A Notes Table A-1B	
E _j	Modulus of elasticity for the condition being considered; the as-installed and operating conditions are subscripted as $j=1, 2, 3,$	MPa	ksi		D300	
E _m	Modulus of elasticity at maximum or minimum temperature	MPa	ksi	319.3.2 319.5 319.5.1	•••	(21) (22)
E_t	Modulus of elasticity at test temperature	MPa	ksi	X302.2.3		(X1)
F	Service (design) factor		•••	A302.3.2 A304.1.1 A304.1.2		(26c)
F _a	Axial force range between any two conditions being evaluated	N	lbf	319.4.4	• • •	(17)
F_a	Sustained longitudinal force	N	lb	320.2	•••	(23d)
F _X	Force along the x-axis	N	lb	•••	\$301.5.2 \$302.5.1 \$302.6.3.1 \$303.7.1 \$303.7.2 \$303.7.3	
F _y	Force along the y-axis	N	lb		\$301.5.2 \$302.5.1 \$302.6.3.1	
f	Stress range factor			302.3.5 \$301.1 \$301.7 \$303.1	302.3.5	(1a) (1b) (1c)
f_m	Maximum value of stress range factor			302.3.5		(1c)
g	Root gap for welding	mm	in.	K328.4.3	328.4.4 K328.5.4	
h	Flexibility characteristic		•••	•••	D300	
h	Nominal thread depth	mm	in.	K304.1.1	304.1.1	• • •

		Units [Note (1)]		Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
h _F	Through-wall dimension (height) of a flaw drawn normal to the inside pressure- retaining surface of the component	mm	in.	R307	R307.1 R308.1 R308.2	
h_x	Height of extruded outlet	mm	in.	304.3.4	304.3.4	
I _a	Sustained longitudinal index	•••	•••	320.1 320.2	323.2.2B	(23d)
I _i	Sustained in-plane moment index	•••	•••	320.1 320.2	323.2.2B	(23b1) (23b2)
Io	Sustained out-plane moment index	•••	•••	320.1 320.2	323.2.2B	(23b1) (23b2)
I_t	Sustained torsional moment index	•••		320.1 320.2	323.2.2B	(23c)
i	Stress intensification factor	•••		319.3.6	D300	
i	Service condition			V303.1.1 V303.1.4 V303.2 V304		
i_a	Axial force stress intensification factor			319.4.4	• • •	(17)
iį	In-plane stress intensification factor	• • •		319.4.4 320.2 S301.7	D300	(18) (19) (20) (23b1) (23b2)
i _o	Out-plane stress intensification factor	•••		319.4.4 320.2	D300	(18) (19) (20) (23b1) (23b2)
i_t	Torsional stress intensification factor			319.4.4		(17)
К	Factor determined by ratio of branch diameter to run diameter	• • •	•••	304.3.4	304.3.4	(9)
<i>K</i> ₁	Constant in empirical flexibility equation	• • •		319.4.1		(16)
k	Flexibility factor			319.3.6	D300	
L	Developed length of piping between anchors (the running centerline length between stiffened sections of pipe)	m	ft	304.1.3 319.4.1 K304.2.4		(16)
L ₄	Height of reinforcement zone outside run pipe	mm	in.	304.3.3	304.3.3 App. H	(8)
L ₅	Height of reinforcement zone for extruded outlet	mm	in.	304.3.4	304.3.4	(11)
LMP	Larson-Miller parameter, used to estimate design life	•••	•••	V303.1.3 V303.1.4 V304		(V2) (V3)
l_F	Length of a flaw drawn parallel to the inside pressure-retaining surface of the component	mm	in.	R307	R307.1 R308.1 R308.2	•••

		Unit	Units [Note (1)]		Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation	
М	Length of full thickness pipe adjacent to miter bend	mm	in.	304.2.3	304.2.3	•••	
M_i	In-plane moment range between any two conditions being evaluated	N-mm	inlbf	319.4.4	319.4.4A 319.4.4B	(18) (19) (20)	
M_i	In-plane bending moment for the sustained condition being evaluated	N-mm	inlbf	320.2		(23b1) (23b2)	
M _o	Out-plane moment range between any two conditions being evaluated	N-mm	inlbf	319.4.4	319.4.4A 319.4.4B	(18) (19) (20)	
M _o	Out-plane bending moment for the sustained condition being evaluated	N-mm	inlbf	320.2		(23b1) (23b2)	
M_t	Sustained torsional moment	N-mm	inlbf	320.2		(23c)	
M_t	Torsional moment range between any two conditions being evaluated	N-mm	inlbf	319.4.4	319.4.4A 319.4.4B		
M_{y}	Moment along the y-axis	N-m	ft-lb		\$303.7.1 \$303.7.2 \$303.7.3	•••	
M_z	Moment along the z-axis	N-m	ft-lb	• • •	S301.5.2		
m	Misfit of branch pipe	mm	in.	328.4.3 K328.4.3	328.4.4 K328.5.4		
N	Equivalent number of full displacement cycles	•••	•••	300.2 302.3.5 K304.8.1	302.3.5	(1c) (1d)	
N _E	Number of cycles of maximum computed displacement stress range			302.3.5		(1d)	
N _i	Number of cycles associated with displacement stress range, S_i ($i = 1, 2,$)			302.3.5		(1d)	
P	Internal design gage pressure	kPa	psi	304.1.1 304.1.2 304.2.1 304.4.1 304.5.1 304.5.2 304.5.3 345.4.2 A304.1.1 A304.1.2 K304.7.2 K304.7.2 K304.8.3 K345.4.2 S301.2		(3a) (3b) (3c) (15) (24) (26a) (26b) (26c) (34a) (34b) (34c) (34d) (35a) (35b) (35c) (35d) (37) (38)	
P_{a2}	See BPV Code, Section VIII, Division 1, UG-28			304.1.3	•••		

		Units [Note (1)]	Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
P_i	Gage pressure during service condition i	kPa	psi	V303.1.1 V303.2	•••	(V1)
P _j	Piping internal gage pressure for the condition being considered; the as-installed and operating conditions are subscripted as $j = 1, 2, 3, \ldots$	kPa	psi	320.2 \$300.1 \$301 \$302 \$303	D300 S301.1 S301.3.1 S302.1 S302.6.2.1	(23d) D300 Note (6)
P_m	Maximum allowable internal pressure for miter bends	kPa	psi	304.2.3		(4a) (4b) (4c)
P_{max}	Maximum allowable gage pressure for continuous operation of component at maximum design temperature	kPa	psi	V303.1.1	•••	(V1)
P_S	Limiting design pressure based on column instability, for convoluted U-shaped bellows	kPa	psi	X302.2.3	• • •	(X1)
P_T	Minimum test gage pressure	kPa	psi	345.4.2 A382.2.5 K345.4.2 X302.2.3		(24) (27) (38) (X1)
9	Temporary symbol for D/t			H302	• • •	
R	Range of reaction forces or moments in flexi- bility analysis	N or N-mm	lbf or inlbf	319.5.1	• • •	(21)
R_a	Estimated instantaneous reaction force or moment at installation temperature	N or N-mm	lbf or inlbf	319.5.1		
Ra	Roughness average	μm	μin.	K302.3.3	302.3.3C 341.3.2 K341.3.2	•••
R _m	Estimated instantaneous maximum reaction force or moment at maximum or minimum metal temperature	N or N-mm	lbf or inlbf	319.5.1	•••	(21)
R_T	Ratio of the average temperature dependent trend curve value of tensile strength to the room temperature tensile strength			302.3.2(d)(7)	•••	•••
R_Y	Ratio of the average temperature dependent trend curve value of yield strength to the room temperature yield strength			302.3.2(d)(7) K302.3.2	•••	(31)
R_1	Effective radius of miter bend	mm	in.	304.2.3	304.2.3	(4b) (5)
R_1	Bend radius of welding elbow or pipe bend	mm	in.	304.2.1	304.2.1 D300	(3d) (3e)
r	Corner radius of lap joint stub end	mm	in.	308.2.1	• • •	
r _i	Ratio of lesser computed displacement stress range, S_i , to maximum computed stress range, S_E ($i = 1, 2,$)			302.3.5		(1d)

		Units [Note (1)]		Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
r_{x}	External contour radius of extruded outlet	mm	in.	304.3.4	304.3.4 D300	(12)
r_2	Mean radius of pipe using nominal wall thickness, \overline{T}	mm	in.	304.2.3 319.4.4	304.2.3 D300	(4a) (4b) (4c)
S	Basic allowable stress for metals	MPa	ksi	300.2 302.3.1 302.3.5 304.1.1 304.1.2 304.1.3 304.2.1 304.2.3 304.3.3 304.4.1 304.5.1 304.5.2 304.5.2 304.5.3 304.7.2 345.4.2 H300 S301.2	A-1 A-1M	(3a) (3b) (3c) (4a) (4b) (4c) (15) (24)
S	Bolt design stress	MPa	ksi	300.2 302.3.1	A-2	
S	Design stress for nonmetals			A302.3.1 A304.1.1 A304.1.2 A304.5.2 A345.4.2	B-1	(26a) (26b) (26c)
S	Allowable stress for metals	MPa	ksi	K304.1.2 K304.5.3 K304.7.2 K345.4.2	K-1	(34a) (34b) (34c) (34d) (35a) (35b) (35c) (35d) (38)
S	Stress intensity	MPa	ksi	K304.8.3	• • •	(37)
S_A	Allowable displacement stress range	МРа	ksi	300.2 302.3.5 319.2.3 319.3.4 319.4.1 319.4.4 K302.3.5 S301.7 S303.8	\$301.7 \$303.7.1 \$303.7.2 \$303.7.3	(1a) (1b) (16) (32)
S_a	Bolt design stress at atmospheric temperature	MPa	ksi	304.5.1 A304.5.1	•••	•••
S_a	Axial stress range due to displacement strains	MPa	ksi	319.4.4	•••	(17)
S_a	Stress due to sustained longitudinal force	MPa	ksi	320.2	•••	(23a) (23d)
S_b	Bolt design stress at design temperature	MPa	ksi	304.5.1 A304.5.1		

		Units [Note (1)]				
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
S_b	Bending stress range due to displacement strains	MPa	ksi	319.4.4	•••	(17) (18) (19) (20)
S_b	Stress due to sustained bending moments	MPa	ksi	320.2	•••	(23a) (23b1) (23b2)
S_c	Basic allowable stress at minimum metal tem- perature expected during the displacement cycle under analysis	MPa	ksi	302.3.5 K302.3.5 S301.7	•••	(1a) (1b) (32)
S_d	Allowable stress from Table A-1 or Table A-1M for the material at design temperature	MPa	ksi	V303.1.1 V304	•••	(V1)
S _E	Computed displacement stress range	MPa	ksi	300.2 302.3.5 319.2.3 319.4.4 319.5.1 K302.3.5 S301.7 S303.7	\$301.7 \$303.7.1 \$303.7.2 \$303.7.3	(17) (22)
S_F	Separation distance between the outer extent of a flaw and the nearest surface	mm	in.	R307	R307.1	
S_f	Allowable stress for flange material or pipe	MPa	ksi	304.5.1 304.5.2 A304.5.1		• • •
S_H	Mean long-term hydrostatic strength (LTHS)	kPa	psi	A328.2.5	• • •	(27)
S_h	Basic allowable stress at maximum metal temperature expected during the displacement cycle under analysis	MPa	ksi	302.3.5 319.5.1 K302.3.5 S301.6 S301.7	\$301.6 \$302.6.3.1	(1a) (1b) (22) (32)
S_i	A computed displacement stress range smaller than $S_{\mathcal{E}}(i=1, 2, \ldots)$	MPa	ksi	302.3.5	•••	(1d)
S _i	Equivalent stress during service condition, i (the higher of S_{pi} and S_L)	MPa	ksi	V303.1.1 V303.1.2 V304		• • • •
S_L	Stress due to sustained loads	MPa	ksi	302.3.5 302.3.6 320.1 320.2 K302.3.5 K302.3.6 S301.3 S301.6 S301.7 S302.6.1 S302.6.3 S303.6 V303.1.1 V303.1.4 V304	\$301.6 \$302.6.3.1 \$307.7.3	(1b) (23a)

_		Units	Units [Note (1)]		Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation	
T_h	Header pipe wall thickness (measured or mini- mum in accordance with purchase specification)	mm	in.	304.3.1 304.3.3 304.3.4	304.3.3 304.3.4 App. H	(7) (10)	
T _i	Temperature of the component for the coincident operating pressure—temperature condition, i, under consideration	°C	°F	V303.1.4 V303.2	302.3.5	(V3)	
T _j	Pipe metal temperature for the condition being considered; the as-installed and operating conditions are subscripted as $j = 1, 2, 3, \ldots$	°C	°F	\$300.1 \$301 \$302 \$303	\$301.1 \$301.3.1 \$302.1	•••	
T _r	Minimum thickness of reinforcing ring or sad- dle made from pipe (nominal thickness if made from plate)	mm	in.	304.3.3 H304 H312 H314	304.3.3		
T_s	Effective branch wall thickness	mm	in.	319.4.4	• • •		
T_X	Corroded finished thickness of extruded outlet	mm	in.	304.3.4	304.3.4	(12)	
T_1	Maximum temperature (for stress analysis)	°C	°F	S301.7 S302.5	S301.3.1	• • •	
<i>T</i> ₂	Minimum temperature (for stress analysis)	°C	°F	S301.7 S302.5	S301.3.1		
T_2	Minimum thickness of fabricated lap	mm	in.		328.5.5		
Ŧ	Nominal wall thickness of pipe	mm	in.	A328.2.5 S301.2	323.2.2A 328.5.2B 328.5.5 K302.3.3D D300	(27)	
\overline{T}_b	Nominal branch pipe wall thickness	mm	in.	319.4.4 328.5.4 331.1.3	304.3.3 328.5.4D 328.5.4F App. H		
\overline{T}_h	Nominal header pipe wall thickness	mm	in.	319.4.4 328.5.4 331.1.3	304.3.3 328.5.4D	• • •	
\overline{T}_m	Nominal thickness of branch weld for integrally reinforced branch connection fittings [see para. 328.5.4(c) for further details]	mm	in.	328.5.4(c) 331.1.3	328.5.4F	•••	
\overline{T}_r	Nominal thickness of reinforcing ring or saddle	mm	in.	328.5.4 331.1.3 H302	328.5.4D D300	•••	
\overline{T}_w	Nominal wall thickness, thinner of components joined by butt weld	mm	in.	344.6.2 R304 R307 R308	341.3.2 K341.3.2 R307.1 R308.1 R308.2		

		Units	s [Note (1)]	Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
t	Pressure design thickness	mm	in.	304.1.1 304.1.2 304.1.3 304.2.1 304.3.3 304.4.1 304.5.2 A304.1.1 A304.1.2 A304.1.1 K304.1.2 K304.1.3 K304.1.2	304.1.1 App. A Notes	(2) (3a) (3b) (3c) (13) (14) (25) (26a) (26b) (26c) (33) (34a) (34b) (34c) (34d) (36)
t_b	Pressure design thickness of branch	mm	in.	304.3.3 304.3.4	304.3.3 304.3.4 App. H	(8) (11)
t_c	Throat thickness of cover fillet weld	mm	in.	328.5.4 331.1.3	328.5.4D 328.5.4F App. H	•••
t_h	Pressure design thickness of header	mm	in.	304.3.3 304.3.4	304.3.3 304.3.4 App. H	(6) (7) (9) (10)
t _i	Total duration of service condition, i , at pressure, P_i , and temperature, T_i	h	hr	V303.2 V304		(V4)
t _m	Minimum required thickness, including mechanical, corrosion, and erosion allowances	mm	in.	304.1.1 304.2.1 304.4.1 304.5.2 304.5.3 328.4.2 A304.1.1 K304.2.1 K304.2.1 K304.5.2 K328.4.2 S301.2	304.5.3 328.3.2 328.4.3 K341.3.2 U304.5.3	(2) (13) (14) (15) (25) (33) (36)
t_{min}	For branch, the smaller of \overline{T}_b or \overline{T}_r	mm	in.	328.5.4	328.5.4D	
t_{ri}	Rupture life of a component subjected to repeated service conditions, i , and stress, S_i	h	hr	V303.1.4 V303.2 V304	• • •	(V3) (V4)
U	Straight line distance between anchors	m	ft	319.4.1	•••	(16)
и	Creep-rupture usage factor, summed up from individual usage factors, t_i/t_{ri}	•••	•••	V303.2 V303.3 V304		(V4)

		Units	s [Note (1)]	Reference		
Symbol	Definition	SI	U.S.	Paragraph	Table/Fig./App.	Equation
W	Weld joint strength reduction factor			302.2.2 302.3.5 304.1.1 304.1.2 304.2.1 304.2.3 304.3.3 304.4.1 304.5.1 304.5.2 304.5.3 V303.1.1	302.3.5 App. H	(3a) (3b) (3c) (4a) (4b) (4c) (15)
Χ	Factor for modifying the allowable stress range, S_t , for bellows expansion joint (see para. X302.1.3 for further details)	•••		X302.1.3		(X2)
X_1	Ring reinforcement area	mm^2	in. ²	H304	• • •	
X_2	Fillet weld reinforcement area	mm^2	in. ²	H304		
X _{min}	Size of fillet weld to slip-on or socket welding flange	mm	in.	•••	328.5.2B	
Υ	Coefficient for effective stressed diameter	•••	• • •	304.1.1 304.1.2 S301.2	304.1.1	(3a) (3b) (3c)
Y+	Single acting support — a pipe support that provides support to the piping system in only the vertically upward direction	•••		\$300.1 \$302 \$302.1 \$302.6.2	\$302.5.1 \$302.6.3.1	
y	Resultant of total displacement	mm	in.	319.4.1		(16)
Ζ	Section modulus of pipe	mm^3	in. ³	319.4.4		(18) (19)
Ζ	Sustained section modulus of pipe	mm^3	in. ³	320.2	• • •	(23b1) (23c)
Z_e	Effective section modulus for branch	mm^3	in. ³	319.4.4		(20)
Z_e	Sustained effective section modulus for branch	mm ³	in. ³	320.2		(23b2)
α	Angle of change in direction at miter joint	deg	deg	304.2.3 306.3.2 306.3.3 M306.3	304.2.3	
β	Smaller angle between axes of branch and run	deg	deg	304.3.1 304.3.3	304.3.3	(6) (8)
γ	Span of the pipe bend	deg	deg	304.2.1	304.2.1	
θ	Angle of miter cut	deg	deg	304.2.3	304.2.3 D300	(4a) (4c) (5)

GENERAL NOTE: For Code reference to this Appendix, see para. 300.3.

⁽¹⁾ Note that the use of these units is not required by the Code. They represent sets of consistent units (except where otherwise stated) that may be used in computations, if stress values in ksi and MPa are multiplied by 1,000 for use in equations that also involve pressure in psi and kPa values.

INTENTIONALLY LEFT BLANK

APPENDIX K ALLOWABLE STRESSES FOR HIGH PRESSURE PIPING

Specification Index for Appendix K

Spec. No.	Title	Page
ASTM		
A53 A105 A106 A182	Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless Carbon Steel Forgings for Piping Applications Seamless Carbon Steel Pipe for High-Temperature Service Forged or Rolled Alloy and Stainless Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-	426 426 426
71102	Temperature Service	428, 430
A210 A234	Seamless Medium-Carbon Steel Boiler and Superheater Tubes	426 426
A312 A333	Seamless, Welded, and Heavily Cold Worked Austenitic Stainless Steel Pipes	428, 430
A334 A335 A350 A358	Toughness	426, 428 426, 428 426 426, 428 428, 430
A403 A420	Wrought Austenitic Stainless Steel Piping Fittings	430 426, 428
A508	Quenched and Tempered Vacuum-Treated Carbon and Alloy Steel Forgings for Pressure Vessels	428
A694	Carbon and Alloy Steel Forgings for Pipe Flanges, Fittings, Valves, and Parts for High-Pressure Transmission	
	Service	426
A723	Alloy Steel Forgings for High-Strength Pressure Component Application	428
B164 B165 B166	Nickel-Copper Alloy Rod, Bar and Wire	432 432
B167	Tungsten Alloy (UNS N06674) Rod, Bar, and Wire	432
	Tungsten Alloy (UNS N06674) Seamless Pipe and Tube	432
B338 B363	Seamless and Welded Titanium and Titanium Alloy Tubes for Condensers and Heat Exchangers	434 434
B366	Factory-Made Wrought Nickel and Nickel Alloy Fittings	434
B381	Titanium and Titanium Alloy Forgings	434
B564 B574	Nickel Alloy Forgings Low-Carbon Nickel-Chromium-Molybdenum, Low-Carbon Nickel-Molybdenum-Chromium, Low-Carbon Nickel-Molybdenum-Chromium-Tantalum, Low-Carbon Nickel-Chromium-Molybdenum-Copper, and Low-	432
	Carbon Nickel-Chromium-Molybdenum-Tungsten Alloy Rod	432
B622	Seamless Nickel and Nickel-Cobalt Alloy Pipe and Tube	432
B861	Titanium and Titanium Alloy Seamless Pipe	434
API		
5L	Line Pipe	426

GENERAL NOTE: It is not practical to refer to a specific edition of each standard throughout the Code text. Instead, the approved edition references, along with the names and addresses of the sponsoring organizations, are shown in Appendix E.

NOTES FOR TABLE K-1

GENERAL NOTES:

- (a) The allowable stress values and P-Number assignments in Table K-1, together with the referenced Notes, are requirements of Chapter IX.
- (b) Notes (1) through (5) and (12) are referenced in column headings or in body headings for material type and product form; Notes (6) through (11) and (13) through (18) are referenced in the Notes column for specific materials.
- (c) At this time, metric equivalents have not been provided in Table K-1. To convert stress values in Table K-1 to MPa at a given temperature in °C, determine the equivalent temperature in °F and interpolate to calculate the stress value in ksi at the given temperature. Multiply by 6.895 to determine allowable stress in MPa at the given temperature.
- (d) The following abbreviations are used in the Condition and Size Range columns: ann., annealed; A.W., as worked; C.W., cold worked; H.W., hot worked; hex., hexagons; O.D., outside diameter; rd., rounds; rec., rectangles; rel., relieved; sq., squares; and str., stress.
- (e) Samples representative of all piping components, as well as their fabrication welds, shall be impact tested in accordance with para. K323.3.
- (f) A product analysis of the material shall be performed. See para. K323.1.5.
- (g) Material defects may be repaired by welding only in accordance with para. K323.1.6.

NOTES:

- See the BPV Code, Section IX, QW-200.3 for a description of P-Number groupings. P-Numbers are indicated by number or by a number followed by a letter (e.g., 8, 5B, and 11A).
- (2) The stress values in Table K-1 are allowable stresses in tension in accordance with para. K302.3.1(a). Stress values in shear and bearing are stated in para. K302.3.1(b), those in compression in para. K302.3.1(c).
- (3) Material minimum service temperature shall be in accordance with para. K323.2.2.
- (4) The temperature limit for materials shall be in accordance with para, K323.2.1.
- (5) Pipe and tubing shall be examined for longitudinal defects in accordance with Table K305.1.2.

- (6) This type or grade is permitted only in the seamless condition.
- (7) Galvanized pipe furnished to this specification is not permitted for pressure containing service. See para. K323.4.2(b).
- (8) If this grade is cold expanded, the most severely deformed portion of a representative sample shall be impact tested in accordance with para. K323.3.
- (9) For High Pressure Fluid Service at temperatures above 100°F but not exceeding 400°F, either the allowable stresses listed in Table A-1 for this material or allowable stresses derived in accordance with the requirements of para. K323.2.4 may be used. This material shall not be used for Chapter IX service above 400°F.
- (10) This material may require special consideration for welding qualification. See the BPV Code, Section IX, QW/QB-422. For use in this Code, a qualified WPS is required for each strength level of material.
- (11) No welding is permitted on this material.
- (12) Stress values printed in *italics* exceed two-thirds of the expected yield strength at temperature. Stress values in **bold-face** are equal to 90% of yield strength at temperature. See para. K302.3.2.
- (13) Welds shall be of a design that permits fully interpretable radiographic examination; joint quality factor, E_j , shall be 1.00 in accordance with para. K302.3.4.
- (14) Pipe furnished to this specification shall be supplied in the solution heat treated condition.
- (15) This unstabilized grade of stainless steel increasingly tends to precipitate intergranular carbides as the carbon content increases above 0.03%. See also para. F323.4(c)(2).
- (16) For material thickness >127 mm (5 in.), the specified minimum tensile strength is 448 MPa (65 ksi).
- (17) For material thickness >127 mm (5 in.), the specified minimum tensile strength is 483 MPa (70 ksi).
- (18) Stress values shown are for the lowest strength base material permitted by the specification to be used in the manufacture of this grade of fitting. If a higher strength base material is used, the higher stress values for that material may be used in design.

Specified Min. Strength, ksi P-No. Spec. Type Material (1) or Grade Notes Tensile Yield No. Carbon Steel Pipes and Tubes (5) A53 1 В (6)(7) 60 35 A106 1 В 60 35 . . . (6) A333 1 6 60 35 . . . (6) A334 1 6 60 35 API 5L В 35 1 (6)(8)60 . . . A210 1 A-1 60 37 A106 1 C 70 40 A210 C 1 70 40 API 5L 1 X42 (6)(8)(9)60 42 . . . API 5L X46 (6)(8)(9) 1 63 46 . . . API 5L X52 (6)(8)(9) 66 52 1 . . . API 5L (6)(8)(9)(10) 1 X56 71 56 . . . API 5L X60 (6)(8)(9)(10) 75 60 . . . API 5L X65 (6)(8)(9)(10) 77 65 1 . . . API 5L 1 X70 (6)(8)(9)(10) 82 70 API 5L 1 X80 (6)(8)(9)(10) 90 80 . . . Forgings and Fittings A234 WPB 1 (6) 60 35 A420 1 WPL6 (6) 60 35 . . . A105 1 70 36 LF2 70 A350 1 36 . . . WPC A234 1 (6) 70 40 . . . A694 1 F42 60 42 . . . A694 1 F46 60 46 F48 A694 62 48 1 A694 1 F50 64 50 A694 1 F52 66 52 . . . A694 1 F56 68 56 . . . A694 F60 75 60 1 A694 77 65 1 F65 A694 1 F70 82 70 . . . Low and Intermediate Alloy Steel Pipes and Tubes (5) $C - \frac{1}{2}Mo$ P1 A335 3 55 30 . . . $1Cr^{-1}/_{2}Mo$ 4 P12 60 32 A335 . . . $1^{1}/_{4}Cr-^{1}/_{2}Mo$ A335 P11 60 30 4 . . . $2^{1}/_{4}$ Cr-1Mo A335 5A P22 60 30 . . . $5Cr-\frac{1}{2}Mo$ A335 5B P5 60 30 . . .

Table K-1 Allowable Stresses in Tension for Metals for Chapter IX

Numbers in Parentheses Refer to Notes for Appendix K Table; Specifications Are ASTM Unless Otherwise Indicated

		ding	Not Excee	erature, °F,	Metal Tempo		to Obtain [Notes (2	ply by 1000	ksi (Multij	ble Stress,	Allowable Stres			
											Min.			
Spec. No	Type or Grade	700	650	600	500	400	300	250	200	150	Temp. to 100			
Carbon Stee														
d Tubes (5)	Pipes and													
A53	В	16.7	17.3	17.9	19.0	19.9	20.7	21.0	21.4	21.9	23.3			
A106	В	16.7	17.3	17.9	19.0	19.9	20.7	21.0	21.4	21.9	23.3			
A333	6	16.7	17.3	17.9	19.0	19.9	20.7	21.0	21.4	21.9	23.3			
A334	6	16.7	17.3	17.9	19.0	19.9	20.7	21.0	21.4	21.9	23.3			
API 5L	В	16.8	16.9	17.3	18.9	20.0	20.7	• • •	21.3	• • •	23.3			
A210	A-1	17.7	18.3	18.9	20.1	21.1	21.8	22.2	22.6	23.2	24.7			
A106	С	19.1	19.7	20.5	21.7	22.8	23.6	24.0	24.4	25.1	26.7			
A210	С	19.1	19.7	20.5	21.7	22.8	23.6	24.0	24.4	25.1	26.7			
API 5L	X42										28.0			
API 5L	X46	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •		30.7			
API 5L	X52										34.7			
API 5L	X56										37.3			
API 5L	X60										40.0			
ADI EI	VCF										42.2			
API 5L API 5L	X65	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	43.3 46.7			
API 5L API 5L	X70 X80	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •				
API 5L	780	• • • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	• • •	53.3			
nd Fittings	Forgings a													
A234	WPB	16.7	17.3	17.9	19.0	19.9	20.7	21.0	21.4	21.9	23.3			
A420	WPL6	16.7	17.3	17.9	19.0	19.9	20.7	21.0	21.4	21.9	23.3			
A105		17.2	17.8	18.4	19.5	20.5	21.2	21.6	22.0	22.5	24.0			
A350	LF2	17.2	17.8	18.4	19.5	20.5	21.2	21.6	22.0	22.5	24.0			
A234	WPC	19.1	19.7	20.5	21.7	22.8	23.6	24.0	24.4	25.1	26.7			
A694	F42	18.1	18.5	18.9	19.8	21.1	22.6	23.6	24.7	25.9	28.0			
A694	F46	19.8	20.2	20.7	21.7	23.1	24.8	25.9	27.1	28.4	30.7			
A694	F48	20.7	21.1	21.6	22.6	24.1	25.9	27.0	28.2	29.6	32.0			
A694	F50	21.5	22.0	22.5	23.6	25.1	27.0	28.1	29.4	30.9	33.3			
A694	F52	22.4	22.9	23.4	24.5	26.1	28.0	29.2	30.6	32.1	34.7			
A694	F56	24.1	24.6	25.2	26.4	28.1	30.2	31.5	33.0	34.6	37.3			
A694	F60	25.8	26.4	27.0	28.3	30.1	32.3	33.7	35.3	37.0	40.0			
A694	F65	28.0	28.6	29.2	30.6	32.6	35.0	36.6	38.2	40.1	43.3			
A694	F70	30.1	30.8	31.4	33.0	35.1	37.7	39.4	41.2	43.2	46.7			
te Allov Stee	Low and Intermedia													
d Tubes (5)		·												
A335	P1	15.7	16.1	16.3	16.9	17.4	18.1	18.4	18.8	19.3	20.0			
A335	P12	15.8	16.0	16.3	16.7	17.3	18.1	18.7	19.3	20.0	21.3			
A335	P11	15.1	15.4	15.7	16.3	16.9	17.5	18.0	18.5	19.0	20.0			
A335	P22	17.9	17.9	17.9	17.9	17.9	18.1	18.4	18.7	19.1	20.0			
A335	P5	16.3	16.6	16.8	17.1	17.2	17.4	17.7	18.1	18.7	20.0			

	Spec.	P-No.	Туре		Specified Min. Strength, ksi	
Material	No.	(1)	or Grade	Notes	Tensile	Yield
Low and Intermediate Alloy Ste Pipes and Tubes (5) (Cont'd)						
3 ¹ / ₂ Ni	A333	9B	3	(6)	65	35
3 ¹ / ₂ Ni	A334	9B	3	(6)	65	35
9Ni	A333	11A	8	(6)	100	75
9Ni	A334	11A	8	(6)	100	75
Forgings and Fittings						
$C-\frac{1}{2}Mo$	A182	3	F1		70	40
$1Cr^{-1}/_2Mo$	A182	4	F12, Cl. 2		70	40
$1\frac{1}{4}Cr - \frac{1}{2}Mo - Si$	A182	4	F11, Cl. 2		70	40
2 ¹ / ₄ Cr–1Mo	A182	5A	F22, Cl. 3		75	45
$5Cr-\frac{1}{2}Mo$	A182	5B	F5	• • •	70	40
2Ni-1 ¹ / ₂ Cr- ¹ / ₄ Mo-V	A723		1, Cl. 1	(11)	115	100
2Ni-1 ¹ / ₂ Cr- ¹ / ₄ Mo-V	A723		1, Cl. 2	(11)	135	120
$2Ni-1\frac{1}{2}Cr-\frac{1}{4}Mo-V$	A723		1, Cl. 3	(11)	155	140
2 ³ / ₄ Ni-1 ¹ / ₂ Cr- ¹ / ₂ Mo-V	A723		2, Cl. 1	(11)	115	100
$2^{3}/_{4}$ Ni- $1^{1}/_{2}$ Cr- $^{1}/_{2}$ Mo-V	A723		2, Cl. 2	(11)	135	120
$2\frac{3}{4}$ Ni- $1\frac{1}{2}$ Cr- $\frac{1}{2}$ Mo-V	A723		2, Cl. 3	(11)	155	140
3 ¹ / ₂ Ni	A420	9B	WPL3	(6)	65	35
3 ¹ / ₂ Ni	A350	9B	LF3	•••	70	37.5
$3\frac{1}{2}Ni-1\frac{3}{4}Cr-\frac{1}{2}Mo-V$	A508	11B	4N, Cl. 2		115	100
4Ni-1 ¹ / ₂ Cr- ¹ / ₂ Mo-V	A723		3, Cl. 1	(11)	115	100
$4Ni-1\frac{1}{2}Cr-\frac{1}{2}Mo-V$	A723		3, Cl. 2	(11)	135	120
$4\text{Ni}-1\frac{1}{2}\text{Cr}-\frac{1}{2}\text{Mo-V}$	A723		3, Cl. 3	(11)	155	140
9Ni	A420	11A	WPL8	(6)	100	75
Stainless Steel (12) Pipes and Tubes (5)						
16Cr-12Ni-2Mo	A312	8	TP316L	(13)	70	25
316L, A240	A358	8	316L, Cl. 1 & 3	(13)(14)	70	25
16Cr-12Ni-2Mo-N	A312	8	TP316LN	(13)	75	30
316LN, A240	A358	8	316LN, Cl. 1 & 3	(13)(14)	75	30
18Cr-8Ni	A312	8	TP304L	(13)	70	25
304L, A240	A358	8	304L, Cl. 1 & 3	(13)(14)	70	25
18Cr-8Ni-N	A312	8	TP304LN	(13)	75	30
304LN, A240	A358	8	304LN, Cl. 1 & 3	(13)(14)	75	30
18Cr–10Ni–Ti smls. $> \frac{3}{8}$ in. thick	A312	8	TP321		70	25

Table K-1 Allowable Stresses in Tension for Metals for Chapter IX (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix K Table; Specifications Are ASTM Unless Otherwise Indicated

Allowable Stress, ksi (Multiply by 1000 to Obtain psi), for Metal Temperature, °F, Not Exceeding [Notes (2)-(4)] Min. Temp. to 100 150 200 250 300 400 500 600 650 700 Type or Grade Spec. No. Low and Intermediate Alloy Steel (Cont'd) Pipes and Tubes (5) (Cont'd) 20.9 20.6 19.9 3 A333 23.3 21.9 21.4 18.9 17.5 16.7 15.7 3 20.9 20.6 A334 23.3 21.9 21.4 19.9 18.9 17.5 16.7 15.7 50.0 48.5 48.0 47.0 44.7 8 A333 . . . 8 50.0 48.5 48.0 47.0 44.7 A334 Forgings and Fittings 26.7 25.7 25.1 24.5 24.1 23.2 22.5 21.8 21.4 21.0 F1 A182 20.9 20.3 20.1 19.7 F12, Cl. 2 26.7 25.0 24.1 23.3 22.7 21.7 A182 26.7 25.3 24.6 24.0 23.4 22.5 21.7 20.9 20.5 20.1 F11, Cl. 2 A182 F22, Cl. 3 30.0 28.3 27.5 26.8 26.3 25.4 24.9 24.3 24.1 23.7 A182 F5 A182 26.7 24.9 24.1 23.6 23.2 22.9 22.7 22.4 22.1 21.7 66.7 65.0 64.0 63.1 62.3 61.3 60.4 59.3 58.4 57.3 1, Cl. 1 A723 71.1 80.0 78.0 76.8 75.7 74.8 73.5 72.5 70.1 68.8 1, Cl. 2 A723 85.8 1, Cl. 3 93.3 91.0 89.6 88.3 87.3 84.6 83.0 81.8 80.3 A723 66.7 65.0 64.0 63.1 62.3 61.3 60.4 59.3 58.4 57.3 2, Cl. 1 A723 80.0 78.0 76.8 75.7 74.8 73.5 72.5 71.1 70.1 68.8 2, Cl. 2 A723 93.3 91.0 89.6 88.3 87.3 85.8 84.6 83.0 81.8 80.3 2, Cl. 3 A723 23.3 21.9 21.4 20.9 20.6 19.9 18.9 17.5 16.7 WPL3 A420 . . . 25.0 23.5 22.9 22.5 22.1 21.3 20.3 18.8 17.9 LF3 A350 . . . 4N, Cl. 2 A508 66.7 64.1 62.8 61.7 60.8 59.5 58.5 57.3 56.7 . . . 65.0 66.7 64.0 63.1 62.3 61.3 60.4 59.3 58.4 57.3 3, Cl. 1 A723 80.0 72.5 70.1 3, Cl. 2 A723 78.0 76.8 75.7 74.8 73.5 71.1 68.8 93.3 91.0 89.6 88.3 87.3 85.8 84.6 83.0 81.8 80.3 3, Cl. 3 A723 50.0 48.5 48.0 47.0 WPL8 44.7 A420 Stainless Steel (12) Pipes and Tubes (5) 16.7 16.7 16.7 15.8 14.8 14.0 13.8 13.5 TP316L A312 16.7 16.7 16.7 15.8 14.8 14.0 13.8 13.5 316L, Cl. 1 & 3 A358 20.0 20.0 20.0 18.9 17.5 16.5 16.0 15.6 TP316LN A312 20.0 20.0 20.0 18.9 17.5 16.5 16.0 15.6 316LN, Cl. 1 & 3 A358 . . . 16.7 16.7 16.7 15.8 14.7 14.0 13.7 13.4 TP304L A312 16.7 16.7 16.7 15.8 14.7 14.0 13.7 13.4 304L, Cl. 1 & 3 A358 20.0 20.0 18.6 16.4 TP304LN 20.0 17.5 16.1 15.9 A312 20.0 20.0 20.0 18.6 17.5 16.4 16.1 15.9 304LN, Cl. 1 & 3 A358 16.7 16.7 15.2 14.9 14.6 TP321 A312 16.7 16.7 16.1 smls. $> \frac{3}{8}$ in. thick

Table K-1 Allowable Stresses in Tension for Metals for Chapter IX (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix K Table; Specifications Are ASTM Unless Otherwise Indicated

	Spec.	P-No.	Туре		Specified Min. Strength, ksi	
Material	No. (1)		or Grade	Notes	Tensile	Yield
Stainless Steel (12) (Cont'd) Pipes and Tubes (5) (Cont'd)						
18Cr−10Ni−Ti smls. $\leq \frac{3}{8}$ in. thick or wld.	A312	8	TP321	(13)	75	30
321, A240	A358	8	321, Cl. 1 & 3	(13)(14)	75	30
18Cr-8Ni 304, A240	A312 A358	8 8	TP304 304, Cl. 1 & 3	(13)(15) (13)(14)(15)	75 75	30 30
16Cr-12Ni-2Mo	A312	8	TP316	(13)(15)	75	30
316, A240	A358	8	316, Cl. 1 & 3	(13)(14)(15)	75 	30
18Cr-13Ni-3Mo	A312	8	TP317	(13)(15)	75	30
18Cr-10Ni-Cb	A312	8	TP347	(13)	75	30
347, A240	A358	8	347, Cl. 1 & 3	(13)(14)	75	30
18Cr-8Ni-N	A312	8	TP304N	(13)(15)	80	35
304N, A240	A358	8	304N, Cl. 1 & 3	(13)(14)(15)	80	35
16Cr-12Ni-2Mo-N 316N, A240	A312 A358	8 8	TP316N 316N, Cl. 1 & 3	(13)(15) (13)(14)(15)	80 80	35 35
Forgings and Fittings						
	4400	0	F24.61	(4.6)	70	25
16Cr 12Ni 2Mo	A182	8 8	F316L	(16)	70 70	25 25
16Cr-12Ni-2Mo	A403	0	WP316L, Cl. S & WX	(13)	70	25
16Cr-12Ni-2Mo-N	A182	8	F316LN	(17)	75	30
16Cr-12Ni-2Mo-N	A403	8	WP316LN, Cl. S & WX	(13)	75	30
18Cr-8Ni	A182	8	F304L	(16)	70	25
18Cr-8Ni	A403	8	WP304L, Cl. S & WX	(13)	70	25
18Cr-8Ni-N	A182	8	F304LN	(17)	75	30
18Cr-8Ni-N	A403	8	WP304LN, Cl. S & WX	(13)	75	30
18Cr-10Ni-Ti	A182	8	F321	(17)	75	30
18Cr-10Ni-Ti	A403	8	WP321, Cl. S & WX	(13)	75	30
18Cr-8Ni	A182	8	F304	(15)(17)	75	30
18Cr–8Ni	A403	8	WP304, Cl. S & WX	(13)(15)	75	30
16Cr-12Ni-2Mo	A182	8	F316	(15)(17)	75	30
16Cr-12Ni-2Mo	A403	8	WP316, Cl. S & WX	(13)(15)	75	30
18Cr-13Ni-3Mo	A403	8	WP317, Cl. S & WX	(13)(15)	75	30
18Cr-10Ni-Cb	A182	8	F347	(17)	75	30
18Cr–10Ni–Cb	A403	8	WP347, Cl. S & WX	(13)	75	30
18Cr-8Ni-N	A182	8	F304N	(15)	80	35
18Cr-8Ni-N	A403	8	WP304N, Cl. S & WX	(13)(15)	80	35
16Cr-12Ni-2Mo-N	A182	8	F316N	(15)	80	35
16Cr-12Ni-2Mo-N	A403	8	WP316N, Cl. S & WX	(13)(15)	80	35

Table K-1 Allowable Stresses in Tension for Metals for Chapter IX (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix K Table; Specifications Are ASTM Unless Otherwise Indicated

Allowable Stress, ksi (Multiply by 1000 to Obtain psi), for Metal Temperature, °F, Not Exceeding [Notes (2)-(4)] Min. Temp. 400 250 to 100 150 200 300 500 600 650 700 Type or Grade Spec. No. Stainless Steel (12) (Cont'd) Pipes and Tubes (5) (Cont'd) 20.0 20.0 20.0 19.4 18.3 TP321 A312 20.0 17.9 17.5 smls. $\leq \frac{3}{8}$ in. thick & wld. 20.0 20.0 20.0 20.0 19.4 18.3 17.9 17.5 321, Cl. 1 & 3 A358 . . . 20.0 20.0 20.0 18.6 17.5 16.4 16.1 15.9 TP304 A312 20.0 20.0 20.0 18.6 17.5 16.4 16.1 15.9 304, Cl. 1 & 3 A358 . . . 20.0 19.3 20.0 20.0 18.0 17.0 16.7 16.3 TP316 A312 20.0 20.0 20.0 19.3 18.0 17.0 16.7 16.3 316, Cl. 1 & 3 A358 20.0 20.0 20.0 19.3 18.0 17.0 16.7 16.3 TP317 A312 20.0 20.0 . . . 20.0 20.0 20.0 19.4 19.0 18.6 TP347 A312 . . . 20.0 20.0 20.0 20.0 19.0 347, Cl. 1 & 3 A358 20.0 19.4 18.6 23.3 22.5 20.3 18.8 17.8 17.6 17.2 TP304N 23.3 A312 22.5 23.3 23.3 20.3 18.8 17.8 17.6 17.2 304N, Cl. 1 & 3 A358 . . . 23.3 . . . 23.3 . . . 23.3 23.3 22.2 21.1 20.5 20.1 TP316N A312 23.3 23.3 23.3 23.3 22.2 21.1 20.5 20.1 316N, Cl. 1 & 3 A358 Forgings and Fittings 16.7 16.7 16.7 15.8 14.8 14.0 13.8 13.5 A182 F316L WP316L, Cl. S & WX 16.7 . . . 16.7 . . . 16.7 15.8 14.8 14.0 13.8 13.5 A403 20.0 20.0 20.0 18.9 17.5 16.5 16.0 15.6 F316LN A182 20.0 18.9 17.5 WP316LN, Cl. S & WX A403 20.0 20.0 16.5 16.0 15.6 16.7 A182 16.7 16.7 15.8 14.7 14.0 13.7 13.4 F3041 WP304L, Cl. S & WX A403 16.7 16.7 15.8 14.7 14.0 13.7 13.4 . . . 16.7 . . . 20.0 20.0 20.0 18.6 17.5 16.4 16.1 15.9 F304LN A182 20.0 20.0 20.0 18.6 17.5 16.4 16.1 15.9 WP304LN, Cl. S & WX A403 20.0 20.0 20.0 20.0 19.4 18.3 17.9 17.5 A182 F321 20.0 20.0 19.4 18.3 17.9 WP321, Cl. S & WX A403 20.0 20.0 17.5 20.0 20.0 20.0 18.6 17.5 16.4 16.1 15.9 F304 A182 20.0 20.0 20.0 18.6 17.5 16.4 16.1 15.9 WP304, Cl. S & WX A403 20.0 20.0 20.0 19.3 18.0 17.0 16.7 16.3 A182 WP316, Cl. S & WX 20.0 20.0 20.0 19.3 18.0 17.0 16.7 16.3 A403 . . . WP317, Cl. S & WX 20.0 20.0 20.0 19.3 18.0 17.0 16.7 16.3 A403 . . . 20.0 20.0 20.0 20.0 20.0 19.4 19.0 18.6 F347 A182 20.0 20.0 20.0 20.0 20.0 19.4 19.0 18.6 WP347, Cl. S & WX A403 23.3 23.3 22.5 20.3 18.8 17.8 17.6 17.2 A182 F304N WP304N, Cl. S & WX 23.3 23.3 22.5 20.3 18.8 17.8 17.6 17.2 A403 23.3 23.3 23.3 23.3 22.2 21.0 20.5 20.1 A182 F316N 22.2 20.1 WP316N, Cl. S & WX 23.3 23.3 23.3 23.3 21.0 20.5 A403

Numbers in Parentheses Refer to Notes for Appendix K Table; Specifications Are ASTM Unless Otherwise Indicated

	Spec.	P-No	Size P-No. UNS Range,					ed Min. gth, ksi
Material	No.	(1)	Number	Condition	in.	Notes	Tensile	Yield
Nickel and I Pipes and	Nickel Alloy d Tubes (5)	(12)						
Ni-Cu	B165	42	N04400	Annealed	>5 O.D.		70	25
Ni-Cr-Fe	B167	43	N06600	H.W.	>5 O.D.		75	25
Ni–Cr–Fe	B167	43	N06600	H.W. ann.	>5 O.D.		75	25
Ni-Cu	B165	42	N04400	Annealed	≤5 O.D.		70	28
Ni-Cr-Fe	B167	43	N06600	H.W.	≤5 O.D.		80	30
Ni-Cr-Fe	B167	43	N06600	H.W. ann.	≤5 O.D.		80	30
Ni-Cr-Fe	B167	43	N06600	C.W. ann.	>5 O.D.		80	30
Ni-Cr-Fe	B167	43	N06600	C.W. ann.	≤5 O.D.		80	35
Ni-Mo-Cr	B622	43	N10276	• • •	All		100	41
Ni-Cu	B165	42	N04400	Str. rel.	All		85	55
Forgings	and Fittings							
Ni-Cu	B366	42	N04400		All	(13)(18)	70	25
Ni-Cu	B564	42	N04400	Annealed	All		70	25
Ni-Cr-Fe	B366	43	N06600	• • •	All	(13)(18)	75	25
Ni-Cr-Fe	B564	43	N06600	Annealed	All		80	35
Ni-Mo-Cr	B366	43	N10276	• • •	All	(13)	100	41
Ni-Mo-Cr	B564	43	N10276	Annealed	All	• • •	100	41
Rod and	Bar							
Ni-Cu	B164	42	N04400	Annealed	All		70	25
Ni-Cr-Fe	B166	43	N06600	C.W. ann. & H.W. ann.	All		80	35
Ni-Cr-Fe	B166	43	N06600	H.W., A.W.	Sq., rec. & hex.		85	35
Ni-Cr-Fe	B166	43	N06600	H.W., A.W.	>3 rd.	• • •	85	35
Ni-Cu	B164	42	N04400	H.W.	Rod, sq. & rec. ≤ 12 , hex. $\leq 2\frac{1}{8}$	•••	80	40
Ni-Cr-Fe	B166	43	N06600	H.W., A.W.	$\frac{1}{2}$ to 3 rd.		90	40
Ni-Mo-Cr	B574	43	N10276		All		100	41
Ni-Cr-Fe	B166	43	N06600	H.W., A.W.	$\frac{1}{4}$ to $\frac{1}{2}$ rd.		95	45

Table K-1 Allowable Stresses in Tension for Metals for Chapter IX (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix K Table; Specifications Are ASTM Unless Otherwise Indicated

	Allowab	le Stress, k			Obtain psi), lotes (2)–(4)		emperature,	°F, Not			
Min. Temp.										UNS	
to 100	150	200	250	300	400	500	600	650	700	Number	Spec. No.
										Nickel and Nic Pipes an	ckel Alloy (12) d Tubes (5)
16.7		14.7		13.7	13.2	13.2	13.2	13.2	13.2	N04400	B165
16.7		16.7		16.7	16.7	16.7	16.7	16.7	16.7	N06600	B167
16.7		16.7		16.7	16.7	16.7	16.7	16.7	16.7	N06600	B167
18.7		16.5		15.4	14.8	14.8	14.8	14.8	14.8	N04400	B165
20.0		20.0		20.0	20.0	20.0	20.0	20.0	20.0	N06600	B167
20.0		20.0		20.0	20.0	20.0	20.0	20.0	20.0	N06600	B167
20.0		20.0		20.0	20.0	20.0	20.0	20.0	20.0	N06600	B167
23.3		23.3		23.3	23.3	23.3	23.3	23.3	23.3	N06600	B167
27.3		27.3		27.3	27.3	26.9	25.2	24.6	24.0	N10276	B622
36.7		32.3		30.2	29.1	29.1				N04400	B165
										Forgings	and Fittings
16.7		14.7		13.7	13.2	13.2	13.2	13.2	13.2	N04400	B366
16.7		14.7		13.7	13.2	13.2	13.2	13.2	13.2	N04400	B564
16.7		16.7		16.7	16.7	16.7	16.7	16.7	16.7	N06600	B366
23.3		23.3		23.3	23.3	23.3	23.3	23.3	23.3	N06600	B564
27.3		27.3	• • •	27.3	27.3	26.9	25.2	24.6	24.0	N10276	B366
27.3	• • •	27.3	• • •	27.3	27.3	26.9	25.2	24.6	24.0	N10276	B564
										F	Rod and Bar
16.7		14.7		13.7	13.2	13.2	13.2	13.2	13.2	N04400	B164
23.3		23.3		23.3	23.3	23.3	23.3	23.3	23.3	N06600	B166
23.3		23.3		23.3	23.3	23.3	23.3	23.3	23.3	N06600	B166
23.3	• • •	23.3		23.3	23.3	23.3	23.3	23.3	23.3	N06600	B166
26.7		23.5		21.9	21.2	21.2	21.2	21.2	21.2	N04400	B164
26.7		24.5		23.1	22.0	21.2	20.7	20.6	20.4	N06600	B166
27.3		27.3		27.3	27.3	26.9	25.2	24.6	24.0	N10276	B574
30.0		21.2		21.2	21.2	21.2	21.2	21.2	21.1	N06600	B166

Table K-1 Allowable Stresses in Tension for Metals for Chapter IX (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix K Table; Specifications Are ASTM Unless Otherwise Indicated

	Spec. P-No.				Specified Min. Strength, ksi		
Material	No.	(1)	Grade	Notes	Tensile	Yield	
Titanium and Tit Pipes and Tub							
Ti	B861	51	2		50	40	
Ti	B338	51	2	(6)	50	40	
Ti-0.2Pd	B861	51	7		50	40	
Ti-0.2Pd	B338	51	7	(6)	50	40	
Ti	B861	52	3		65	55	
Ti	B338	52	3	(6)	65	55	
Forgings and	Fittings						
Ti	B363	51	WPT2	(6)	50	40	
Ti	B381	51	F2		50	40	
Ti-0.2Pd	B381	51	F7	• • •	50	40	
Ti	B363	52	WPT3	(6)	65	55	
Ti	B381	52	F3	• • •	65	55	

Table K-1 Allowable Stresses in Tension for Metals for Chapter IX (Cont'd)

Numbers in Parentheses Refer to Notes for Appendix K Table; Specifications Are ASTM Unless Otherwise Indicated

	Allowal	ole Stress, k	. , ,	•	Obtain psi), lotes (2)–(4)		emperature,	°F, Not			
Min. Temp. to 100	150	200	250	300	400	500	600	650	700	Grade	Spec. No.
										Titanium and [*] Pipes ar	Fitanium Alloy nd Tubes (5)
26.7		21.0		17.1	13.1	9.9	7.6			2	B861
26.7		21.0		17.1	13.1	9.9	7.6			2	B338
26.7		21.0		17.1	13.1	9.9	7.6			7	B861
26.7	• • •	21.0		17.1	13.1	9.9	7.6			7	B338
36.7		29.3		23.8	19.1	15.0	11.4			3	B861
36.7		29.3		23.8	19.1	15.0	11.4			3	B338
										Forgings	and Fittings
26.7		21.0		17.1	13.1	9.9	7.6			WPT2	B363
26.7		21.0		17.1	13.1	9.9	7.6			F2	B381
26.7		21.0		17.1	13.1	9.9	7.6			F7	B381
36.7		29.3		23.8	19.1	15.0	11.4			WPT3	B363
36.7		29.3		23.8	19.1	15.0	11.4			F3	B381

APPENDIX L ALUMINUM ALLOY PIPE FLANGES

L300 GENERAL

This Appendix covers pressure–temperature ratings, materials, dimensions, and marking of forged aluminum alloy flanges, as an alternative to applying the rules in paras. 304.5.1(b) and 304.5.2(b). DN 15 (NPS $^{1}\!_{2}$) through DN 600 (NPS 24) flanges may be welding neck, slip-on, socket welding, lapped, or blind in ratings of Classes 150, 300, and 600.

Requirements and recommendations regarding bolting and gaskets are included.

L301 PRESSURE-TEMPERATURE RATINGS

L301.1 Ratings Basis

Ratings are maximum allowable working gage pressures at the temperatures shown in Tables L301.2M and L301.2U for the applicable material and pressure Class. For intermediate temperatures, linear interpolation is permitted.

L301.2 Ratings of Flanged Joints

- (a) In addition to the considerations in para. F312.1, consideration must be given to the low modulus of elasticity of aluminum alloys. External moments should be limited, and controlled bolt tightening or other techniques may be necessary to achieve and maintain a leak-free joint.
- (*b*) For ratings of slip-on and socket welding flanges made of Alloy 6061-T6, see Tables L301.2M and L301.2U, Note (3).

L301.3 Temperature Considerations

Application of the ratings in this Appendix to flanged joints at both high and low temperatures shall take into consideration the risk of leakage due to forces and moments developed in the connected piping or equipment. The following provisions are intended to minimize these risks.

L301.3.1 Flange Attachment. Slip-on and socket welding flanges are not recommended for service below –50°F if flanges are subject to thermal cycling.

L301.3.2 Differential Thermal Expansion and Conductivity. Because aluminum alloys have thermal expansion coefficients approximately twice those for steel, and thermal conductivity approximately three times that of steel, it may be necessary to provide for

differential expansion and expansion rates between components of the flanged joint. Consideration shall be given to thermal transients (e.g., startup, shutdown, and upset) in addition to the operating temperature of the joint.

L301.4 Hydrostatic Test

A flange shall be capable of withstanding a hydrostatic test at 1.5 times its 100°F pressure rating.

L302 MARKING

Marking shall be in accordance with MSS SP-25, except as follows. Marking shall be stamped on the edge of each flange.

L302.1 Name

The manufacturer's name or trademark shall be applied.

L302.2 Material

The marking ASTM B247 shall be applied, followed by the applicable alloy and temper designations.

L302.3 Rating

The marking shall be the applicable rating Class — 150, 300, or 600.

L302.4 Designation

The marking B31.3L shall be applied.

L302.5 Size

The marking of NPS shall be applied. A reducing size shall be designated by its two nominal pipe sizes. See examples in Note (4) of Table 6, ASME B16.5.

L303 MATERIALS

L303.1 Flange Material

Flanges shall be forgings conforming to ASTM B247. For specific alloys and tempers, see Tables L301.2M and L301.2U. For precautions in use, see para. 323.5 and Appendix F, para. F323.

L303.1.1 Repair Welding of Flanges. Repair welding of flanges manufactured to this Appendix shall be restricted to any damaged areas of the weld bevel of welding neck flanges unless specifically approved by

Table L301.2M Pressure-Temperature Ratings (Metric Units)

Class 150 Material ASTM B247 Temperature [Note (1)]		Т	Class 300 Temperature [Note (1)]			Class 600 Temperature [Note (1)]						
Alloy, Temper	38	66	93	121	38	66	93	121	38	66	93	121
3003-H112	275	275	240	240	725	690	655	655	1 415	1 380	1 345	1 275
6061-T6 [Note (2)]	1 895	1 860	1 825	1 795	4 965	4 895	4 825	4 655	9 930	9 790	9 655	9 345
6061-T6 [Note (3)]	1 265	1 240	1 215	1 195	3 310	3 265	3 215	3 105	6 620	6 525	6 435	6 230

GENERAL NOTE: Pressures are in kPa; temperatures are in $^{\circ}$ C.

- (1) The minimum temperature is -269°C (-425°F). The maximum rating below 38°C (100°F) shall be the rating shown for 38°C.
- (2) Ratings apply to welding neck, lapped, and blind flanges.
- (3) Ratings apply to slip-on and socket welding flanges.

Table L301.2U Pressure-Temperature Ratings (U.S. Customary Units)

Material ASTM B247	Class 150 al ASTM B247 Temperature [Note (1)]		Te	Class 300 Temperature [Note (1)]			Class 600 Temperature [Note (1)]					
Alloy and Temper	100	150	200	250	100	150	200	250	100	150	200	250
3003-H112	40	40	35	35	105	100	95	95	205	200	195	185
6061-T6 [Note (2)]	275	270	265	260	720	710	700	675	1 440	1 420	1 400	1 355
6061-T6 [Note (3)]	185	180	175	175	480	475	465	450	960	945	935	905

GENERAL NOTE: Pressures are in psig; temperatures are in °F.

NOTES:

- (1) The minimum temperature is -269°C (-425°F). The maximum rating below 38°C (100°F) shall be the rating shown for 38°C.
- (2) Ratings apply to welding neck, lapped, and blind flanges.
- (3) Ratings apply to slip-on and socket welding flanges.

Table L303.2 Aluminum Bolting Materials

ASTM Specification	Alloy	Temper	
B211	2014	T6, T261	
B211	2024	T4	
B211	6061	T6, T261	

GENERAL NOTE: Repair welding of bolting material is prohibited.

the Purchaser after consideration of the extent, location, and effect on temper and ductility. Repair welding of any area other than the weld bevel on 6061-T6 welding neck flanges shall restrict the pressure/temperature ratings to those specified for slip-on and socket welding flanges in Tables L301.2M and L301.2U. Any repair welding shall be performed in accordance with para. 328.6.

L303.2 Bolting Materials

Bolting listed in Table L303.2 and in ASME B16.5, Table 1B, may be used subject to the following limitations.

L303.2.1 High Strength Bolting. Bolting materials listed as high strength in ASME B16.5, Table 1B, may be used in any flanged joints. See para. L305.

L303.2.2 Intermediate Strength Bolting. Bolting materials in Table L303.2, and bolting listed as intermediate strength in ASME B16.5, Table 1B, may be used in any flanged joints. See para. L305.

L303.2.3 Low Strength Bolting. Bolting materials listed as low strength in ASME B16.5, Table 1B, may be used in Classes 150 and 300 flanged joints. See para. L305.

L303.3 Gaskets

Gaskets listed in ASME B16.5, Nonmandatory Appendix B, Table B-1, Group Ia may be used with any rating Class and bolting.

L303.3.1 Gaskets for Low-Strength Bolting. If bolting listed as low strength (see para. L303.2.3) is used, gaskets listed in ASME B16.5, Nonmandatory Appendix B, Table B-1, Group Ia shall be used.

L303.3.2 Gaskets for Class 150 Flanged Joints. It is recommended that only gaskets listed in ASME B16.5, Nonmandatory Appendix B, Table B-1, Group Ia be used.

L303.3.3 Gaskets for Class 300 and Higher Flanged Joints. It is recommended that only gaskets listed in

ASME B16.5, Nonmandatory Appendix B, Table B-1, Group I be used. For gaskets in Group Ib, line flanges should be of the welding neck or lapped joint type; controlled-torque tightening practices should be used.

L304 DIMENSIONS AND FACINGS

- (a) Flanges shall meet the dimensional and tolerance requirements of ASME B16.5.
- (b) Flange facing and facing finish shall be in accordance with ASME B16.5, except that small male and female facings (on ends of pipe) shall not be used.

L305 DESIGN CONSIDERATIONS


The following design considerations are applicable to all flanged joints that incorporate a flange manufactured to this Appendix:

- (a) The differential expansion within a flanged joint must be considered; also, see para. F312.
- (b) Where a gasket other than those recommended in para. L303.3 is specified, the designer shall verify by calculations the ability of the selected bolting to seat the selected gasket and maintain a sealed joint under the expected operating conditions without over-stressing the components.

APPENDIX M GUIDE TO CLASSIFYING FLUID SERVICES

See Fig. M300.

440



GENERAL NOTES:

- (a) See paras. 300(b)(1), 300(d)(4) and (5), and 300(e) for decisions the owner must make. Other decisions are the designer's responsibility; see para. 300(b)(2).
- (b) The term "fluid service" is defined in para. 300.2.

NOTE:

(1) Severe cyclic conditions are defined in para. 300.2. Requirements are found in Chapter II, Parts 3 and 4, and in paras. 323.4.2 and 241.4.3.

APPENDIX N APPLICATION OF ASME B31.3 INTERNATIONALLY

N100 INTRODUCTION

The ASME B31.3 Process Piping Code is an internationally recognized code for pressure piping. ISO 15649, Petroleum and natural gas industries — Piping, incorporates ASME B31.3 by normative reference and contains provisions for agreed common international practice that are additional to B31.3. ISO 15649 was prepared by Technical Committee TC 67, Subcommittee SC 6, Working Group WG 5.

(16) N200 COMPLIANCE WITH THE EUROPEAN PRESSURE EQUIPMENT DIRECTIVE (PED)

The European Pressure Equipment Directive 97/23/EC is mandatory throughout all Member States of the European Union (EU) and the rest of the European Economic Area, effective May 30, 2002. The PED contains essential safety requirements that must be satisfied before a manufacturer can declare conformity with the Directive and place its product on the market anywhere in the European Community.

Some articles of the PED and its essential safety requirements are either not satisfied or are not addressed by ASME B31.3, and aspects of ASME B31.3 differ from the PED and the essential safety requirements.

Examples of where essential safety requirements are not fully satisfied by ASME B31.3 are as follows:

(a) decomposition of unstable fluids

- (b) draining and venting
- (c) short duration pressure surge
- (d) temperature monitoring devices
- (e) external fire
- (f) marking and labeling
- (g) operating instructions
- (h) route of underground piping
- (i) joint coefficients
- (j) listed materials

To assist industry in using ASME B31.3, the Engineering Equipment and Materials Users' Association (EEMUA) has cooperated with the European Petroleum Industry Association (Europia) to publish CEN/TR 14549 — Guide to the use of ISO 15649 and ANSI/ASME B31.3 for piping in Europe in compliance with the Pressure Equipment Directive.

The format of the guide is that of a set of additional and modified requirements to ISO 15649 and ASME B31.3 that are required by the PED. It also gives a more-detailed explanation of the principal aspects and processes that require attention in order to be in compliance with the PED, especially where different from industry practice that was current before May 2002.

The full text of the PED can be found at http://ec.europa.eu/growth/sectors/pressure-gas/pressure-equipment/directive_en.

APPENDIX Q QUALITY SYSTEM PROGRAM

[This Appendix is a Code requirement only when specified by the owner in accordance with para. 300(b)(1).]

Design, construction, inspection, examination, testing, manufacture, fabrication, and erection of piping in accordance with this Code shall be performed under a Quality System Program following the principles of an appropriate standard such as the ISO 9000 series. The details describing the quality system shall be documented and shall be available upon request. A determination of the need for registration and/or certification of the quality system program shall be the responsibility of the owner.

¹ The series is also available from the American National Standards Institute (ANSI) and the American Society for Quality (ASQ) as American National Standards that are identified by the prefix "Q," replacing the prefix "ISO." Each standard of the series is listed under Appendix E.

APPENDIX R USE OF ALTERNATIVE ULTRASONIC ACCEPTANCE CRITERIA

R300 GENERAL

- (a) This Appendix provides alternative acceptance criteria based on ultrasonic fracture mechanics that may be used for Code piping in lieu of those described in para. 344.6.
- (b) The acceptance criteria within this Appendix are applicable to \overline{T}_w having a thickness equal to or greater than 25 mm (1.0 in.). The acceptance criteria stated in para. 344.6.2 shall be used for all thicknesses less than 25 mm (1.0 in.).

R301 SCOPE

- (a) The examination shall be conducted using automated or semiautomated techniques utilizing computer-based data acquisition.
- (b) The examination shall be performed in accordance with a written procedure approved by UT (ultrasonic testing) Level III personnel [see para. R303(a)] and conforming to the requirements of ASME BPV Code, Section V, Article 4, Mandatory Appendix VIII, and
- (1) for phased array Section V, Article 4, Mandatory Appendix V
- (2) for time of flight diffraction (TOFD) Section V, Article 4, Mandatory Appendix III
- (c) Procedure qualification shall meet the requirements of Section V, Article 4, Mandatory Appendix IX.

R302 EQUIPMENT

A mechanical guided scanner capable of maintaining a fixed and consistent search unit position relative to the weld centerline shall be used.

R303 PERSONNEL

- (a) Personnel performing nondestructive examination to the requirements of this Appendix shall be qualified and certified in the ultrasonic testing method in accordance with a procedure as described in Section V, Article 1, T-120(e) or (f).
- (b) Setup and scanning of welds shall be performed by personnel certified as UT Level II or III (or by Level I personnel under the direct supervision of Level II or Level III personnel).

- (c) Interpretation and evaluation of data shall be performed by UT Level II or III personnel.
- (d) Personnel demonstration requirements shall be as stated in Section V, Article 4, Mandatory Appendix VIII.

R304 EXAMINATION

- (a) The initial straight beam scan for reflectors that could interfere with the angle beam examination shall be performed (1) manually, (2) as part of a previous manufacturing process, or (3) during the weld examination, provided detection of these reflectors is included in the demonstration as required in para. R301(c).
- (b) The examination area shall include the volume of the weld, plus the lesser of 25 mm (1.0 in.) or \overline{T}_w of adjacent base metal on each side of the weld. Alternatively, the examination volume may be reduced to include the actual heat affected zone (HAZ) plus 6 mm (0.25 in.) of base material beyond the heat affected zone on each side of the weld, provided the extent of the weld HAZ is measured and documented.


R305 DATA RECORDING AND CAPTURE

Data shall be recorded in the unprocessed form as specified in Section V, Article 4, V-471.6. The data record shall include the complete examination area as specified in para. R304(b).


R306 DATA ANALYSIS


- (a) Reflectors exceeding the limits of (1) or (2) below shall be investigated to determine whether the indication originates from a flaw or is a geometric indication as described in (b) below.
- (1) For amplitude-based techniques, the location, amplitude, and extent of all reflectors that produce a response greater than 20% of the reference level shall be evaluated.
- (2) For non-amplitude-based techniques, the location and extent of all images that have an indicated length greater than 4.0 mm (0.16 in.) shall be investigated.
- (b) Ultrasonic indications of geometric and metallurgical origin shall be classified as specified in Section V, Article 4, T-481. Alternatively, other techniques or non-destructive examination methods may be used to classify an indication as geometric (e.g., alternative beam

(16)



(a) Surface Flaw





 $S_{F} > 0.5 h_{E}$

(c) Subsurface Flaw

angles, radiography). The method employed is for information only to classify the indication as geometric, and the Code requirements for examination techniques are only required to the extent that they are applicable.

R307 FLAW EVALUATION

- (a) Dimensions. The dimensions of the flaw(s) shall be determined by the rectangle that fully contains the area of the flaw(s). Refer to Fig. R307.
- (1) The length, $l_{\rm F}$ of the flaw shall be drawn parallel to the inside pressure-retaining surface of the component.
- (2) The height, h_F , of the flaw shall be drawn normal to the inside pressure-retaining surface of the component.
- (3) The flaw shall be characterized as a surface or subsurface flaw, as shown in Fig. R307.
- (4) A subsurface flaw shall be considered as a surface flaw if the separation (S_F in Fig. R307) of the flaw from the nearest surface of the component is equal to

or less than half the through-wall dimension [h_F in Fig. R307, illustration (b)] of the subsurface flaw.

- (b) Multiple Flaws
- (1) Discontinuous flaws that are oriented primarily in parallel planes shall be considered to lie in a single plane if the distance between the adjacent planes is equal to or less than 13 mm (0.50 in.) or $0.5\overline{T}_w$, whichever is less.
- (2) If the space between two flaws aligned along the axis of weld is less than the height of the flaw of greater height, the two flaws shall be considered a single flaw.
- (3) If the space between two flaws aligned in the through-thickness dimension is less than the height of the flaw of greater height, the two flaws shall be considered a single flaw.

R308 FLAW ACCEPTANCE CRITERIA

Flaws shall be evaluated using the applicable criteria of Table R308.1 or Table R308.2. Regardless of flaw height or aspect ratio, flaw length shall not exceed $4\overline{T}_w$

Table R308.1 Acceptance Criteria for Surface Flaws

	Maximum $h_{\it F}/\overline{T}_{\it w}$ for Nominal Weld Thickness				
Aspect Ratio, h_F/l_F	25 mm to 65 mm (1.0 in. to 2.5 in.)	100 mm to 300 mm (3.9 in. to 11.8 in.)			
0.00	0.031	0.019			
0.05	0.033	0.020			
0.10	0.036	0.022			
0.15	0.041	0.025			
0.20	0.047	0.028			
0.25	0.055	0.033			
0.30	0.064	0.038			
0.35	0.074	0.044			
0.40	0.083	0.050			
0.45	0.085	0.051			
0.50	0.087	0.052			

GENERAL NOTES:

- (a) Aspect ratio (h_F/l_F) used may be determined by rounding the calculated h_F/l_F down to the nearest 0.05 increment value within the column, or by linear interpolation.
- (b) For intermediate thickness \overline{T}_W [thicknesses greater than 65 mm (2.5 in.) and less than 100 mm (3.9 in.)], linear interpolation is permitted to obtain $h_{\it F}/\overline{T}_{\it W}$ values. Otherwise, the lower values shall be used.

Table R308.2 Acceptance Criteria for Subsurface Flaws

	Maximum $h_{\it F}/\overline{T}_{\it W}$ for Nominal Weld Thickness				
Aspect Ratio, h_F/l_F	25 mm to 65 mm (1.0 in. to 2.5 in.)	100 mm to 300 mm (3.9 in. to 11.8 in.)			
0.00	0.068	0.040			
0.10	0.076	0.044			
0.20	0.086	0.050			
0.30	0.108	0.058			
0.40	0.132	0.066			
0.50	0.156	0.080			
0.60	0.180	0.094			
0.70	0.206	0.108			
0.80	0.232	0.122			
0.90	0.258	0.138			
1.00	0.286	0.152			

GENERAL NOTES:

- (a) Aspect ratio (h_F/l_F) used may be determined by rounding the calculated h_F/l_F down to the nearest 0.10 increment value within the column, or by linear interpolation.
- (b) For intermediate thickness \overline{T}_W [thicknesses greater than 65 mm (2.5 in.) and less than 100 mm (3.9 in.)], linear interpolation is permitted to obtain $h_{\it F}/\overline{T}_{\it W}$ values. Otherwise, the lower values shall be used.

APPENDIX S PIPING SYSTEM STRESS ANALYSIS EXAMPLES

S300 INTRODUCTION

The example in this Appendix is intended to illustrate the application of the rules and definitions in Chapter II, Part 5, Flexibility and Support; and the stress limits of para. 302.3.5. The loadings and conditions necessary to comply with the intent of the Code are presented.

S300.1 Definitions and Nomenclature

global axes: these are Cartesian X, Y, and Z axes. In this Appendix, vertically upward is taken to be the +Y direction with gravity acting in the -Y direction.

 P_j : piping internal pressure; see para. 301.2; when more than one condition exists for the piping system, each is subscripted (e.g., P_1 , P_2 , ...)

 T_j : pipe maximum or minimum metal temperature; see paras. 301.3 and 319.3.1(a); when more than one condition exists for the piping system, each is subscripted (e.g., T_1 , T_2 , ...)

Y+: a "single acting support" that provides support in only the vertically upward direction and is considered to be "active" when the pipe exerts a downward force on the support. The pipe is free to move upward, i.e., the pipe "lifts off" the support; the support in the "lift-off" situation is considered to be "removed" from providing support, i.e., inactive, during the load condition considered.

S301 EXAMPLE 1: CODE COMPLIANT PIPING SYSTEM

S301.1 Example Description

This example is intended to illustrate the design of an adequately supported and sufficiently flexible piping system. The piping system in Fig. S301.1 is fabricated from ASTM A106 Grade B seamless pipe (i.e., E=1.00); the pipe is DN 400 (NPS 16) with a nominal wall thickness of 9.53 mm (0.375 in.), 127 mm (5 in.) thickness of calcium silicate insulation, and 1.59 mm (0.063 in.) corrosion allowance; the fluid has a specific gravity of 1.0. The equivalent number of cycles expected for the piping system is fewer than 7 000 [i.e., f=1.00 in accordance with para. 302.3.5(d)].

The piping system is in normal fluid service. The installation temperature is 21°C (70°F). The reference modulus of elasticity used for the piping analysis is 203.4 GPa (29.5 Msi) from Appendix C, Table C-6 in

Fig. S301.1 Simple Code Compliant Model




Table S301.1 Temperature/Pressure Combinations

Conditions	Pressure	Temperature
Design conditions	3 795 kPa (550 psi)	288°C (550°F)
Operating (P_1, T_1) maximum metal temperature	3 450 kPa (500 psi)	260°C (500°F)
Operating (<i>P</i> ₂ , <i>T</i> ₂) minimum metal temperature	0 kPa (0 psi)	−1°C (30°F)
Installation temperature	0 kPa (0 psi)	21°C (70°F)

accordance with paras. 319.3.2 and 319.4.4, and Poisson's ratio is 0.3 in accordance with para. 319.3.3.

The piping internal pressure, maximum and minimum metal temperatures expected during normal operation, and the design conditions are listed in Table S301.1. The design conditions are set sufficiently in excess of the operating conditions so as to provide additional margin on the allowable stress for pressure design as required by the owner.

S301.2 Design Conditions

The design conditions establish the pressure rating, flange ratings, component ratings, and minimum required pipe wall thickness in accordance with para. 301.2.1. For example, ASME B16.5 requires a minimum of Class 300 for ASTM A105 flanges. Also, the minimum required pipe wall thickness, t_m , is determined from the

design conditions by inserting eq. (3a) into eq. (2); terms are defined in para. 304.1.1 and Appendix J.

E = 1.0

P = design pressure

= 3795 kPa (550 psi)

S = allowable stress from Appendix A, Table A-1

= 125 MPa (18.1 ksi) at design temperature 288°C (550°F)

Y = 0.4 from Table 304.1.1

Insert eq. (3a) into eq. (2).

$$t_m = t + c = \frac{PD}{2(SE + PY)} + c$$

$$= \frac{(3.795 \text{ kPa})(406.4 \text{ mm})}{2[(125 \text{ MPa})(1.00) + (3.795 \text{ kPa})(0.4)]} + 1.59 \text{ mm}$$

$$= 6.10 \text{ mm} + 1.59 \text{ mm} = 7.69 \text{ mm} (0.303 \text{ in.})$$

In accordance with para. 304.1.2(a), t must be less than D/6 for eq. (3a) to be appropriate without considering additional factors to compute the pressure design thickness, t (i.e., t < D/6, or 7.69 mm < 406.4 mm/6). Since 7.69 mm (0.303 in.) < 67.7 mm (2.67 in.), eq. (3a) is applicable without special consideration of factors listed in para. 304.1.2(b).

Now select a pipe schedule of adequate thickness. Determine the specified minimum pipe wall thickness, T, from nominal pipe wall thickness, \overline{T} , considering a mill tolerance of 12.5%.

Select DN 400 (NPS 16) Schedule 30/STD nominal wall thickness from ASME B36.10M.

 $\overline{T} = 9.53 \text{ mm } (0.375 \text{ in.})$

T = (9.53 mm)(1.00 - 0.125) = 8.34 mm (0.328 in.)

Since $T \ge t_m$ (i.e., 8.34 mm > 7.69 mm), the selection of the nominal pipe wall thickness, \overline{T} , for Schedule 30/STD pipe is acceptable. The long radius elbows specified for this piping system are in accordance with ASME B16.9 and are specified to be for use with Schedule 30/STD wall thickness pipe.

S301.3 Computer Model Input

Tables S301.3.1 and S301.3.2 list the "node numbers," lengths, etc., for each piping element displayed in Fig. S301.1. A bend radius of 1.5 times the nominal pipe diameter [i.e., 609.6 mm (24 in.)] and nominal wall thickness of 9.53 mm (0.375 in.) are used for the elbows in the computer model.

Generic computer program option "flags" are as follows:

- (a) include pressure stiffening on elbows
- (b) exclude pressure thrust and Bourdon effects
- (c) use nominal section properties for both the stiffness matrix and the displacement stress analysis
- (*d*) use "nominal less allowances" section properties for sustained stress, S_L

Table S301.3.1 Generic Pipe Stress Model Input

Term	Value
Operating conditions: internal pressure, P_1 maximum metal temp., T_1 minimum metal temp., T_2 installation temperature	3 450 kPa (500 psi) 260°C (500°F) –1°C (30°F) 21°C (70°F)
Line size Pipe	DN 400 (NPS 16) Schedule 30/STD, 9.53 mm (0.375 in.)
Mechanical allowance, <i>c</i> Mill tolerance Elbows Fluid specific gravity	1.59 mm (0.063 in.) 12.5% Long radius 1.0
Insulation thickness Insulation density	127 mm (5 in.) 176 kg/m³ (11.0 lbm/ft³)
Pipe material Pipe density Total weight Unit weight	ASTM A106 Grade B 7 833.4 kg/m³ (0.283 lbm/in.³) 7 439 kg (16,400 lbm) 248.3 kg/m (166.9 lbm/ft)

- (e) include axial load and internal pressure force in the sustained stress, S_L
- (f) intensify the elbows' in-plane bending moment in the calculation of the elbows' effective stress due to sustained loads, S_I

S301.4 Pressure Effects

For the operating, sustained, and displacement stress range load cases, the effect of pressure stiffening on the elbows is included to determine the end reactions in accordance with Appendix D, Note (7). The effects of pressure-induced elongation and Bourdon effects are not included, as both are deemed negligible for this particular example.

S301.5 The Operating Load Case

The operating load case is used to determine the operating position of the piping and reaction loads for any attached equipment, anchors, supports, guides, or stops. The operating load case is based on the temperature range from the installation temperature of 21°C (70°F) to the maximum operating metal temperature of 260°C (500°F), in accordance with para. 319.3.1(b). The operating load case in this example also includes the effects of internal pressure, pipe weight, insulation weight, and fluid weight on the piping system. Both pipe stiffness and stress are based on the nominal thickness of the pipe. Pipe deflections and internal reaction loads for the operating load case are listed in Table S301.5.1. Piping loads acting on the anchors and support structure are listed in Table S301.5.2.

Table S301.3.2 Element Connectivity, Type, and Lengths

From	То	<i>D_X</i> , m (ft)	D _% m (ft)	Element Type
10	15	6.10 (20)		10 anchor 15 bisection node
15	20	6.10 (20)	• • •	20 Y support
20	30	3.05 (10)	• • •	Three-node elbow [Note (1)]
30	40		6.10 (20)	Three-node elbow [Note (1)]
40	45	3.05 (10)	• • •	Informational node
45	50	6.10 (20)		50 anchor

GENERAL NOTE: This piping system is planar, i.e., $D_Z=0\,\mathrm{m}$ (ft) for each piping element. NOTE:

Table S301.5.1 Operating Load Case Results: Internal Loads and Deflections

Node Number	Axial Force, N (lb) (Signed) [Note (1)]	Bending Moment, N-m (ft-lb) (Unsigned) [Note (1)]	Horizontal Deflection, mm (in.) [Note (1)]	Vertical Deflection, mm (in.) [Note (1)]
10	+26 500 (+5,960)	21 520 (15,870)	0.00	0.00
15	-26 500 (-5,960)	10 710 (7,900)	18.3 (0.72)	-1.3 (-0.05)
20	-26 500 (-5,960)	47 560 (35,080)	36.7 (1.44)	0.00
30 near	-26 500 (-5,960)	57 530 (42,440)	44.0 (1.73)	-3.7 (-0.14)
30 mid	-46 300 (-10,410)	69 860 (51,530)	44.7 (1.76)	-2.3 (-0.09)
30 far	-37 800 (-8,500)	65 320 (48,180)	41.4 (1.63)	0.4 (0.02)
40 near	-25 920 (-5,830)	63 930 (47,160)	-23.0 (-0.91)	15.1 (0.59)
40 mid	-36 250 (-8,150)	70 860 (52,270)	-26.4 (-1.04)	17.8 (0.70)
40 far	-26 500 (-5,960)	65 190 (48,080)	-25.7 (-1.01)	19.2 (0.75)
45	-26 500 (-5,960)	14 900 (10,990)	-18.3 (-0.72)	13.5 (0.53)
50	-26 500 (-5,960)	47 480 (35,030)	0.00	0.00

NOTE:

Table S301.5.2 Operating Load Case Results: Reaction Loads on Supports and Anchors

		Global Axis Forces and Moments				
Node	<i>F_X</i> ,	F _%	<i>M_Z</i> ,			
	N (lb)	N (lb)	N-m (ft-lb)			
	(Signed)	(Signed)	(Unsigned)			
	[Note (1)]	[Note (1)]	[Note (1)]			
10 anchor	-26 500 (-5,960)	-12 710 (-2,860)	21 520 (15,870)			
20 support		-63 050 (-14,180)				
50 anchor	+26 500 (+5,960)	+2 810 (+630)	47 480 (35,030)			

⁽¹⁾ The specified element lengths are measured to and/or from each elbow's tangent intersection point.

⁽¹⁾ Loads and deflections are averaged from commercial programs with a variance within units' conversion tolerance.

⁽¹⁾ Loads and deflections are averaged from commercial programs with a variance within units' conversion tolerance.

Table S301.6	Sustained	Forces and	l Stresses
[Allowable,	$S_h = 130$	MPa (18,90)0 psi)]

Node	Axial Force, N (lb) (Signed) [Note (1)]	Bending Moment, N-m (ft-lb) (Unsigned) [Note (1)]	Sustained Stress, S _L , kPa (psi) [Note (2)]
10 anchor	+3 270 (+735)	17 260 (12,730)	59 100 (8,560)
20 support	-3 270 (- 735)	56 130 (41,400)	99 200 (14,370)
30 far	-19 880 (-4,470)	16 320 (12,040)	72 700 (10,540)
40 far	+3 270 (+735)	2 340 (1,730)	46 050 (6,680)
50 anchor	+3 270 (+735)	37 860 (27,930)	80 350 (11,650)

NOTES:

- (1) Loads, deflections, and stresses are averaged from commercial programs with a variance within units' conversion tolerance.
- (2) Axial forces have their sign retained and do not include the signed axial pressure force, which is also included in the sustained stress, S_I .

S301.6 The Sustained Load Case

Sustained stresses due to the axial force, internal pressure, and intensified bending moment in this example are combined to determine the sustained longitudinal stress, S_L . The sustained load case excludes thermal effects and includes the effects of internal pressure [P_1 = 3450 kPa (500 psi)], pipe weight, insulation weight, and fluid weight on the piping system.

Nominal section properties are used to generate the stiffness matrix and sustained loads for the computer model in accordance with para. 319.3.5. The nominal thickness, less allowances, is used to calculate the section properties for the sustained stress, S_L , in accordance with para. 302.3.5(c).

A summary of the sustained load case internal reaction forces, moments, and sustained stresses, S_L , is provided in Table S301.6. Since this example model lies in only one plane, only the sustained bending stress due to the in-plane bending moment is not zero. The inplane bending moment is intensified at each elbow by the appropriate index for an unflanged elbow. Note that sustained stresses for the nodes listed in Table S301.6 do not exceed the 130 MPa (18,900 psi) sustained allowable stress, S_h , for A106 Grade B piping at the maximum metal temperature, $T_1 = 260^{\circ}\text{C}$ (500°F), from Appendix A, Table A-1. By limiting S_L to the sustained allowable, S_h , the piping system is deemed adequately protected against collapse.

S301.7 The Displacement Stress Range Load Case

The displacement stress range, S_E , in this example is based on the temperature range from the installation [21°C (70°F)] to minimum metal temperature [$T_2 = -1$ °C (30°F)] and from the installation [21°C (70°F)] to maximum metal temperature for the thermal cycles under analysis [$T_1 = 260$ °C (500°F)], in accordance with para. 319.3.1(a). The displacement stress range, S_E , for each

element is calculated in accordance with eq. (17) and is listed in Table S301.7, along with the internal reaction loads. Nominal section properties are used to generate the stiffness matrix and displacement stress in the piping in accordance with para. 319.3.5. Since this example model lies in only one plane, only the in-plane bending moment is not zero. The in-plane moment is intensified at each elbow by the appropriate Appendix D stress intensification factor, i_i , for an unflanged elbow.

For simplicity, the allowable displacement stress range, S_A , is calculated in accordance with eq. (1a). Though eq. (1a) is used in this example, it is also acceptable to calculate S_A in accordance with eq. (1b), which permits S_A to exceed the eq. (1a) value for each piping element, based on the magnitude of each element's sustained stress, S_L .

The following terms are as defined in para. 302.3.5(d) and Appendix J:

f = 1.00 for ≤ 7000 equivalent cycles, from Fig. 302.3.5 or eq. (1c)

 $S_A = f (1.25S_c + 0.25S_h)$

= (1.00)[(1.25)(138 MPa) + (0.25)(130 MPa)]

= 205 MPa (29,725 psi)

 S_c = allowable stress from Appendix A, Table A-1

 $= 138 \text{ MPa } (20.0 \text{ ksi}) \text{ at } T_2$

 S_h = allowable stress from Appendix A, Table A-1

 $= 130 \text{ MPa} (18.9 \text{ ksi}) \text{ at } T_1$

 T_1 = maximum metal temperature

 $= 260^{\circ}\text{C} (500^{\circ}\text{F})$

 T_2 = minimum metal temperature

 $= -1^{\circ}C (30^{\circ}F)$

Note that each piping element's displacement stress range, based on minimum to maximum metal temperature for the thermal cycles under analysis, S_E , does not exceed the eq. (1a) allowable, S_A . By limiting S_E to S_A , the piping system is deemed adequate to accommodate up to 7 000 full excursion equivalent cycles.

Table S301.7 Displacement Stress Range $[S_A = 205 \text{ MP}]$

	Global Axis Forces and Moments				
Node	F _X , N (lb) (Unsigned) [Note (1)]	F _% N (lb) (Unsigned) [Note (1)]	<i>M_Z,</i> N-m (ft-lb) (Unsigned) [Note (1)]	<i>S_E</i> From Eq. (17), kPa (psi) [Note (1)]	
10 anchor	25 070 (5,640)	1 130 (260)	4 600 (3,390)	4 000 (580)	
20 support	25 070 (5,640)	1 130 (260)	9 250 (6,820)	8 040 (1,170)	
30 mid	25 070 (5,640)	19 330 (4,350)	60 250 (44,440)	137 000 (19,870)	
40 mid	25 070 (5,640)	19 330 (4,350)	76 740 (56,600)	174 500 (25,300)	
50 anchor	25 070 (5,640)	19 330 (4,350)	92 110 (67,940)	79 900 (11,600)	

NOTE:

(1) Loads, deflections, and stresses are averaged from commercial programs with a variance within units' conversion tolerance.

Considering both the sustained and displacement stress range load cases, the piping system is compliant with the requirements of the Code; redesign of the piping system is not required unless the sustained or operating reaction loads at either anchor data point 10 or 50 exceed the allowable loads for the attached equipment nozzle or the support structure at node 20 is overloaded. The nozzle load and support structure analyses are beyond the scope of this Appendix and are not addressed.

S302 EXAMPLE 2: ANTICIPATED SUSTAINED CONDITIONS CONSIDERING PIPE LIFT-OFF

S302.1 Example Description

This example is intended to illustrate the analysis of a piping system in which a portion of the piping lifts off at least one *Y*+ support in at least one operating condition. The emphasis of this example is to describe the effect this removal of support has on the determination of anticipated sustained conditions. The same principles utilized for this example would also apply for guides and stops (that are single directional or gap-type) that are not engaged during any anticipated operating condition.

The examples in this Appendix are intended for illustration purposes only and are not intended to portray the same as either adequate or even acceptable piping geometries and/or support scenarios. The piping system in Fig. S302.1 is the same in material and dimensional properties as in Example 1; see para. S301.1. Note that both the design and operating conditions are well below the creep regime; therefore, the piping system will not develop any permanent creep-related displacements, relaxation, or sag.

S302.2 Design Conditions

The design conditions are similar to those in the Example 1 model; see para. S301.2 and Table S302.1. Note that the minimum thickness remains unchanged

Fig. S302.1 Lift-Off Model




Table S302.1 Temperature/Pressure Combinations

Conditions	Pressure	Temp	erature
Design conditions	3 968 kPa (575 psi)	302°C	(575°F)
Operating (P_1, T_1) maximum metal temperature (Operating Case 1)	3 795 kPa (550 psi)	288°C	(550°F)
Operating (<i>P</i> ₂ , <i>T</i> ₂) minimum metal temperature (Operating Case 2)	0 kPa (0 psi)	-1°C	(30°F)
Installation temperature		21°C	(70°F)

from Example 1 even though the design conditions have increased slightly. The hydrotest pressure does increase from 6 039 kPa (875 psi) to 6 729 kPa (975 psi).

S302.3 Computer Model Input

Table S302.3 lists the node numbers, lengths, etc., for each piping component that is displayed in Fig. S302.1. The computer-based options are the same as those for the Example 1 model; see para. S301.3.

Table S302.3	Generic Pipe Stress Model Input:
Component	Connectivity, Type, and Lengths

From	То	<i>D_X</i> , m (ft)	<i>D</i> _γ , m (ft)	Component Type
10	15	6.10 (20)		10 anchor
				15 informational node
15	20	6.10 (20)		20 Y support
20	30	3.05 (10)		Three node elbow [Note (1)]
30	40		6.10 (20)	Three node elbow [Note (1)]
40	45	3.05 (10)		Informational node
45	50	6.10 (20)		50 Y+ support
110	115	-6.10 (-20)		110 anchor
				115 informational node
115	120	-6.10 (-20)		120 Y support
120	130	-3.05 (-10)		Three node elbow [Note (1)]
130	140		6.10 (20)	Three node elbow [Note (1)]
140	145	-3.05 (-10)		Informational node
145	50	-6.10 (-20)		• • •

NOTE:

S302.4 Pressure Effects

The pressure effect considerations are the same as those for Example 1; see para. 301.4.

S302.5 The Operating Load Case

The operating condition evaluated and discussed in this example, Operating Case 1, includes the effects of pipe weight, insulation weight, fluid weight, internal pressure [$P_1 = 3.795 \text{ kPa } (550 \text{ psi})$], and temperature [$T_1 = 288^{\circ}\text{C } (550^{\circ}\text{F})$]. An operating load case is evaluated to determine the operating position of the piping and determine the reaction loads for any attached equipment, anchors, supports, guides, or stops. In particular, each operating load case's support scenario is evaluated or assessed by the designer in order to determine whether any anticipated sustained conditions need to be evaluated with one or more Y+ supports removed. Further operating load case discussion can be found in para. S301.5.

Piping loads acting on the anchors and support structure for Operating Case 1 are listed in Table S302.5.1. Note that only nodes 10 through 50 are listed in the following tables; this is both for convenience, since the model is symmetric, and for comparison to Example 1, e.g., the loads, deflections, and stresses for nodes 10 through 40 are the same as for nodes 110 through 140 except that some signs may be reversed.

S302.6 Sustained Conditions

S302.6.1 The Stress Due to Sustained Loads, S_L , Calculations. The stress due to (long-term) sustained loads, S_L , is computed in accordance with para. 320.2

for each sustained condition that is evaluated; see para. S302.6.2.

\$302.6.2 Anticipated Sustained Conditions. All anticipated sustained conditions utilizing all possible support scenarios should be considered. The designer has identified four anticipated sustained conditions for this piping system; each is listed in Table \$302.6.2.1, along with the support status of the node 50 Y+ support, as either assessed by analysis or determined by the designer. The designer has deemed the Sustained Condition 3 as both controlling the sustained design and requiring evaluation.

S302.6.3 Results for the Evaluated Sustained Condition. The Sustained Condition 3 reflects the support scenario of the Operating Case 1, excludes thermal effects, and includes the effects of internal pressure [P_1 = 3 795 kPa (550 psi)], pipe weight, insulation weight, and fluid weight on the piping system. A summary of the Sustained Condition 3 internal reaction forces, moments, and sustained stresses, S_L , appears in Table S302.6.3.1. See para. S301.6 for additional information concerning the sustained stress determination.

S302.7 Displacement Stress Range Load Cases

The displacement stress range load cases are not listed, since they are not the subject of this example.

S302.8 Code Compliance — Satisfying the Intent of the Code

The Sustained Condition 3 results indicate that the piping system is not protected against collapse for the cycles under analysis when considering the Operating

⁽¹⁾ The specified component lengths are measured to and/or from each elbow's tangent intersection point.

Node	F _x , N (lb) (Signed) [Note (1)]	F _y , N (lb) (Signed) [Note (1)]	M_z , N-m (ft-lb) (Unsigned) [Note (1)]
10 anchor	-26 600 (-5,975)	-14 050 (-3,150)	27 000 (19,900)
20 support		-58 900 (-13,250)	
50 Y+	• • •	0 [Note (2)]	

NOTES:

- (1) Loads and deflections are averaged from commercial programs with a variance within units' convergence tolerances. Magnitudes of loads for nodes 10 and 20 are the same for 110 and 120, but may differ in sign.
- (2) No support is provided at the node 50 Y+ restraint for Operating Case 1.

Table S302.6.2.1 Sustained Load Condition Listing

Susta	ined Condition	Node 50's Support Status (Active/Removed)
1: As in	stalled [Note (1)]	Active
2: P ₁ [N	ote (2)]	Active
3: P ₁ [N	ote (2)]	Inactive
4: P ₂ [N	ote (2)]	Active

NOTES:

- The original (as-installed) condition considers only pipe weight and insulation weight without fluid contents or internal pressure.
- (2) The Sustained Conditions reflect the support scenario of the related Operating Conditions, exclude thermal effects, and include the effects of the related internal pressure, pipe weight, insulation weight, and fluid weight on the piping system.

Table S302.6.3.1 Sustained Forces and Stresses for Sustained Condition 3
With Node 50 Support Removed
[Allowable $S_h = 124.5 \text{ MPa} (18,100 \text{ psi}): \text{Fails}$]

	Glob	Global Axis Forces and Moments [Note (1)]			
Node	F _x , N (lb) (Signed) [Note (2)]	F _y , N (lb) (Signed) [Note (2)]	M_z , N-m (ft-lb) (Unsigned)	Sustained S_L , kPa (psi) [Notes (2), (3)]	
10 anchor	12 575 (2,825)	8 385 (1,885)	3 995 (2,945)	48 645 (7,055)	
20 support	12 575 (2,825)	64 565 (14,515)	82 845 (61,095)	129 975 (18,850)	
30 far	12 575 (2,825)	34 985 (7,865)	29 985 (22,115)	101 920 (14,780)	
40 mid	12 575 (2,825)	21 950 (4,935)	32 770 (24,165)	108 525 (15,740)	
50 Y+	12 575 (2,825)	0 [Note (4)]	62 885 (46,375)	109 385 (15,865)	

- (1) Loads and deflections are averaged from commercial programs with a variance within units' convergence tolerance. The magnitude of loads and stresses for nodes 10 through 40 are the same for 110 and 140, though the loads may differ in sign.
- (2) Forces have their sign retained, but do not include the signed axial pressure force necessary to compute the axial stress, which is included in the sustained stress, S_I .
- (3) Stress may differ by slightly more than units' conversion tolerance.
- (4) No support is provided at the node 50 Y+ restraint for Sustained Condition 3.




Fig. S303.1 Moment Reversal Model

Case 1. Therefore, redesign of the piping system is required.

If the piping system is redesigned such that it is compliant with the intent of the Code, then the piping system would require no further attention unless the sustained, hydrotest, or operating reaction loads at either anchor data point 10 or 110 exceed the allowable loads for the attached equipment nozzle, or the support structure at either node 20 or 120 is overloaded. The nozzle loads and support structure analyses are beyond the scope of this Appendix and are not addressed. Although the occasional load cases are important to the design and analysis of a piping system, they are not discussed in this example.

S303 EXAMPLE 3: MOMENT REVERSAL

S303.1 Example Description

This example is intended to illustrate the flexibility analysis required for a piping system that is designed for more than one operating condition and also experiences a "reversal of moments" between any two of the anticipated operating conditions. The examples in this Appendix are intended for illustration purposes only and are not intended to portray the same as either adequate or even acceptable piping geometries and/or support scenarios. Both the design and operating conditions are well below the creep regime.

The piping system in Fig. S303.1 consists of two headers and two branches, which are referred to as gas "meter runs." Only one of the branches is in service (operating) at a given time; the out-of-service branch is purged and at ambient condition. The design specification calls for each of the meter run branches to alternate in and out of service once per week for the piping system's planned 20-year service life, i.e., f = 1.20 in accordance with para. 302.3.5(d). The piping system is fabricated from

ASTM A53 Grade B pipe (E = 1.00), both piping headers are DN 600 (NPS 24) and the branches are DN 500 (NPS 20), and both branch and header are 9.53 mm (0.375 in.) thick. For simplicity, each piping segment or component is 1.524 m (5 ft) in length.

The piping system is in normal fluid service. The fluid is gaseous; is considered to add no weight; and to be neither a corrosive nor an erosive hazard, i.e., there is no corrosion allowance. The line is not insulated. The installation temperature is 4.5°C (40°F). The reference modulus of elasticity used is 203.4 GPa (29.5 Msi) and Poisson's ratio is 0.3. Consideration is given to the close proximity of the three tees in each header in accordance with the guidance in para. 319.3.6, and the stress intensification factors from Appendix D are considered to adequately represent the header tees for this piping system. The piping internal pressure, and minimum and maximum metal temperatures, expected during normal operation for each meter run and the design conditions, are listed in Table S303.1. The design conditions are set sufficiently in excess of the operating conditions so as to provide additional margin on the allowable as required by the owner.

S303.2 Design Conditions

The design conditions establish the pressure rating, flange ratings, components ratings, and minimum required pipe wall thickness. ASME B16.5 requires a minimum of Class 300 for ASTM A105 flanges. The minimum required wall thickness for both the branch and header is 4.4 mm (0.171 in.), considering a 12.5% mill tolerance; therefore, selection of the standard wall thickness of 9.5 mm (0.375 in.) is acceptable.

S303.3 Computer Model Input

Table S303.3 lists the node numbers, lengths, etc., for each piping component that is displayed in Fig. S303.1.

Table S303.1 Pressure/Temperature Combinations

	Header(s)		West Branch		East Branch	
Condition	Pressure	Temperature	Pressure	Temperature	Pressure	Temperature
Design	2 069 kPa	149°C	2 069 kPa	149°C	2 069 kPa	149°C
	(300 psi)	(300°F)	(300 psi)	(300°F)	(300 psi)	(300°F)
Operating Case 1	1 724 kPa	121°C	1 724 kPa	121°C	0 kPa	4.5°C
[Note (1)]	(250 psi)	(250°F)	(250 psi)	(250°F)	(0 psi)	(40°F)
Operating Case 2	1 724 kPa	121°C	0 kPa	4.5°C	1 724 kPa	121°C
[Note (2)]	(250 psi)	(250°F)	(0 psi)	(40°F)	(250 psi)	(250°F)
Installation temperature	•••	4.5°C (40°F)	•••	4.5°C (40°F)	•••	4.5°C (40°F)

GENERAL NOTE: For computer based temperature and pressure data input, consider the West Branch temperature and pressure to be in effect from nodes 30 through 330 as listed in Table S303.3. Likewise, consider the East Branch temperature and pressure to be in effect from nodes 40 through 340 as listed in Table S303.3; see para. S303.3.

NOTES:

- (1) East Branch is at ambient conditions.
- (2) West Branch is at ambient conditions.

Table S303.3 Generic Pipe Stress Model Input: Component Connectivity, Type, and Lengths

From	То	<i>D_χ</i> , m (ft)	<i>D_Z</i> , m (ft)	Component Type
10	20			, ,
10	20	1.52 (5)		10 anchor (DN 600 Header 20 welding tee
20	30		1.52 (5)	30 welding tee
30	35		0.76 (2.5)	35 simulated end cap
20	40		-1.52 (-5)	40 welding tee
40	45		-0.76 (-2.5)	45 end cap
40	110	1.52 (5)		(East DN 500 Branch)
				110 Y support
110	120	1.52 (5)		120 pipe segment
120	130	1.52 (5)		8 890 N (2,000 lb) meter
130	140	1.52 (5)		140 pipe segment
140	340	1.52 (5)		340 welding tee
30	210	1.52 (5)		(West DN 500 Branch)
				210 Y support
210	220	1.52 (5)		220 pipe segment
220	230	1.52 (5)	• • •	8 890 N (2,000 lb) meter
230	240	1.52 (5)	• • •	240 pipe segment
240	330	1.52 (5)	• • •	330 welding tee
310	320	-1.52 (-5)		(DN 600 Header)
				310 anchor [free in the
				X (axial) direction]
				320 welding tee
320	330		1.52 (5)	330 welding tee
330	335		0.76 (2.5)	335 end cap
320	340	• • •	-1.52 (-5)	340 welding tee
340	345		-0.76 (-2.5)	345 end cap

GENERAL NOTE: This piping system is planar, i.e., $D_Y = 0 \text{ m}$ (0 ft) for each piping component.

Note that flanges and valve components are not explicitly included in the model listing in Table S303.3. For simplicity, an entire branch (from tee centerline to tee centerline) is considered to be at the operating conditions listed in Table S303.1, e.g., the East meter run branch from nodes 40 through 340 operates at 1 724 kPa (250 psi) and 121°C (250°F) for Operating Case 2. The computer-based options are the same as those for the Example 1 model, except that pressure stiffening is not included in the analyses for this example; see para. S301.3.

S303.4 Pressure Effects

Neither pressure stiffening nor Bourdon effects are included in the analyses.

S303.5 Operating Load Case(s)

The operating load case is used to determine the operating position of the piping and reaction loads for any attached equipment, anchors, supports, guides, or stops. The owner has mandated in the design specification that the meter runs and piping be more than adequately supported. Therefore, the operating load case, while necessary to set the limits of the strain ranges, does not contribute to the emphasis of this example, and its output is not included.

S303.6 Sustained Load Case

Sustained stresses due to the axial force, internal pressure, and intensified bending moment in this example are combined to determine the sustained stress, S_L . For reasons similar to those expressed for the operating load case, the sustained load case output is not included.

S303.7 Displacement Stress Range Load Cases

The displacement stress range, S_E , is computed in accordance with para. 319.2.3(b), in which the strains evaluated for the original (as-installed) condition (for this particular example) are algebraically subtracted from the strains evaluated for the Operating Case 1 as listed in Table S303.1. Similarly, the displacement stress range, S_E , is computed from the algebraic strain difference evaluated from the as-installed condition to the

Operating Case 2 as listed in Table S303.1. The individual displacement stress range, S_E , along with the internal reaction loads, is evaluated for each piping component in accordance with eq. (17) and is listed in Tables S303.7.1 and S303.7.2 for Operating Cases 1 and 2, respectively.

The algebraic strain difference between the two resultant case evaluations discussed above produces the largest overall stress differential for the piping system in accordance with paras. 319.2.1(d), 319.2.3(b), and 319.3.1(b), i.e., S_E , the "stress range corresponding to the total displacement strains." The resulting load combination and S_E for each piping component are listed in Table S303.7.3.

S303.8 Code Compliance — Satisfying the Intent of the Code

The piping system is compliant with the sustained load requirements of the Code. The displacement stress range from the original (as-installed) condition to each of the operating cases indicates the piping system is in compliance with the intent of the Code even when limited to the eq. (1a) allowable, S_A . But, the "stress range corresponding to the total displacement strains," which considers the algebraic strain difference between the two operating cases, indicates that the piping system is not protected against fatigue for the cycles under analysis even when considering the eq. (1b) allowable, S_A . Therefore, redesign of the piping system is required.

The redesign should consider the additional impact of average axial displacement stresses in accordance with the recommendations in para. 319.2.3(c). If the piping system is redesigned such that it is compliant with the intent of the code, then the piping system would require no further attention unless the sustained, hydrotest, or operating reaction loads at either anchor data point 10 or 310, or meter runs 130 or 230, exceeded the allowable loads for the attached equipment, nozzles, or support structure. The meter loads, nozzle loads, and support structure analyses are beyond the scope of this example. Although the occasional load cases are important to the design and analysis of a piping system, they are not discussed in this example.

Table S303.7.1 Case 1: Displacement Stress Range [Eq. (1a) Allowable $S_A = 248.2$ MPa (36 ksi): Passes]

	Global Axis Fo	Global Axis Forces and Moments			
Node	F _x , N (lb) (Signed) [Note (1)]	M _y , N-m (ft-lb) (Signed) [Note (1)]	Eq. (17) <i>S_E,</i> kPa (psi) [Note (2)]		
10 anchor	0	147 470 (108,755)	55 610 (8,065)		
20 tee	0	-147 470 (-108 , 755)	189 945 (27,550)		
30 tee	-78 485 (- 17,645)	45 900 (33,850)	84 360 (12,235)		
40 tee	78 485 (17,645)	45 900 (33,850)	84 360 (12,235)		
110 Y	78 485 (17,645)	45 900 (33,850)	25 155 (3,650)		
120	78 485 (17,645)	45 900 (33,850)	25 155 (3,650)		
130 meter	78 485 (17,645)	45 900 (33 , 850)	25 155 (3,650)		
140 Y	78 485 (17,645)	45 900 (33,850)	25 155 (3,650)		
340 tee	78 485 (17,645)	45 900 (33,850)	84 360 (12,235)		
210 Y	-78 485 (-17 , 645)	45 900 (33 , 850)	25 155 (3,650)		
220	-78 485 (-17 , 645)	45 900 (33,850)	25 155 (3,650)		
230 meter	-78 485 (-17,645)	45 900 (33,850)	25 155 (3,650)		
240 Y	-78 485 (-17,645)	45 900 (33,850)	25 155 (3,650)		
330 tee	-78 485 (- 17 , 645)	45 900 (33,850)	84 360 (12,235)		
310 anchor	0	-147 470 (-108,755)	55 610 (8,065)		
320 tee	0	147 470 (108,755)	189 945 (27,550)		

- (1) Loads are averaged from commercial programs and are directly affected by the stiffness chosen for valves, flanges, and other relatively stiff components.
- (2) Stress may differ by slightly more than units' conversion tolerance.

Table S303.7.2 Case 2: Displacement Stress Range [Eq. (1a) Allowable $S_A = 248.2$ MPa (36 ksi): Passes]

	Global Axis Fo			
Node	F _x , N (lb) (Signed) [Note (1)]	M _y , N-m (ft-lb) (Signed) [Note (1)]	Eq. (17) <i>S_E</i> , kPa (psi) [Note (2)]	
10 anchor	0	-147 470 (-108,755)	55 610 (8,065)	
20 tee	0	147 470 (108,755)	189 945 (27,550)	
30 tee	78 485 (17,645)	-45 900 (-33 , 850)	84 360 (12,235)	
40 tee	-78 485 (-17,645)	-45 900 (-33 , 850)	84 360 (12,235)	
110 Y	-78 485 (-17,645)	-45 900 (-33 , 850)	25 155 (3,650)	
120	-78 485 (- 17,645)	-45 900 (-33 , 850)	25 155 (3,650)	
130 meter	-78 485 (- 17 , 645)	-45 900 (-33 , 850)	25 155 (3,650)	
140 Y	-78 485 (-17,645)	-45 900 (-33 , 850)	25 155 (3,650)	
340 tee	-78 485 (-17,645)	-45 900 (-33 , 850)	84 360 (12,235)	
210 Y	78 485 (17,645)	-45 900 (-33 , 850)	25 155 (3,650)	
220	78 485 (17,645)	-45 900 (-33 , 850)	25 155 (3,650)	
230 meter	78 485 (17,645)	-45 900 (-33 , 850)	25 155 (3,650)	
240 Y	78 485 (17,645)	-45 900 (-33 , 850)	25 155 (3,650)	
330 tee	78 485 (17,645)	-45 900 (-33 , 850)	84 360 (12,235)	
310 anchor	0	147 470 (108,755)	55 610 (8,065)	
320 tee	0	-147 470 (-108,755)	189 945 (27,550)	

- (1) Loads are averaged from commercial programs and are directly affected by the stiffness chosen for valves, flanges, and other relatively stiff components.
- (2) Stress may differ by slightly more than units' conversion tolerance.

Table S303.7.3 Load Combination Considering Cases 1 and 2, Total Strain Based: Displacement Stress Range [Eq. (1b) Allowable $S_A = 379.8$ MPa (55.1 ksi): Fails]

	Global Axis Forces and Moments [Note (1)]		Eq. (17)
Node	F _x , N (lb) (Signed)	<i>M_y,</i> N-m (ft-lb) (Signed)	S _E , kPa (psi) [Notes (2), (3)]
10 anchor	0	294 940 (217,510)	111 220 (16,130)
20 tee	0	-294 940 (-217,510)	379 890 (55,100)
30 tee	-156 970 (-35,290)	91 800 (67,700)	168 720 (24,470)
40 tee	156 970 (35,290)	91 800 (67,700)	168 720 (24,470)
110 Y	156 970 (35,290)	91 800 (67,700)	50 310 (7,300)
120	156 970 (35,290)	91 800 (67,700)	50 310 (7,300)
130 meter	156 970 (35,290)	91 800 (67,700)	50 310 (7,300)
140 Y	156 970 (35,290)	91 800 (67,700)	50 310 (7,300)
340 tee	156 970 (35,290)	91 800 (67,700)	168 720 (24,470)
210 Y	-156 970 (-35,290)	91 800 (67,700)	50 310 (7,300)
220	-156 970 (-35,290)	91 800 (67,700)	50 310 (7,300)
230 meter	-156 970 (-35,290)	91 800 (67,700)	50 310 (7,300)
240 Y	-156 970 (-35,290)	91 800 (67,700)	50 310 (7,300)
330 tee	-156 970 (-35,290)	91 800 (67,700)	168 720 (24,470)
310 anchor	0	-294 940 (-217,510)	111 220 (16,130)
320 tee	0	294 940 (217,510)	379 890 (55,100)

GENERAL NOTE: The sustained stress used in determining the eq. (1b) allowable for nodes 20 and 320 is $S_L=28\,380\,$ kPa (4,115 psi).

- (1) Loads are averaged from commercial programs and are directly affected by the stiffness chosen for valves, flanges, and other relatively stiff components.
- (2) Stress may differ by slightly more than units' conversion tolerance.
- (3) The additional impact of average axial displacement stresses in accordance with the recommendations in para. 319.2.3(c) has not been included in determining the displacement stress range.

APPENDIX V ALLOWABLE VARIATIONS IN ELEVATED TEMPERATURE SERVICE

V300 APPLICATION

- (a) This Appendix covers application of the Linear Life Fraction Rule, which provides a method for evaluating variations at elevated temperatures above design conditions where material creep properties [see para. V302(c)] control the allowable stress at the temperature of the variation. This Appendix is a Code requirement only when specified by the owner in accordance with the last sentence of para. 302.2.4(f)(1).
- (b) Life Fraction analysis addresses only the gross strength of piping components; it does not consider local stress effects. It is the designer's responsibility to provide construction details suitable for elevated temperature design.

V300.1 Definitions

operating condition: any condition of pressure and temperature under which the design conditions are not exceeded.

excursion: any condition under which pressure or temperature, or both, exceed the design conditions.

service condition: any operating condition or excursion. duration

- (a) the extent of any service condition, hours
- (b) the cumulative extent of all repetitions of a given service condition during service life, hours

service life: the life assigned to a piping system for design purposes, hours.

V301 DESIGN BASIS

Life Fraction analysis shall be performed in accordance with one of the following design basis options selected by the owner.

- (a) All service conditions in the creep range and their durations are included.
- (b) To simplify the analysis, less severe service conditions need not be individually evaluated if their durations are included with the duration of a more severe service condition.

(16) V302 CRITERIA

- (a) All of the criteria in para. 302.2.4 shall be met.
- (b) Only carbon steels, low and intermediate alloy steels, austenitic stainless steels, and high nickel alloys are included.

- (c) Service conditions are considered only in the calculation of the usage factors in accordance with para. V303 when the allowable stress at the temperature of those conditions in Table A-1 or Table A-1M is based on the creep criteria stated in para. 302.3.2.
- (d) Creep-fatigue interaction effects shall be considered when the number of cycles exceeds 100.

V303 PROCEDURE

The cumulative effect of all service conditions during the service life of the piping is determined by the Linear Life Fraction Rule in accordance with the following procedure.

V303.1 Calculations for Each Service Condition i

The following steps shall be repeated for each service condition considered.

V303.1.1 Equivalent Stress for Pressure

(a) Using eq. (V1), compute a pressure-based equivalent stress, S_{vi}

$$S_{vi} = S_d P_i / P_{\text{max}} \tag{V1}$$

where

 P_i = gage pressure, kPa (psig), during service condition i

 P_{max} = maximum allowable gage pressure, kPa (psig), for continuous operation of pipe or component at design temperature, considering allowances, c, and mill tolerance, but without considering weld joint strength reduction factor, W; weld joint quality factors, E_i ; or casting quality factor, E_c

 S_d = allowable stress, MPa (ksi), at design temperature, °C (°F)

 S_{pi} = pressure-based equivalent stress, MPa (ksi)

- (b) Compute the maximum longitudinal stress, S_L , during service condition i, in accordance with para. 302.3.5(c).
- (c) The equivalent stress, S_i , for use in para. V303.1.2 is the greater of the values calculated in (a) and (b) above, divided by their respective weld joint strength reduction factor, W, in accordance with para. 302.3.5(e).

V303.1.2 Effective Temperature. From Table A-1 or (16) Table A-1M, find the temperature corresponding to a basic allowable stress equal to the equivalent stress, S_i ,

V303.1.3 Larson-Miller Parameter. Compute the LMP for the basic design life for service condition i, using eq. (V2)

SI units:
$$LMP = (C + 5) (T_E + 273)$$

U.S. Customary units: $LMP = (C + 5) (T_E + 460)$

where

C = 20 (carbon, low, and intermediate alloy steels)

= 15 (austenitic stainless steel and high nickel

 T_E = effective temperature, °C (°F); see para. V303.1.2

V303.1.4 Rupture Life. Compute the rupture life, t_{ri} , h, using eq. (V3)

$$t_{ri} = 10^a \tag{V3}$$

where

SI units:
$$a = \frac{LMP}{T_i + 273} - C$$

U.S. Customary units:
$$a = \frac{LMP}{T_i + 460} - C$$

 T_i = temperature, °C (°F), of the component for the coincident operating pressure-temperature condition i under consideration

 t_{ri} = allowable rupture life, h, associated with a given service condition i and stress, S_i

LMP and C are as defined in para. V303.1.3.

V303.2 Determine Creep-Rupture Usage Factor

The usage factor, u, is the summation of individual usage factors, t_i/t_{ri} , for all service conditions considered in para. V303.1. See eq. (V4).

$$u = \sum (t_i/t_{ri}) \tag{V4}$$

where

i = as a subscript, 1 for the prevalent operatingcondition; i = 2, 3, etc., for each of the other service conditions considered

 t_i = total duration, h, associated with any service condition, i, at pressure, P_i , and temperature, T_i

as defined in para. V303.1.4

V303.3 Evaluation

The calculated value of *u* indicates the nominal amount of creep-rupture life expended during the service life of the piping system. If $u \le 1.0$, the usage factor is acceptable including excursions. If u > 1.0, the designer shall either increase the design conditions (selecting piping system components of a higher allowable working pressure if necessary) or reduce the number and/or severity of excursions until the usage factor is acceptable.

V304 EXAMPLE

The following example illustrates the application of the procedure in para. V303:

Pipe material: ASTM A691, Gr. 2½Cr pipe using A387, Gr. 22 Cl. 1 plate

Pipe size: NPS 30 (30 in. O.D.)

Nominal pipe wall thickness: 0.85 in.

Corrosion allowance: 0.0625 in.

Mill tolerance: 0.01 in. Design pressure: 250 psig Design temperature: 1,050°F Total service life: 175,200 hr

Three service conditions are considered.

- (a) Normal operation is 157,200 hr at 250 psig, 1,025°F.
- (b) Expect up to 16,000 hr at design conditions of 250 psig, 1,050°F.
- (c) Total of 2,000 hr at excursion condition of 330 psig, 1,050°F. [This is a 32% variation above the design pressure and, with the owner's approval, it complies with the criteria of para. 302.2.4. As a simplification, and in accordance with para. V301(b), this 2,000 hr total includes less severe excursions.]

Compute pressure-based equivalent stress, S_{pi} , from

From Table A-1, $S_d = 5.7$ ksi at 1,050°F.

$$P_{\text{max}} = \frac{2(\overline{T} - c - \text{mill tol.}) \times SEW}{D - 2(\overline{T} - c - \text{mill tol.}) \times Y}$$

Letting $S = S_d$ and, in accordance with the definition of P_{max} in para. V303.1.1, E = 1 and W = 1,

$$P_{\text{max}} = 306 \text{ psi}$$

$$\begin{split} S_{p1} &= 5.7(250/306) = 4.65 \text{ ksi} \\ S_{p2} &= 5.7(250/306) = 4.65 \text{ ksi} \\ S_{p3} &= 5.7(330/306) = 6.14 \text{ ksi} \end{split}$$

$$S_{n3} = 5.7(330/306) = 6.14 \text{ ks}$$

NOTE: In eq. (V1), design pressure could be used in this example for P_{max} , as this will always be conservative. Here the actual P_{max} of the piping system is used.

The stress due to sustained loads, S_L , for each condition i, calculated in accordance with para. 320.2, is

$$S_{L1} = 3.0 \text{ ksi}$$

 $S_{L2} = 3.0 \text{ ksi}$

$$S_{I3} = 3.7 \text{ ksi}$$

For pipe with a longitudinal weld (E = 1), W is 0.8, 0.77, and 1.0 for S_{p1} , S_{p2} , and S_{p3} , respectively. Note that condition 3 is short term, so W = 1. Also note that with the owner's approval, and in accordance with para. 302.3.5(f)(2), W may be larger than the W factors

listed in Table 302.3.5. The designer chooses not to apply W for girth welds, so W is 1.00 for S_{L1} , S_{L2} , and S_{L3} . The equivalent stress, S_i , is the greater of S_{pi}/W and S_{Li}/W . Therefore, S_i is as follows:

$$\begin{split} S_1 &= \text{MAX} \ (S_{p1}/W, \, S_{L1}/W) \\ &= \text{MAX} \ (4.65/0.8, \, 3.0/1.0) \\ &= \text{MAX} \ (5.81, \, 3.00) \, = \, 5.81 \text{ ksi} \end{split}$$

$$S_2 = \text{MAX} (S_{p2}/W, S_{L2}/W)$$

= MAX (4.65/0.77, 3.0/1.0)
= MAX (6.04, 3.00) = 6.04 ksi

$$S_3 = \text{MAX} (S_{p3}/W, S_{L3}/W)$$

= MAX (6.14/1.0, 3.7/1.0)
= MAX (6.14, 3.70) = 6.14 ksi

From Table A-1, find the temperature, T_E , corresponding to each S_i .

$$T_{E1} = 1.048$$
°F
 $T_{E2} = 1.043$ °F
 $T_{E3} = 1.041$ °F

Compute the LMP for each condition i using eq. (V2).

$$LMP = (20 + 5) (1,048 + 460) = 37,690$$

 $LMP = (20 + 5) (1,043 + 460) = 37,567$
 $LMP = (20 + 5) (1,041 + 460) = 37,513$

Compute the rupture life, t_{ri} , using eq. (V3).

$$a = 37,690/(1,025 + 460) - 20 = 5.38$$

$$t_{r1} = 10^{5.38} = 240,187 \text{ hr}$$

$$a = 37,567/(1,050 + 460) - 20 = 4.88$$

$$t_{r2} = 10^{4.88} = 75,660 \text{ hr}$$

$$a = 37,513/(1,050 + 460) - 20 = 4.84$$

$$t_{r3} = 10^{4.84} = 69,700 \text{ hr}$$

Compute the usage factor, u, the summation of t_i/t_{ri} , for all service conditions.

$$t_1/t_{r1} = 157,200/240,187 = 0.654$$

$$t_2/t_{r2} = 16,000/75,660 = 0.211$$

$$t_3/t_{r3} = 2,000/69,700 = 0.029$$

$$u = 0.654 + 0.211 + 0.029 = 0.895 < 1.0$$

Therefore, the excursion is acceptable.

APPENDIX X METALLIC BELLOWS EXPANSION JOINTS

(Design requirements of Appendix X are dependent on and compatible with EJMA standards.)

X300 GENERAL

(16)

The intent of this Appendix is to set forth design, manufacturing, and installation requirements and considerations for bellows type expansion joints, supplemented by the EJMA standards. It is intended that applicable provisions and requirements of Chapters I through VI of this Code shall be met, except as modified herein. This Appendix does not specify design details. The detailed design of all elements of the expansion joint is the responsibility of the manufacturer. This Appendix is not applicable to expansion joints in piping designed in accordance with Chapter IX.

X301 PIPING DESIGNER RESPONSIBILITIES

The piping designer shall specify the design conditions and requirements necessary for the detailed design and manufacture of the expansion joint in accordance with para. X301.1 and the piping layout, anchors, restraints, guides, and supports required by para. X301.2.

X301.1 Expansion Joint Design Conditions

The piping designer shall specify all necessary design conditions including the following.

X301.1.1 Static Design Conditions. The design conditions shall include any possible variations of pressure or temperature, or both, above operating levels. Use of a design metal temperature other than the fluid temperature for any component of the expansion joint shall be verified by computation, using accepted heat transfer procedures, or by test or measurement on similarly designed equipment in service under equivalent operating conditions.

X301.1.2 Cyclic Design Conditions. These conditions shall include coincident pressure, temperature, imposed end displacements and thermal expansion of the expansion joint itself, for cycles during operation. Cycles due to transient conditions (startup, shutdown, and abnormal operation) shall be stated separately. (See EJMA standards, 4.12.1.5 on fatigue life expectancy, for guidance in defining cycles.)

X301.1.3 Other Loads. Other loads, including dynamic effects (such as wind, thermal shock, vibration, seismic forces, and hydraulic surge); and static loads,

such as weight (insulation, snow, ice, etc.), shall be stated.

X301.1.4 Fluid Properties. Properties of the flowing medium pertinent to design requirements, including the owner-designated fluid service category, flow velocity and direction, for internal liners, etc., shall be specified.

X301.1.5 Other Design Conditions. Other conditions that may affect the design of the expansion joint, such as use of shrouds, external or internal insulation, limit stops, other constraints, and connections in the body (e.g., drains or bleeds) shall be stated.

X301.2 Piping Design Requirements

X301.2.1 General. Piping layout, anchorage, restraints, guiding, and support shall be designed to avoid imposing motions and forces on the expansion joint other than those for which it is intended. For example, a bellows expansion joint is not normally designed to absorb torsion. Pipe guides, restraints, and anchorage shall conform to the EJMA standards. Anchors and guides shall be provided to withstand expansion joint thrust forces when not self-restrained by tie rods, hinge bars, pins, etc. (See para. X302.1.) Column buckling of the piping (e.g., due to internal fluid pressure) shall also be considered.

X301.2.2 Design of Anchors

- (a) Main Anchors. Main anchors shall be designed to withstand the forces and moments listed in X301.2.2(b), and pressure thrust, defined as the product of the effective thrust area of the bellows and the maximum pressure to which the joint will be subjected in operation. Consideration shall be given to the increase of pressure thrust loads on anchors due to unrestrained expansion joints during leak testing if supplemental restraints are not used during the test (see para. 345.3.3). For convoluted, omega, or disk type joints, the effective thrust area recommended by the manufacturer shall be used. If this information is unavailable, the area shall be based on the mean diameter of the bellows.
- (b) *Intermediate Anchors*. Anchors shall be capable of withstanding the following forces and moments:
- (1) those required to compress, extend, offset, or rotate the joint by an amount equal to the calculated linear or angular displacement

- (2) static friction of the pipe in moving on its supports between extreme extended and contracted positions (with calculated movement based on the length of pipe between anchor and expansion joint)
- (3) operating and transient dynamic forces caused by the flowing medium
 - (4) other piping forces and moments

X302 EXPANSION JOINT MANUFACTURER RESPONSIBILITIES

The expansion joint manufacturer shall provide the detailed design and fabrication of all elements of the expansion joint in accordance with the requirements of the Code and the engineering design. This includes

- (a) all piping within the end connections of the assembly supplied by the manufacturer, including pipe, flanges, fittings, connections, bellows, and supports or restraints of piping
- (b) specifying the need for supports or restraints external to the assembly as required, and of the data for their design
- (c) determining design conditions for all components supplied with the expansion joint that are not in contact with the flowing medium

X302.1 Expansion Joint Design

The design of bellows-type expansion joints shall be based on recognized and accepted analysis methods and design conditions stated in para. X301.1. These joints shall be designed so that permanent deformation of the expansion joint and pressure-restraint hardware will not occur during leak testing. Convoluted-type bellows shall be designed in accordance with the EJMA standards, except as otherwise required or permitted herein. Design of other types of bellows shall be qualified as required by para. 304.7.2.

- **X302.1.1 Factors of Safety.** The factor of safety on squirm pressure shall be not less than 2.25. The factor of safety on ultimate rupture pressure shall be not less than 3.0.
- (16) **X302.1.2 Design Stress Limits.** For convoluted type bellows, stresses shall be calculated either by the formulas shown in the EJMA standards or by other methods acceptable to the owner.
 - (a) The circumferential and meridional membrane stress in the bellows, the tangent end, and reinforcing ring members (including tensile stress in fasteners) due to design pressure shall not exceed the allowable stress values given in Table A-1 or Table A-1M.
 - (b) Meridional membrane and bending stresses at design pressure shall be of a magnitude that will not result in permanent deformation of the convolutions at test pressure. Correlation with previous test data may be used to satisfy this requirement.

For an unreinforced bellows, annealed after forming, the meridional membrane plus bending stress in the bellows shall not exceed 1.5 times the allowable stress given in Table A-1 or Table A-1M.

- (c) Stresses shall be calculated in restraints (tie rods, hinge bars, pins, etc.) in self-restrained expansion joints and in the attachments of the restraining devices to the pipe or flanges. Direct tension, compression, bearing, and shear stresses shall not exceed the allowable stress limits stated in para. 302.3.1. The summation of general bending stress plus tension or compression stress shall not exceed the stress values listed in Appendix A, Table A-1 or A-1M, and Table A-2 or A-2M, times the shape factor of the cross section. The shape factor is the ratio of the plastic moment to the yield moment (e.g., 1.5 for a rectangular section). For attachment of restraints to piping, see para. 321.3. Local stresses may be evaluated using the criteria of ASME Section VIII, Division 2, Part 5. Compression members shall be evaluated for buckling in accordance with the AISC Manual of Steel Construction, Allowable Stress Design. For selfrestrained expansion joints, the restraints shall be designed to withstand the full design pressure thrust. Additional considerations may be required where timedependent stresses prevail.
- (d) Pressure design of pipe sections, fittings, and flanges shall meet the requirements of paras. 303 and 304.
- (e) When the operating metal temperature of the bellows element is in the creep range,¹ the design shall be given special consideration and, in addition to meeting the requirements of this Appendix, shall be qualified as required by para. 304.7.2.

X302.1.3 Fatigue Analysis

- (a) A fatigue analysis¹ that takes into account all design cyclic conditions shall be performed and the calculated design cycle life shall be reported. The method of analysis for convoluted U-shaped bellows shall be in accordance with EJMA standards.
- (b) Material design fatigue curves for bellows with seams welded using an autogeneous method are provided in the EJMA standards. The curves are for use only in conjunction with the EJMA stress equations.
- (c) Fatigue testing in accordance with Appendix F of the EJMA standards is required to develop fatigue curves for bellows of materials other than those provided for use in conjunction with the EJMA stress equations.
- (*d*) When applying the fatigue curves from the EJMA standards, a fatigue correction factor, $f_c = 75\%$, shall be used.
- (e) An alternate fatigue correction factor, f_c , may be used with the permission of the owner.

(16)

¹ Consideration shall be given to the detrimental effects of creepfatigue interaction when the operating metal temperature of the bellows element will be in the creep range. Creep-fatigue interaction may become significant at temperatures above 425°C (800°F) for austenitic stainless steels.

X302.1.4 Limitations

- (a) Expansion joint bellows shall not be constructed from lap welded pipe or lap welded tubing.
- (b) All pressure containing or pressure thrust restraining materials shall conform to the requirements of Chapter III and Appendix A.

X302.2 Expansion Joint Manufacture

Expansion joints shall be produced in accordance with the manufacturer's specification, which shall include at least the following requirements.

X302.2.1 Fabrication

- (a) All welds shall be made by qualified welders or welding operators using welding procedures qualified as required by para. 328.2.
- (b) The longitudinal seam weld in the bellows element shall be a full penetration butt weld. Prior to forming, the thickness of the weld shall be not less than 1.00 nor more than 1.10 times the thickness of the bellows material.
- (c) A full fillet weld may be used as a primary weld to attach a bellows element to an adjoining piping component.
- (d) When bellows are attached directly to an adjoining piping component by welding and the piping component is P-Nos. 4, 5A, 5B, or 5C base metal, the attachment weld shall be heat treated in accordance with para. 331.1, except that the exemptions from heat treatment given in para. 331 shall not be permitted. The holding time shall be based on the thickness of the piping component at the bellows attachment weld location. Examination of the attachment welds shall be performed after heat treatment. This heat treatment may affect bellows pressure capacity, mechanical properties, and corrosion resistance. If the required heat treatment is determined to be detrimental to the bellows' performance, the bellows shall not be attached directly to the piping component. In that case, the piping component side of the weld joint shall be buttered in accordance with ASME Section IX, para. QW-283 with appropriate filler metal, heat treated in accordance with Table 333.1.1, and then welded to the bellows.

X302.2.2 Examination. The following are minimum quality control requirements:

- (a) Required examinations shall be in accordance with paras. 341 and 344.
- (b) The longitudinal seam weld in the bellows tube shall be 100% examined prior to forming, either by radiography or, for material thickness ≤ 2.4 mm ($\frac{3}{32}$ in.) welded in a single pass, by liquid penetrant examination of both inside and outside surfaces. For the purposes of this Appendix, either examination is acceptable for design with a factor E_j of 1.00 when used within the stated thickness limits.

- (c) After forming, a liquid penetrant examination shall be conducted on all accessible surfaces of the weld, inside and outside. Welds attaching the bellows to the piping, etc., shall be 100% liquid penetrant examined.
- (d) Acceptance criteria for radiography shall be in accordance with Table 341.3.2. Acceptance criteria for liquid penetrant examination shall be that cracks, undercutting, and incomplete penetration are not permitted.

X302.2.3 Leak Test

(16)

(a) Each expansion joint shall receive a hydrostatic, pneumatic, or combination hydrostatic-pneumatic shop pressure test by the manufacturer in accordance with para. 345, except that the test pressure shall be the lesser of that calculated by eq. (24) (para. 345.4.2) or eq. (X1), but not less than 1.5 times the design pressure. R_r in eq. (24) shall be based on the bellows material. When the bellows' design temperature is equal to or greater than T_{cr} as defined in Table 302.3.5, General Note (b), R_r in eq. (24) shall be replaced by S_{yT}/S_{yt} , where S_{yT} is the yield strength at the test temperature and S_{yt} is the yield strength at the bellows' design temperature. Yield strength values shall be determined in accordance with para. 302.3.2(f), with the bellows material treated as an unlisted material. The test pressure shall be maintained for not less than 10 min.

$$P_T = 1.5 P_S E_t / E \tag{X1}$$

where

E =modulus of elasticity at design temperature

 E_t = modulus of elasticity at test temperature

 P_S = limiting design pressure based on column instability (for convoluted U-shaped bellows, see 4.13.1 and 4.13.2 of the EJMA standards)

 P_T = minimum test gage pressure

- (b) Expansion joints designed to resist the pressure thrust shall not be provided with any additional axial restraint during the leak test. Moment restraint simulating piping rigidity may be applied if necessary.
- (c) In addition to examination for leaks and general structural integrity during the pressure test, the expansion joint shall be examined before, during, and after the test to confirm that no unacceptable squirm has occurred. Squirm shall be considered to have occurred if under the internal test pressure an initially symmetrical bellows deforms, resulting in lack of parallelism or uneven spacing of convolutions. Such deformation shall be considered unacceptable when the maximum ratio of bellows pitch under pressure to the pitch before applying pressure exceeds 1.15 for unreinforced bellows or 1.20 for reinforced bellows. Examination for leakage and deformation shall be performed at a pressure not less than two-thirds of the test pressure, after full test pressure has been applied.

(d) Examination for squirm shall be performed at full test pressure. For safety purposes, this may be accomplished by remote viewing (e.g., by optical magnification or video recording) of the changes in convolution spacing with respect to a temporarily mounted dimensional reference. Examination for leakage shall be performed at a pressure not less than two-thirds of test pressure, after application of full test pressure. For a pneumatic test, the precautions of para. 345.5.1 shall be observed.

APPENDIX Z PREPARATION OF TECHNICAL INQUIRIES

Z300 INTRODUCTION

The ASME B31 Committee, Code for Pressure Piping, will consider written requests for interpretations and revisions of the Code rules, and develop new rules if dictated by technological development. The Committee's activities in this regard are limited strictly to interpretations of the rules or to the consideration of revisions to the present rules on the basis of new data or technology. As a matter of published policy, ASME does not approve, certify, rate, or endorse any item, construction, proprietary device, or activity, and, accordingly, inquiries requiring such consideration will be returned. Moreover, ASME does not act as a consultant on specific engineering problems or on the general application or understanding of the Code rules. If, based on the inquiry information submitted, it is the opinion of the Committee that the inquirer should seek professional assistance, the inquiry will be returned with the recommendation that such assistance be obtained.

An inquiry that does not provide the information needed for the Committee's full understanding will be returned.

The Introduction states that "it is the owner's responsibility to select the Code Section" for a piping installation. An inquiry requesting such a decision will be returned.

Z301 REQUIREMENTS

Inquiries shall be limited strictly to interpretations of the rules or to the consideration of revisions to the present rules on the basis of new data or technology. Inquiries shall meet the following requirements:

(a) Scope. Involve a single rule or closely related rules in the scope of the Code. An inquiry letter concerning unrelated subjects will be returned.

(b) Background. State the purpose of the inquiry, which may be either to obtain an interpretation of Code rules, or to propose consideration of a revision to the present rules. Provide concisely the information needed for the Committee's understanding of the inquiry, being sure to include reference to the applicable Code Section, Edition, Addenda, paragraphs, figures, and tables. If sketches are provided, they shall be limited to the scope of the inquiry.

(c) Inquiry Structure

- (1) Proposed Question(s). The inquiry shall be stated in a condensed and precise question format, omitting superfluous background information, and, where appropriate, composed in such a way that "yes" or "no" (perhaps with provisos) would be an acceptable reply. The inquiry statement should be technically and editorially correct.
- (2) *Proposed Reply(ies)*. Provide a proposed reply stating what it is believed that the Code requires.

If in the inquirer's opinion, a revision to the Code is needed, recommended wording shall be provided in addition to information justifying the change.

Z302 SUBMITTAL

Inquiries should be submitted in typewritten form; however, legible handwritten inquiries will be considered. They shall include the name and mailing address of the inquirer, and be mailed to the following address:

> Secretary ASME B31 Committee Two Park Avenue New York, NY 10016-5990 E-mail: customercare@asme.org

 $INDEX^1$ (16)

Abbreviations, A326.4, Table A-1 General Notes, Table K-1 General Notes (<i>see also</i> symbols) Acceptance criteria, Tables 302.3.3C and D, 323.3.5, 341.3.2, 341.3.3, 341.4, 341.5, 344.1.2, 344.6.2, A328.2.1, A341.3, Table A341.3.2, A341.4.1, A341.5.1, K302.3.3, K323.3.5, K341.3, K341.5, K344.6.2, K344.8.2, U341.3.2 Acidic materials, effects of, F323.4 Adhesive joints (<i>see also</i> solvent cemented) definition (<i>see</i> bonded joint) in metallic piping, 325.1, M318, K318.2 in nonmetallic piping, A328.5.6, MA311.2 Air condensation, 301.11, F301.11 Alignment, 328.4.2, 328.4.3, 335.1, 341.4.1, 341.4.3, 344.7, A328.4, M335.1.1, K328.4.3, U344.8.1 Allowable pressures, nonmetals, Table B-4, Table B-5, Table B-6 Allowable stress (<i>see also</i> basic allowable stresss) definition, 300.2 values, Table B-1, Table B-1M, Table K-1	Ambient effects, 301.4, F301.4 Analysis fatigue (<i>see</i> fatigue analysis) flexibility, 319.4, 320, 321.1.2, A319.4, K319, App. S product, K323.1.5 properties for, 319.3, A319.3 support, 321.1.2, K321 Anchors, 319.7, 321.2.1, 345.3.3, A319.7 Antimony, effects of, F323.4 A-Numbers, Tables 330.1.1 and 331.1.1 Appendices (<i>see</i> Contents) status of, 300(e), 300.4 Application of Code, Introduction, 300.1 Assembly, 300.2, 335, A335, M335, K335, U335 Attachments, 321.1.4, 321.3, K321 (<i>see also</i> supports) Backing filler material (<i>see</i> consumable insert) Backing material, 300.2, 328.3.2, M328.3, K311.2.3, K328.3.2 Base material, def. 300.2
Allowable stress amplitude, K302.3.1, K304.8.2	Base material, def., 300.2
Allowable stress bases, 302.3, A302.3, M302.3, K302.3	Bases for allowable stresses (<i>see</i> allowable stress bases)
Allowable stress range, 302.3.5, 319.1, 319.3.4, K302.3.5	Basic allowable stress definition, 300.2
Allowable stress values for	values, Table A-1, Table A-1M, Table A-2,
bolting, Tables A-2 and A-2M	Table A-2M
clad metals, linings, 323.4.3, K323.4.3	Bearing
metals, Table A-1, Table A-1M, Table K-1	allowable stress, 302.3.1, K302.3.1
supports, 321.1.3	test, A302.3.3
testing, 302.3.6, 345.2.1, A302.3.4, K302.3.6	Bell type joints (see also caulked joints and packed
thermoplastics, Tables B-1 and B-1M	joints)
Allowances	assembly, 335.5
corrosion, erosion, grooving, threading, 302.4, 304.1.1, 320.1, A304.1.1, K302.4, K304.1.1	fluid service requirements, 316, 318, A318, M318, K318
for pressure–temperature variations, 302.2.4,	Bellows expansion joints, 304.7.4, 345.3.3, 345.4.2,
A302.2.4, M302.2.4, K302.2.4, App. V	F304.7.4, K304.7.4, App. X
grooving, threading, 302.4, K302.4	Bending, 332.2, A332.2, M332, K332.2
mechanical strength, 302.5	Bending moments, 319.4.4, 320.2, App. S
Alternating stress, K302.3.2, K304.8.2	Bending temperature, 332.2.2, K332.2.2
Alternative leak test, 345.1, 345.9, K345.1, U345.9	Bends
Aluminum and aluminum alloys	corrugated, 306.2.2, 306.2.3, 332.2.3, A306.2.2, M332,
allowable stresses, 319.3.4, Table A-1, Table A-1M,	K306.2.3, App. D
Table A-2, Table A-2M effects, F323.4	fabrication, 332.2, A332.2, K332.2
flanges, specification, App. L	flattening, 306.2.1, 332.2.1, K332.2.1
fluid service requirements, 323.4.2	fluid service requirements, 306.2, A306.2, M306.2,
precautions, F323.4	K306.2
quality factors, Tables A-1A and A-1B	miter, 300.2, 304.2.3, 304.2.4, 306.3, A304.2.3, A306.3, M306.3, MA206.3, K304.2.3, K306.3, App. D
welding, 323.4.2, Notes for App. A	M306.3, MA306.3, K304.2.3, K306.3, App. D
Ο,	pipe, 304.2.1, 306.2, 332.2, A304.2.1, A306.2, M306.2, M332, K304.2.1, K306.2, K332.2, App. D
1 General Notes follow at end of this Index	pressure design, 304.2.1, 8304.2.4, A304.2.1, K304.2.1

ASME B31.3-2016

Branch connections (see also branch connection fitting, Bimetallic piping, 301.7.3, 323.4.3, M323.4.3, K323.4.3 extruded outlets) (Cont'd) Bismuth, effects of, F323.4 reinforcement, 304.3.3, 304.3.4, 328.5.4, 331.1.3, Blanks, 304.5.3, 308.1, M308.5, K304.5.3, K308.5, A328.5.3, A328.5.6, K328.5.4, App. H Fig. U304.5.3 small, 302.5, 304.3.5, 322.3.2, 319.4.3, A319.6 Blind flanges, 304.5.2, A304.5.2, K304.5.2 strength, 304.3.2, A304.3.2, M304.3.2, K304.3.2 Boiler piping, Fig. 300.1.1, 300.1.3 welded, 304.3.3, 328.5.4, K328.5.4, App. H Bolt design stress basis, 302.3.2, M302.3, K302.3.2 Branches (see branch connection fittings; branch Bolt design stress values, Tables A-2 and A-2M connections; and extruded outlets) **Bolted** joints Brazed joints assembly, 335.2, A335.2, K335.2, U335.7, U335.8 fabrication, 328, 333, K333 design, 304.5.1, 308.4, 309.2, 312, A304.5, A308, limitations, 317.2, M317, K317.2, U333 A309, A312, M308, MA309, K304.5, K308, K309, materials, 325, 333.2, M325 U308, F308, F309, F312 Braze welding, 317.2, 328, 333, M317, K317.2, K333 fluid service requirements, 309, 312, A309, A312, Brazing, 300.2, 317.2, 328, 333, M317, K317.2, K333 K309, K312, U308 Brittle piping, A319.2, A321.5.2, A335.8, FA323.4 (see Bolting, bolts, 309, Table 326.1, A309, K309, also ductility) Tables K323.3.1 and K326.1, F309.1 Butt-and-wrapped joint (for definition see bonded joint) procedure, 309.2.3, 312, 335.1, 335.2, A335.8.2, F309, bonding, A328.5.7 F312 Butt joint, def., 300.2 sequence, 309.2.3, A335.2 Butt weld torque, 309.2.3, 312.1, 312.2, 335.2.2, A335.2.4, acceptance criteria, 341.3.2, 341.3.3, K341.3.2, A335.8.1 K341.3.3 Bond, seal, 300.2, A311.2.4, A328.7, A335.3.2 fluid service requirements, 311.2, A318.3.1, M311, Bonded joints K311.2, U311 acceptance criteria, A341.3.2 girth, 311, 328.5, M311, M328, K311, K328.5 definition, 300.2 longitudinal, 302.3.4, 328.4.3, 328.5, K302.3.4, fabrication, A328 K328.4.3, K328.5 fluid service requirements, A311, MA311.2 preparation, 328.4, K328.4 materials, A328.2.1, A328.3.1, A328.5.3, A328.5.6, repair, 328.6, K328.6 A328.7 requirements, 328, A329.1, K328, U328 procedures, A328.1, A328.2, A328.5 qualification, A328.2 records, A328.2.4 repair of defects, A328.6, A341.3.3 Cadmium, effect, F323.4 regualification, A328.2.6 Carbon steel (see steel, other than stainless) responsibility, A328.1 Casting quality factor, E_c , 302.3.3, K302.3.3, Bonder, def., 300.2 Table A-1A Borosilicate glass, A321.5.3, A323.4.2, A334.1, A335.8, Categories, fluid service, 300(b), 300.2, App. M Table B-5, Table C-5, Table C-8, FA323.4 Category D Fluid Service Bowing (of piping), 301.7.2, F301.7 definition, 300.2, App. M Branch connection fittings requirements for, 300(d), 305.2.1, 305.2.2, 306.3.2, application, 304.3.1, K304.3.1 307.2, 311.2.1, 314.1, 314.2.1, 316, 317.1, 323.7.2, definition, 300.2 333.1, Table 341.3.2, 341.4.2, 345.1, 345.7, limitations, 304.3.2, 304.3.3, 328.5.4, K306.1.2, A311.2.3, A323.4.2, A341.4.2, A345.7 K328.5.4 Category M Fluid Service Branch connections (see also branch connection fitting, definition, 300.2, App. M extruded outlets) piping for, 300(d), Ch. VIII, K300.1.4, UM300 acceptance criteria, 341.3.2, K341.3.2 Caulked joints, 300.2; 316; 335.5; A316; A335.5; M316; considerations, 304.3.5, A304.3.3 M335.5; MA316; K316; Ch. X, Part 4 (see also bell design, 304.3, A304.3, K304.3 type joints and packed joints) fabrication, 328.4.3, Fig. 328.4.4, 328.5.4, A328.5.2, Cautions, Introduction (see precautions) A328.5.3, A328.5.4, A328.5.5, A328.5.6, K328.5.4 Cemented joints (see adhesive joints; solvent cemented fluid service requirements, 306.5, A306.5, M306.5, MA306.5, K306.5 Cements, 325, A328.2.1, A328.3.1, A328.5.3, F323.1

ASME B31.3-2016

Charpy impact test, 323.3, K323.3	Concrete pipe, Table A326.2, Table B-4
Chemical plant, def., 300.2	Condensation, air, 301.11, F301.11
Chemicals piping coverage, 300.1.1	atmospheric (moisture), 301.4.3, F304.7.4
Clad materials, 323.4.3, M323.4.3, K323.4.3	Conditions, design (see design conditions)
Clamps, hygienic, 300.2, U306.6, U315, U335.8, FU315	Connections
Clamps, support, 321.2.2, 321.3.1	branch (see branch connection fittings and branch
Classifying fluid services, App. M	connections)
Cleaning, 323.1.4, 328.4.1, 333.3, A323.1.4, A328.4,	hose, Table 326.1
A328.5, K323.1.4, F335.9	instrument, 322.3.2, A322.3, M322.3, K314.2,
Clips, support, 321.3.2	K322.3.2, UM322.3 structural (support), 321.4
Closures, 304.4, A304.4, M306.6, K304.4	Connections for piping, 300.1.3, 300.2
Closure weld, 345.2.3, K345.2.3	Constant-support hangers, 321.2.3
Code	Consumable inserts, 300.2, 311.2.4, 328.3.1, 328.3.3,
application, Introduction	328.4.2, M328.3, K311.2, K328.3, K328.4.2 (see also
cases, Introduction, 300(f)	backing material)
coverage, 300.1.1	Continuity
description, 300(a)	electrical, A335.2.6
exclusions, 300.1.3	of lining, A329.1.2
inquiries, Introduction, App. Z	Contraction, thermal (see expansion)
intent of, Introduction, 300(c)	Control piping, 322.3, A322.3, M322.3, K322.3,
interpretation, Introduction, App. Z	UM322.3
scope, 300.1	Cooling of fluid, effects, 301.4.1
service requirements, 300(d)	Copper and copper alloys, 319.3.4, Tables A-1, A-1M,
Coefficient of expansion (see thermal expansion)	A-1A, A-1B, A-2, and A-2M
Cold spring, 319.2.4, 335.1.1, 341.4, A319.2.3, K341.4.1	effects, F323.4 Corrosion
Components	allowance, 302.4, 304.1.1, A304.1.1, K302.4, K304.1.1,
•	F323
criteria for pressure–temperature design, 302.2,	in service, 323.5
A302.2, M302.2, K302.2 definition, 300.2	Counterweight supports, 321.2.4
	Coupling, 304.3, 314.2.1, A328.5
dimensions (standards), 326, A326, M326, K326	Criteria, acceptance (see acceptance criteria)
fluid service requirements, 300(d); Ch. II, Part 3;	Criteria, design (see design criteria)
A306; A308; M305–M308; MA306; MA308; K306–K309; Ch. X, Parts 3 and 4	Criteria, impact test, 323.3.5, K323.3.5
	Crushing (see bearing test)
listed, 302.2.1, 302.2.2, 304.7.1, 305.1, 306.1.1, 307.1.1,	Curved pipe (see also bends, elbows)
308.1.1, 309.1.1, 326.1.1, 326.2.1, A302.2.1,	external pressure, 304.2.4, K304.2.4
A302.2.2, A304.7.1, A305, A306.1.1, M305, M326.1.1, K302.2.1, K302.2.2, K304.7.1, K306.1.1,	fatigue, K304.8.3
K307.1.1, K326	Cyanides, effects of, F323.4
metallic_nonmetallic, 304.7.3, A304.7.3	Cyclic effects (loads), 301.10, F301.10
	Cyclic service, 302.3.5, K302.3.5, K304.8.1 (see also
pressure design, 304, A304, M304, K304	severe cyclic conditions)
ratings (standards), 326, A326, K326	
standards, 326, A326, K326	Damaging to human tissue, def., 300.2
tabular listing, Table 326.1, Table A326.1, Table K326.1	Dead load, 301.6.2, 304.3.5, 321.1
	Defects, Table 302.3.3C, 306.4.2, 328.6, 341.3.3, 341.3.4,
unlisted, 302.2.3, 304.7.2, 307.1.2, 326.1.2, 326.2.2,	A328.6, A334.2, A341.3.3, K305.1.2, K323.1.4,
A302.2.3, A304.7.2, M326.1.2, K302.2.3, K304.7.2,	K328.6, K341.3.3
K307.1, K308.1, K326	Definitions (alphabetically listed), 300.2
Compounds	nomenclature, App. J
sealing, 325, M325	Deformation, stress limits, 302.3.2
thread, 314.1, 325, 335.3.1, 335.3.2, A335.3.2,	Delayed heat treatment, 331.2.4
F323.4(e) Compression joints, tubing, 300.2, 315, 335.4.2	Design
Compression joints, tubing, 300.2, 315, 335.4.2, M335.4.2, K315, U315	allowances, 302.2.4, 302.4, A302.2.4, M302.2.4, K302.2.4, K302.4, App. V

```
Design (Cont'd)
                                                             Ductility
  conditions, 301, A301, M301, K301, U301, F301
                                                               reduced, 301.9, 319.1, A302.1, K302.1, F323.1
  criteria, 302, A302, M302, MA302, K302
                                                               requirements (see toughness requirements)
                                                             Dynamic effects (loads), 301.5, M301.5, K301.5, F301.5
  minimum temperature, 301.3.1, 323.2.2, A301.3.1,
       A323.3.2, M323.2, K301.3.1, K323.2.2, F323.2.2
  of (specific) systems, 322, A322, M322, K322
                                                             Earthquake loads, 301.5.3, 302.3.6, A302.3.4, K302.3.6
  philosophy, Introduction, 300(c), K304.7.2
                                                             Eddy current examination, Table K305.1.2, K344.8
  pressure, 301.2, 322.6.3, A301.2, M322.6.3, K301.2,
                                                             Elastic modulus, 319.3.2, 319.4.4, 319.5.1, A319.3.2,
      K322.6.3
                                                                 A321.5.2, App. C
  requirements, 300(c), 300.1, App. X (see also
                                                             Elastomeric seals, A318.4, A335.6.3
      designer)
                                                             Elbows, 304.2.1, 304.2.2, 319.4.4, A304.2.2, K304.2.2 (see
  responsibilities (see engineering design and other
                                                                 also bends; fittings)
      specific terms)
                                                             Electrical continuity, A335.2.6
  stresses, bolting, 302.3.2, M302.3, K302.3.2,
                                                             Electrofusion, 300.2, A328.5.5
      Tables A-2 and A-2M
                                                             Elements, piping, def., 300.2
  stresses, metals (see stresses, allowable)
                                                             Elongated indications, Tables 341.3.2 and K341.3.2
  stresses, nonmetals, A302.3, App. B
                                                             End preparation (see welding preparation)
  supports, 321, A321, K321
                                                             Engineered safeguards, 300(d), M300(d), App. G
  temperature, 301.3, A301.3, M301.3, K301
                                                             Engineering design, 300(b), 300(c), M300(e)
                                                               definition, 300.2
                                                             Engineering requirements, 300(c)
  approval by definition, 331.2.1, M323.1.4
                                                             Equipment connections (see connections for piping)
  definition, 300.2
                                                             Equipment excluded, 300.1.3, Fig. 300.1.1
  qualifications, 301.1
                                                             Equipment, packaged, 300.1.2, 300.2
  responsibilities, 300(b), 300(c), 302.2.3, 302.2.4,
                                                             Erection, 300.2, 335, A335, M335, K335, U335, UM335
      302.3.5, 304.3.5, 304.7.2, 315.1, 319.2.2, 319.3.6,
                                                             Erector responsibilities, 300(b), 341.2, 346, K346, U346
      319.5, 319.7, 320, 321.1, 323.2, 323.4.2, 325.1,
                                                             Erosion allowances, 302.4, 304.1, A304.1, K302.4,
      328.2.3, 331.2.1, 331.2.2, 345.5.1, 346, A302.1,
                                                                 K304.1
      A304.3.5, A308.2.1, A312, A319.2.2, A319.4.2,
                                                             Examination
      A323.2, M302.3.2, MA302.3.2, M323.1.4,
                                                               definition, 341.1
      K300(b), K302.1, K302.2.3, K323.2, K346, U315.1,
                                                               personnel, 342
      U346.2, F304.7.4, App. L
                                                               procedures, 343
Deterioration in service, 300(c), 323.5, A302.1, K302.1,
                                                             Examination methods, 344
    F323
                                                               eddy current, Table K305.1.2, K344.8
Device, pressure relieving, 301.2.2, 322.6, 345.5.1,
                                                               in-process, 341.4.1, 341.4.3, 344.7, A341.4, M341.4,
    K322.6.3, K345.1
                                                                    K341.4, UM341.4
Differential thermal expansion, 301.7.3, 313, 331.1.3,
                                                               liquid penetrant, Table 302.3.3C, Table 341.3.2,
    K331.1.3, F309, App. L
                                                                    341.4.3, 341.4.4, 344.4, 345.9.1, K302.3.3, K344.4,
Dimensional standards, 326, A326, M326, K326
Discharge piping, 301.5.5, 322.6.2, G300.2
                                                               magnetic particle, Table 302.3.3C, 341.4.3, 341.4.4,
Discontinuities, 344.6, K302.3.3 (see also acceptance
                                                                    344.3, 344.7, 345.9.1, K302.3.3, K344.3, App. X
    criteria, indications)
                                                               qualification, 342.1, 343
Displacement
                                                               radiographic, Table 302.3.3C, Table 302.3.3D,
                                                                    Table 302.3.4, 305.2.4, Fig. 328.5.4E, 341.4.1,
  strains, 319.2.1, 319.2.3, 321.1, A319.2.1
                                                                    341.4.3, 341.4.4, 341.5.1, 344.5, 345.2.3, 345.9.1,
  stresses, 319.2.2, A319.2.2
                                                                    M341.4, K302.3.3, K328.5.4, K341.3.2, K341.4.2,
  stress range, 302.3.5, 319.2.3, 319.4.4, K302.3.5
                                                                    K345.2.3, K344.5, App. X
Dissimilar metals, 323.2.2, 330.2.1, 331.2.3, F323.1
                                                               supplementary, 302.3.1, 302.3.3, 341.5, A341.5,
Ductile iron
                                                                    K341.5
  allowable stresses, Tables A-1 and A-1M
                                                               ultrasonic, Table 302.3.3C, 305.2.4, 341.4.1, 341.4.3,
  fluid service requirements, Table 323.2.2, 323.4.2,
                                                                    341.4.4, 344.6, 345.2.3, 345.9.1, M341.4, K302.3.3,
      M323.4.2, K323.4.2
                                                                    K305.1.2, K341.3.2, K341.4.2, K344.6
  quality factor, E_c, Table A-1A
                                                               visual, 302.3.3, 341.4, 344.2, 344.7.2, 345.2.2, A341.4,
  standards, Table 326.1
                                                                    M341.4, MA341.2, K341.4.1, U344.2, U344.8.2
  supports, 321.1.4
```

weld coupon, U344.8

ASME B31.3-2016

Examination, progressive (see progressive	Face seal joint, U335.7
examination)	Facing, flange (see flange facing)
Examination required, 302.3.3, 302.3.4, 323.4.3, 341.3,	Factor of safety, X302.1.1
341.4, 345.2.2, A341.3, A341.4, M341.4, K302.3.3,	Factors
K302.3.4, K323.4.3, K341.3, K341.4, U341	casting quality, E_c (see references in App. J)
alternative leak test, 345.9.1, U345.9	flexibility, <i>k</i> , 319.3.6, App. D
branch connection, 341.3.1, Table 341.3.2, 341.4.3,	stress intensification, i, 319.3.6, 319.4.4, App. D
341.4.4, M341.4, Table K341.3.2, K341.4.2	stress range, f, 302.3.5
castings, 302.3.3, K302.3.3	weld joint quality, E_i (see references in App. J)
Category D Fluid Service, 341.4.2, A341.4.2	weld joint strength reduction, W, 302.3.5
Category M Fluid Service, M341.4	Fatigue, 301.10, 304.1.2, 319.1.1, 319.3.4, 322.3.2,
clad or lined pipe, 323.4.3, K323.4.3	A319.1.1, K302.3.1, K304.7.2, K304.8, K323.1.4,
High Pressure Fluid Service, Table K341.3.2, K341.4	F301.10, X301.1.2, X302.1.3
longitudinal welds, 302.3.4, Table 341.3.2, 341.4.1,	Fatigue analysis, K302.2.3, K304.8, K319, X302.1.3
341.4.4, 341.5, 345.9.1, K302.3.4, K305.1,	Fatigue life, K304.7.2, K323.1.4
Table K341.3.2, K341.4.2	extended, K304.8.5
Normal Fluid Service, 341.4.1, A341.4.1, U341.4	
pneumatic test, 341.4.1, 345.2.2, 345.5.5	Filler material, 300.2, 323.2.2, Table 323.3, 328.3, 328.5, 330.2.2, Table 331.1.1, 331.2.3, 333.2, Table
progressive, 341.3.4, 341.5.1	K323.3.1, K328.3.1, K328.5
severe cyclic conditions, Table 341.3.2, 341.4.3	
visual (see visual examination)	Fillet weld, 300.2, 311.2.6, 328.5.2, 328.5.4, 328.7,
Examiner qualifications, 342.1	331.1.3, Table 341.3.2, K311.2.2, K328.5.2, K331.1.3,
Excluded piping, 300.1.3, Fig. 300.1.1	Table K341.3.2, Table D300, App. H
Excursion, definition, V300.1	Fired heater (see heater piping)
Expanded joints, 313, M313, MA313, K313	Fittings (see also branch connection fittings)
Expansion, thermal	definition (see components)
data, 319.3.1, A319.3.1, App. C	fluid service requirements, 306, A306, M306,
design for, 301.7, 304.3.5, 319, A319, M319, K319	MA306, K306, U306.6
differences, 301.7.3	Fixtures, support, 321.2
effects, 301.7, 313, 314.1, 315.1, F301.7	definition (see pipe-supporting elements)
fluid, 301.4.2, F301.4	Flammable, def., 300.2 (see also hazardous)
piping, 301.7, 319, A319, M319, K319	Flanged joints (see also bolted joints)
Expansion joints, 304.7.4, 319.7, 320.2, 321.2.1, 345.3.3,	assembly, 302.3.2, 312, 335.2, A335.2, K312, K335.2,
A319.7, F304.7.4	F312
bellows type, 345.3.3, 345.4.2, K304.7.4, App. X	bolting (see bolting, bolts)
Experimental stress analysis, 304.7.2	fluid service requirements, 312, A312, K312
Extended fatigue life, K304.8.5	gaskets (see gaskets)
External pressure	Flange facing, 308.3, A308.2.1, K308.4, F308.4
design, 301.4.1, 302.3.5, 304.1.3, 304.2.4, 304.3.2,	Flanges
304.3.3(b), 304.3.6, 332.2, A302.3.3, A304.1.3,	aluminum, specification, App. L
A304.3.2, K302.3.5, K304.1.3, K304.2.4, K332.2.1	blind, 304.5.2, A304.5.2, K304.5.2
test, 345.2.4, 345.2.5	expanded joint, 308.2.2, M308.2, K308.2.2, U308
Extruded outlets, 304.3.1, 304.3.4, K304.3.1, K304.3.2,	facing, 308.3, A308.2.1, A308.4.1, M308.3, K308.3,
Table D300	F308.4
	flat-faced, 309.2.3, 312.2, A335.2.5, F308.4 (see also
Fabricated branches	full-face gaskets)
fluid service requirements, 306.5, A306.5, M306.5,	fluid service requirements, 308, A308.2, M308,
K306.5	MA308.2, K308
pressure design, 304.3, A304.3, K304.3	for severe cyclic conditions, 308.2.4
Fabricated laps, 306.4.1, 306.4.4, 308.2.1, 328.5.5,	pressure design, 304.5, A304.5, A312, K304.5, F312
A306.4, M306.4, MA306.4, K306.4, K328.5.5	slip-on, 308.2.1, 328.5.2, Table 341.3.2, M308.2,
Fabrication, 300.2, 323.4.3, 327–333, A328–A334,	K308.2, F308.2
M328–M333, K323.4.3, K328–K333, U327, U341.4.1	threaded, 308.2.3, 314.1, A308.2.2, M308.2, K308.2.1
Fabricator responsibilities, 300(b), Table 323.3.1, 328.1,	welding neck, 308.2.4
341.2, 346.2, A328.1, A341.2, K328.1, K346.1,	Flared laps, 306.4.2, 306.4.4, 308.2.5, 332.1, 332.3,
U346.2	A306.4.2, M306.4.2, K306.4

Flared tube joints, 315, 335.4.1, A335.4.1, M335.4.1, K315	Grooving allowance, 302.4, K302.4 Guides (support), 321.2.1
Flareless tube joints, 315, 335.4.2, M335.4.2, K315 Flexibility, 319, A319, M319, K319, U319.3.6 analysis, 319.4, 321.1.2, 345.9.2, A319.4, M319.4,	Hangers, pipe (see supports) Hardness requirements, 331.2.2, K331.1.3
K319 characteristic, <i>h</i> , Table D300 examples, App. S factor, <i>k</i> , 319.3.6, Table D300 increased, 319.7, A319.7	testing, 341.5.2 Hazardous properties of fluids, 300(c) (<i>see</i> damaging to human tissues, flammable, fluid service, <i>and</i> instability of fluids), G300.1 (<i>see also</i> fluid service
stresses, 319.4.4 Flexible joints, 319.7	requirements for specific piping elements) Header, 304.3.4, 319.4.4, App. H (see also run)
Fluidized solids coverage, 300.1.1	extruded outlet, 304.3.4
Fluids	Heat-affected zone, 300.2, Table 323.2.2, Table 323.3.1,
cooling of, effects, 301.4.1	Table K323.3.1
coverage, 300.1.1	Heater piping, 300.1.3, Fig. 300.1.1
flashing, 301.5.1, F301.5	Heat fusion joint, 300.2, A328.5.4, MA311.2
geysering, 301.5.1, F301.5	Heat treatment, 300.2, Tables 323.2.2 and 323.3.1, 331,
instability, 300(c), F323(a)	M331, Table K323.3.1, K331, F331
reactivity, F323(a)	for bending and forming, 332.4, K332.4
slugging, 301.5.1	for welding-end valves, 328.5.1
thermal expansion of, 301.2.2, 301.4.2	local (see local heat treatment)
two-phase flow of, 301.5.1, 301.7.2, F301.7	High pressure piping, 300(e), Ch. IX
Fluid service	scope and applicability, K300
categories, 300(d), 300.2, App. M	High silicon iron, 323.4.2, F323.4
definitions, 300.2	Holes, tapped, 309.3, A309.3
guide to classifying, App. M	Hose connection (standard), Table 326.1 Hot gas welded joint, 300.2, A328.5.2, MA311.2
precautions, materials, F323, FA323.4	Hydraulic
requirements, 305–318, 323.4, A305–A318, A323.4, M305–M318, M323.4, MA305–MA318, MA323.4, K305–K318, K323.4, U306–U315	impact (shock) (see shock, hydraulic) support, 321.2.5
Forged fittings, 306.1, M306.1, K306.1	surge, X301.1.3
Forged laps, 306.1, 306.4, M306.1, K306.1, K306.4	Hydrogen, effects, F323.4
Forming, 332.1, 332.3, K332.3	Hydrostatic design stress, 300.2 definition, A302.3
	values, Tables B-1 and B-1M
Gallium, effects, F323.4 Gaskets, 308.1, 308.4, 325, 335.2.4, A308.4, K308.1,	Hydrostatic leak test, 345.1, 345.4, A345.1, A345.4, K345.1, K345.4
K308.4, F308.4, F312, U308 full-face, 304.5.1, 309.2.3, 312.2, A304.5.1, F308.4	Hydrostatic–pneumatic leak test, 345.6, A345.6, K345.6 Hygienic clamp assembly, U335.8
Geysering of fluids, 301.5.1, F301.5	Hygienic ferrules, Fig. U335.8C
Girth weld	Ice loads, 301.6.1
fluid service requirements, 311, M311, K311, U311	Icing, atmospheric, 301.4.3, F307
imperfections, 341.3.2, K341.3.2, U341.3.2	Identification
Gland type joint, 318, 335.6, A318, K318, U306	bond, A328.5.1
Glass, borosilicate, A321.5.3, A323.4.2, A334.1, A335.8, Table B-5, Table C-5, Table C-8, F323.4	piping, F335.10 weld, A328.5.1
Governmental jurisdiction, Introduction, 300(b), 301.1	Impact (see also toughness)
Gradients, temperature, 301.7.2, 321.3, 331.2.5, F301.7	acceptance criteria, 323.3.5, K323.3.5
Gray iron	forces or loads, 301.5.1, 301.5.4, 321.1, A302.1,
allowable stresses, 302.3.2, Table A-1	A323.4.1, M301.5.1, K304.7.2
flanges, bolting for, 309.2.3	hydraulic, 301.5.1
fluid service requirements, 323.4.2, M323.4.2, K323.4.2, F323.4	testing, metals, 323.2.2, 323.3, K323.2.2, K323.3, F323.2.2
quality factor, E_c , 302.3.3, Table A-1A	Imperfections, 341.3.3, Fig. 341.3.2, Table A341.3.2,
standards, Table 326.1	K341.3.3 (see also acceptance criteria; indications)
supports, 321.1.4	illustrations, Figs. 328.4.3, 328.4.4, and 341.3.2

Increasing flexibility, 319.7, A319.7 Indications, 300.2, Tables 341.3.2 and K341.3.2 Initial service leak test, 345.7, M345, MA345, K345.1 In-process examination, 341.4.1, 341.4.3, 342.2, 344.7, A341.4.1, K341.4.2, UM341.4 Inquiries, Introduction, App. Z Inserts, consumable, 300.2, 311.2.4, 328.3.1, 328.3.3, Fig. 328.3.2, 328.4.2, M328.3, K311.2.1, K328.3.3, K328.4.2 Inspection, 340 Inspector	Listed components (see components, listed) definition, 300.2 materials (see materials, listed) specifications, 323.1.1, Apps. A, B, E, and K standards, 326.1.1, A326.1, K326.1, App. E Live load, 301.6.1, 304.3.5, 321.1 Loads (see specific type of load) Local heat treatment, 331.2.6 Longitudinal joints, 302.3.4, 302.3.5(e), 305.2.4, 328.4.3, 341.4,
approval by, 341.4.1, 341.4.3, 341.5.1, A328.2.2,	K302.3.4, K328.4.3, K341.4, Table A-1B stresses, 302.2.4, 302.3.5, K302.3.5 Low alloy steel (<i>see</i> steel, other than stainless) Low temperature requirements, 323.2.2, A323.2.2, K323.2.2 Lubricant, thread, 325, 335.3.1, A314.2.1, A335.6.3, F323.1
components, def., 300.2 Insulated piping, 301.3.3, 301.3.4, F323.1 Insulation loads, 301.6.2, App. S Intensification factors (<i>see</i> stress intensification factors) Intent of Code, Introduction, 300(c) Internal insulation, 301.3.4 Interpretation of Code, Introduction, App. Z Interrupted welding, 330.2.2	Magnesium, effects, F323.4 Magnetic particle examination (<i>see</i> examination methods, magnetic particle) Malfunctions, 301.2.1, 301.4.3, 302.2.4 Malleable iron allowable stresses, 302.3.2, Tables A-1 and A-1M fluid service requirements, 323.4.2, M323.4.2, K323.4.2, F323.4 quality factors, E_c , 302.3.3, Table A-1A
Jacketed piping, 301.2.1, 301.7.3, 345.2.5 leak test, 345.2.5 Joint (<i>see also</i> specific types of joints) fit-up (<i>see</i> alignment) fluid service requirements, 300(d), 310–318,	standards, Table 326.1 supports, 321.1.4 Manufacturer responsibilities, 300(b), 304.3.4, Table 323.3.1, 341.2, 346, K346, U346, App. L, App. N, App. X Materials, 323, 325, A323, M323, MA323, K323 bonding, A328 clad, 323.4.3, M323.4.3, K323.4.3 deterioration in service, 323.5, F323 fluid service requirements, 323.4, A323.4, M323.4, MA323.4, K323.4 listed, 323.1.1, M321 metallic lining, 323.4.3, K323.4.3
Jurisdiction (see governmental) Laps (see fabricated laps; flared laps; or forged laps) for severe cyclic conditions, 306.4, 306.4.4 Larson-Miller parameter, App. V	miscellaneous, 325 nonmetallic lining, A323.4.3 precautions, F323, FA323.4 properties for flexibility analysis, 319.3, A319.3, App. C
Lateral (fitting), 304.3.1 Lead, 323.4.2, M323.4.2, F323.4 Leak test, 345, A345, M345, K345, U345, X302.2.3 Life Fraction Rule, App. V Lined piping, 301.7.3, 323.4.3, A300, A304.1.3, A308.4.1, A312, A318.3, A323.4.3, A329, A335.2.6, A335.8.1, M323.4.3, MA323 Liquid penetrant examination, Table 302.3.3C, 341.4,	reclaimed, 323.1.4, A323.1.4, M323.1.4, K323.1.4 supports, 321.1.4, M321, K323.1.4 temperature limitations, 323.2, A323.2, Tables A323.4.2C and A323.4.3, M323.2, K323.2 unknown, 321.1.4, 323.1.3, M321.1.3, K323.1.3 unlisted, 302.3.2, 323.1.2, 323.2.3, M323.1.2, MA323.1.2, K323.1.2, K323.2.3 welding, 328, A329.1, K328
344.4, 345.9.1, K302.3.3, K344.4, X302.2.2	Mechanical joints, 300.2, 318, A318, M318, K318

Mechanical loads, 302.5, 313, 319.1, 320, 321.1.1,	Owner's Inspector (see Inspector)
A323.4.1, K310	Oxidizing fluid service, F323.4, F335.9
Metallic bellows expansion joints, 304.7.4, 345.3.3,	
345.4.2, K304.7.2, F304.7.4, App. X	Packaged equipment (see equipment, packaged)
Misalignment (see alignment)	Packed joints, 304.7.4, 318, 318.2.3, 321.2.1, 335.6.2,
Miter, def., 300.2	A335.5, A335.6, K318, F323.1 (see also caulked
Miter bend	joints)
flexibility analysis, 319.4.4	Packing, joint or valve, 325, F307, F323.1
fluid service requirements, 306.3, A306.3, M306.3,	Pad, reinforcing (see reinforcing ring)
MA306.3, K306.3	Peening of welds, 328.5.1
	Penetration (see joint penetration)
pressure design, 304.2.3, A304.2.3	Performance testing (see test, performance)
Modulus of elasticity, 319.3.2, 319.5, A319.3.2, App. C	Petroleum refinery, def., 300.2
Multiple branches, 304.3.3, 304.3.4	•
Multiple outlet closures, 304.4.2	Pipe
	definitions, 300.2
Nickel and nickel alloys, Tables A-1, A-1M, A-1A,	fittings, 306, A306, M306, K306, Table 326.1, A326.1
A-1B, A-2, and A-2M; F323.4	fluid service requirements, 300(d), 305, A305, M305,
Nomenclature and symbols, 300.3, App. J	K305
Nominal, 300.2	pressure design, 304.1, A304.1, K304.1
Nominal pipe size (NPS), 300.2	Pipe bends
	fluid service requirements (see bend, fluid service
Nonmetallic lined piping, 300(d), Ch. VII, MA300	requirements)
Nonmetallic lining material, A323.4.3, MA323.4.3	pressure design (see bend, pressure design)
Nonmetallic-metallic piping, 301.7.3, 304.7.3, A304.7.3	Pipe hangers, 321.2.2, 321.3.1
Nonmetals, 300(d), Ch. VII, MA300–MA346, App. B,	Pipe supports, 300.2, 301.8, 321, A321, M321, K321
App. C	Piping
Normal Fluid Service	clad, 323.4.3, M323.4.3, K323.4.3
definition, 300.2	Code coverage, 300.1.1
requirements for, 300(d), 305.1, 306.1.1, 306.3.1,	components (see components)
306.4, 306.5.1, 307.1.1, 308.1.1, 309.1.1, 311.1,	connections for (see connections)
314.1, 315.2, 317.2, 318.1.1, Table 341.3.2, 341.4.1,	cross-country, 300.1.3, Fig. 300.1.1
A305, A306.1.1, A306.3, A306.5.1, A311.1,	definition, 300.2
A314.1, A318.3, A341.4.1, App. M	
Notch-sensitive, 300.2	elements, def. (see elements, piping)
Notch toughness (see impact testing and toughness)	excluded (see excluded, piping)
NPS (see nominal pipe size)	fire protection, 300.1.3
1 1 /	high pressure (see high pressure piping)
	instrument (see instrument piping)
Occasional loads, 302.3.6, A302.3.4, K302.3.6	jacketed (see jacketed piping)
Occasional variations (see allowances for pressure-	joints (see joint; see also specific type of joint)
temperature variations)	lined (see lined piping)
Oil piping coverage	moments, 319.4.4
in-plant, 300.1.1	movements, 304.3.5, 319.6, A319.6
transmission lines, 300.1.3, Fig. 301.1.1	pressure relief (see pressure relief piping)
Openings in closures, 304.4.2, A304.4	supports, 321, A321, M321, K321
Operators, qualification, 328.2, A328.2, K328.2	transmission lines, 300.1.3
O-rings, 325.1, F323.1	Piping system, def. (see system, piping)
Outlet fittings, 304.3.1, 304.3.2, 304.4.2	Plumbing, 300.1.3
Outlet headers (see extruded outlets)	Pneumatic leak test, 341.4.1, 345.1, 345.5, 345.9.1,
Owner's	A345.5, K345.1, K345.5, U345.1, F345.5
approval, 302.2, 302.3.5, 304.7.2, 322.6.3, 345.4.3,	P-Numbers, 328.2.1, 328.2.2, 331.1.3, Tables 330.1.1 and
A345.5.1, K302.2.1, K323.1.6, K326.4, K328.3.1,	
	331.1.1, 332.4.1, 341.3.1, K330.1.1, K331.1, K332.4.1
K341.1.2, K345.5.1, U342.2	Table A-1, Table A-1M, Table K-1
guide to classifying fluid services, App. M	Poisson's ratio, 319.3.3, A319.3.3
option for testing, 345.1, 345.7	Postweld heat treatment (see heat treatment)
responsibilities, 300(b), 300(d), 300(e), 302.2.1,	Power boilers, 300.1.3, Fig. 300.1.1
302.2.4, 340.2, 346.3, M300(a), K300(a), K300(b),	Precautions, App. F
K302.2.1, K304.8.5, K328.3.1, K333, App. M	materials (see materials, precautions)

Regulatory considerations, Introduction

Prohibitions, Introduction

Reinforced plastic mortar (RPM)	RTR (see reinforced thermosetting resin)
assembly, A335.3.5	Run (pipe), 304.3, 319.2.2, 319.4.1, 319.4.4, 328.5.4,
bonding, A328.5.1, A328.5.6, A328.5.7	App. H (see also header)
design stresses, A302.3.2, App. B	• • • • • • • • • • • • • • • • • • • •
fluid service requirements, A314.2.2, A323.4.2	
Reinforced thermosetting resin (RTR)	Saddle, 321.3.1, A306.5.2, A328.5.3, A328.5.4, A328.5.5,
assembly, A335.3.5	A328.5.6 (see also reinforcing ring)
bonding, A328.5.1, A328.5.6, A328.5.7	Safeguarding, safeguards, 300(d), 300.2, 305.2.2,
design stresses, A302.3.2, App. B	308.2.4, 313, Table 314.2.1, 314.2.2, 315.2, 317.2,
9	318.2.3, 323.4.2, A323.4.1, A323.4.2, M300(d),
fluid service requirements, A314.2.3, A323.4.2	FA323.4, App. G
Reinforcement of	* *
branch connections, 300.2, 304.3.3, 328.5.4, K304.3.3,	Safety relief (see pressure relieving)
App. H	Scope of Code, 300.1
extruded outlet headers, 304.3.4	diagram of scope, Fig. 300.1.1
welds, 300.2, Table 341.3.2, Fig. 341.3.2,	Seal bond, 300.2, A311.2.4, A328.7, A335.3.2
Table K341.3.2	Seal weld, 300.2, 311.2.6, 314.1, 328.5.3, 331.1.3, 335.3.2
Reinforcing ring (or pad, or saddle), 304.3.3, 328.5.4,	K311.2.6
331.1.3, App. H	Sensitive leak test, 345.8, 345.9.3, M345.1, K345.1,
Relieving, pressure (see pressure relieving)	U345.8, UM345
Repair of defects, Table 302.3.3C, 328.6, 335.2.1,	Separator, 307, M307, K307
335.4.1, 341.3.3, A328.7, A329.1.2, A334.1, A335.8,	Set pressure, 322.6.3
A341.3.3, K328.6, K341.3.3	Severe cyclic conditions, 300(d), 300.2, 305.2.3, 306.1.4,
Requalification	306.2.3, 306.3.3, 306.4.3, 306.5.2, 308.2.1, 308.2.4,
bonder, bonding operator, A328.2.6	309.2.4, 311.2.2, 311.2.3, 314.1, 317.2, 318.2.2,
welder, welding operator, 328.1, K328.2.1	323.4.2, Table 341.3.2, 341.4.3, A300(e), M300(e),
Request for revision, App. Z	K302
Required examination, 341.4, A341.4, M341.4, K341.4,	Shear, allowable stress, 302.3.1, K302.3.1
U341.4, UM341.4	Shear test, 323.4.3
	Shielding of piping, G300.3
Requirements for welding (see welding requirements)	Shock, hydraulic, 301.5.1, 315.1, 321.1, A302.1,
Resilient support, 321.2.3	•
Responsibility	A304.7.2, A323.4.1, K304.7.2
bonding, A328.1	thermal, A302.1, A304.7.2, A323.4.2, A335.8.1
designer, 300(b), 300(c), 300(d), 300.4, K300(b),	Size of weld, 300.2, Fig. 328.5.2, 328.5.4, 328.5.5
U246.2	Slag, 300.2, Tables 341.3.2 and K341.3.2
erector, 300(b), 341.2, U346.2	Sliding supports, 321.2.2
examiner, 341.2	Slip-on flanges (see flanges)
fabricator (see fabricator responsibilities)	Snow loads, 301.6.1, 321.1
Inspector (see Inspector responsibilities)	Socket weld, 311.2.4, 311.2.5, 328.5.2, 331.1.3, Table
manufacturer, 300(b), Table 323.2.2, 341.2	341.3.2, 341.4.3, M311.1, K311.2.3
owner (see owner's responsibilities)	Soldered joints, 317, 325, 333, M317, K317.1, K333,
welding, 328.1, K328.1	F323.1
Restraint	Soldering, 300.2, 333
definition, 319.2.1	Solvent cemented joints, A328.5.3
effects of, 319.2.1	Spacing (see welding preparation)
fixtures, 321.2.1	Special joints, 318, 335.6, A318, A335.6, M318, M335.6,
loads due to, 301.7.1	K318, K335.4
	Special testing, 345.7, 345.8, 345.9
materials, 321.1.4	Specifications (<i>see also</i> standards)
Room temperature, for tension testing, K302.3.2	± ,
Root	indexes to, Apps. A, B, and K
imperfections, Table 341.3.2, Fig. 341.3.2,	listed, 302.2.1, 302.2.2, 323.1.1
Table K341.3.2	referenced, Apps. A, B, E, and K
opening, 300.2, Fig. 328.4.2, Fig. 328.4.3, Fig. 328.4.4	unlisted, 302.2.3, 323.1.2
penetration, 328.5.4, Table 341.3.2, Fig. 341.3.2,	Spiral (helical seam) weld (see longitudinal joint)
Table K341.3.2	Spot radiography, Table 302.3.4, 341.5.1, 344.5.2
spacing (see welding preparation)	Spring support, 321.2.3
RPM (see reinforced plastic mortar)	Squirm (bellows expansion joint), X302.2.3

Stainless steel, Tables A-1, A-1M, A-1A, A-1B, A-2, A2M, C-1, C-3, and C-6, F323.4	Structural attachments, 321.3 definition (<i>see</i> pipe-supporting elements)
Standards (see also specifications)	Structural connections, 321.4
component, 302.2.1, 302.2.2, 302.2.3, 303, 326, A326,	Structures, support, 321.4 (see also piping, definition)
M326, K326	Sulfur compounds, effects, F323.4
dimensional, 326.1, M326.1	Supplementary examination, 302.3.1, 302.3.3, 341.5,
rating, 302.2.1, 303, 326.2	A341.5, K341.5
referenced, Tables 326.1, A326.1, K326.1, App. E	Supports, 321, A321, M321, K321
unlisted, 302.2.3	anchors, 319.5.1, 319.7, 321.2.1, A319.7
Static sparking, A335.2.6	attachments, 311.2.5, 321.3, 328.5.2, 331.1.3,
Status of Appendices, 300(f), 300.4	Tables 341.3.2 and K341.3.2
Steam piping coverage, 300.1.1, 300.1.3	brittle piping, A321.5.3
Steel, other than stainless, Tables A-1, A-1M, A-1A,	constant weight, 321.2.3
A-1B, A-2, A-2M, C-1, C-3, and C-6, F323.4	counterweight, 321.2.4
Stiffening, pipe under external pressure, 304.1.3	definitions (see pipe-supporting elements)
Stop valves, 322.6.1, F332.6	design, 321.1, A321.5, K321
Straight threads, 314.2.2, 335.3.3, M314.2.2, M335.3.3,	fixtures, 321.2
K314.3.2, K341.4.1	guides, 321.2.1
Strainer, 307, M307, K307	hangers, 321.2.2, 321.3.1
Strains (see displacement strains)	hydraulic, 321.2.5
Strength of branch connections, 304.3.2, A304.3.2,	inextensible, 321.2.2
K304.3	loads, 321.1
Stress amplitude (alternating), K304.8.2, K304.8.3	materials, 321.1.4, M321.1.4
Stress analysis, 319.4, 321.1.3, 345.9.2, A319.4, M319.4,	movements, 301.8, 319.2.1
K319	nonmetals, A321.5
experimental, 304.7.2	resilient, 321.2.3
-	sliding, 321.2.2
fatigue, K304.8 rigorous, 319.4.1, M319.4, K319	spring, 321.2.3
=	structure, 321.4 (see also piping, def.)
simplified, 319.4.1, 319.4.2, M319.4 Stress evaluation, V204.8.4	threads for, 321.1.5
Stress evaluation, K304.8.4	Surface texture/finish, Table 326.1, Table 341.3.2,
Stress intensification factor, 319.3.6, 319.4.4, U319.3.6,	Table K341.3.2
App. D	Sustained loads, 302.3.5, A302.3.3, K302.3.5
Stress range reduction factor, 302.3.5	Swivel joints, 319.7, A319.7
Stresses	Symbols, 300.3, App. J (see also abbreviations,
allowable, 302.3.1, A302.3.1, K302.3.1, Apps. A, B,	nonmetals)
and K	System, piping
analysis (see stress analysis)	definition, 300.2
bases, 302.3, A302.3, M302.3.2, K302.3.2	Systems (specific), design, 322, M322, K322
bolt design, 302.3.2(a), Tables A-2 and A-2M	
design (nonmetals), A302.3, App. B	
displacement, 319.2.2, A319.2.2	Tack welds, 300.2, 328.5.1, K328.5.1, U328.2.1, U328.5.1
displacement range, 302.3.5, 319.1, 319.3.4, K302.3.5	Tank farm piping, 300.1.1
allowable, 302.3.5, K302.3.5	Tantalum, F323.4
computed, 319.4.4	Taper threads, 314.2.1, 335.3, A314.2.1, M314.2.1,
flexibility, 319.2.2, 319.4.4, A319.2.2	M335.3.4, K314.3.1, K344.4.1
limits, 302.3.1, 302.3.5, 302.3.6, 321.1.3, A302.3.3,	Tapped bolt holes, 309.3, A309.3
A302.3.4, K302.3.1, K302.3.5, K302.3.6	Tees, 304.3, 319.4.4, A304.3.2 (see also branches and
longitudinal, 302.3.5, K302.3.5	fittings)
occasional loads, 302.2.4, 302.3.6, A302.2.4, A302.3.4,	Temperature
M302.2.4, MA302.2.4, K302.2.4, K302.3.6	cycles, 302.3.5, 319.2.3, K304.8.1
pressure, 304, A304, M304, MA304, K304	design (see design temperature)
sustained loads, 302.3.5, A302.3.3, K302.3.5	gradients, 301.7.2, K304.7.2, F301.7
tabulated, Tables A-1, A-1M, A-2, A-2M, B-1, B-1M, and K-1	limits, limitations, 323.2, A323.2.2, Table A323.4.3, M323.2, K323.2
terms, defined, 300.2	minimum (see design minimum temperature)
,	(

Test, 345, A345, M345, K345, U345 assembly, A328.2.5	Threaded joints, U314 assembly, 335.3, 341.4.1, 341.4.3, A335.3, M335.3,
joint, 328.2.2, K328.2.1 loads, 302.3.6, 321.1, K302.3.6	K341.4.1, UM335.3.3 fluid service requirements, 314, A314, M314,
records, 345.2.7	MA314.1, K314
requirements, 323.4.3, 328.2.2, 345.1, K328.2.1,	seal bonds, A311.2.4, A328.6, A335.3.2
K345.1	seal welds, 311.2.6, 314.1, 328.5.3, 335.3.2, K311.2.6,
stresses, 302.3.6, 345.2.1, A302.3.4	K335.6
Test,	Threads
alternative, 345.9, K345.1	allowance, 302.4, 304.1.1, A304.1.1, K304.1.1
burst, A328.2.5(b)	compound, 314.1, 325, 335.3.1, 335.3.2, A335.3.2 condition of, M335.3.4, K341.4.1
hardness, 341.5.2	for supports, 321.1.5
helium mass spectrometer, U345.8.1, U345.9	lubricant, 325, 335.3.1, A314.2.1
hydrostatic, 345.1, 345.4, A328.2.5(c), A345.1,	sealant, A314.2.1, A335.3.2, A335.3.5
A345.4, K345.1, K345.4	standards, Table 326.1, Table A326.1, Table K326.1
impact, Table 323.2.2, 323.3, Table 323.3.1, K323.3,	Tie rods, 319.7, A319.7
Table K323.3.1, F323.4	Tin
leak, 345.1, A345.1, K345.1	effects, F323.4
performance, A304.7.2, K304.7.2	fluid service requirements, 323.4.2
pneumatic, 341.4.1, 345.1, 345.5, K345.1	Titanium, Tables A-1 and A-1M, Table A-1B, F323.4
pressure, 345, K345	Tolerances, 328.4.3, Figs. 328.4.3 and 328.4.4, A328.2.1
proof, 304.7.2	Torque, bolting (see bolting torque)
qualification, 328.2.1, A328.2.5, K328.2.1	Toughness, 301.9 (see also impact test)
sensitive leak, 345.8, M345, K345.1, U345.8	requirements, 314.2.1, 323.2.2, 323.3, K323.2.2, K323.3
shear, 323.4.3	Transmission pipelines, 300.1.3, Fig. 300.1.1
toughness (see impact)	Trap, 307, K307
Thermal	Tubing joints, 315, 335.4, A315, A335.4, M315, M335.4
analysis (see flexibility analysis)	K315
cycling, 301.10, 302.3.5, 319.2, A319.2, K302.3.5, K304.8	Tungsten inclusion, Table 341.3.2
	Two-phase flow, 301.7.2, F301.7
gradients, 301.7.2, K304.7.2, F301.7 Thermal expansion	
coefficients, 319.3.1, A319.3.1, App. C	Ultrasonic examination, Table 302.3.3C, 341.4.1,
data, App. C	341.4.3, 344.6, K305.1, K341.4.1, K344.6
differential, 301.7.3	Unbalanced piping system, 319.2.2, 319.7, A319.2.2,
effects (see expansion effects)	A319.7
of fluids, 301.4.2	Uninsulated piping, 301.3.2
of piping, 301.7, 319, A319, M319, K319	Unknown materials, 321.1.4, 323.1.3, M323.1.3,
relief, 301.2.2	K323.1.3
stresses, 319.2.2, 319.4, A319.2.2	Unlisted
Thermally induced loads, 301.7, F301.7	components (see components, unlisted) joints, 315.3, 318.1.2
Thermoplastics	materials, 323.1.2
bonding, A328.5.1, A328.5.2, A328.5.3, A328.5.4	Unstable fluids, 300(c), F323(a)
definition, 300.2	Used materials, 323.1.4, A323.1.4, M323.1.4, K323.1.4
design stresses, A302.3.2, App. B	, , , , , , , , , , , , , , , , , , , ,
fluid service requirements, A314.2.1, A323.4.2	Valvo packing 200(a) 225 E207 E222 1
precautions, FA323.4	Valve packing, 300(c), 325, F307, F323.1 Valves
Thermosetting resin (including RPM, RTR), definition,	fluid service requirements, 302.2.5, 307, 323.4.2,
300.2	A302.2.5, M302.2.5, M307, K307, F307
Thermosetting wrapped joint, A328.5.7	heat treatment, 328.5.1
Thickness	high purity fluid service, U307, U319.3
allowances, 302.4, 304.1.1, 304.4.1, 304.5.2, 304.5.3,	relief, 301.2.2, 322.6.3 (see also device)
A304.1.1, K304.1.1, K304.5.2	stop, 322.6.1, F322.6
effect on heat treatment, 331.1.3, K331.1.3	Variations, pressure–temperature (see allowances for)

Vent (piping), 345.1, K314.2, F335.9, N200 (see also	Welding (Cont'd)
pressure relieving system)	of aluminum, 323.4.2
Venting (welds), 328.5.4, F308.2	of metals, 328, K328
Vibration effects, 301.5.4, 304.7.2, 313, 315.1, 321.1,	operator, 300.2, 328.2, A329.1.2, K328.2
A304.7.2, A323.4.1, M301.5.4, K301.5.4, K304.7.2	orbital, U328.2.1, U328.4
Visual examination, 302.3.3, Table 341.3.2, 341.4, 344.2,	outlet fittings, 304.3.1, 304.4.2, 306.1.2, M304.3.2
Table K341.3.2, K341.4.1	preheating, 330, Table 330.1.1, K330
	preparation, 328.4, K328.4
747 11 c1 : 1	procedures, 300.2, 328.2, A329.1.2, K328.2
Wall thickness	qualification, 328.2, A329.1.2, K328.2
allowance, 302.4, 304.1.1, A304.1.1, K304.1.1	quality assurance, 319.4.5, 341.3
governing, 331.1.1, K331.1.1	records, 328.2.4, K328.2.4
pressure design, 304, A304, K304	repair, Table 302.3.3C, 328.6, 341.3.3, A329.1.2,
thinner component, T_w , Table 341.3.2, 344.6.2,	K328.6, K341.3.3
Table K341.3.2, App. J	requirements, 328.5, A329, K328.5
Water hammer, 301.5.1	responsibility, 328.1, K328.1
Water piping coverage, 300.1.1, 300.1.3	spacing, 328.4.3
Weight loads, 301.6, 321.1	Welds
Weld (see also welded joints; welds; welding)	branch, 328.4.3, Fig. 328.4.4, 328.5.4, K328.4.3,
coupon, 300.2, U328.4, U328.4.4	K328.5.4
definition, 300.2	circumferential, 328.4.2, 328.4.3, 331.2.6, Table
fluid service limitations, 311, A318.3, M311, K311	341.3.2, 341.4.1, 341.4.3, 341.5.1, 345.9.1, M341.4
identification, 328.5.1	K328.4.2, K328.4.3, K328.5.1
quality assurance, required, 319.4.5	closure, 345.2.3(c)
quality factor, E_i , 302.3.4, Tables 302.3.4 and A-1B,	dissimilar metals, 331.2.3
K302.3.4	fillet (see fillet weld)
reinforcement (excess thickness), 300.2,	laps (see fabricated laps)
Table 341.3.2, Fig. 341.3.2, Table K341.3.2	± 1
size, 300.2, Fig. 328.5.2, Fig. 328.5.4, Fig. 328.5.5	longitudinal (see longitudinal joints)
Welded joints	miter, 328.4.3
acceptance criteria (imperfections), Table 341.3.2,	seal, 328.5.3
Fig. 341.3.2, Table K341.3.2	socket, 304.3.2, 308.3.2, 311.2.5, 311.2.6, 328.5.2,
fabrication, 328, A328.5.2, A329, M328, K328	Fig. 328.5.2B, Fig. 328.5.2C
fluid service requirements, 311, A318.3, M311, K311	tack, 328.5.1, K328.5.1, U328.2.1, U328.5.1
Welder, 300.2, 328.2, A329.1.2, K328.2	Wind loads, 301.5.2, 301.5.5, 301.8, 302.3.5, 302.3.6,
Welding, U328	319.2.1, 321.1, A302.3.4, K302.3.6
alignment, 328.4.2, 328.4.3, 328.5.1, K328.4.3,	Wrapped (see butt-and-wrapped joint and
K328.5.1, Fig. K328.4.3, U344.8.1	thermosetting wrapped joint)
automatic, U315.2	
environment, M307.2, M323.4.3, MA323.4.3,	X-ray examination (see radiography)
Tables B-1 and B-1M, F304.7.4, G300	Truj chairmancii (ccc radiograpii)
heat treatment, 301.9, 311.1, 321.3.2, 323.1.2, 328.6,	
328.7, 330.2.2, 331, M331, K331	Young's modulus (see modulus of elasticity)
	Y values (for metal pipe), 304.1.1
hot gas, A328.5.2	
imperfections (see welded joints)	Zina
interrupted (see interrupted welding)	Zinc
materials, 328.3, M328.3, K328.3	coatings, K323.4.2
neck flanges (see flanges)	effects, F323.4
nonmetallic lined pipe, A318.3, A329	Zirconium and zirconium alloys, F323.4

NOTES FOR INDEX

GENERAL NOTES:

- (a) Reference is not made to a paragraph that merely states that a previous paragraph applies.
- (b) To locate references with letter prefix, refer to the following table:

Prefix	Location	Prefix	Location	Prefix	Location
A*	Chapter VII	FU	App. F	N	App. N
В	App. B	G	App. G	U	Chapter X
C	App. C	K	Chapter IX,	UM	Chapter X
D	App. D		App. K	V	App. V
F	App. F	M	Chapter VIII	X	App. X
FA	App. F	MA	Chapter VIII		

^{*}For Tables A-1, A-1M, A-1A, A-1B, A-2, and A-2M, see Appendix A.

ASME B31.3 INTERPRETATIONS VOLUME 25

Replies to Technical Inquiries April 14, 2014 through September 23, 2015

GENERAL INFORMATION

It has been agreed to publish interpretations issued by the B31 Committee concerning B31.3 as part of the update service to the Code. The interpretations have been assigned numbers in chronological order. Each interpretation applies to the Edition stated in the interpretation, or if none is stated, to the Edition in effect on the date of issuance of the interpretation. Subsequent revisions to the Code may have superseded the reply.

These replies are taken verbatim from the original letters, except for a few typographical and editorial corrections made for the purpose of improved clarity. In some instances, a review of the interpretation revealed a need for corrections of a technical nature. In these cases, a revised reply bearing the original interpretation number with the suffix R is presented. In the case where an interpretation is corrected by errata, the original interpretation number with the suffix E is used.

ASME procedures provide for reconsideration of these interpretations when or if additional information is available which the inquirer believes might affect the interpretation. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. As stated in the Statement of Policy in the Code documents, ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

For detailed instructions on preparation of technical inquiries to the B31 Committee, refer to Appendix Z.

NUMERICAL AND SUBJECT INDEXES

Numerical and Subject Indexes have been prepared to assist the user in locating interpretations by location or by subject matter in the Code. They cover interpretations issued from Volume 1 up to and including the present volume, and will be updated with each volume.

B31.3

D31.3		
Subject	Interpretation	File No.
Chapters V and VI (P21 2 1006 Through P21 2 2012)	25.00	14 402
Chapters V and VI (B31.3-1996 Through B31.3-2012)	25-09 25-27	14-483
Fig. 323.2.2B, General Notes, Allowable Stress, S, at Temperature Lower	23-27	14-1817
Than Impact Test Temperature/Minimum Temperature (B31.3-2012)	25-12	14-1182
Fig. 328.5.4D, Acceptable Details for Branch Attachment Welds	25-12	14-1102
(B31.3-2012)	25-20	14-1470
Paras. 302.3.2(f), 304.7.2, and 323.1.2, Additive Manufacturing	20 20	111110
(B31.3-2014)	25-40	15-2053
Paras. 302.3.2(f), 304.7.2, and 323.1.2, Additive Manufacturing Materials		
(B31.3-2014)	25-39	15-2052
Para. 302.3.5(c), Stress Due to Sustained Loads (B31.3-2012)	25-02	14-44
Paras. 304.3, 304.7.2, and 300.2, Branch Connections, Unlisted		
Components, and Definitions (B31.3-2012)	25-11	14-1171
Paras. 304.3, 304.7.2, and 300.2, Branch Connections, Unlisted	05.45	4.4.4.4.0
Components, and Definitions (B31.3-2012)	25-15	14-1312
Paras. 304.3.4(d)(4), Limitations on Radius (B31.3-2014)	25-31	15-788
Para. 304.7.2, Clarification of Pressure Design Using Proof Testing (B31.3-2012)	25-19	14-1466
Para. 304.7.2, Pressure Design of Other Components, Unlisted Components	23-19	14-1400
(B31.3-2012)	25-03	14-257
Para. 304.7.2, Unlisted Components (B31.3-2006 Through B31.3-2012)	25-08	14-482
Para. 306.1, Pipe Fittings (B31.3-1996 Through B31.3-2014)	25-41	15-2061
Paras. 323.2.2(d), (d)(1), and (d)(2), and Fig. 323.2.2B, Impact Tested		
Material (B31.3-2008 Through B31.3-2014)	25-32	15-810
Para. 323.3 and Table 323.3.1, Item A-4, Impact Testing Requirements for		15-1992,
Metals (B31.3-2012 and B31.3-2014)	25-37	15-1995
Para. 323.3.5(d), Retest for Impact Test (B31.3-2012)	25-38	15-1997
Para. 323.4.3, Cladding and Lining Materials (B31.3-2012)	25-25	14-1683
Paras. 328.2 and U341.4.1, Welding Radiography (B31.3-2012)	25-26	14-1790
Para. 328.5.1(c), Tack Welding Welder Performance Qualifications		
(B31.3-2008)	22-35R	09-1003
Paras. 331.1.3(a)(2) and (c), Preheat and PWHT Governing Thickness	25.20	15 (1)
(B31.3-2014)	25-30 25-06	15-616 14-433
Para. 335.1(c), Alignment of Assembly and Erection (B31.3-1999)	25-01	13-1677
Para. 341.3.3, Defective Components and Workmanship (B31.3-2012)	25-13	14-1259,
Talan o 1100) December Componento una Profitamiento (2010 2012)	20 10	14-1266
Para. 341.3.4, Progressive Sampling for Examination (B31.3-2012)	25-14	14-1287
Para. 341.3.4, Progressive Sampling for Examination (B31.3-2012)	25-21	14-1482
Para. 341.3.4(f), Progressive Sampling for Examination (B31.3-2010)	25-05	14-355
Paras. 341.4.1(b), 345.2.3(c), and 345.2.6, and Figs. 328.5.4D and 328.5.4E,		
Branch Attachment Welds and Radiography (B31.3-2012)	25-17	14-1383
Paras. 344.2 and 342.1, Visual Examination (B31.3-2012)	24-21R	13-710
Paras. 345.1, 345.2.3, and 345.9, Leak Test (B31.3-2012)	25-23	14-1681
Para. 345.2.3(c), Special Provisions for Testing, Closure Welds	25.24	15 1500
(B31.3-2014)	25-34	15-1723
Paras. 345.2.3(c) and K345.2.3(c), Closure Welds (B31.3-2012)	25-24	14-1682
Para. 345.5, Pneumatic Leak Test (B31.3-2012)	25-07 25-04	14-435 14-269
Para. 345.5.5, Pneumatic Leak Test Procedure (B31.3-2012)	25-04 25-28	14-209
Para. K304.7.3, Components With Nonmetallic Parts (B31.3-2012)	25-33	15-1690
Para. K331.1.1(b), Minimum Difference Between Tempering and PWHT	25 55	13 1070
Temperature (B31.3-2012)	25-10	14-690
Paras. M341/341 and M345/345, Examination and Testing: VT/PT/MT		
and RT/UT Versus Leak Testing and Pressure Testing (B31.3-2012)	25-18	14-1401
Para. X302.2.3, Leak Test Under Pneumatic Condition on Appendix X		
Expansion Joints (B31.3-2012)	25-16	14-1372
Table 302.3.5, Para. 302.2.4, and Para. 302.3.5(e), Pressure and		
Temperature Conditions (B31.3-1996 Through B31.3-2014)	25-42	15-2137

Subject	Interpretation	File No.
Table 308.2.1, Flange Thickness (B31.3-2014)	25-36	15-1885
Use of Austenitic Stainless Steel Materials at Low Temperatures		
(B31.3-2006)	22-03R	08-477
Table 323.3.1, Column B, Simulation Heat Treatment for Low		
Temperature Carbon Steel Piping Material (B31.3-2012)	25-22	14-1553
Table 323.3.1, Welding Procedures With Impact Tests (B31.3-2012)	25-29	15-586
Table K326.1 and Para. K323.3, HP Valve Product Codes (B31.3-2014)	25-35	15-1804

Interpretation 22-03R

Subject: Table 323.2.2, Items A-4(a) and A-4(b), and Paras. 323.2.2(f)(1) and (2), Use of Austenitic Stainless Steel Materials at Low Temperatures (ASME B31.3-2006)

Date Issued: April 14, 2014

File: 08-477

Question: Does the code permit austenitic stainless steel materials listed in Table A-1 to be used to the minimum temperatures listed regardless if they are seamless or welded product form?

Reply: Yes, provided the requirements of Table 323.2.2, items A-4(a) and A-4(b), and applicable Notes in Table A-1 are followed.

Interpretation 22-35R

Subject: Para. 328.5.1(c), Tack Welding Welder Performance Qualifications (B31.3-2008)

Date Issued: September 23, 2015

File: 09-1003

Question (1): Does ASME B31.3, para. 328.5.1(c) require that tack welds, whether they are to be incorporated into the final weld or be removed, be made by a qualified welder?

Reply (1): Yes.

Question (2): Does ASME B31.3, para. 328.5.1(c) require that tack welds be made to a qualified WPS for that joint?

Reply (2): Yes; see para. 328.5.1(a).

Question (3): Does ASME B31.3, para. 328.5.1(c) provide rules for the qualification of welders or welding operators depositing tack welds?

Reply (3): No. See para. 328.2.

Interpretation 24-21R

Subject: Paras. 344.2 and 342.1, Visual Examination (B31.3-2012)

Date Issued: September 23, 2015

File: 13-710

Question (1): Does ASME B31.3-2012 have any qualification requirements for visual examiners performing Code-required examinations?

Reply (1): Yes. See paras. 342.1 and 344.2.

Question (2): Does ASME B31.3-2012 require individuals to be qualified for visual examination as described in paras. 342.1 and 344.2 when performing visual examinations of weld joints to meet the examination requirements of para. 341.4.1(a) and the engineering design?

Reply (2): Yes.

Question (3): Does ASME B31.3-2012 require individuals to be qualified for visual examination as described in paras. 342.1 and 344.2 when performing visual examinations of weld joints beyond the examination requirements of para. 341.4.1(a) and the engineering design?

Reply (3): No.

Question (4): Does ASME B31.3-2012 require individuals that check the fit and alignment of weld joints during fabrication to be qualified for visual examination as described in paras. 342.1 and 344.2?

Reply (4): No.

Interpretation 25-01

Subject: Para. 335.1(c), Alignment of Assembly and Erection (B31.3-1999)

Date Issued: April 14, 2014

File: 13-1677

Question (1): Does the Code specify who is responsible for meeting the flange alignment requirements of ASME B31.3-1999, para. 335.1(c)?

Reply (1): No.

Question (2): May the flange alignment requirements of ASME B31.3-1999, para. 335.1(c) be verified by measuring the parallelism between flanges?

Reply (2): The Code does not address this issue.

Interpretation 25-02

Subject: Para. 302.3.5(c), Stress Due to Sustained Loads (B31.3-2012)

Date Issued: April 14, 2014

File: 14-44

Question (1): In accordance with ASME B31.3-2012, does the phrase "all possible support scenarios" in para. S302.6.2 include the effects of liftoff due to the effects of temperature?

Reply (1): Yes.

Question (2): In accordance with ASME B31.3-2012, are the requirements of para. 302.3.5(c) satisfied by compliance with ASME B31.3-2012, Appendix P, para. P302.3.5?

Reply (2): No, Appendix P does not provide an alternative to 302.3.5(c). See para. P300(c).

Interpretation 25-03

Subject: Para. 304.7.2, Pressure Design of Other Components, Unlisted Components (B31.3-2012)

Date Issued: April 14, 2014

File: 14-257

Question (1): In accordance with ASME B31.3-2012, do branch outlet fittings in accordance with MSS SP-97 require qualification in accordance with para. 304.7.2?

Reply (1): No; see para. 303.

Question (2): In accordance with ASME B31.3-2012, do tees and reducing tees in accordance with ASME B16.9 require qualification in accordance with para. 304.7.2?

Reply (2): No; see para. 303.

Interpretation 25-04

Subject: Para. 345.5.5, Pneumatic Leak Test Procedure (B31.3-2012)

Date Issued: April 14, 2014

File: 14-269

Question (1): Does ASME B31.3-2012, para. 345.5.5 specify the method of examination for leakage under the provisions of para. 345.2.2(a)?

Reply (1): No.

Question (2): In accordance with ASME B31.3-2012, para. 345.5.5, are leak detection fluids, noble gas leak detection methods, pressure gauge measurements, and other methods prohibited during the examination for leakage during a pneumatic leak test?

Reply (2): No.

Question (3): In accordance with ASME B31.3-2012, are examination personnel qualifications in para. 342 and examination procedures in para. 343 required for para. 345.5.5?

Reply (3): No. See Interpretation 24-07.

Interpretation 25-05

Subject: Para. 341.3.4(f), Progressive Sampling for Examination (B31.3-2010)

Date Issued: April 14, 2014

File: 14-355

Question: A weld in an examination lot is found defective, is replaced or repaired, and is again found defective. Per para. 341.3.4(f) of ASME B31.3-2010, does the second failure of this weld require further progressive examinations?

Reply: No.

Interpretation 25-06

Subject: Para. 333.1.2, Soldering Qualification (B31.3-2012)

Date Issued: April 14, 2014

File: 14-433

Question: Does ASME B31.3-2012 include qualification criteria for solderers?

Reply: No.

Interpretation 25-07

Subject: Para. 345.5, Pneumatic Leak Test (B31.3-2012)

Date Issued: April 14, 2014

File: 14-435

Question: In accordance with ASME B31.3-2012, para. 345.5.4, for piping connected with no isolation capability and different design pressures, does the Code permit the pneumatic test pressure to be less than 1.1 times the highest design pressure or more than 1.33 times the lowest design pressure?

Reply: No.

Interpretation 25-08

Subject: Para. 304.7.2, Unlisted Components (B31.3-2006 Through B31.3-2012)

Date Issued: April 14, 2014

File: 14-482

Question: In accordance with ASME B31.3-2006 through ASME B31.3-2012, para. 304.7.2(a), does the Code limit the source of the extensive, successful service experience?

Reply: No.

Interpretation 25-09

Subject: Chapters V and VI (B31.3-1996 Through B31.3-2012)

Date Issued: April 14, 2014

File: 14-483

Question: Do ASME B31.3-1996 through B31.3-2012 require that welding-related requirements presented in B31.3 Chapters V and VI, including weld acceptance criteria, welding procedures, and welding and nondestructive examination personnel certifications, be met in the manufacture of unlisted components meeting the requirements of para. 302.2.3?

Reply: No.

Interpretation 25-10

Subject: Para. K331.1.1(b), Minimum Difference Between Tempering and PWHT Temperature (B31.3-2012)

Date Issued: September 25, 2014

File: 14-690

Question: In accordance with ASME B31.3-2012, para. K331.1.1, for welds other than longitudinal in P-No. 1 quenched and tempered materials where heat treatment is required by the engineering design, shall the heat treatment requirements specified in Table 331.1.1 apply?

Reply: Yes, unless the requirements in para. K331.1.1(b) apply or the provisions of para. 331.2.2 are met.

Interpretation 25-11

Subject: Paras. 304.3, 304.7.2, and 300.2, Branch Connections, Unlisted Components, and

Definitions (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1171

Question: Does ASME B31.3-2012 permit the use of a branch connection fitting qualified in accordance with para. 304.7.2?

Reply: Yes, provided the other applicable requirements of the Code are met.

Interpretation 25-12

Subject: Fig. 323.2.2B, General Notes, Allowable Stress, *S*, at Temperature Lower Than Impact Test Temperature/Minimum Temperature (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1182

Question (1): In accordance with ASME B31.3-2012, Fig. 323.2.2B, General Note (a)(1), is *S* the allowable stress listed in the column "Min. Temp. to 100" of Table A-1?

Reply (1): Yes. Also see para. 323.2.2(e).

Question (2): In accordance with ASME B31.3-2012, Fig. 323.2.2B, General Note (a)(2), is the component pressure rating used to determine the stress ratio the component pressure rating at the temperature for the condition under consideration?

Reply (2): Yes.

Interpretation 25-13

Subject: Para. 341.3.3, Defective Components and Workmanship (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1259, 14-1266

Question: If a weld that is part of an examination lot is repaired or replaced by the same or a different welder, is the repair or replacement weld subject to progressive sampling?

Reply: No. See para. 341.3.3 and Interpretation 16-01.

Interpretation 25-14

Subject: Para. 341.3.4, Progressive Sampling for Examination (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1287

Question: When both radiography and ultrasonic examination are acceptable methods in accordance with the engineering design, and a weld defect is located, may progressive sampling of welds per para. 341.3.4(a) be performed by either of these examination methods?

Reply: Yes.

Interpretation 25-15

Subject: Paras. 304.3, 304.7.2, and 300.2, Branch Connections, Unlisted Components, and Definitions (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1312

Question: Does ASME B31.3-2012 permit the use of a branch connection using a branch connection fitting conforming to the referenced edition of MSS SP-97?

Reply: Yes, provided the other applicable requirements of the Code are met.

Interpretation 25-16

Subject: Para. X302.2.3, Leak Test Under Pneumatic Condition on Appendix X Expansion Joints (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1372

Question: If a pneumatic leak test is performed in accordance with the requirements of para. X302.2.3, does the Code permit the use of a test pressure value of 1.1 times the design pressure in accordance with the rules of para. 345.5.4?

Reply: No.

Interpretation 25-17

Subject: Paras. 341.4.1(b), 345.2.3(c), and 345.2.6, and Figs. 328.5.4D and 328.5.4E, Branch Attachment Welds and Radiography (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1383

Question (1): Are welds attaching contour outlet fittings to the run pipe as shown in Fig. 328.5.4E, sketch (1) in a Normal Fluid Service piping system required to be included in the random radiographic or ultrasonic examinations of para. 341.4.1(b)?

Reply (1): No.

Question (2): May branch connection welds that cannot be fully examined by radiography or ultrasonic examination, such as those shown in Fig. 328.5.4D, be considered closure welds in accordance with para. 345.2.3(c)?

Reply (2): No.

Question (3): May welds connecting contour outlet fittings to a run pipe, like those shown in Fig. 328.5.4E, sketch (1), be considered closure welds per para. 345.2.3(c)?

Reply (3): Yes.

Question (4): May a socket weld that cannot be fully examined by radiography or ultrasonic examination be considered a closure weld in accordance with para. 345.2.3(c)?

Reply (4): No.

Question (5): May welds connecting a contour outlet fitting to the run pipe and to the branch pipe, as shown in Fig. 328.5.4E, sketch (1), both be considered closure welds per para. 345.2.3(c)?

Reply (5): Yes; see Interpretation 22-16.

Interpretation 25-18

Subject: Paras. M341/341 and M345/345, Examination and Testing: VT/PT/MT and RT/UT Versus Leak Testing and Pressure Testing (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1401

Question (1): Are the leak tests required in para. 345.1 independent from the examinations required in para. 341.4.1?

Reply (1): Yes.

Question (2): In accordance with para. 345.1, are the applicable examinations required by para. 341 to be performed prior to leak testing?

Reply (2): Yes.

Interpretation 25-19

Subject: Para. 304.7.2, Clarification of Pressure Design Using Proof Testing (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1466

Question: Does the Code permit substantiation of the pressure design of an unlisted component using a proof test in accordance with para. 304.7.2(c) when the component will be used at temperatures where time-dependent properties govern allowable stress values?

Reply: Yes.

Interpretation 25-20

Subject: Fig. 328.5.4D, Acceptable Details for Branch Attachment Welds (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1470

Question (1): Does ASME B31.3 prohibit branch connections like those shown in Fig. 328.5.4D to be installed through a circumferential butt weld?

Reply (1): No.

Question (2): If branch connections like that shown in Fig. 328.5.4D are installed through a circumferential butt weld, must the Code-required leak test be performed prior to installation of any required ring or saddle reinforcement?

Reply (2): No, provided that all joints and connections are examined for leaks during the leak test, as required in para. 345.2.2(a).

Question (3): If branch connections like those shown in Fig. 328.5.4D are installed through a circumferential butt weld that requires examination, does the portion of the weld that will be covered by the reinforcement ring or saddle require examination of the weld prior to installation of the ring or saddle?

Reply (3): Yes.

Question (4): Does ASME B31.3 allow branch connections like those shown in Fig. 328.5.4D to be installed through a longitudinal butt weld in pipe?

Reply (4): Yes.

Question (5): Does ASME B31.3 allow branch connections like those shown in Fig. 328.5.4D to be installed through the weld intersection of a longitudinal butt weld in pipe and a circumferential butt weld?

Reply (5): Yes.

Question (6): Does ASME B31.3 provide any rules, restrictions, or limits for the distance between circumferential butt welds in a piping assembly?

Reply (6): No.

Interpretation 25-21

Subject: Para. 341.3.4, Progressive Sampling for Examination (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1482

Question: Does para. 341.3.4(e) require that all welds represented by the progressive sampling in para. 341.3.4(c) be evaluated in accordance with para. 341.3.4(e)(1) or (e)(2)?

Reply: Yes.

Interpretation 25-22

Subject: Table 323.3.1, Column B, Simulation Heat Treatment for Low Temperature Carbon Steel

Piping Material (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1553

Question (1): In accordance with ASME B31.3-2012, Table 323.3.1, is item B-3 applicable to manufacturers?

Reply (1): No.

Question (2): In accordance with ASME B31.3-2012, is it mandatory to procure Low Temperature Carbon Steel (LTCS) fittings of thickness greater than 20 mm to be tested with simulation heat treatment?

Reply (2): The Code does not address this issue.

Interpretation 25-23

Subject: Paras. 345.1, 345.2.3, and 345.9, Leak Test (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1681

Question (1): When the owner considers hydrostatic and pneumatic leak testing impracticable, does para. 345.1(c) allow use of the alternative leak test per para. 345.9, provided at least one condition in each of paras. 345.1(c)(1) and (c)(2) are met?

Reply (1): Yes.

Question (2): Does para. 345.1 require leak testing of each piping system, except for specific joints where the provisions of para. 345.2.3 are applicable?

Reply (2): Yes; see Interpretation 22-16.

Interpretation 25-24

Subject: Paras. 345.2.3(c) and K345.2.3(c), Closure Welds (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1682

Question (1): May a through-wall or partial weld removal and repair of a weld that has previously passed the required leak test be examined in accordance with the requirements of para. 345.2.3(c)?

Reply (1): No; however, see para. 300(c)(3).

Question (2): May a through-wall or partial weld removal and repair of a weld in a High Pressure Fluid Service system meeting Chapter IX, which has previously passed the required leak test, be examined in accordance with the requirements of para. K345.2.3(c)?

Reply (2): No; however, see para. 300(c)(3).

Interpretation 25-25

Subject: Para. 323.4.3, Cladding and Lining Materials (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1683

Question (1): Shall the stress caused by differential thermal expansion between the metallic liner and base metal be considered in the piping design?

Reply (1): Yes; see para. 301.7.3.

Question (2): Is the residual base metal hoop stress caused by liner mechanical expansion during fabrication required to be included in the base metal pipe pressure design wall thickness calculations?

Reply (2): No.

Question (3): Does the Code prescribe specific methodology for flexibility analyses of lined pipe?

Reply (3): No.

Interpretation 25-26

Subject: Paras. 328.2 and U341.4.1, Welding Radiography (B31.3-2012)

Date Issued: September 25, 2014

File: 14-1790

Question (1): May a welding operator be qualified by radiography of his/her initial production welding?

Reply (1): Yes; see para. 328.2.

Question (2): May the production welding be examined by weld coupon examination in lieu of radiography?

Reply (2): Yes, in accordance with para. U341.4.1.

Question (3): May weld coupon examination be used for welding operator's performance qualification in lieu of radiography?

Reply (3): No.


Interpretation 25-27


Subject: Chapter VI (B31.3-2012) Date Issued: September 25, 2014

File: 14-1817

Question: Does ASME B31.3-2012 provide an acceptance criterion for the amount of base material deformation adjacent to butt welds, commonly referred to as "hoop shrinkage," shown in the following diagram?

Fig. 25-27 Schematic Showing Shrinkage in Buttwelded Pipe





GENERAL NOTE: Diagram extracted from "Analysis of Shrinkage in Stainless Steel Pipe to Pipe Butt Welds," Chakrapani Basavaraju, PVP1997 Conf Proc, Vol 347; 231–244. ASME ©1997.

Reply: No.

Interpretation 25-28

Subject: Para. 345.9, Alternative Leak Test (B31.3-2012)

Date Issued: April 28, 2015

File: 14-1907

Question: When the owner elects to apply alternative leak-testing provisions given in para. 345.9 as permitted by para. 345.1(c), does the Code require that all of the requirements described in para. 345.9 be followed?

Reply: Yes.

Interpretation 25-29

Subject: Table 323.3.1, Welding Procedures With Impact Tests (B31.3-2012)

Date Issued: April 28, 2015

File: 15-586

Question: The requirements for qualification of a welding procedure with impact tests given in Table 323.3.1 are different from the requirements of ASME Section IX, QW-403.6. Moreover, QG-100(b) of Section IX states that the rules of the construction code take precedence over the rules of Section IX. Does the Code require Table 323.3.1 be applied when qualifying a welding procedure with impact tests?

Reply: Yes.

Interpretation 25-30

Subject: Paras. 331.1.3(a)(2) and (c), Preheat and PWHT Governing Thickness (B31.3-2014)

Date Issued: April 28, 2015

File: 15-616

Question (1): In para. 331.1.3(a)(2), does the phrase "the thickness of the materials being joined at the weld" mean the nominal thickness of the materials being joined at the weld?

Reply (1): Yes.

Question (2): In para. 331.1.3(a)(2), does the phrase "the thickness of the pressure-containing material" mean the nominal thickness of the pressure-containing material?

Reply (2): Yes.

Question (3): In para. 331.1.3(c), does the phrase "the thicker of the materials being joined at the weld" mean the nominal thickness at the weld of the thicker of the materials being joined?

Reply (3): Yes.

Interpretation 25-31

Subject: Para. 304.3.4(d)(4), Limitations on Radius (B31.3-2014)

Date Issued: April 28, 2015

File: 15-788

Question: Does para. 304.3.4(d)(4) apply only to extruded outlets?

Reply: Yes; see para. 304.3.1(a).

Interpretation 25-32

Subject: Paras. 323.2.2(d), (d)(1), and (d)(2), and Fig. 323.2.2B, Impact Tested Material (B31.3-2008 Through B31.3-2014)

Date Issued: April 28, 2015

File: 15-810

Question (1): For a carbon steel material, when applying the rules of paras. 323.2.2(d) and (d)(2) in B31.3-2014, if the design metal temperature is colder than -55°F but at or warmer than -155°F, and the stress ratio as defined in Fig. 323.2.2B does not exceed 0.3, does the Code require impact tested material if the piping under question

- (a) may experience shock loading or thermal bowing?
- (b) contains welds between dissimilar materials?

Reply (1):

- (a) Yes.
- (b) Yes.

Question (2): For a carbon steel material, when applying the rules of paras. 323.2.2(d) and (d)(1) in B31.3-2008 through B31.3-2012, if the design metal temperature is -55°F or warmer, and the stress ratio as defined in Fig. 323.2.2B is less than 1.0, is the designer required to consider shock loading or thermal bowing and/or welds between dissimilar materials, beyond what is required in paras. 301.4 through 301.11 of the Code, when using Fig. 323.2.2B?

Reply (2): No; however, see para. 300(c)(5).

Interpretation 25-33

Subject: Para. K304.7.3, Components With Nonmetallic Parts (B31.3-2012)

Date Issued: September 23, 2015

File: 15-1690

Question (1): In accordance with ASME B31.3-2012, para. K304.7.3, is a valve considered to be a piping component?

Reply (1): Yes; see para. 300.2.

Question (2): In accordance with ASME B31.3-2012, para. K304.7.3, may O-rings and lip seals acting as gaskets or packing be used in valves in High Pressure Fluid Service?

Reply (2): Yes.

Question (3): In accordance with ASME B31.3-2012, para. K304.7.3, may nonmetallic seats be used in valves in High Pressure Fluid Service?

Reply (3): No.

Interpretation 25-34

Subject: Para. 345.2.3(c), Special Provisions for Testing, Closure Welds (B31.3-2014)

Date Issued: September 23, 2015

File: 15-1723

Question: Does ASME B31.3-2014, para. 345.2.3(c) permit the use of a socket weld that cannot be 100% examined in accordance with paras. 344.5 or 344.6 as a closure weld?

Reply: No.

Interpretation 25-35

Subject: Table K326.1 and Para. K323.3, HP Valve Product Codes (B31.3-2014)

Date Issued: September 23, 2015

File: 15-1804

Question: In accordance with ASME B31.3-2014, may API Specification 6A piping components be used in Chapter IX High Pressure Fluid Service?

Reply: No, unless the requirements of para. K302.2.3 are met.

Interpretation 25-36

Subject: Table 308.2.1, Flange Thickness (B31.3-2014)

Date Issued: September 23, 2015

File: 15-1885

Question: May slip-on flanges be used as lapped flanges within the size ranges specified in Table 308.2.1 when the thickness at the bolt circle satisfies the minimum requirements for slip-on flanges, but does not meet the minimum requirements for lapped flanges?

Reply: No, unless pressure design is qualified per para. 304.5.1.

Interpretation 25-37

Subject: Para. 323.3 and Table 323.3.1, Item A-4, Impact Testing Requirements for Metals (B31.3-2012 and B31.3-2014)

Date Issued: September 23, 2015

File: 15-1992 and 15-1995

Question (1): For welds made by the fabricator, does ASME B31.3-2014, Table 323.3.1, item 4 require the heat treatment of test pieces to be the same as for production welds?

Reply (1): Yes.

Question (2): For welds made by the component manufacturer, does ASME B31.3-2014, Table 323.3.1, item 4 require the heat treatment of test pieces to be the same as for production welds?

Reply (2): Yes.

Question (3): Does ASME B31.3-2014, Table 323.3.1, item 4 require that separate test pieces be qualified individually using base materials in the various heat treated conditions (e.g., as-rolled, normalized, quenched and tempered, etc.)?

Reply (3): No.

Interpretation 25-38

Subject: Para. 323.3.5(d), Retest for Impact Test (B31.3-2012)

Date Issued: September 23, 2015

File: 15-1997

Question: In accordance with ASME B31.3-2014, para. 323.3.5(d)(1), where the average absorbed energy value in Charpy V-notch impact test results exceeds the minimum required value for a single specimen, two individual values are below the required average value, and one of the individual values is below the minimum required value for a single specimen, is a retest permitted?

Reply: Yes.

Interpretation 25-39

Subject: Paras. 302.3.2(f), 304.7.2, and 323.1.2, Additive Manufacturing Materials (B31.3-2014)

Date Issued: September 23, 2015

File: 15-2052

Question: Does ASME B31.3 permit the use of an unlisted piping component manufactured using the additive manufacturing process?

Reply: Yes, provided it meets all of the requirements of the Code, including the material being qualified in accordance with the requirements of para. 323.1.2, and the component meeting the requirements of paras. 326.1.2 and 326.2.2.

Interpretation 25-40

Subject: Paras. 302.3.2(f), 304.7.2, and 323.1.2, Additive Manufacturing (B31.3-2014)

Date Issued: September 23, 2015

File: 15-2053

Question (1): Does ASME B31.3 permit the use of an unlisted piping component manufactured using the additive manufacturing process?

Reply (1): Yes, provided it meets all of the requirements of the Code, including the material being qualified in accordance with the requirements of para. 323.1.2, and the component meeting the requirements of paras. 326.1.2 and 326.2.2.

Question (2): Does ASME B31.3 provide different requirements for piping that is inside a secondary containment?

Reply (2): No.

Question (3): According to ASME B31.3, may piping that is inside a secondary containment be considered to be safeguarded?

Reply (3): Yes. See Appendix G.

Interpretation 25-41

Subject: Para. 306.1, Pipe Fittings (B31.3-1996 Through B31.3-2014)

Date Issued: September 23, 2015

File: 15-2061

Question (1): Does the Code address the pressure boundary portions of an instrument that is inserted through a threaded, welded, or flanged joint?

Reply (1): No.

Question (2): Does the Code address the pressure boundary portions of a thermowell that is inserted through a threaded, welded, or flanged joint?

Reply (2): Yes; see para. 306.6.

Interpretation 25-42

Subject: Table 302.3.5, Para. 302.2.4, and Para. 302.3.5(e), Pressure and Temperature Conditions (B31.3-1996 Through B31.3-2014)

Date Issued: September 23, 2015

File: 15-2137

Question (1): Are the values to be determined for *W* to be based on anticipated coincident operating pressure and temperature conditions?

Reply (1): Yes; see Table 302.3.5, General Note (c).

Question (2): May a value of W = 1.0 be used for the assessment of pressure and temperature conditions that exceed the anticipated long-term operating conditions?

Reply (2): Yes, provided the requirements of paras. 302.2.4 and 302.3.5(e) are satisfied.

NUMERICAL INDEX

Code references are based on ASME B31.3-1990 or later editions. References in brackets are to previous editions and addenda.

Reference	Interpretation	Reference	Interpretation	Reference	Interpretation
Introduction	1-3	Fig. 300.1.1	1-8	301.3	2-3
	1-6	<u> </u>	1-19		17-07
	1-7		2-26		22-06
	13-04		7-10	301.3.1	10-02
	20-08		8-17		21-47
300	7-10		22-39	301.3.2	4-11
	8-17	300.1.3 [300.1.4]	1-8	0011012	23-06
	19-11		1-16	301.5.3	4-07
300(b)	1-26		1-19	301.7.2	3-4
500(2)	1-32		1-26	301.10	22-04
	4-08		3-2	302	1-32
	5-03		15-09	302	19-03
	8-09	300.1.3(d)	10-05	202.2	
	10-11		21-22	302.2	1-50
	13-14	300.2		302.2.1	16-18
300(c) [300(e)]	1-3	branch connection	25-15	302.2.2	17-11
300(c) [300(e)]	1-6	Category D Design	22-06	202.2.2	19-02
		Temperature		302.2.3	19-19
	1-7 3-2	Category D Fluid	4-13	302.2.4 [302.2.3]	1-3
		Service			1-32
	3-4		5-03		2-14
	4-10		6-01		3-4
	6-03R (Vol. 7)		19-34		4-11
	7-05	Category M Fluid	1-40		7-01
	8-30	Service			7-04
	13-02		1-73		8-04
	16-12		6-01		14-09
	18-09		8-09		17-12
	19-31		9-02		20-03
	19-48	flammable	21-25		20-22
	20-03	notch-sensitive	2-22		20-51
	20-20	owner	2-30		21-45
	20-38	piping components	3-2		22-04
300(c)(3)	22-32		8-01		22-37
300.1	7-10		14-03		25-42
	8-17		17-23	202.2 5	13-15
	9-06		21-24	302.2.5	
	12-20		22-41	302.3	20-25
	21-07	piping system	1-30	302.3.2	1-18
	21-32		9-06		1-38
300.1.1	1-47	severe cyclic	5-12		2-16
	1-52	conditions			3-13
	2-26		8-09		8-25
	3-1	Table 300.4	20-23		11-05
	4-19	301	5-11		16-04
	6-01	301.1	20-40		19-37
	8-01	301.2	2-3		19-38
	9-02		7-01	302.3.2(f)	25-39
	17-01	301.2.1	2-29		25-40
	22-34		13-15	Table 302.3.3C	23-10

Reference	Interpretation	Reference	Interpretation	Reference	Interpretation
302.3.4	2-20	304.1.2	1-42	304.7.2	1-51
	17-14		1-57		3-2
Table 302.3.4	1-42		1-68		4-05
	1-78		1-70		5-05
	2-20				5-11
	3-11		2-11		6-09
	20-34		10-20		10-07
	21-06		21-13		10-11
	21-37		22-04		10-18
	22-10	304.2	15-14		12-09
302.3.5	1-20	304.2.1	21-13		13-02
	1-50	304.2.2	18-06		13-03
	2-14	304.2.3	1-22		13-05
	2-15	304.2.3			13-11 19-29
	2-24	T	5-11		20-26
	3-4	Fig. 304.2.3	1-22		20-26
	4-10 4-12	304.3	1-21		21-02
			1-46		21-34
	6-03R (Vol. 7) 6-07		5-01		23-03
	6-07 7-04		6-09		23-07
	7-0 4 7-05		25-11		24-09
	8-16		25-15		25-03
	15-15	20121			25-08
	16-11	304.3.1	19-33		25-15
	17-04	304.3.2	4-05		25-19
	17-18	304.3.3	4-03		25-39
	18-16		7-02		25-40
	20-02		8-06	304.7.4	1-16
	21-34		8-37	305.1	22-43
	22-07		11-10	305.2	3-8
	25-02		12-05		3-9
	25-42			305.2.1	1-38
Table 302.3.5	16-10		14-10	305.2.3	6-01
	22-36		15-05		7-03
	24-12		17-26	207.1	21-29
	25-42		21-39	306.1 306.4	25-41
302.3.6	1-50		23-18	306.4.2	12-16 11-03
	2-15	Fig. 304.3.3	8-37	307.1.2	24-18
	2-16	304.3.4	1-21	308.2.1	5-12
	2-17	304.3.4	1-37	Table 308.2.1	25-36
	19-18			308.2.4	5-12
	20-02		1-55	311.2.4	6-02
	20-49		1-75		6-05
202.2 (/)	20-50		2-27	311.2.5	10-04
302.3.6(a)	24-24		25-31	312	9-07
302.4	1-20	Fig. 304.3.4	1-70	314	20-48
303	6-05	304.3.5	12-13	314.2.1	2-22
304.1	23-16	304.3.5(e)	22-20	Table 314.2.1	8-33
304.1.1	1-42 1-54	304.5		245.0	11-16
	1-54 1-70	304.3	3-4	315.2	3-6
	1-70 13-07		9-07	315.3	3-6
	13-07 15-06		10-14	317.2	1-17
	15-06 15-10		19-12	318	8-13
	16-14	304.5.1	8-18	318.2.2	19-45
	21-38		20-12	319.1.1 319.2.1	20-48 2-17
	22-21	304.5.1(b)	9-10	J17.4.1	20-45
	ZZ-Z1	304.3.1(D)	9-10		∠∪ -4 Э

Reference	Interpretation	Reference	Interpretation	Reference	Interpretation
328.4.2 and Fig. 328.4.2	12-10	Table 331.1.1 [Table 33	31.3.1] (Cont'd)	340.4 [336.2]	1-31
328.4.3	14-04		9-03		17-15
Fig. 328.4.4	8-28		12-14		20-33
	9-08		14-16	340.4(a)	24-05
328.5 [327.4]	5-09		17-01	341	10-16
328.5.1 [327.4.1]	5-17		20-44		15-13
	22-25		21-12		19-49
	22-35		21-19		21-17
	22-35R	331.1.2	8-05	341.1.4.1	21-20
328.5.2 [327.4.2]	5-12	331.1.3 [331.3.6]	1-39	341.2 [336.1.1, 336.1.3]	1-10
	16-06		1-59		1-26
	19-20		4-06		1-27
Fig. 328.5.2 [Fig. 327.4.2]	1-28		5-06		2-28
	5-12		9-03		10-03
	6-02		11-06	341.3.1 [336.5]	1-64
	6-05		14-01	341.5.1 [550.5]	2-4
	8-27		15-18		19-15
	15-08		17-13		21-48
	19-16		17-21	341.3.1(a)	24-30
	20-01		18-02	341.3.2	8-32
328.5.3	20-05		19-24	341.3.2	21-44
328.5.4 [327.4.4]	1-59		22-19		22-40
	1-74		25-30	Fig. 341.3.2 [Fig. 327.4.1]	
	2-10	331.1.4 [331.1.2]	5-08	Fig. 341.3.2 [Fig. 327.4.1]	13-16
	4-03	331.1.6 [331.3.4]	5-08	Table 341.3.2	
	4-14	331.1.0 [331.3.4]	16-09	Table 341.3.2	14-02
	7-08	221 1 7 [221 2 2]			14-07
	8-13	331.1.7 [331.3.2]	1-78 8-22		14-15
	10-04	221.2			16-07
	13-11	331.2	18-04		17-03
	21-02	331.2.2 [331.1.1]	1-39		17-22
	22-22	221.2.4	1-78		18-07
	24-10	331.3.4	8-05		20-16
	24-15	331.3.7	8-05		20-20
328.5.4(d)	24-23	332.1	8-03		20-34
328.5.4(e)	24-23	222 2 [222 4]	19-04		23-02
Fig. 328.5.4 [Fig. 327.4.4]		332.2 [329.1]	1-23		24-02
	1-74		1-53	f= 11	24-03
	4-03		4-02	[Table 327.4.1A]	1-1
	4-16		8-20		1-9
	7-08 25-17	332.2.2	16-08		1-14
	25-20	332.4 [329.3, 330.2]	2-2		1-41
328.6	2-18		19-04		2-8
330	8-21	332.4.2	11-03		5-04
330.1	8-23		15-17		5-13
Table 330.1.1	9-05	333.1.2	25-06		5-16
331	8-12	335.1	25-01		5-17
551	20-39	335.1.1	15-07		5-18
	21-46R (Vol. 23)		17-25		5-20
331.1.1	8-08	335.2	2-5		6-04
	9-05	335.2.3	17-20		7-06
	14-01		21-14	[Table 341.3.2A]	8-32
	19-15	Fig. 335.3.3(a)	20-36		8-38
Table 331.1.1	1-69	Chapter VI	25-09		9-04
[Table 331.3.1]			25-27		11-08
	2-2	340.2 [336.1.2]	1-26		11-14
	5-06	340.3 [336.3]	1-10		12-22
	8-24		10-03		13-16

Reference	Interpretation	Reference	Interpretation	Reference	Interpretation
341.3.3	14-14	341.4.3	8-10	345.1 [337.1]	1-4
	22-33		20-09		1-30
	24-29	341.5	8-38		4-04
	25-13	341.5.1 [336.6.1]	1-5		6-08
341.3.4 [336.5, 336.5.4]	1-62		3-12		8-15
	2-25		20-34		12-21
	2-32	342	15-21		20-24
	3-5	342.1 [336.4.1]	2-28		21-36
	3-14		21-05		22-14
	10-09		24-21		25-23
	10-12		24-21R	345.1(b)	23-05
	11-02	343 [336.4.1]	2-28	345.1(d)	23-20
	11-04	344 [336.4]	5-09	345.2.2	8-31
	13-12	[]	16-13		18-10
	16-01		18-11		20-46
	16-02		20-42		20-47
	16-05	344.1	13-12		21-42
	18-01			345.2.2(a)	24-07
	25-05	344.1.3	24-20	345.2.3	20-07
	25-14	344.2 [336.4.2]	2-28		20-11
	25-21		8-10		20-24
341.4 [336.5]	1-24		8-26		20-27
	1-45		11-11		25-23
	3-12		15-21	345.2.3(a)	22-15
	5-20		18-17		22-18
	11-01	344.2.1	19-17	345.2.3(b)	24-19
	21-23		24-21	345.2.3(c)	21-10
	22-17		24-21R		22-16
341.4.1 [336.5.1]	1-10	344.2.2	21-20		24-25
	1-26	344.5 [336.4.5]	1-10		25-17
	1-27		1-60		25-24
	1-60		2-12		25-34
	2-12	344.5.1	20-34	345.2.3(i)	17-28
	2-28		20-41		20-37
	3-7		22-08	345.2.4 [337.4.3]	1-35
	3-12	344.6 [336.4.6]	1-60		23-17
	4-12	344.6.2	10-17	345.2.5	19-44
	5-10	344.7 [336.4.7]	2-28	345.2.6 [337.1]	1-2
	8-02	344.7 [330.4.7]	3-14		5-22
	8-10				19-23
	8-26		12-01		20-06
	10-03	244.7.1	19-17	245 2 [227 2]	25-17
	10-17	344.7.1	11-11	345.3 [337.3]	2-6
	11-11	0.45 [0.05]	21-20		3-10 5-02
	11-14	345 [337]	1-2		12-03
	11-15		1-72	345.3.1	20-28
	18-14		2-31	343.3.1	22-09
	19-05		3-3		22-09
	19-42		8-31	345.3.4	22-14
	20-09		16-03	345.4	8-04
	20-34		17-30	010.1	19-25
	21-04		19-23		22-11
	24-02		19-30	345.4.1	12-19
341.4.1(b)	24-08		19-49	345.4.2 [337.4.1]	1-35
	25-17		20-17	510.1.2 [007.4.1]	1-61
341.4.1(b)(1)	24-22		21-11		1-63
341.4.2	8-38		23-14		2-23

Reference	Interpretation	Reference	Interpretation	Reference	Interpretation
345.4.2 [337.4.1] (Cont'd)		A327.2.4	7-09	MA323.4	9-02
	9-09	A328	21-15		19-08
	13-13	A328.2(a)	10-08	MA323.4.2	8-35
	18-03	A328.2.1	8-14	Appendix A Notes (no	2-20
	19-10		18-05	equivalent) [(14)]	
	20-46	A328.2.5	17-06	Note (17)	4-18
345.4.3 [337.4.2]	1-63	A328.5	8-14	Note (20) [(30)]	1-77
345.5 [337.4.4]	1-35	H320.5	10-08	Note (57) [(2)]	1-58
0 10 10 [007 1111]	1-43		13-08	Appendix A	100
	6-08			Table A-1 [Table 1]	1-13
	11-07	Chapter IX	24-13	Table A-1 [Table 1]	1-18
	13-06	K300	20-09		1-10
	19-32	K300(a)	17-16		1-38
		K303	20-21		
	22-11	K304.1.2	11-21		1-48
	23-15		14-11		1-77
	25-07	K304.7.3	25-33		2-1
345.5.1	22-14	K304.8	22-04		3-8
345.5.2	11-19	K314.2	17-19		3-9
	23-11	K315	7-07		3-13
345.5.4	12-02	K322.3	7-07		4-12
	20-46	K323.1.2	19-09		4-13
345.5.5	25-04	K323.1.5	21-03		6-01
345.7 [337.5.2]	1-36	K323.3	25-35		6-06
345.8 [337.6]	1-25				7-03
	3-10	Table K323.3.1	20-41 21-18		8-11
	17-02	1/200 2 F			8-18
	19-06	K323.3.5	21-27		8-25
	20-18	Table K326.1	20-21		8-34
345.9 [337.5.1]	4-09		25-35		8-36
040.9 [007.0.1]	5-07	K328.2.1(a)	17-27		11-13
		K328.2.1(b)	24-06		
	6-08	K328.2.1(d)	24-17		12-09
	8-15	Fig. K328.5.4	8-37		15-01
	10-15	K331.1	25-10		19-43
	12-01	K341.4.2	20-09		19-46
	12-21	K345.2.3(c)	25-24		20-29
	15-02	K346.2(b)	21-03		20-32
	17-05	M305.1	12-15		21-28
	17-10	M307.2	8-35		22-12
	18-15	M313	21-21		22-28
	20-18				22-42
	25-23	M314.2.2	20-36		23-19
	25-28	M322.3	2-13	Table A-1B [Table 1]	1-78
345.9.1	20-06		3-6		2-20
	20-43	M323.1.3	3-7		4-18
A302.2.3	20-30	M326	2-13		7-03
A302.2.4	21-33	M335.3.3	20-36		23-09
A304	8-14	M335.4 [M335.5, M335.6]	3-6	Appendix B	19-13
A304.1.1	14-17	M341	25-18	Table B-1	22-38
AUU4.1.1	14-18	M341.4 [M336.5]	1-24	Appendix D	1-6
A304.5.1	1-67	-	1-45	Tipperaix D	1-7
A304.7.2	13-08		20-09		1-34
A304.7.2 A305	11-17		24-02		1-34 1-46
		M341.4.1 [M336.5.1]	2-28		
A314	8-33	MO11.1.1 [MO00.0.1]	3-7		1-55
A322.6	17-29	M245			1-56
A323.4.2	10-06	M345	20-47		1-71
	11-18) (O (E 1	25-18		2-7
	21-30	M345.1	6-08		2-24
	21-31	MA306.5	9-02		4-16
Table A326.1	20-30	MA313	21-21		5-01

Reference	Interpretation	Reference	Interpretation	Reference	Interpretation
Appendix D (Cont'd)		Appendix F [F323.2]	1-29	Appendix P	22-07
Appendix E [Appendix K]	5-15	Appendix F, F323	20-20	Appendix V	17-17
	6-06	Appendix F, FA323.4	20-30	Appendix X, X3.1.3	12-23
	12-08	Appendix G	5-12	Appendix X, X3.2.2	13-09
	12-11	Appendix J Appendix M	8-06	Appendix X, X302.2.3 Case 137 Case 141 Case 181	15-22
	12-17		11-10		
	13-05		1-28 1-54		25-16
	18-18		1-34		3-1
	1-44		5-04		1-51
			6-01		22-13
	5-10	ripperiant ivi	8-09		22-29
	19-20		20-23		22-31

SUBJECT INDEX

Subject	Interpre- tation	Subject	Interpre- tation	Subject	Interpre- tation
Acceptance Criteria		Alternative Tests (see Leak Tes	ts)	Branch Connections (Cont'd)	
pressure tests	1-2			reinforcement	8-06
weld	1-1	Assembly and Erection	25-01		8-37
	1-9		25-09		12-05
	1-14				12-13
	1-41	Authorized Inspector (see Own	ier's		14-10
	2-8	Inspector)			15-05
	5-09				21-39
	5-13	Bellows	13-09	weld requirements	2-10
	5-17			-	4-03
	5-18	Bending	4-02		4-14
	5-20		8-03		7-02
	6-04		15-17		7-08
	7-06		16-08		10-04
	8-32				13-11
	12-22	Bends			17-26
	13-16	corrugated	1-23		22-22
	14-02	miter (see Miter Bends)			23-18
	14-07	reduction of outside	8-20		24-23
	24-03	diameter			25-11
	24-26				25-15
		Bolting Materials	4-15		
Additive Manufacturing	25-39		17-20	Brazed Joints	
	25-40		20-12	for flammable service	1-17
			21-14		
Allowable Loads	14-06			Buckles	1-23
Allowahla Characa	4.10	Bonding Qualification Test			1-53
Allowable Stresses	4-12	hot gas welded	8-14		
bases for	1-18	minimum burst pressure	7-09	Casting Quality Factor	23-10
	3-13		8-14		
	8-11	procedure specifications	10-08	Cast Irons	
	8-25	for plastic piping		specific requirements	10-01
	10-13		21-15	•	
for ASTM A182	15-01 22-28	requirements	18-05	Category D Design	22-06
for ASTM A312	1-29	solvent cement	8-14	Temperature	
for ASTM A351					
	11-13	Bonds		Category D Fluid Service	
for ASTM A387	8-25	heat fusion	8-14	alternative pressure test for	1-36
for ASTM A464	8-11	hot gas welded	8-14	limitations	4-13
for ASTM A570 for ASTM A587	1-38	test assembly	7-09		5-03
	1-13				21-47
for ASTM A671	1-48	Branch Connections		radiographic examination	8-38
for austenitic stainless steels	3-13	couplings	19-33		21-23
	19-09	extruded outlets	1-37		
for unlisted alloy steel pipe	19-07		2-27	Category M Fluid Service	
P ¹ P ^c			6-09	clarification of term	1-73
Allowable Stress Range	22-07	flexibility analysis	9-01		9-02
	23-19	integrally reinforced fitting	4-05		20-23
	25-12	<u> </u>	11-10	double contained piping	8-35
		projection into run pipe	8-28	fittings	20-36
Alterations of Piping	13-04		9-03	leak test	6-08

Subject	Interpre- tation	Subject	Interpre- tation	Subject	Interpre- tation
Category M Fluid Service (Con	nt'd)	Compressors		Examination (Cont'd)	
liquid oxygen	8-09	internal piping	1-8	, ,	2-32
piping flexibility	21-21	11 0			4-12
requirements	8-35	Corrugated Bends	1-23		11-15
	9-02				24-20
	12-15	Cyclic Loading	5-12		24-22
tubing size limitations	2-13		17-04	records	11-11
"very small quantity"	1-40				21-20
		Design (see also <i>Pressure Des</i>		required	1-24
Code Case	22-13	additional design	12-13		1-60
	22-29	considerations	20.24		6-04
	22-31	calculations	20-26		11-14
		11.0	21-13		11-15
Code Coverage		conditions	2-3		15-13
B31.3 versus B31.4	1-47	for stainless bellows	12-23		15-21
	7-10	Lame theory	1-57		18-14
B31.3 versus B31.9	21-32	minimum temperature	10-02		21-17
buried piping	21-07	1:6:	24-04		22-17
cryogenic piping	21-22	qualification	20-38	sample	24-08
fired heaters	15-09		20-40	severe cyclic conditions	10-17
general hydrocarbon	6-01	Displacement Strain	20.45		11-14
service		Displacement Strain	20-45	spot	1-62
inline sensing devices	8-01	Displacement Street	2-14	types	16-13
	21-24	Displacement Stress	2-14		18-11
intent	16-12		12-06	ultrasonic (see <i>Ultrasonic</i>	
later editions	19-01		18-13	Examination)	
new and replacement	5-22		21-09	visual (see Visual	
piping			21-09	Examination)	
	12-21	Earthquake (see Seismic)			
	19-49	zartiiquate (see seisiiie)		Exclusions	
offshore platform	8-17	Effective Date	22-24	for compressors and	1-8
oil heating system	4-19			internal piping	1.10
radioactive fluids	12-20	Empty System		for interconnecting piping	1-19
synfuel plant piping	1-52	transportation	9-06	11 . 1 .	21-22
	2-26	F	, ,	listed in scope	10-05
tobacco plant piping	3-1	Examination			
		acceptance criteria	16-07	Expansion Joints	1-16
Components (see also Fittings		during leak test	24-07		12-23
Standard Components, Unli	sted, and	extent of	1-24		13-09
Valves)	1.26		5-18		
certification	1-26		11-01	Extruded Outlet	
	3-7		21-04	pressure design of	1-21
	5-10		21-23		1-70
1.6.0	13-10	in-process	3-14	tees considered as	1-55
defective	25-13	-	11-15		
defining	17-23	liquid penetrant (see Liquid		Extruded Welded Tee	5-01
1	20-11	Penetrant Examination)			
design conditions	2-3	personnel	21-05	Fatigue	18-09
fabricated or flared flaps	11-03	postweld heat treatment	21-48	latigue	10-07
	12-16	progressive (see Progressive		P111 - C NV - 1 1	
inline sensing devices	8-01	Examination)		Fillet Weld	0.07
1 1	21-24	radiographic (see		internal, slip-on flange	8-27
listed	20-25	Radiographic Examination)		pressure containing	8-13
metric size	19-29	random	1-27	size	1-74
referenced standards	1-44		1-45	use	10-04
	5-10		1-62		23-09
	22-05		2-12		24-02

Subject	Interpre- tation	Subject	Interpre- tation	Subject	Interpre- tation
Fittings		Flexibility Factors (Cont'd)		Heat Treatment (Cont'd)	
B16.9	1-7	for pressure piping	13-05	requirements (Cont'd)	
	5-01	components		, ,	8-21
	19-14	for welded elbows	1-6		8-23
	20-21				8-24
conforming to two grades	8-18	Fluid Service			9-03
flared, flareless, or	3-6	definition	19-34		9-05
compression types			20-23		12-14
	12-16	general hydrocarbon	6-01		14-01
MSS SP-75	1-11	requirements, metallic	11-16		14-16
pipe	25-41		12-15		15-18
			12-16		18-04
Flame Arrester	22-39		15-03		21-46
		requirements, nonmetallic	11-17		21-48
Flammable Service	1-17		11-18	SP-1 through SP-5	8-24
	21-25		21-30	when radiography is	1-64
			21-31	required	
Flanges		responsibility for	4-08		2-4
assembly	2-5	categorizing			
design	1-67		8-09	High Pressure Piping	24-13
	3-4				
	9-07	Graphitization		Hydrostatic Tests (see <i>Leak Te</i>	sts)
general	9-10	temperature relative to	1-58		
long welding neck	4-05	onset		Impact Tests	
slip-on	5-12			absorbed energy data	2-9
_	8-27	Hardness		alternative methods	8-30
thickness	25-36	limitations on	2-2	base metal	4-01
use of aluminum	1-51	records	8-22		11-12
use of raised and flat face	9-07	testing	15-20		18-12
metallic					20-10
		Heat Fusion Joints	13-08		24-14
Flexibility Analysis					25-37
branch connections	9-01	Heat Treatment		exclusions from	1-76
exemptions from	1-33	cooling rate	1-69		5-14
modulus of elasticity	21-26	for austenitic stainless steel	1-65		8-30
qualification	13-05	for bending and forming	2-2	HAZ	23-13
	13-14		19-04	heat treatment required	5-19
thermal expansion data	15-24	for carbon steel pipe	21-12	in qualifying procedures	8-29
	21-16		25-22	material	25-32
		for flared laps	11-03	of aluminum filler metals	2-19
Flexibility Characteristic		for valve parts	8-12	of austenitic stainless steel	1-65
effect of branch to run	1-56	governing thickness	1-39	of bolting materials	4-15
diameters			1-59	of duplex stainless steel	20-13
for a tee	1-55		4-06	of heat-affected zone	1-76
	1-56		5-06		5-21
	5-01		11-06	of high pressure piping	21-27
for components not listed	1-55	heating rate	1-69	of weldments	1-12
in Appendix D		local	5-08		1-65
	2-24		8-05		1-76
= 11111		monitoring	5-08		5-21
Flexibility Factors			8-05		19-21
basis for	1-56	postweld	20-39		21-19
for B16.9 tee	1-7		20-44	requirements	15-23
	12-08		22-19		17-09
	12-17		24-30		20-31
for fabricated intersections	1-6		25-10		21-18
	4-16		25-30	retest	25-38
	5-15	requirements	8-08	size specimen	24-01

Subject	Interpre- tation	Subject	Interpre- tation	Subject	Interpre- tation
Pipe Supports (Cont'd)	_	Pressure Design (Cont'd)		Progressive Sampling	25-05
materials	19-36	of unlisted components	13-02		25-14
	21-41	1	13-03		25-21
use of plastic	1-49		13-05		
1			21-34	Published Specification	1-15
Plastic			24-09	·	
lined pipe — use of	8-33	of valves	8-04	Radiographic Examination	
screwed flanges	6-33		13-15	100%	5-09
pipe supports	1-49	using proof testing	25-19		20-17
p.pe supports	1 1/			as supplementary	8-38
Pneumatic Tests (see Leak Tes	-tc)	Pressure Rating		examination	
Fileumatic lests (see Leak les	5(5)	components	19-02	digital radiography	20-42
		valve	8-04	normal fluid service	20-20
Positions		variations	4-11	on fillet welds	24-02
qualification of welding	1-66		20-22	random radiography	1-27
		D. C. C. D. C.			1-45
Postweld Heat Treatment (see	e Heat	Pressure Relief Devices	2.21		1-62
Treatment)		acceptable devices	2-21 2-29		2-12
					2-32
Preheat (see Heat Treatment)			19-41 23-11		3-12
		and test museums	23-11 11-07	records	1-10
Pressure Conditions	25-42	and test pressure	11-07	requirements	6-04
			11-19		11-01
Pressure Design			14-09		11-05
-	17-12		18-03		12-03
allowance		prossure reducing station	19-31		22-08
	20-03	pressure reducing station	17-29	selection of welds for	2-25
	20-51	requirements	23-17	examination	
	21-33		24-16	spot radiography	1-62
	21-45	setting	1-32		3-12
for elevated temperatures	3-4	Setting	7-01	survey plugs	19-48
in the high pressure range	1-68		12-04	when PWHT is required	1-64
	17-16	stop valves	10-10		2-4
of extruded headers	1-21	stop varves	12-18		
	1-70			Radius	25-31
of flanges and blanks	10-14	Pressure Surges		B I.	
	13-15	loads due to	1-50	Records	F 10
	19-12			certification	5-10
of miter bends	1-21	Pressure-Temperature	5-05		8-02
of nonmetallic piping	14-17	Rating			10-03
components	4440		8-34	6 4:	21-03
	14-18	D		for radiographic examination	1-10
of pipe	1-42	Pressure Test (see Leak Test)		of examinations	11-11
	1-54	Pressure Thickness	22-21	or examinations	21-20
	1-57	Flessule Illickliess	22-21	of hardness tests	8-22
	1-68	Progressive Examination	1-5	retention of	1-10
	1-70	riogressive Examination	1-62	retention of	1-10
	2-11		3-5	Reinforcement, Branch	
	11-21		10-09	attachment weld	4-03
	13-07		10-12	The state of the s	7-08
	15-06		11-02	clarification of terms	1-37
	15-10		11-04	Charmication of terms	11-10
	17-06		13-12	limits of	2-27
	21-38		16-01	minto oi	9-04
	22-04		16-02		/ UI
of listed components	16-14		16-05	Reinforcement Pad	22-20
1	16-18		18-01	Thickness	

Subject	Interpre- tation	Subject	Interpre- tation	Subject	Interpre- tation
Repairs		Stresses (see also Allowable	Stresses)	Temperatures (Cont'd)	
to welds	2-18	(Cont'd) due to pressure surges	1-50	design minimum temperature	10-02
Responsibility		due to seismic loads	2-17	temperature	14-08
designer	10-11	due to sustained loads	15-15		14-12
rights of owner's	10-03		16-04		15-11
inspection			16-11		15-16
	17-15		20-02		17-07
			25-02		19-35
Safeguarding	5-12	due to thermal gradients	3-4	fluid	23-06
		hydrostatic design	19-13	large changes	8-09
Scope (see <i>Code Coverage</i>)		longitudinal	1-20	limitations	4-13
	4.05	G	1-50		5-14
Seismic Loads	4-07		2-15		15-12
effect of friction	23-04		2-24		15-25
stresses due to	23-12 2-17		4-10		19-47
stresses due to	2-17		4-12	maximum metal	19-40
Severe Cyclic Conditions			6-03R	temperature	
cyclic loading	5-12		(Vol.	minimum design metal	20-13R
large rapid temperature	8-09		7)	temperature (MDMT)	
change	0 0,		6-07	reduction	4-11
material	21-29		7-05		20-15
spiral (helical seam)	7-03		8-16	variation in elevated	17-17
welded pipe			17-18	temperature service	
			18-16	verification	16-09
Simplified Flexibility	1-33	ratio figure	23-01		
Analysis		reduction factors	16-10	Thermoplastic Piping	
C. I. I. I. I. O. I. I'C. I'C.	25.04		21-34	neat fusion joints	13-08
Soldering Qualification	25-06			solvent cemented joints	10-08
Stainless Steel	22-03	Stress Intensification Factors		specific requirements	10-06
Stanness Steet	22-03 22-03R	application of	1-34		
	22-03R 22-23		2-24	Thickness Allowances	
	22 23		6-03R	governing	17-13
Standard Components			(Vol.	80.000	17-21
manufacturer's markings	3-7		7)		18-02
C	8-02	basis for	1-56	in stress calculations	1-20
valves	5-05	branch connections	2-7	range	25-29
	8-04	for B16.9 tees	1-7	wall	23-16
	8-07	for fabricated intersections	1-6	welding tee	18-18
			5-15		
Standards		for tees	1-46	Thickness Requirements	20-17
compliance	5-10		1-55	illickliess kequilellelits	20-17
superseded	1-44		1-71		20-41
Strange (see also Allowable	Ctuasa as)		5-01		
Stresses (see also <i>Allowable</i> Sallowable	19-37		12-08	Tubing	
allowable	19-37		12-17	category M fluid service	16-17
	19-36	for unlisted components	13-05	joints	7-07
	20-32	for welded elbows	1-6	limitations	2-13
analysis	23-07		12-11		3-6
displacement stress range	7-04				
T	12-06	Temperatures		Ultrasonic Examination	
	20-02	allowance	17-12	in place of radiography	11-05
due to cold spring	8-16		20-03		20-09
due to occasional loads	2-16	bending	16-08		20-42
	24-24	critical	22-36	requirements	10-17

Subject	Interpre- tation	Subject	Interpre- tation	Subject	Interpre- tation
Unlisted		Weld (Cont'd)		Weld (Cont'd)	
components	1-6	bevels	12-10	qualification of position	1-66
components	1-51	closure	22-16	radiography	25-26
	3-6	closure	24-25	reinforcement	7-08
	4-05		25-24	remorecinen	11-08
	5-05		25-34	repair	2-18
	8-07	configuration	19-16	repuir	21-19
	10-18	definition	14-03	sign	22-25
	10-07		19-05	size	22-32
	10-11	double submerged arc	21-46R	socket	6-02
	12-09	welded (DSAW)		SOCKCE	6-05
	13-02	examination of welds	10-15		10-19
	13-03		11-01		15-08
	13-05		11-14		16-06
	19-03		13-16		19-20
	19-19		14-14	spacing of	7-02
	20-25		14-15	tack	22-35
	20-37		15-02	tack	22-35R
	21-34		19-17	lana a a	
	23-03		19-42	types	20-05
	25-03		20-06		20-07
	25-08		20-43		
materials (see Materials)		fillet size	1-74	Welder Qualification	
,			10-19	by others	15-19
U-Stamp	22-34		16-06		18-08
			20-01		19-26
Valves		final	19-15		22-35
Category M Fluid Service	8-35	for branch connections	2-10	requirements	17-27
Flanged Ball Valves	16-16		4-03		24-06
materials	8-07		4-14		
	15-26		8-37	Welding Procedure	
pressure buildup	8-04		11-10	qualification of	1-12
products	25-35		19-25	•	1-65
qualification	24-18		24-10		1-66
ratings	5-05		24-15		1-76
Visual Examination			25-17		4-17
internal	8-10		25-20		8-23
ntertai	8-26	imperfections (see also	21-02		8-29
	13-16	Acceptable Criteria)			11-09
requirements	2-28	joint quality factor	21-06		14-05
requirements	10-03		21-37		14-13
	13-16	joint strength reduction	21-35		19-22
	18-17	factor			24-17
	24-21		22-37	responsibility	12-07
	24-21R		24-12	responsibility	12-12
	21 2110	longitudinal	2-20	specification	
Washers, Use of	2-5		3-11	specification	8-21 8-22
			4-18		
Weld		map	22-10		20-14
acceptable criteria	17-03		22-25		20-19
	17-22	of valves	12-12		20-31
	18-07	partial joint penetration	23-02		
	21-44	preparation for welding	13-01	Workmanship	22-33
	22-40		14-04		24-29

INTENTIONALLY LEFT BLANK

B31.3 Code Cases

ASME issues replies to inquiries that are applicable to ASME B31.3. When a reply modifies the existing requirements of the Code, the inquiry and reply are issued as a Code Case.

Code Cases remain available for use until annulled by the ASME B31 Code for Pressure Piping Standards Committee.

B31.3 Code Cases that are approved after this edition will be published on the following ASME web page: https://cstools.asme.org/csconnect/CommitteePages.cfm?Committee=N10020400.

As of the date of issuance of this edition of B31.3, the following Code Cases are in effect:

Case 180	Leak testing of subassemblies of jacketed piping
Case 181	Use of alternative ultrasonic examination acceptance criteria
Case 185	Use of standard helium leak test for a vacuum-only piping system (para. 345)
Case 191	Cu-13Zn-1.1Ni-Si-Al alloy seamless pipe and tube
Case 193	Cu-5.5Zn-4Si casting alloy UNS No. C87600
Case 196	Ductile iron casting UNS No. F33100

SUMMARY OF CHANGES

The Code Cases affected by this edition are as follows:

Page	Code Case	Change
C-9	196	Added

B31 CASE 180 Leak Testing of Subassemblies of Jacketed Piping for Use in ASME B31.3 Piping Systems

Approval Date: January 5, 2007

Inquiry: Does ASME B31.3 permit an alternate leak test for jacketed piping in which it is impracticable to visually examine the welded joints and connections for leaks in accordance with para. 345.2.2(a)?

Reply: Visually observing the joints and connections during the leak test in accordance with paras. 345.2.2(a) and 345.3.1 is not required, provided all of the following conditions are satisfied:

- (a) The welded joints and connections are on the inner pipe of jacketed piping.
- (*b*) A leak test is performed that otherwise meets the requirements of para. 345.1, except visual examination of joints and connection in accordance with paras. 345.2.2(a) and 345.3.1 is not required.
- (c) A sensitive leak test is performed in accordance with para. 345.8 to demonstrate leak tightness of welded joints and connections that are not visually examined during the leak testing required in (b) above.

B31 CASE 181 Use of Alternative Ultrasonic Examination Acceptance Criteria in ASME B31.3

Approval Date: January 4, 2012

Inquiry: Under what conditions and limitations may alternative UT acceptance criteria apply in lieu of those described in para. 344.6.2 of ASME B31.3?

Reply: When specified by the owner, the ultrasonic examination acceptance criteria included below may be applied for welds in material greater than or equal to 25 mm (1.0 in.) in thickness¹ in accordance with ASME B31.3, provided the following requirements are met:

(a) General/Scope

- (1) The examination shall be conducted using automated or semiautomated techniques utilizing computer-based data acquisition.
- (2) The examination shall be performed in accordance with a written procedure approved by Level III personnel and conforming to the requirements of ASME BPV Code Section V, Article 4, Mandatory Appendix VIII and
- (a) for phased array ASME Section V, Article 4, Mandatory Appendix V
- (b) for time of flight diffraction (TOFD) ASME Section V, Article 4, Mandatory Appendix III
- (3) Procedure qualification shall meet the requirements of ASME Section V, Article 4, Mandatory Appendix IX.
- (b) Equipment. A mechanical guided scanner capable of maintaining a fixed and consistent search unit position relative to the weld centerline shall be used.

(c) Personnel

- (1) Setup and scanning of welds shall be performed by personnel certified as Level II or III (or by Level I personnel under the direct supervision of Level II personnel).
- (2) Interpretation and evaluation of data shall be performed by Level II or III personnel.
- (3) Examination personnel shall be qualified and certified following a procedure or program as described in ASME Section V, Article 1, T-120(e), (f), (h), and (i).
- (4) Personnel demonstration requirements shall be as stated in ASME Section V, Article 4, Mandatory Appendix VII.

(d) Examination


- (1) The initial straight beam scan for reflectors that could interfere with the angle beam examination shall be performed
 - (a) manually
- (b) as part of a previous manufacturing process or
- (c) during the weld examination, provided detection of these reflectors is included in the demonstration as required in (a)(3) above
- (2) The examination area shall include the volume of the weld, plus the lesser of 25 mm (1.0 in.) or t of adjacent base metal. Alternatively, the examination volume may be reduced to include the actual heat affected zone (HAZ) plus 6 mm (0.25 in.) of base material beyond the heat affected zone on each side of the weld, provided the extent of the weld HAZ is measured and documented.
- (3) Scanning may be performed at reference level, provided the procedure qualification was performed at reference level.
- (e) Data Recording. Data shall be recorded in the unprocessed form with no thresholding. The data record shall include the complete examination area as specified in (d)(2) above.


(f) Data Analysis

- (1) Reflectors exceeding the limits below shall be investigated to determine whether the indication originates from a flaw or is a geometric indication, in accordance with (2) below.
- (a) For amplitude-based techniques, the location, amplitude, and extent of all reflectors that produce a response greater than 20% of the reference level shall be investigated.
- (b) For non-amplitude-based techniques, the location and extent of all images that have an indicated length greater than 4.0 mm (0.16 in.) shall be investigated.
- (2) Ultrasonic indications of geometric and/or metallurgical origin shall be classified as specified in ASME Section V, Article 4, T-481.
- (3) Alternatively, other techniques or NDE methods may be used to classify an indication as geometric (e.g., alternative beam angles, radiography). The method employed is for information only to classify the indication as geometric, and ASME B31.3 requirements for

 $^{^{\}rm 1}$ For wall thicknesses less than 25 mm (1.0 in.), the acceptance criteria stated in para. 344.6.2 of B31.3 shall be used.

Fig. 1 Surface and Subsurface Indications





 $S_{F} > 0.5 h_{F}$

(c) Subsurface Flaw

examination techniques are only required to the extent that they are applicable.

(g) Flaw Evaluation

- (1) *Dimensions*. The dimensions of the flaw(s) shall be determined by the rectangle that fully contains the area of the flaw(s). (Refer to Fig. 1.)
- (a) The length, ℓ , of the flaw shall be drawn parallel to the inside pressure-retaining surface of the component.
- (b) The height, h, of the flaw shall be drawn normal to the inside pressure-retaining surface of the component.
- (c) The flaw shall be characterized as a surface or subsurface flaw, as shown in Fig. 1.
- (*d*) A subsurface indication shall be considered as a surface flaw if the separation (*S* in Fig. 1) of the indication from the nearest surface of the component is equal to or less than half the through-wall dimension [*h* in Fig. 1, sketch (b)] of the subsurface indication.

(2) Multiple Flaws

- (a) Discontinuous flaws that are oriented primarily in parallel planes shall be considered to lie in a single plane if the distance between the adjacent planes is equal to or less than 13 mm (0.50 in.) or 0.5t, whichever is less.
- (b) If the space between two flaws aligned along the axis of weld is less than the height of the flaw of greater height, the two flaws shall be considered a single flaw.
- (c) If the space between two flaws aligned in the through-thickness dimension is less than the height of the flaw of greater height, the two flaws shall be considered a single flaw.
- (h) Flaw Acceptance Criteria. Flaws shall be evaluated against the applicable acceptance criteria of Table 1 or Table 2, except that flaw length (ℓ) shall not exceed 4t, regardless of flaw height (h) or the calculated aspect ratio.

Table 1 Acceptance Criteria for Surface Flaws

	Maximum h/t for Weld Thickness			
Aspect Ratio, h/ℓ	25 mm to 64 mm (1.0 in. to 2.5 in.)	100 mm to 300 mm (3.9 in. to 11.8 in.)		
0.00	0.031	0.019		
0.05	0.033	0.020		
0.10	0.036	0.022		
0.15	0.041	0.025		
0.20	0.047	0.028		
0.25	0.055	0.033		
0.30	0.064	0.038		
0.35	0.074	0.044		
0.40	0.083	0.050		
0.45	0.085	0.051		
0.50	0.087	0.052		

GENERAL NOTES:

- (a) t = thickness of the weld excluding any allowable reinforcement. For a butt joint joining two members having different thicknesses at the joint, t is the thinner of the two thicknesses joined. If a full penetration weld includes a fillet weld, the effective throat dimension of the fillet weld shall be included in t.
- (b) Aspect ratio (h/ℓ) used may be determined by rounding the calculated h/ℓ down to the nearest 0.05 increment value within the column, or by linear interpolation.
- (c) For intermediate thickness t [weld thicknesses between 64 mm and 100 mm (2.5 in. and 3.9 in.)], linear interpolation is required to obtain h/t values.

Table 2 Acceptance Criteria for Subsurface Flaws

Aspect Ratio, h/ℓ	Maximum h/t for Weld Thickness			
	25 mm to 64 mm (1.0 in. to 2.5 in.)	100 mm to 300 mm (3.9 in. to 11.8 in.)		
0.00	0.068	0.040		
0.10	0.076	0.044		
0.20	0.086	0.050		
0.30	0.098	0.058		
0.40	0.114	0.066		
0.50	0.132	0.076		
0.60	0.156	0.088		
0.70	0.180	0.102		
0.80	0.210	0.116		
0.90	0.246	0.134		
1.00	0.286	0.152		

GENERAL NOTES:

- (a) t = thickness of the weld excluding any allowable reinforcement. For a butt joint joining two members having different thicknesses at the joint, t is the thinner of the two thicknesses joined. If a full penetration weld includes a fillet weld, the effective throat dimension of the fillet weld shall be included in t.
- (b) Aspect ratio (h/ℓ) used may be determined by rounding the calculated h/ℓ down to the nearest 0.05 increment value within the column, or by linear interpolation.
- (c) For intermediate thickness t [weld thicknesses between 64 mm and 100 mm (2.5 in. and 3.9 in.)], linear interpolation is required to obtain h/t values.

B31 CASE 185 Use of Standard Helium Leak Test for a Vacuum-Only Piping System (Para. 345)

Approval Date: December 22, 2009

Inquiry: Under what circumstances does ASME B31.3 permit the use of helium mass spectrometer leak tests performed under a vacuum as a substitute for the leak test requirements specified in ASME B31.3, para. 345?

Reply: In the opinion of the Committee, the qualified helium leak tests under vacuum conditions in the ASME BPV Code, Section V, Article 10, Appendices V and IX are acceptable substitutes for the testing requirements identified in para. 345 of ASME B31.3, provided the following conditions are met:

- (a) The piping system is expected to operate only under vacuum (i.e., subatmospheric pressure) conditions.
- (b) Any leakage into the piping system that could result in an internal reaction (e.g., combustion or explosion) that increases the pressure above atmospheric shall be prevented.
- (c) All system joints and connections shall be leak tested. Piping welds and joints to be tested shall be uninsulated and exposed, and shall not be primed, painted, or otherwise coated.
- (d) Helium leak testing is performed at vacuum conditions sufficient for the mass spectrometer helium leak tests of ASME BPV Code, Section V, Article 10, Appendices V and IX, or at pressures below 10 mbar absolute (less than 1% of atmospheric pressure), whichever is lower.

- (e) ASME B31.3, para. 345.2 applies, except for the minimum "10 min" leak test period, the leak test pressure requirements, and the limitation of the need for access for jacketed piping to "visual access." Paragraph 345.3 also applies, except for the leak test pressure requirements. All other inspection, examination, and records requirements of ASME B31.3 Chapter VI must still be satisfied (i.e., paras. 340, 341, 342, 343, 344, and 346).
- (f) Written procedures shall be qualified in accordance with ASME BPV Code, Section V, Article 10.
- (*g*) Test personnel shall have training and certification consistent with ASME B31.3, para. 342.
- (h) Test reports, including records of personnel qualifications, shall meet the requirements of ASME BPV Code, Section V, Article 10, para. T-1091 and shall be retained for at least 5 yr.
- (i) Options of the ASME BPV Code, Section V, Article 10 test methods that allow the engineering design to modify specified requirements of the Appendix V and Appendix IX test methods (such as acceptability limits for system leak tightness) may only be exercised so as to make these requirements more sensitive or more conservative.
- (*j*) The use of the vacuum leak test instead of the pressurized leak test of ASME B31.3, para. 345 shall be specified in the engineering design and shall be accepted by the owner.

B31 CASE 191 Cu-13Zn-1.1Ni-Si-Al Alloy Seamless Pipe and Tube

Approval Date: January 21, 2015

Inquiry: May precipitation-hardened (temper designation TF00) Cu-13Zn-1.1Ni-Si-Al alloy (UNS No. C69100) seamless pipe and tube conforming to the requirements of ASTM B706-00 (R2011) be used under the rules of ASME B31.3?

Reply: Yes, with the following provisions:

- (a) The maximum allowable stress values for the material shall be those given in Table 1.
 - (b) Welded and brazed construction is not permitted.
- (c) The maximum use temperature shall be 204°C (400°F).
- (*d*) Certification to the ASTM B706-00 (R2011) specification requirements shall be mandatory.

Table 1 Maximum Allowable Stress Values

For Metal Temperature Not Exceeding, °C	Stress, MPa	For Metal Temperature Not Exceeding, °F	Stress, ksi
40	138	100	20.0
65	138	150	20.0
100	138	200	20.0
125	138	250	20.0
150	138	300	20.0
175	137	350	19.9
200	135	400	19.5
225 [Note (1)]	132		

NOTE:

(1) The maximum use temperature for this alloy is 204°C (400°F). The value listed at 225°C is provided for interpolation purposes only.

B31 CASE 193 Cu-5.5Zn-4Si Casting Alloy UNS No. C87600

Approval Date: October 9, 2014

Inquiry: May Cu–5.5Zn–4Si casting alloy UNS No. C87600 conforming to the requirements of ASTM B584 be used for construction under the rules of ASME B31.3?

Reply: Yes, with the following provisions:

- (a) The basic allowable stress values for the material shall be those given in Table 1. A casting quality factor, E_c , needs to be applied.
- (*b*) The maximum use temperature shall be 177° C (350°F).
- (*d*) Separate weld procedure and performance qualifications shall apply to this material. The welding procedure qualifications shall be in accordance with ASME Section IX.

Table 1 Basic Allowable Stress Values

For Metal Temperature Not Exceeding, °C	Stress, MPa	For Metal Temperature Not Exceeding, °F	Stress, ksi
40	138	100	20.0
65	138	150	20.0
100	138	200	20.0
125	138	250	20.0
150	138	300	20.0
175	138	350	20.0
200 [Note (1)]	137		

NOTE:

(1) The maximum use temperature for this alloy is 177°C (350°F). The value listed at 200°C is provided for interpolation purposes only.

B31 CASE 196 Ductile Iron Casting UNS No. F33100

Approval Date: May 15, 2015

Inquiry: May ductile iron castings UNS No. F33100 conforming to the requirements of ASTM A536, Grade 65-45-12 be used for construction under the rules of ASME B31.3?

Reply: Yes, with the following provisions:

- (a) The maximum allowable stress values for the material shall be those given in Table 1.
- (b) A casting quality factor, E_c , of 0.80 shall also be applied, except as permitted in (c).
- (c) The casting quality factor may be increased by performing supplementary examination(s) listed in Table 302.3.3(c). The casting shall have first been visually examined as required by MSS SP-55, Quality Standard for Steel Castings for Valves, Flanges, Fittings and Other Piping Components Visual Method.
- (d) The maximum use temperature shall be 260°C (500°F).
- (e) The minimum use temperature shall be -30° C (-20° F).

Table 1 Maximum Allowable Stress Values

For Metal Temperature Not Exceeding, °C	Stress, MPa	For Metal Temperature Not Exceeding, °F	Stress, ksi
40	149	100	21.7
65	149	150	21.7
100	149	200	21.7
125	149	250	21.7
150	149	300	21.7
175	149	350	21.7
200	148	400	21.7
225	148	450	21.7
250	148	500	21.6
275 [Note (1)]	147		

NOTE:

- (1) The maximum use temperature for this alloy is 260°C (500°F). The value listed at 275°C is provided for interpolation purposes only.
- (f) All other requirements of ASME B31.3 shall be followed.



ASME CODE FOR PRESSURE PIPING, B31

Dower Dining	2016
Power Piping	
Process Piping	
Tuberias de Proceso	-2010
Pipeline Transportation Systems for Liquids and Slurries	-2016
Refrigeration Piping and Heat Transfer Components	-2016
Gas Transmission and Distribution Piping Systems	-2016
Managing System Integrity of Gas Pipelines	-2016
Gestión de Integridad de Sistemas de GasoductosB31.8S-	-2010
Building Services Piping	-2014
Hydrogen Piping and Pipelines	2014
Standard for the Seismic Design and Retrofit of Above-Ground Piping Systems	-2008
Manual for Determining the Remaining Strength of Corroded Pipelines: Supplement to ASME B31 Code for Pressure Piping B31G-	
Manual para la determinación de la resistencia remanente de tuberiás corroÍdas	-2012
Standard Test Method for Determining Stress Intensification Factors (i-Factors) for Metallic Piping ComponentsB31J-2008 (R2	2013)
Método de prueba estándar para determinar factores de intensificación de esfuerzo (Factores i) para componentes	
de tuberías metálicas	2013)
Pipeline Personnel Qualification	-2016
Calificación del personal de líneas de tuberías	-2010
Standard Toughness Requirements for Piping	-2015

The ASME Publications Catalog shows a complete list of all the Standards published by the Society. For a complimentary catalog, or the latest information about our publications, call 1-800-THE-ASME (1-800-843-2763).

ASME Services

ASME is committed to developing and delivering technical information. At ASME's Customer Care, we make every effort to answer your questions and expedite your orders. Our representatives are ready to assist you in the following areas:

ASME Press Codes & Standards Credit Card Orders **IMechE Publications** Meetings & Conferences Member Dues Status

Member Services & Benefits Other ASME Programs **Payment Inquiries Professional Development Short Courses Publications**

Public Information Self-Study Courses Shipping Information Subscriptions/Journals/Magazines Symposia Volumes **Technical Papers**

How can you reach us? It's easier than ever!

There are four options for making inquiries* or placing orders. Simply mail, phone, fax, or E-mail us and a Customer Care representative will handle your request.

ASME 150 Clove Road, 6th Floor

Mail

Little Falls, New Jersey 07424-2139

Call Toll Free

US & Canada: 800-THE-ASME (800-843-2763)

Mexico: 95-800-THE-ASME (95-800-843-2763)

Fax—24 hours E-Mail-24 hours 973-882-1717 customercare@asme.org

973-882-5155

^{*} Customer Care staff are not permitted to answer inquiries about the technical content of this code or standard. Information as to whether or not technical inquiries are issued to this code or standard is shown on the copyright page. All technical inquiries must be submitted in writing to the staff secretary. Additional procedures for inquiries may be listed within.

ASME B31.3-2016

ISBN 978-0-7918-7119-5



